



Local Government Energy Audit Report

Former Parks and Recreation Building

March 1, 2019

Prepared for:

Middletown Township
900 Leonardville Rd
Leonardo, NJ 07737

Prepared by:

TRC Energy Services
900 Route 9 North
Woodbridge, NJ 07095

Disclaimer

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information about financial incentives that may be available. Most energy conservation measures have received preliminary analysis of feasibility that identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to establish a basis for further discussion and to help prioritize energy measures.

TRC Energy Services (TRC) reviewed the energy conservation measures and estimates of energy savings were reviewed for technical accuracy. Actual, achieved energy savings depend on behavioral factors and other uncontrollable variables and, therefore, estimates of final energy savings are not guaranteed. TRC and the New Jersey Board of Public Utilities (NJBP) shall in no event be liable should the actual energy savings vary.

TRC bases estimated installation costs on our experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from RS Means. We encourage the owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Actual installation costs can vary widely based on individual measures and conditions. TRC and NJBP do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

The New Jersey Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBP reserves the right to extend, modify, or terminate programs without prior notice. Please review all available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

The customer and their respective contractor(s) are responsible to implement energy conservation measures in complete conformance with all applicable local, state and federal requirements.

Copyright ©2019 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Table of Contents


1	Executive Summary	5
1.1	Planning Your Project	9
	Pick Your Installation Approach	9
	More Options from Around the State	11
2	Existing Conditions	13
2.1	Site Overview.....	13
2.2	Building Occupancy	13
2.3	Building Envelope	14
2.4	Lighting Systems	15
2.5	Air Handling Systems	16
	Air Conditioners	16
2.6	Heating Hot Water Systems	17
2.7	Domestic Hot Water	17
2.8	Plug Loads.....	18
2.9	Water-Using Systems	18
3	Energy Use and Costs	19
3.1	Electricity	21
3.2	Natural Gas.....	22
3.3	Benchmarking.....	23
	Tracking Your Energy Performance.....	24
4	Energy Conservation Measures	25
4.1	Lighting	28
	ECM 1: Retrofit Fixtures with LED Lamps.....	28
4.2	Lighting Controls.....	29
	ECM 2: Install Occupancy Sensor Lighting Controls	29
	ECM 3: Install High/Low Lighting Controls	29
4.3	Electric Unitary HVAC	30
	ECM 4: Install High Efficiency Air Conditioning Units.....	30
4.4	Gas-Fired Heating	30
	Install High Efficiency Hot Water Boilers.....	30
5	Energy Efficient Best Practices	31
	Energy Tracking with ENERGY STAR® Portfolio Manager®.....	31
	Weatherization.....	31
	Doors and Windows	31
	Lighting Maintenance.....	31
	Lighting Controls	32
	AC System Evaporator/Condenser Coil Cleaning	32
	HVAC Filter Cleaning and Replacement	32

Boiler Maintenance	32
Water Conservation	32
Procurement Strategies	33
6 On-site Generation	34
6.1 Solar Photovoltaic	35
6.2 Combined Heat and Power	36
7 Project Funding and Incentives	37
7.1 SmartStart	38
7.2 Direct Install	39
8 Energy Purchasing and Procurement Strategies	40
8.1 Retail Electric Supply Options.....	40
8.2 Retail Natural Gas Supply Options	40
Appendix A: Equipment Inventory & Recommendations	1
Appendix B: ENERGY STAR® Statement of Energy Performance	1
Appendix C: Glossary	2

1 EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) report for the Former Parks and Recreation Building. This report provides you with information about your facility’s energy use, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help make changes in your facility. TRC Energy Services (TRC) conducted this study as part of a comprehensive effort to assist New Jersey school districts and local governments in controlling their energy costs and help protect our environment by reducing statewide energy consumption.

BUILDING PERFORMANCE REPORT



<p>ENERGY STAR® Benchmarking Score</p>	<p>N/A <i>(1-100 scale)</i></p>	<p>This building performs at or below the national average. This report contains suggestions about how to improve building performance and reduce energy costs.</p> <p>A standard energy use benchmark is not available for this facility type. This report contains suggestions about how to improve building performance and reduce energy costs.</p>
--	-------------------------------------	---




Figure 1 - Energy Use by System


POTENTIAL IMPROVEMENTS



This energy audit considered a range of potential energy improvements in your building. Costs and savings will vary between improvements. Presented below are two potential scopes of work for your consideration.


Scenario 1: Full Package (all evaluated measures)

Installation Cost	\$31,663
Potential Rebates & Incentives ¹	\$3,522
Annual Cost Savings	\$3,119
Annual Energy Savings	Electricity: 18,680 kWh Natural Gas: 288 Therms
Greenhouse Gas Emission Savings	11 Tons
Simple Payback	9.0 Years
Site Energy Savings (all utilities)	12%



Scenario 2: Cost Effective Package²

Installation Cost	\$15,509
Potential Rebates & Incentives	\$2,262
Annual Cost Savings	\$2,738
Annual Energy Savings	Electricity: 18,680 kWh
Greenhouse Gas Emission Savings	9 Tons
Simple Payback	4.8 Years
Site Energy Savings (all utilities)	8%



On-site Generation Potential

Photovoltaic	None
Combined Heat and Power	None

¹ Incentives are based on current SmartStart Prescriptive incentives. Other program incentives may apply.

² A cost-effective measure is defined as one where the simple payback does not exceed two-thirds of the expected proposed equipment useful life. Simple payback is based on the net measure cost after potential incentives.

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Lifetime Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		13,557	4.3	-3	\$1,980	\$29,700	\$6,618	\$1,732	\$4,886	2.5	13,323
ECM 1	Retrofit Fixtures with LED Lamps	13,557	4.3	-3	\$1,980	\$29,700	\$6,618	\$1,732	\$4,886	2.5	13,323
Lighting Control Measures		963	0.2	0	\$141	\$1,125	\$1,410	\$70	\$1,340	9.5	946
ECM 2	Install Occupancy Sensor Lighting Controls	474	0.1	0	\$69	\$553	\$810	\$70	\$740	10.7	465
ECM 3	Install High/Low Lighting Controls	490	0.1	0	\$71	\$572	\$600	\$0	\$600	8.4	481
Electric Unitary HVAC Measures		4,160	1.4	0	\$618	\$9,267	\$7,481	\$460	\$7,021	11.4	4,189
ECM 4	Install High Efficiency Air Conditioning Units	4,160	1.4	0	\$618	\$9,267	\$7,481	\$460	\$7,021	11.4	4,189
Gas Heating (HVAC/Process) Replacement		0	0.0	32	\$381	\$7,613	\$16,153	\$1,260	\$14,893	39.1	3,719
	Install High Efficiency Hot Water Boilers	0	0.0	32	\$381	\$7,613	\$16,153	\$1,260	\$14,893	39.1	3,719
TOTALS		18,680	5.9	29	\$3,119	\$47,705	\$31,663	\$3,522	\$28,141	9.0	22,177

* - All incentives presented in this table are based on NJ SmartStart equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 2 – Evaluated Energy Improvements

1.1 Planning Your Project

Careful planning makes for a successful energy project. When considering this scope of work, you will have some decisions to make, such as:

- ◆ How will the project be funded and/or financed?
- ◆ Is it best to pursue individual ECMs, groups of ECMs, or use a comprehensive approach where all ECMs are installed together?
- ◆ Are there other facility improvements that should happen at the same time?

Pick Your Installation Approach

New Jersey Clean Energy Programs give you the flexibility to do a little or a lot. Rebates, incentives, and financing are available to help reduce both your installation costs and your energy bills. If you are planning to take advantage of these programs, make sure to review incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives before purchasing materials or starting installation.

The potential ECMs identified for this building likely qualify for multiple incentive and funding programs. Based on current program rules and requirements, your measures are likely to qualify for the following programs:

Energy Conservation Measure		SmartStart	Direct Install	Pay For Performance
ECM 1	Retrofit Fixtures with LED Lamps	X	X	
ECM 2	Install Occupancy Sensor Lighting Controls	X	X	
ECM 3	Install High/Low Lighting Controls		X	
ECM 4	Install High Efficiency Electric AC	X	X	

Figure 3 – Funding Options



New Jersey Clean Energy Programs At-A-Glance

	SmartStart Flexibility to install at your own pace	Direct Install Turnkey installation	Pay for Performance Whole building upgrades
Who should use it?	Buildings installing individual measures or small group of measures.	Small to mid-size facilities that can bundle multiple measures together. Peak demand should be below 200 kW. Not suitable for significant building shell issues.	Mid to large size facilities looking to implement as many measures as possible at one time. Peak demand should be over 200 kW.
How does it work?	Use in-house staff or your preferred contractor.	Pre-approved contractors pass savings along to you via reduced material and labor costs.	Whole-building approach to energy upgrades designed to reduce energy use by at least 15%. The more you save, the higher the incentives.
What are the Incentives?	Fixed incentives for specific energy efficiency measures.	Incentives pay up to 70% of eligible costs, up to \$125,000 per project. You pay the remaining 30% directly to the contractor.	Up to 25% of installation cost, calculated based on level of energy savings per square foot.
How do I participate?	Submit an application for the specific equipment to be installed.	Contact a participating contractor in your region.	Contact a pre-qualified Partner to develop your energy reduction plan and set your energy savings targets.

Take the next step by visiting www.njcleanenergy.com for program details, applications, and to contact a qualified contractor.

Individual Measures with SmartStart

For facilities wishing to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate, you can use internal resources or an outside firm or contractor to perform the final design of the ECM(s) and install the equipment. Program pre-approval is required for some SmartStart incentives, so only after receiving pre-approval should you proceed with ECM installation.

Turnkey Installation with Direct Install

The Direct Install program provides turnkey installation of multiple measures through an authorized network of participating contractors. This program can provide substantially higher incentives than SmartStart, up to 70% of the cost of selected measures. Direct Install contractors will assess and verify individual measure eligibility and, in most cases, they perform the installation work. The Direct Install program is available to sites with an average peak demand of less than 200 kW.

Whole Building Approach with Pay for Performance

Pay for Performance can be a good option for medium to large sized facilities to achieve deep energy savings. Pay for Performance allows you to install as many measures as possible under a single project as well as address measures that may not qualify for other programs. Many facilities pursuing an Energy Savings Improvement Program (ESIP) loan also use this program. Pay for Performance works for larger customers with a peak demand over 200 kW. The minimum installed scope of work must include at least two unique measures resulting in at least 15% energy savings, where lighting cannot make up the majority of the savings.

More Options from Around the State

Financing and Planning Support with the Energy Savings Improvement Program (ESIP)

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the ESIP. Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. You have already taken the first step as an LGEA customer, because this report is required to participate in ESIP.

Resiliency with Return on Investment through Combined Heat & Power (CHP)

The CHP program provides incentives for combined heat and power (aka cogeneration) and waste heat to power projects. Combined heat and power systems generate power on-site and recover heat from the generation system to meet on-site thermal loads. Waste heat to power systems use waste heat to generate power. You will work with a qualified developer who will design a system that meets your building's heating and cooling needs.

Ongoing Electric Savings with Demand Response

The Demand Response Energy Aggregator program reduces electric loads at commercial facilities when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. By enabling commercial facilities to reduce their electric demand during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment service providers provide regular payments to medium and large consumers of electric power for their participation in demand response (DR) programs. Program participation is voluntary, and facilities receive payments regardless of whether they are called upon to curtail their load during times of peak demand.

2 EXISTING CONDITIONS

The New Jersey Board of Public Utilities (NJBPU) has sponsored this Local Government Energy Audit (LGEA) Report for the Former Parks and Recreation Building. This report provides information on how your facility uses energy, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help you implement the ECMs. This report also contains valuable information on financial incentives from New Jersey’s Clean Energy Program (NJCEP) for implementing ECMs.

TRC conducted this study as part of a comprehensive effort to assist New Jersey educational and local government facilities in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

2.1 Site Overview

On July 10, 2018, TRC performed an energy audit at the Former Parks and Recreation Building located in Leonardo, NJ. TRC met with Anthony Mercantante to review the facility operations and help focus our investigation on specific energy-using systems.

The Former Parks and Recreation Building is a single-story, 14,545 square foot building built in 1961. Spaces include: classrooms, offices, corridors and meeting rooms.

Facility concerns include: the building needs a new roof. The existing roof is in poor condition.

2.2 Building Occupancy

The facility is currently unoccupied. The building is used for seven weeks during the summer for summer camp. At that time, four classrooms are used.

Building Name	Weekday/Weekend	Operating Schedule
Former Parks and Recreation Building	Weekday	8:00 AM - 5:00 PM
	Weekend	Closed

Figure 4 - Building Occupancy Schedule

2.3 Building Envelope

Building walls are concrete block over structural steel with a brick facade. The roof is flat and covered with black membrane, and is in poor condition.

Most of the windows are double glazed and have aluminum frames. The windows are operable and the window weather seals are in fair condition. Exterior doors have aluminum frames and are in good condition. Degraded window and door seals increase drafts and outside air infiltration.



Façade, Windows



Roof

2.4 Lighting Systems

The primary interior lighting system uses 32-Watt linear fluorescent T8 lamps. The fixture types include 2 or 3 lamp, 3 or 4 foot long recessed and surface mounted fixtures. There are also a few 2-foot fixtures with U-bend tube lamps. Most fixtures are in fair condition. Most of the fixtures are controlled by occupancy sensors and the remainder by wall switches.



T8 Fixture



T8 Fixture



T8 Fixture



T8 Fixture

The exterior fixtures include incandescent and LED flood lights. The exterior fixtures are controlled by a time-clock.



PAR 38 Flood



PAR 38 Flood

2.5 Air Handling Systems

Air Conditioners

Most of the classrooms and offices use window air conditioning (AC) units. These vary in cooling capacity between 3/4 and 1-ton. The units are in fair condition. The efficiency for these units is estimated at approximately 11 EER. Other areas in the building are conditioned by a 5-ton split-system AC. The split-system AC is about 25 years old which is well beyond the useful life of the unit.



Split System Condenser



Window AC

2.6 Heating Hot Water Systems

One HydroTherm, 720 MBh hot water boiler serves the building heating load. The burners are modulating with a nominal efficiency of 80%. The boiler was installed about 1994 and is in fair condition.

The hydronic distribution system is a 2- pipe heating only system. The hot water is distributed via hot water pumps through radiator baseboards located throughout the building.



Hot Water Pumps



Boiler

2.7 Domestic Hot Water

Hot water is produced with a 40 gallon 38 MBh gas-fired storage water heater with an 82% efficiency.

The domestic hot water pipes are insulated and the insulation is in good condition.



DHW Heater

2.8 Plug Loads

The utility bill analysis estimated plug load usage as the building was partially occupied. The analysis indicates that plug loads consume approximately 1.4% of total building energy use. This is lower than a typical building.


2.9 Water-Using Systems

There are four restrooms with toilets, urinals, and sinks. Faucet flow rates are at 0.5 gallons per minute (gpm) or higher. Toilets are rated at 1.6 gallons per flush (gpf)

3 ENERGY USE AND COSTS

Twelve months of utility billing data are used to develop annual energy consumption and cost data. This information creates a profile of the annual energy consumption and energy costs.

Utility Summary		
Fuel	Usage	Cost
Electricity	57,184 kWh	\$8,493
Natural Gas	5,616 Therms	\$6,730
Total		\$15,223



An energy balance identifies and quantifies energy use in your various building systems. This can highlight areas with the most potential for improvement. This energy balance was developed using calculated energy use for each of the end uses noted in the figure.

The energy auditor collects information regarding equipment operating hours, capacity, efficiency and other operational parameters from facility staff, drawings, and on-site observations. This information is used as the inputs to calculate the existing conditions energy use for the site. The calculated energy use is then compared to the historical energy use and the initial inputs are revised, as necessary, to balance the calculated energy use to the historical energy use.





Figure 5 - Energy Balance

3.1 Electricity

JCP&L delivers electricity under rate class General Service Secondary, with electric production provided by South Jersey Energy, a third-party supplier.




Electric Billing Data					
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost
8/3/16	34	4,510	23		\$710
9/2/16	29	3,857	16		\$585
10/4/16	31	3,337	11		\$515
11/3/16	29	5,387	17		\$759
12/6/16	32	6,251	16		\$864
1/6/17	30	5,414	17		\$790
2/6/17	30	5,842	17		\$872
3/6/17	27	5,592	17		\$825
4/6/17	30	2,719	7		\$384
5/3/17	26	6,898	18		\$928
6/5/17	32	2,112	6		\$319
7/7/17	31	4,638	17		\$849
Totals	361	56,557	23	\$0	\$8,400
Annual	365	57,184	23	\$0	\$8,493

Notes:

- Peak demand of 23 kW occurred in August of 2016.
- The average electric cost over the past 12 months was \$0.149/kWh, which is the blended rate that includes energy supply, distribution, demand, and other charges. This report uses this blended rate to estimate energy cost savings.
- The current usage for the building is lower than the period which was analyzed. The building is currently partially occupied and used only in the summer.

3.2 Natural Gas

NJ Natural Gas delivers natural gas under rate class.



Gas Billing Data			
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost
7/1/16	32	0	\$15
8/2/16	33	47	\$162
8/30/16	28	30	\$146
9/28/16	29	78	\$181
10/28/16	30	146	\$273
12/1/16	34	390	\$475
1/3/17	33	1,604	\$1,704
2/1/17	29	1,200	\$1,436
3/2/17	29	862	\$947
4/3/17	32	1,100	\$1,091
5/3/17	30	187	\$262
6/2/17	30	33	\$112
Totals	369	5,678	\$6,804
Annual	365	5,616	\$6,730

Notes:

- The average gas cost for the past 12 months is \$1.198/therm, which is the blended rate used throughout the analysis.
- The current usage for the building is lower than the period which was analyzed. The building is currently partially occupied and used only in the summer.

3.3 Benchmarking

Your building was benchmarked using the United States Environmental Protection Agency’s (EPA) Portfolio Manager® software. Benchmarking compares your building’s energy use to that of similar buildings across the country, while neutralizing variations due to location, occupancy and operating hours. Some building types can be scored with a 1-100 ranking of a building’s energy performance relative to the national building market. A score of 50 represents the national average and a score of 100 is best.

This ENERGY STAR® benchmarking score provides a comprehensive snapshot of your building’s energy performance. It assesses the building’s physical assets, operations, and occupant behavior, which is compiled into a quick and easy-to-understand score.

Benchmarking Score	N/A
---------------------------	------------

Due to its unique characteristics, this building type is not able to receive a benchmarking score. This report contains suggestions about how to improve building performance and reduce energy costs.




Figure 6 - Energy Use Intensity Comparison

Energy use intensity (EUI) measures energy consumption per square foot and is the standard metric for comparing buildings’ energy performance. A lower EUI means better performance and less energy consumed. A number of factors can cause as building to vary from the “typical” energy usage. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and occupant behavior all contribute to a building’s energy use and the benchmarking score.

Tracking Your Energy Performance

Keeping track of your energy use on a monthly basis is one of the best ways to keep energy costs in check. Update your utility information in Portfolio Manager® regularly, so that you can keep track of your building's performance.

We have created a Portfolio Manager® account for your facility and we have already entered the monthly utility data shown above for you. Account login information for your account will be sent via email.

Free online training is available to help you use ENERGY STAR® Portfolio Manager® to track your building's performance at: <https://www.energystar.gov/buildings/training>. For more information on ENERGY STAR® and Portfolio Manager®, visit their website.³

³ <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.

4 ENERGY CONSERVATION MEASURES

The goal of this audit report is to identify and evaluate potential energy efficiency improvements, provide information about the cost effectiveness of those improvements, and recognize potential financial incentives from NJBPU. Most energy conservation measures have received preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is typically sufficient to demonstrate project cost-effectiveness and help prioritize energy measures.

Calculations of energy use and savings are based on the current version of the *New Jersey Clean Energy Program Protocols to Measure Resource Savings*, which is approved by the NJBPU. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances.

Operation and maintenance costs for the proposed new equipment will generally be lower than the current costs for the existing equipment—especially if the existing equipment is at or past its normal useful life. We have conservatively assumed there to be no impact on overall maintenance costs over the life of the equipment.

Financial incentives are based on the current NJCEP prescriptive SmartStart program. A higher level of investigation may be necessary to support any SmartStart Custom, Pay for Performance, or Direct Install incentive applications. Some measures and proposed upgrades may be eligible for higher incentives than those shown below through other NJCEP programs described in a following section of this report.

Appendix A: Equipment Inventory & Recommendations provides a detailed list of the locations and recommended upgrades for each energy conservation measure.

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		13,557	4.3	-3	\$1,980	\$6,618	\$1,732	\$4,886	2.5	13,323
ECM 1	Retrofit Fixtures with LED Lamps	13,557	4.3	-3	\$1,980	\$6,618	\$1,732	\$4,886	2.5	13,323
Lighting Control Measures		963	0.2	0	\$141	\$1,410	\$70	\$1,340	9.5	946
ECM 2	Install Occupancy Sensor Lighting Controls	474	0.1	0	\$69	\$810	\$70	\$740	10.7	465
ECM 3	Install High/Low Lighting Controls	490	0.1	0	\$71	\$600	\$0	\$600	8.4	481
Electric Unitary HVAC Measures		4,160	1.4	0	\$618	\$7,481	\$460	\$7,021	11.4	4,189
ECM 4	Install High Efficiency Air Conditioning Units	4,160	1.4	0	\$618	\$7,481	\$460	\$7,021	11.4	4,189
Gas Heating (HVAC/Process) Replacement		0	0.0	32	\$381	\$16,153	\$1,260	\$14,893	39.1	3,719
	Install High Efficiency Hot Water Boilers	0	0.0	32	\$381	\$16,153	\$1,260	\$14,893	39.1	3,719
TOTALS		18,680	5.9	29	\$3,119	\$31,663	\$3,522	\$28,141	9.0	22,177

* - All incentives presented in this table are based on NJ SmartStart equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 7 – All Evaluated ECMs

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		13,557	4.3	-3	\$1,980	\$6,618	\$1,732	\$4,886	2.5	13,323
ECM 1	Retrofit Fixtures with LED Lamps	13,557	4.3	-3	\$1,980	\$6,618	\$1,732	\$4,886	2.5	13,323
Lighting Control Measures		963	0.2	0	\$141	\$1,410	\$70	\$1,340	9.5	946
ECM 2	Install Occupancy Sensor Lighting Controls	474	0.1	0	\$69	\$810	\$70	\$740	10.7	465
ECM 3	Install High/Low Lighting Controls	490	0.1	0	\$71	\$600	\$0	\$600	8.4	481
Electric Unitary HVAC Measures		4,160	1.4	0	\$618	\$7,481	\$460	\$7,021	11.4	4,189
ECM 4	Install High Efficiency Air Conditioning Units	4,160	1.4	0	\$618	\$7,481	\$460	\$7,021	11.4	4,189
TOTALS		18,680	5.9	-3	\$2,738	\$15,509	\$2,262	\$13,247	4.8	18,458

* - All incentives presented in this table are based on NJ SmartStart equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 8 – Cost Effective ECMs

4.1 Lighting

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		13,557	4.3	-3	\$1,980	\$6,618	\$1,732	\$4,886	2.5	13,323
ECM 1	Retrofit Fixtures with LED Lamps	13,557	4.3	-3	\$1,980	\$6,618	\$1,732	\$4,886	2.5	13,323

When considering lighting upgrades, we suggest using a comprehensive design approach that simultaneously upgrades lighting fixtures and controls to maximize energy savings and improve occupant lighting. Comprehensive design will also consider appropriate lighting levels for different space types to make sure that the right amount of light is delivered where needed. If conversion to LED light sources are proposed, we suggest converting all of a specific lighting type (e.g. linear fluorescent) to LED lamps to minimize the number of lamp types in use at the facility, which should help reduce future maintenance costs.

ECM 1: Retrofit Fixtures with LED Lamps

Replace fluorescent with LED lamps. Many LED tubes are direct replacements for existing fluorescent tubes and can be installed while leaving the fluorescent fixture ballast in place. LED lamps can be used in existing fixtures as a direct replacement for most other lighting technologies.

This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space. Maintenance savings may also be available, as longer-lasting LEDs lamps will not need to be replaced as often as the existing lamps.

Affected building areas: all areas with fluorescent fixtures with T8 tubes

4.2 Lighting Controls

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures		963	0.2	0	\$141	\$1,410	\$70	\$1,340	9.5	946
ECM 2	Install Occupancy Sensor Lighting Controls	474	0.1	0	\$69	\$810	\$70	\$740	10.7	465
ECM 3	Install High/Low Lighting Controls	490	0.1	0	\$71	\$600	\$0	\$600	8.4	481

Lighting controls reduce energy use by turning off or lowering, lighting fixture power levels when not in use. A comprehensive approach to lighting design should upgrade the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

ECM 2: Install Occupancy Sensor Lighting Controls

Install occupancy sensors to control lighting fixtures in areas that are frequently unoccupied, even for short periods. For most spaces, we recommend lighting controls use dual technology sensors, which reduce the possibility of lights turning off unexpectedly.

Occupancy sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Most occupancy sensor lighting controls allow users to manually turn fixtures on/off, as needed. Some controls can also provide dimming options.

Occupancy sensors can be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are best suited to single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in large spaces, locations without local switching, and where wall switches are not in the line-of-sight of the main work area.

This measure provides energy savings by reducing the lighting operating hours.

Affected building areas: Room7, Room 11, and the IT/Storage Room

ECM 3: Install High/Low Lighting Controls

Install occupancy sensors to provide dual level lighting control for lighting fixtures in spaces that are infrequently occupied but may require some level of continuous lighting for safety or security reasons.

Lighting fixtures with these controls operate at default low levels when the area is unoccupied to provide minimal lighting to meet security or safety requirements. Sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Fixtures automatically switch back to low level after a predefined period of vacancy. In parking lots and parking garages with significant ambient lighting, this control can sometimes be combined with photocell controls to turn the lights off when there is sufficient daylight.

This measure provides energy savings by reducing the light fixture power draw when reduced light output is appropriate.

Affected building areas: Main Hall

4.3 Electric Unitary HVAC

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Electric Unitary HVAC Measures		4,160	1.4	0	\$618	\$7,481	\$460	\$7,021	11.4	4,189
ECM 4	Install High Efficiency Air Conditioning Units	4,160	1.4	0	\$618	\$7,481	\$460	\$7,021	11.4	4,189

ECM 4: Install High Efficiency Air Conditioning Units

Replace standard efficiency packaged air conditioning units with high efficiency packaged air conditioning units. The magnitude of energy savings for this measure depends on the relative efficiency of the older unit versus the new high efficiency unit, the average cooling load, and the estimated annual operating hours.

4.4 Gas-Fired Heating

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Gas Heating (HVAC/Process) Replacement		0	0.0	32	\$381	\$16,153	\$1,260	\$14,893	39.1	3,719
	Install High Efficiency Hot Water Boilers	0	0.0	32	\$381	\$16,153	\$1,260	\$14,893	39.1	3,719

Install High Efficiency Hot Water Boilers

Replacing the boilers has a long payback and may not be justifiable based simply on energy considerations. However, the boilers have reached the end of their normal useful life. Typically, the marginal cost of purchasing high efficiency boilers can be justified by the marginal savings from the improved efficiency. When the boiler is eventually replaced, consider purchasing boilers that exceed the minimum efficiency required by building codes. We also recommend working with your mechanical design team to determine whether the heating system can operate with return water temperatures below 130°F, which would allow the use of condensing boilers.

5 ENERGY EFFICIENT BEST PRACTICES

A whole building maintenance plan will extend equipment life; improve occupant comfort, health, and safety; and reduce energy and maintenance costs. You may already be doing some of these things— see our list below for potential additions to your maintenance plan. Be sure to consult with qualified equipment specialists for details on proper maintenance and system operation.

Energy Tracking with ENERGY STAR® Portfolio Manager®



You've heard it before - you can't manage what you don't measure. ENERGY STAR® Portfolio Manager® is an online tool that you can use to measure and track energy and water consumption, as well as greenhouse gas emissions.⁴ Your account has already been established. Now you can continue to keep tabs on your energy performance every month.

Weatherization

Caulk or weather strip leaky doors and windows to reduce drafts and loss of heated or cooled air. Sealing cracks and openings can reduce heating and cooling costs, improve building durability, and create a healthier indoor environment.

Doors and Windows

Close exterior doors and windows in heated and cooled areas. Leaving doors and windows open leads to a loss of heat during the winter and chilled air during the summer. Reducing air changes per hour (ACH) can lead to increased occupant comfort as well as heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

Lighting Maintenance



- Clean lamps, reflectors and lenses of dirt, dust, oil, and smoke buildup every six to twelve months. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust. Together, this can reduce total light output by up to 60% while still drawing full power.

- In addition to routine cleaning, developing a maintenance schedule can ensure that maintenance is performed regularly, and it can reduce the overall cost of fixture re-lamping and re-ballasting. Group re-lamping and re-ballasting maintains lighting levels and minimizes the number of site visits by a lighting technician or contractor, decreasing the overall cost of maintenance.

⁴ <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/use-portfolio-manager>.

Lighting Controls

As part of a lighting maintenance schedule, test lighting controls to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight and photocell sensors, maintenance involves cleaning sensor lenses and confirming that setpoints and sensitivity are configured properly.

AC System Evaporator/Condenser Coil Cleaning

Dirty evaporator and condenser coils restrict air flow and restrict heat transfer. This increases the loads on the evaporator and condenser fan and decreases overall cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

HVAC Filter Cleaning and Replacement

Air filters should be checked regularly (often monthly) and cleaned or replaced when appropriate. Air filters reduce indoor air pollution, increase occupant comfort, and help keep equipment operating efficiently. If the building has a building management system, consider installing a differential pressure switch across filters to send an alarm about premature fouling or overdue filter replacement. Over time, filters become less and less effective as particulate buildup increases. Dirty filters also restrict air flow through the air conditioning or heat pump system, which increases the load on the distribution fans.

Boiler Maintenance

Many boiler problems develop slowly over time, so regular inspection and maintenance is essential to keeping the heating system running efficiently and preventing expensive repairs. Annual tune-ups should include a combustion analysis to analyze the exhaust from the boilers and to ensure the boiler is operating safely. Boilers should be cleaned according to the manufacturer's instructions to remove soot and scale from the water side or fire side of the boiler.

Water Conservation



Installing dual flush or low-flow toilets and low-flow/waterless urinals are ways to reduce water use. The EPA WaterSense™ ratings for urinals is 0.5 gallons per flush (gpf) and for flush valve toilets is 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

For more information regarding water conservation go to the EPA's WaterSense™ website⁵ or download a copy of EPA's "WaterSense at Work: Best Management Practices for Commercial and Institutional Facilities"⁶ to get ideas for creating a water management plan and best practices for a wide range of water using systems.

Water conservation devices that do not reduce hot water consumption will not provide energy savings at the site level, but they may significantly affect your water and sewer usage costs. Any reduction in water use does however ultimately reduce grid-level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users.

⁵ <https://www.epa.gov/watersense>.

⁶ <https://www.epa.gov/watersense/watersense-work-0>.

If the facility has detached buildings with a master water meter for the entire campus, check for unnatural wet areas in the lawn or water seeping in the foundation at water pipe penetrations through the foundation. Periodically check overnight meter readings when the facility is unoccupied, and there is no other scheduled water usage.

Manage irrigation systems to use water more effectively outside the building. Adjust spray patterns so that water lands on intended lawns and plantings and not on pavement and walls. Consider installing an evapotranspiration irrigation controller that will prevent over-watering.

Procurement Strategies

Purchasing efficient products reduces energy costs without compromising quality. Consider modifying your procurement policies and language to require ENERGY STAR® or WaterSense™ products where available.

6 ON-SITE GENERATION

You don't have to look far in New Jersey to see one of the thousands of solar electric systems providing clean power to homes, businesses, schools, and government buildings. On-site generation includes both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) technologies that generate power to meet all or a portion of the facility's electric energy needs. Also referred to as distributed generation, these systems contribute to greenhouse gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases reduction, which results in improved electric grid reliability through better use of transmission and distribution systems.

Preliminary screenings were performed to determine if an on-site generation measure could be a cost-effective solution for your facility. Before deciding to install an on-site generation system, we recommend conducting a feasibility study to analyze existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.

6.1 Solar Photovoltaic

Photovoltaic (PV) panels convert sunlight into electricity. Individual panels are combined into an array that produces direct current (DC) electricity. The DC is converted to alternating current (AC) through an inverter. The inverter is then connected to the building’s electrical distribution system.

A preliminary screening based on the facility’s electric demand, size and location of free area, and shading elements shows that the facility has **no** potential for installing a PV array.

This facility does appear not meet the minimum criteria for a cost-effective solar PV installation. To be cost-effective, a solar PV array needs certain minimum criteria, such as flat or south-facing rooftop or other unshaded space on which to place the PV panels.

The graphic below displays the results of the PV potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.




Figure 9 - Photovoltaic Screening

Solar Renewable Energy Certificate (SREC) Registration Program (SRP)

Rebates are not available for solar projects, but owners of solar projects MUST register their projects in the SREC Registration Program before starting construction. Once your PV system is up and running, you periodically earn credits, which can then be sold on the open market for up to 15 years.

If you are considering installing solar photovoltaics on your building, visit www.njcleanenergy.com/srec for more information about the SREC Registration Program.

Get more information about solar power in New Jersey or find a qualified solar installer who can help you decide if solar is right for your building:

- **Basic Info on Solar PV in NJ:** www.njcleanenergy.com/whysolar
- **NJ Solar Market FAQs:** www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs
- **Approved Solar Installers in the NJ Market:** www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1

6.2 Combined Heat and Power

Combined heat and power (CHP) generates electricity at the facility and puts waste heat energy to good use. Common types of CHP systems are reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines.

CHP systems typically produce a portion of the electric power used on-site, with the balance of electric power needs supplied by the local utility company. The heat is used to supplement (or replace) existing boilers and provide space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for space cooling.

The key criteria used for screening is the amount of time that the CHP system would operate at full load and the facility's ability to use the recovered heat. Facilities with a continuous need for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has **no** potential for installing a cost-effective CHP system.

Based on a preliminary analysis, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation. The lack of gas service, low or infrequent thermal load, and lack of space for siting the equipment are the most significant factors contributing to the lack of CHP potential.

The graphic below displays the results of the CHP potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.




Figure 10 - Combined Heat and Power Screening

Find a qualified firm that specializes in commercial CHP cost assessment and installation: http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/.

7 PROJECT FUNDING AND INCENTIVES

Ready to improve your building’s performance? New Jersey Clean Energy Programs can help. Pick the program that works best for you. Incentive programs that may apply to this facility are identified in the Executive Summary. This section provides an overview of currently available in New Jersey Clean Energy Programs.

	SmartStart <i>Flexibility to install at your own pace</i>	Direct Install <i>Turnkey installation</i>	Pay for Performance <i>Whole building upgrades</i>
Who should use it?	Buildings installing individual measures or small group of measures.	Small to mid-size facilities that can bundle multiple measures together. Average peak demand should be below 200 kW. Not suitable for significant building shell issues.	Mid to large size facilities looking to implement as many measures as possible at one time. Peak demand should be over 200 kW.
How does it work?	Use in-house staff or your preferred contractor.	Pre-approved contractors pass savings along to you via reduced material and labor costs.	Whole-building approach to energy upgrades designed to reduce energy use by at least 15%. The more you save, the higher the incentives.
What are the Incentives?	Fixed incentives for specific energy efficiency measures.	Incentives pay up to 70% of eligible costs, up to \$125,000 per project. You pay the remaining 30% directly to the contractor.	Up to 25% of installation cost, calculated based on level of energy savings per square foot.
How do I participate?	Submit an application for the specific equipment to be installed.	Contact a participating contractor in your region.	Contact a pre-qualified Partner to develop your Energy Reduction Plan and set your energy savings targets.
<p>Take the next step by visiting www.njcleanenergy.com for program details, applications, and to contact a qualified contractor.</p>			

7.1 SmartStart



SmartStart offers incentives for installing prescriptive and custom energy efficiency measures at your facility. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades. This program serves most common equipment types and sizes.

SmartStart routinely adds, removes, or modifies incentives from year-to-year for various energy efficiency equipment based on market trends and new technologies.

Equipment with Prescriptive Incentives Currently Available:

Electric Chillers

Electric Unitary HVAC

Gas Cooling

Gas Heating

Gas Water Heating

Ground Source Heat Pumps

Lighting

Lighting Controls

Refrigeration Doors

Refrigeration Controls

Refrigerator/Freezer Motors

Food Service Equipment

Variable Frequency Drives

Incentives

The SmartStart Prescriptive program provides fixed incentives for specific energy efficiency measures. Prescriptive incentives vary by equipment type.

SmartStart Custom provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentives. Custom incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings. Incentives are capped at 50% of the total installed incremental project cost, or a project cost buy down to a one-year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

How to Participate

Submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. You can work with your preferred contractor or use internal staff to install measures.

Visit www.njcleanenergy.com/SSB for a detailed program description, instructions for applying, and applications.

7.2 Direct Install



Direct Install is a turnkey program available to existing small to medium-sized facilities with an average peak electric demand that does not exceed 200 kW over the recent 12-month period. You work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for

installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives and controls.

Incentives

The program pays up to 70% of the total installed cost of eligible measures, up to \$125,000 per project. Each entity is limited to incentives up to \$250,000 per fiscal year.

How to Participate

To participate in Direct Install, you will need to contact the participating contractor assigned to the region of the state where your facility is located. A complete list of Direct Install program partners is provided on the Direct Install website linked below. The contractor will be paid the measure incentives directly by the program which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the program, subject to program caps and eligibility, while the remaining 30% of the cost is paid to the contractor by the customer.

Detailed program descriptions and applications can be found at: www.njcleanenergy.com/DI

8 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

8.1 Retail Electric Supply Options

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third-party supplier, consider shopping for a reduced rate from third-party electric suppliers. If your facility already buys electricity from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party electric suppliers is available at the NJBPU website.⁷

8.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey is also deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate monthly. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third-party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier typically depends on whether a customer prefers budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third-party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility does not already purchase natural gas from a third-party supplier, consider shopping for a reduced rate from third-party natural gas suppliers. If your facility already purchases natural gas from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party natural gas suppliers is available at the NJBPU website.⁸

⁷ www.state.nj.us/bpu/commercial/shopping.html.

⁸ www.state.nj.us/bpu/commercial/shopping.html.

APPENDIX A: EQUIPMENT INVENTORY & RECOMMENDATIONS

Lighting Inventory & Recommendations

Location	Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis								
	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
FormerParksRec_MechRoom	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	2,750	1	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,750	0.1	399	0	\$58	\$146	\$40	1.8
FormerParksRec_Room11	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	2,750	1, 2	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.2	1,016	0	\$148	\$562	\$115	3.0
FormerParksRec_Storage	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	2,750	1	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,750	0.1	299	0	\$44	\$110	\$30	1.8
FormerParksRec_Room7	3	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	S	62	2,750	1, 2	Relamp	Yes	3	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	1,898	0.1	356	0	\$52	\$487	\$65	8.1
FormerParksRec_RR	1	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	2,750	1	Relamp	No	1	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	2,750	0.0	150	0	\$22	\$55	\$15	1.8
FormerParksRec_StorageRm12	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	2,750	1	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,750	0.0	200	0	\$29	\$73	\$20	1.8
FormerParksRec_WomensRR	2	Linear Fluorescent - T8: 3' T8 (25W) - 2L	Occupancy Sensor	S	48	1,898	1	Relamp	No	2	LED - Linear Tubes: (2) 3' Lamps	Occupancy Sensor	21	1,898	0.0	113	0	\$16	\$73	\$20	3.2
FormerParksRec_WomensRR	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	1,898	1	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.0	138	0	\$20	\$73	\$20	2.6
FormerParksRec_FacultyRR	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	1,898	1	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.0	138	0	\$20	\$73	\$20	2.6
FormerParksRec_Room10	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	1,898	1	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.1	413	0	\$60	\$219	\$60	2.6
FormerParksRec_SmartBrd_Rm	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	1,898	1	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.0	138	0	\$20	\$73	\$20	2.6
FormerParksRec_SmartBrd_Rm	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	2,750	1	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,750	0.0	200	0	\$29	\$73	\$20	1.8
FormerParksRec_RmNexttoSB-Room	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	1,898	1	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.1	207	0	\$30	\$110	\$30	2.6
FormerParksRec_IT-Storage	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	2,750	1, 2	Relamp	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.2	762	0	\$111	\$489	\$60	3.9
FormerParksRec_CenterStorage	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	2,750	1	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,750	0.0	100	0	\$15	\$37	\$10	1.8
FormerParksRec_Room20	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	2,750	1	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,750	0.0	100	0	\$15	\$37	\$10	1.8
FormerParksRec_ConfRoom1	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	1,898	1	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.1	276	0	\$40	\$146	\$40	2.6
FormerParksRec_ConfRoom2	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	2,750	1	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,750	0.0	200	0	\$29	\$73	\$20	1.8
FormerParksRec_ConfRoom3	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	1,898	1	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.1	276	0	\$40	\$146	\$40	2.6
FormerParksRec_tionHall	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	1,898	1	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.1	207	0	\$30	\$110	\$30	2.6
FormerParksRec_tionHall	9	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	1,898	1	Relamp	No	9	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.2	620	0	\$91	\$329	\$90	2.6
MensRR	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	1,898	1	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.1	413	0	\$60	\$219	\$60	2.6
NursesOfficeRoom	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	1,898	1	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.1	276	0	\$40	\$146	\$40	2.6
Office_8_Room1	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	1,898	1	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.0	138	0	\$20	\$73	\$20	2.6
Office_8_Room2	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	1,898	1	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.0	138	0	\$20	\$73	\$20	2.6

Location	Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis								
	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
CR1	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	1,898	1	Relamp	No	10	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.2	689	0	\$101	\$365	\$100	2.6
Science Lab 7	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	1,898	1	Relamp	No	10	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.2	689	0	\$101	\$365	\$100	2.6
CR6	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	1,898	1	Relamp	No	10	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.2	689	0	\$101	\$365	\$100	2.6
CR5	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	1,898	1	Relamp	No	10	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.2	689	0	\$101	\$365	\$100	2.6
CR4	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	1,898	1	Relamp	No	10	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.2	689	0	\$101	\$365	\$100	2.6
CR3	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	1,898	1	Relamp	No	10	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.2	689	0	\$101	\$365	\$100	2.6
CR2	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	1,898	1	Relamp	No	10	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,898	0.2	689	0	\$101	\$365	\$100	2.6
MainHall	3	Exit Signs: LED - 2 W Lamp	None	S	6	8,760		None	No	3	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
MainHall	18	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	2,750	1, 3	Relamp	Yes	18	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	1,898	0.5	2,286	0	\$334	\$1,257	\$180	3.2
Exterior	8	LED Screw-In Lamps: SI Lamps	Timedclock	S	30	400		None	No	8	LED Screw-In Lamps: SI Lamps	Timedclock	30	400	0.0	0	0	\$0	\$0	\$0	0.0
Exterior	7	Incandescent: PAR38	Timedclock	S	60	400	1	Relamp	No	7	LED Screw-In Lamps: PAR38 Screw in lamps	Timedclock	9	400	0.2	143	0	\$21	\$211	\$7	9.6

Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions							Proposed Conditions					Energy Impact & Financial Analysis					
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Remaining Useful Life	Annual Operating Hours	ECM #	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives
FormerParksRec	Whole Building	3	Heating Hot Water Pump	0.1	60.0%	No	B	4,380		No	60.0%	No	0.0	0	0	\$0	\$0	\$0	0.0
FormerParksRec	IT Room	1	Supply Fan	0.8	82.5%	No	B	2,745		No	82.5%	No	0.0	0	0	\$0	\$0	\$0	0.0

Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions							Energy Impact & Financial Analysis					
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (MBh)	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (MBh)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives
FormerParksRec	Room 11	1	Window AC	0.83		w		No						0.0	0	0	\$0	\$0	\$0	0.0
FormerParksRec	Room 10	1	Window AC	0.83		w		No						0.0	0	0	\$0	\$0	\$0	0.0
FormerParksRec	IT/Storage	1	Split-System AC	5.00		b	4	Yes	1	Split-System AC	5.00		14.00	1.4	4,160	0	\$618	\$7,481	\$460	11.4
FormerParksRec	Various Rooms	8	Window AC	0.67		w		No						0.0	0	0	\$0	\$0	\$0	0.0

Fuel Heating Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions				Proposed Conditions							Energy Impact & Financial Analysis						
		System Quantity	System Type	Output Capacity per Unit (MBh)	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
FormerParksRec	Whole Building	1	Non-Condensing Hot Water Boiler	720.00	W	NR	Yes	1	Non-Condensing Hot Water Boiler	720.00	85.00%	Et	0.0	0	32	\$381	\$16,153	\$1,260	39.1

DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions				Proposed Conditions						Energy Impact & Financial Analysis						
		System Quantity	System Type	Remaining Useful Life	ECM #	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
FormerParksRec	Whole Building	1	Storage Tank Water Heater (> 50 Gal)	W		No						0.0	0	0	\$0	\$0	\$0	0.0

Plug Load Inventory

Location	Existing Conditions			Energy Rate (W)	ENERGY STAR Qualified ?
	Quantity	Equipment Description			
FormerParksRec	1	Misc. Loads		3,000.0	

APPENDIX B: ENERGY STAR® STATEMENT OF ENERGY PERFORMANCE

EUI is presented in terms of *site energy* and *source energy*. Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

ENERGY STAR® Statement of Energy Performance

ENERGY STAR®
Score¹

Former Parks & Rec Building

Primary Property Type: Other - Public Services
Gross Floor Area (ft²): 14,545
Built: 1961

For Year Ending: May 31, 2017
Date Generated: October 21, 2018

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information		
Property Address Former Parks & Rec Building 900 Leonardville Road Middletown, New Jersey 07737	Property Owner Middletown Township 1 King's Highway Middletown, NJ 07748 732-615-2000	Primary Contact Anthony Mercantante 1 King's Highway Middletown, NJ 07748 732-615-2000 x 2013 amercant@middletownnj.org
Property ID: 6414814		

Energy Consumption and Energy Use Intensity (EUI)					
Site EUI 52.3 kBtu/ft ²	Annual Energy by Fuel		National Median Comparison		
	Natural Gas (kBtu)	567,764 (75%)		National Median Site EUI (kBtu/ft ²)	59.8
	Electric - Grid (kBtu)	192,972 (25%)		National Median Source EUI (kBtu/ft ²)	89.3
		% Diff from National Median Source EUI	-12%		
Source EUI 78.1 kBtu/ft ²	Annual Emissions				
	Greenhouse Gas Emissions (Metric Tons CO2e/year)		50		

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: _____ Date: _____

Licensed Professional

() - _____



Professional Engineer Stamp (if applicable)

APPENDIX C: GLOSSARY

TERM	DEFINITION
Blended Rate	Used to calculate financial savings. The blended rate is calculated by dividing the amount of your bill by the total energy use. For example, if your bill is \$22,217.22, and you used 266,400 kilowatt-hours, your blended rate is 8.3 cents per kilowatt-hour.
BTU	A British thermal unit is the amount of heat required to increase the temperature of one pound water by one-degree Fahrenheit. Commonly used to measure natural gas consumption.
Demand Response	Demand response reduces or shifts electricity usage at or among participating buildings/sites during peak energy use periods in response to time-based rates or other forms of financial incentives.
Energy Efficiency	Reducing the amount of energy necessary to provide comfort and service to a building/area. Achieved through the installation of new equipment and/or optimizing energy management systems.
Generation	The process of generating electric power from sources of primary energy (e.g., natural gas, the sun, oil).
HVAC	Heating, ventilation, and air conditioning.
kW	Kilowatt. Equal to 1,000 Watts.
Load	The total amount of power used by a building system at any given time.
Measure	A single activity, or installation of a single type of equipment, that is implemented in a building system to reduce total energy consumption.
MMBtu	One million British thermal units.
psig	Pounds per square inch.
Plug Load	Refers to the amount of energy used in a space by products that are powered by means of an ordinary AC plug.
Simple Payback	The amount of time needed to recoup the funds expended in an investment, or to reach the break-even point.
Temperature Setpoint	The temperature at which a temperature regulating device (thermostat, for example) has been set.
Turnkey	Provision of a complete product or service that is ready for immediate use
Watt (W)	Unit of power commonly used to measure electricity use.