




Local Government Energy Audit: Energy Audit Report



Copyright ©2017 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Main Academic South
Brookdale Community College

765 Newman Springs Road
Lincroft, NJ 07738

March 26, 2018

Final Report by:

TRC Energy Services

Disclaimer

The intent of this energy analysis report is to identify energy savings opportunities and recommend upgrades to the facility's energy using equipment and systems. Approximate savings are included in this report to help make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. Further design and analysis may be necessary in order to implement some of the measures recommended in this report.

The energy conservation measures and estimates of energy savings have been reviewed for technical accuracy. However, estimates of final energy savings are not guaranteed, because final savings may depend on behavioral factors and other uncontrollable variables. TRC Energy Services (TRC) and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

Estimated installation costs are based on TRC's experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from *RS Means*. The owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for certain measures and conditions, TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. The owner of the facility should review available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

Table of Contents

1	Executive Summary.....	1
1.1	Facility Summary	1
1.2	Your Cost Reduction Opportunities.....	1
	Energy Conservation Measures.....	1
	Energy Efficient Practices	3
	On-Site Generation Measures.....	3
1.3	Implementation Planning.....	3
2	Facility Information and Existing Conditions	5
2.1	Project Contacts	5
2.2	General Site Information.....	5
2.3	Building Occupancy	5
2.4	Building Envelope	5
2.5	On-Site Generation.....	6
2.6	Energy-Using Systems	6
	Lighting System	6
	Chilled Water or Condenser Water System	7
	Hot Water (or Steam) Heating System.....	7
	Heating, Ventilation, and Air Conditioning (HVAC)	7
	Building Plug Load	8
2.7	Water-Using Systems	9
3	Site Energy Use and Costs.....	10
3.1	Total Cost of Energy	10
3.2	Electricity Usage	11
3.3	Natural Gas Usage	12
3.4	Benchmarking.....	13
3.5	Energy End-Use Breakdown	15
4	Energy Conservation Measures	16
4.1	High Priority ECMs.....	16
4.1.1	Lighting Upgrades.....	17
	ECM 1: Retrofit Fluorescent Fixtures with LED Lamps and Drivers.....	17
	ECM 2: Retrofit Fixtures with LED Lamps.....	18
	ECM 3: Install LED Exit Signs.....	18
4.1.2	Lighting Control Measures	19
	ECM 4: Install Occupancy Sensor Lighting Controls	19
4.1.3	Plug Load Equipment Control - Vending Machines.....	20
	ECM 5: Vending Machine Control	20
5	Energy Efficient Practices	21
	Reduce Air Leakage	21
	Close Doors and Windows	21

Ensure Lighting Controls Are Operating Properly	21
Reduce Motor Short Cycling.....	21
Perform Routine Motor Maintenance	21
Practice Proper Use of Thermostat Schedules and Temperature Resets	22
Check for and Seal Duct Leakage	22
Perform Proper Water Heater Maintenance	22
Plug Load Controls.....	22
Replace Computer Monitors	22
Water Conservation	22
6 On-Site Generation Measures	24
6.1 Photovoltaic.....	24
7 Demand Response	26
8 Project Funding / Incentives	27
8.1 SmartStart	28
8.2 Energy Savings Improvement Program	29
8.3 Demand Response Energy Aggregator.....	29
9 Energy Purchasing and Procurement Strategies	30
9.1 Retail Electric Supply Options.....	30
9.2 Retail Natural Gas Supply Options	30

Appendix A: Equipment Inventory & Recommendations

Appendix B: ENERGY STAR® Statement of Energy Performance

Table of Figures

Figure 1 – Previous 12 Month Utility Costs.....	2
Figure 2 – Potential Post-Implementation Costs	2
Figure 3 – Summary of Energy Reduction Opportunities	2
Figure 4 – Project Contacts	5
Figure 5 - Building Schedule.....	5
Figure 6 - Utility Summary	10
Figure 7 - Energy Cost Breakdown	10
Figure 8 - Electric Usage & Demand.....	11
Figure 9 - Electric Usage & Demand.....	11
Figure 10 - Natural Gas Usage.....	12
Figure 11 - Natural Gas Usage.....	12
Figure 12 - Energy Use Intensity Comparison – Existing Conditions.....	13
Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures	13
Figure 14 - Energy Balance (% and kBtu/SF)	15
Figure 15 – Summary of High Priority ECMs	16
Figure 16 – Summary of Lighting Upgrade ECMs.....	17
Figure 17 – Summary of Lighting Control ECMs	19
Figure 18 - Photovoltaic Screening	25
Figure 19 - ECM Incentive Program Eligibility.....	27

I EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBPUB) has sponsored this Local Government Energy Audit (LGEA) Report for the Main Academic South (MAS) building.

The goal of an LGEA report is to provide public facilities and local governments with valuable information on their facilities' energy usage. The LGEA program identifies energy conservation measures (ECMs) and energy management options that may benefit public facilities and to provides information on financial incentives from New Jersey's Clean Energy Programs (NJCEP) and other sources assistance which may be available to help with ECM implementation.

This study was conducted by TRC Energy Services (TRC), as part of a comprehensive effort to assist New Jersey community colleges in controlling their energy costs and help to protect our environment by promoting more efficient use of energy resources statewide.

I.1 Facility Summary

Main Academic South (MAS) is a 119,796 square foot facility comprised of various space types within a building that is a part of the campus's Main Academic complex. The building is three floors. It includes offices, classrooms and labs.

Lighting at Main Academic South consists primarily of fixtures with T8 linear fluorescent bulbs which are considered inefficient according to new lighting efficiency standards. The buildings also has multiple fixtures containing high output fluorescent T5 bulbs and compact fluorescent. Lights in some offices are controlled by occupancy sensors, but most areas a controlled by manual switches.

The building is conditioned by four main variable air volume (VAV) air handling units (AHU). The AHU receive chilled water and hot water from the campus central utility plant, which is next to the MAS building. The building receives electric power via the campus' main electric account. A thorough description of the facility and our observations are located in Section 2.

I.2 Your Cost Reduction Opportunities

Energy Conservation Measures

TRC evaluated five energy conservation measures. Together these five ECMs represent an opportunity for Main Academic South to reduce its annual energy costs by \$29,777 and its annual greenhouse gas emissions by 266,946 lbs CO₂e. We estimate that if measures are implemented as recommended, then the project would pay for itself in about 4.2 years. The breakdown of existing utility costs and projected annual savings following implementation of all measures are shown in Figure 1 and Figure 2, respectively. Together these measures represent an opportunity to reduce Maintenance Building's annual energy use by about 7% overall.

Figure 1 – Previous 12 Month Utility Costs





Figure 2 – Potential Post-Implementation Costs



A detailed description of Main Academic South’s existing energy use can be found in Section 3.

Estimates of the total cost, energy savings, and financial incentives for the evaluated energy efficient upgrades are summarized below in Figure 3. A brief description of each category can be found below and a description of savings opportunities can be found in Section 4.

Figure 3 – Summary of Energy Reduction Opportunities

Energy Conservation Measure		Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades			223,412	46.3	0.0	\$25,094.79	\$115,349.27	\$15,440.00	\$99,909.27	4.0	224,974
ECM 1	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	Yes	136	0.1	0.0	\$15.24	\$234.00	\$20.00	\$214.00	14.0	137
ECM 2	Retrofit Fixtures with LED Lamps	Yes	222,561	46.2	0.0	\$24,999.20	\$114,577.49	\$15,420.00	\$99,157.49	4.0	224,117
ECM 3	Install LED Exit Signs	Yes	715	0.1	0.0	\$80.34	\$537.78	\$0.00	\$537.78	6.7	720
Lighting Control Measures			37,429	8.6	0.0	\$4,204.22	\$27,524.00	\$3,960.00	\$23,564.00	5.6	37,691
ECM 4	Install Occupancy Sensor Lighting Controls	Yes	37,429	8.6	0.0	\$4,204.22	\$27,524.00	\$3,960.00	\$23,564.00	5.6	37,691
Plug Load Equipment Control - Vending Machine			4,251	0.0	0.0	\$477.52	\$1,610.00	\$0.00	\$1,610.00	3.4	4,281
ECM 5	Vending Machine Control	Yes	4,251	0.0	0.0	\$477.52	\$1,610.00	\$0.00	\$1,610.00	3.4	4,281
TOTALS			265,092	54.9	0.0	\$29,776.53	\$144,483.27	\$19,400.00	\$125,083.27	4.2	266,946

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Lighting Upgrades generally involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measures save energy by reducing the power used by the lighting components due to improved electrical efficiency.

Lighting Controls measures generally involve the installation of automated controls to turn off lights or reduce light output when not needed. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

Plug Load Equipment Control measures generally involve installing automated devices that limit the power usage or operation of equipment that is plugged into an electric outlets when not in use.

Energy Efficient Practices

TRC also identified 11 low-cost (or no-cost) energy efficient practices, which might yield additional energy savings for the facility. A facility's energy performance can be significantly improved by employing certain behavioral or operational adjustments and by performing better routine maintenance on building systems. These practices can extend equipment lifetime, improve occupant comfort, provide better health and safety, as well as reduce annual energy and O&M costs. Potential opportunities identified at Main Academic South include:

- Reduce Air Leakage
- Close Doors and Windows
- Ensure Lighting Controls Are Operating Properly
- Reduce Motor Short Cycling
- Perform Routine Motor Maintenance
- Practice Proper Use of Thermostat Schedules and Temperature Resets
- Check for and Seal Duct Leakage
- Perform Proper Water Heater Maintenance
- Install Plug Load Controls
- Replace Computer Monitors
- Water Conservation

For details on these energy efficient practices, please refer to Section 5.

On-Site Generation Measures

TRC evaluated the potential for installing on-site generation for Main Academic South. Based on the configuration of the site and its loads there is a low potential for installing any solar PV or combined heat and power self-generation measures.

For details on our evaluation and on-site generation potential, please refer to Section 6.

1.3 Implementation Planning

To realize the energy savings from the ECMs listed in this report, a project implementation plan must be developed. Available capital must be considered and decisions need to be made whether it is best to pursue individual ECMs separately, groups of ECMs, or a comprehensive approach where all ECMs are implemented together, possibly in conjunction with other facility upgrades or improvements.

Rebates, incentives, and financing are available from NJCEP, as well as other sources, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any measure, please review the relevant incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives prior to purchasing materials or commencing with installation.

The ECMs outlined in this report may qualify under the following program(s):

- SmartStart
- Energy Savings Improvement Program (ESIP)

For facilities wanting to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate in this program you may utilize internal resources, or an outside firm or contractor, to do the final design of the ECM(s) and do the installation. Program pre-approval is required for some SS incentives,

so only after receiving pre-approval should you proceed with ECM installation. The incentive estimates listed above in Figure 3 are based on the SmartStart program. More details on this program and others are available in Section 8.

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the Energy Savings Improvement Program (ESIP). Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. An LGEA report (or other approved energy audit) is required for participation in ESIP. Please refer to Section 8.2 for additional information on the ESIP Program.

The Demand Response Energy Aggregator is a (non-NJCEP) program designed to reduce electric loads at commercial facilities, when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. Demand Response (DR) service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability. By enabling grid operators to call upon commercial facilities to reduce their electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and facilities receive payments whether or not they are called upon to curtail their load during times of peak demand. Refer to Section 7 for additional information on this program.

Additional information on relevant incentive programs is located in Section 8 or: www.njcleanenergy.com/ci.

2 FACILITY INFORMATION AND EXISTING CONDITIONS

2.1 Project Contacts

Figure 4 – Project Contacts

Name	Role	E-Mail	Phone #
Customer			
Tim Drury	Director of Facilities Management & Construction	tdrury@brookdalecc.edu	732-224-2217
TRC Energy Services			
Tom Page	Auditor	tpage@TRCsolutions.com	(732) 855-0033

2.2 General Site Information

On December 2, 2017, TRC performed an energy audit at Main Academic South located in Lincroft, New Jersey. TRC’s team met with Tim Drury, Director of Facilities Management & Construction to review the facility operations and help focus our investigation on specific energy-using systems.

Main Academic South is an 119,796 square foot facility comprised of various space types within a building that is a part of the campus’s Main Academic complex. The building is three (3) floors. It includes offices, classrooms and labs.

The building is conditioned by four (4) main variable air volume (VAV) air handling units (AHU). The AHU receive chilled water and hot water from the campus central utility plant, which is next to the MAS building. The building has no large boilers, furnaces, chillers, or air conditioning units on site. The building receives electric power via the campus’s main electric account.

2.3 Building Occupancy

The building is open every day. The typical operating schedule is presented in the table below. When classes are in session, the building is typically occupied by approximately 1000 students and staff per day.

Figure 5 - Building Schedule

Building Name	Weekday/Weekend	Operating Schedule
Main Academic South	Weekday	6am-11pm
Main Academic South	Weekend	Sa: 7am-7pm, Su: 7am-1pm

2.4 Building Envelope

The building is constructed of concrete and concrete block with a stone facade. The building has a combination pitched roof sheathed standing seam metal panels. The building’s windows are double paned and in good condition. The exterior doors are constructed of glass with an aluminum frame and in good condition. No signs of sign of excessive air infiltration were observed.

Image 1: MAS Building – Front Exterior



2.5 On-Site Generation

Main Academic South does not have any on-site electric generating capacity.

2.6 Energy-Using Systems

Please see Appendix A: Equipment Inventory & Recommendations for an inventory of the facility's equipment.

Lighting System

Lighting is provided mostly by 32-Watt linear fluorescent T8 lamps with electronic ballasts. A few areas are lit by 54-Watt linear fluorescent T5HO lamps with electronic ballasts. Most of the fixtures are 2-lamp or 3-lamp, 4-foot long troffers with diffusers. The buildings also has many recessed can ceiling fixtures, mostly with two (2) 17-watt compact fluorescent lamps (CFLs).

Lights in some offices are controlled by occupancy sensors, but most areas a controlled by manual switches.

There are very few exterior lighting connected to the building. (Campus walkway and parking lot lights are included in the building report for the Central Utility Plant).

Image 2: Building Lighting



Chilled Water or Condenser Water System

The building is served by the campus's central chilled water plant. The central chilled water plant is comprised of three 740-ton water cooled centrifugal chillers. (See the Central Utility Plant report for a full description of the chilled water system).

Hot Water (or Steam) Heating System

The building is served by the campus's central hot water plant. The central hot water plant is comprised of eight (8) condensing hot water boilers, with an output heating capacity of 2,850 MBh each. (See the Central Utility Plant report for a full description of the hot water system).

Heating, Ventilation, and Air Conditioning (HVAC)

The building has no large boilers, furnaces, chillers, or air conditioning units on site. The building receives all thermal energy for space conditioning from central campus districts heating and cooling loops.

There are four main air handling units that serve building. Each AHU draws air from its own return air shaft and supplies air to its own air shaft. These AHU are variable air volume (VAV) systems with VAV terminal reheat boxes. Heating and cooling coils in the AHU are supplied by hot and chilled water from district heating and cooling loops. They condition the air before it is supplied to the VAV reheat boxes.

The AHU each have a 50-hp supply fan and a 25-hp return fan. All of the fans are controlled by VFDs and the system flow is controlled by changing speed of the supply and return fans. The supply fans maintain a constant duct static pressure. The return fans maintain a building static pressure.

There are roughly seven fume hoods located in the chemistry lab and seven (7) fume hoods located in the biology lab. The flow through the hoods varies based on sash position. Fans controlled by VFDs vary the volume of exhaust air while maintain hood face velocity. It was observed that a few of the VFDs were being operating in bypass or hand mode at a constant speed. The reason for this was not identified during our inspection. The underlying reason should be identified, issues corrected, and the VFDs released back into automatic operation.

The building also has approximately 20 small fan coil units that help condition the building.

No motor upgrade opportunities were found for any AHUs, exhaust fans, or fume hoods. All motors appeared to be high efficiency models and in good condition. All large fan motors throughout the building appeared to be controlled by VFDs.

Image 3: All large fan motors are controlled by VFDs



Building Plug Load

There are 305 computer work stations throughout the facility. All of the computers are desktop units with LCD monitors. There is no centralized PC power management software installed.

There are 14 printers, four large copy machines, 22 medium sized CRT televisions, seven small microwaves and seven standard refrigerators onsite – all fairly typical equipment for academic building of this size. There were also seven vending machines present. Two of the vending machines were operating on Vending Miser controls, while five vending machines were not.

Image 4: Building Plug Load Equipment





2.7 Water-Using Systems

There are 11 restrooms in the building. A sampling of restrooms found that the faucets and other restroom fixtures appeared to meet current federal guidelines for low-flow water conserving devices in public facilities.

3 SITE ENERGY USE AND COSTS

Nearly the entire campus receives electricity through the campus’s main electric account. Power is distributed to campus buildings from the Central Utility Plant, which is next to Main Academic South. The Central Utility Plant also supplies hot and chilled water to the building. There are no building level submeters on campus therefore annual electric usage had to be estimated for individual buildings on the main account. Each building received a pro-rated share based on building size, function, and occupancy. It should be noted that gas used for heating the MAS and electric energy used by the Central Utility Plant to cool the facility is included in our estimated energy usage for this building.

Prorated utility data for electricity and natural gas was evaluated to determine the annual energy performance metrics for the building in energy cost per square foot and energy usage per square foot. These metrics are an estimate of the relative energy efficiency of this building. There are a number of factors that could cause the energy use of this building to vary from the “typical” energy usage profile for facilities with similar characteristics. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and energy efficient behavior of occupants all contribute to benchmarking scores. Please refer to the Benchmarking section within Section 3.4 for additional information.

3.1 Total Cost of Energy


The following energy consumption and cost data is prorated from a recent 12-month period of master metered electric billing data. A profile of the annual energy consumption and energy cost of the facility was developed from this information.

Figure 6 - Utility Summary

Utility Summary for Main Academic South		
Fuel	Usage	Cost
Electricity	2,134,061 kWh	\$239,709
Natural Gas	59,341 Therms	\$68,146
Total		\$307,855

We estimate the current annual energy cost for this building to be about \$307,855 as shown in the figure below.

Figure 7 - Energy Cost Breakdown



3.2 Electricity Usage

Electricity is provided by JCP&L. The average electric rate over a recent 12-month period was found to be \$0.112/kWh, which is the blended rate that includes energy supply, distribution, demand, and other charges. This rate is used throughout the analyses in this report to assess energy costs and savings. The prorated monthly electricity consumption and peak demand are shown in the chart below.

Figure 8 - Electric Usage & Demand




Figure 9 - Electric Usage & Demand

Electric Billing Data for Main Academic South					
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Total Electric Cost	TRC Estimated Usage?
4/13/15	32	140,424	395.6	\$15,773	Yes
5/12/15	29	164,869	246.6	\$18,519	Yes
6/11/15	30	175,789	511.7	\$19,746	Yes
7/13/15	32	204,211	497.7	\$22,938	Yes
8/12/15	30	209,784	554.6	\$23,564	Yes
9/11/15	30	200,246	459.6	\$22,493	Yes
10/13/15	32	175,107	522.9	\$19,669	Yes
11/12/15	30	179,628	486.1	\$20,177	Yes
12/14/15	32	177,322	421.4	\$19,918	Yes
1/13/16	30	151,200	357.2	\$16,984	Yes
2/11/16	29	177,226	342.0	\$19,907	Yes
3/11/16	29	178,257	395.6	\$20,023	Yes
Totals	365	2,134,061	554.6	\$239,709	12
Annual	365	2,134,061	554.6	\$239,709	

3.3 Natural Gas Usage

Natural gas is provided by New Jersey Natural Gas. The average rate for natural gas service over a recent 12-month period was found to be \$1.148/therm, which is the blended rate used throughout the analyses in this report. The monthly prorated gas consumption is shown in the chart below.

Figure 10 - Natural Gas Usage




Figure 11 - Natural Gas Usage

Gas Billing Data for Main Academic South				
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost	TRC Estimated Usage?
4/15/15	29	8,293	\$9,523	Yes
5/14/15	29	4,287	\$4,923	Yes
6/11/15	28	3,152	\$3,620	Yes
7/16/15	30	2,894	\$3,324	Yes
8/12/15	32	2,493	\$2,863	Yes
9/10/15	29	2,711	\$3,114	Yes
10/8/15	28	3,476	\$3,992	Yes
11/9/15	32	3,678	\$4,223	Yes
12/11/15	32	4,568	\$5,246	Yes
1/12/16	31	4,975	\$5,713	Yes
2/11/16	31	10,245	\$11,765	Yes
3/17/16	34	8,568	\$9,839	Yes
Totals	365	59,341	\$68,146	12
Annual	365	59,341	\$68,146	

3.4 Benchmarking

This facility was benchmarked using Portfolio Manager, an online tool created and managed by the United States Environmental Protection Agency (EPA) through the ENERGY STAR® program. Portfolio Manager analyzes your building’s consumption data, cost information, and operational use details and then compares its performance against a national median for similar buildings of its type. Metrics provided by this analysis are Energy Use Intensity (EUI) and an ENERGY STAR® score for select building types.

The EUI is a measure of a facility’s energy consumption per square foot, and it is the standard metric for comparing buildings’ energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more or less energy than similar buildings of its type on a square foot basis. EUI is presented in terms of “site energy” and “source energy.” Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

Figure 12 - Energy Use Intensity Comparison – Existing Conditions

Energy Use Intensity Comparison - Existing Conditions		
	Main Academic South	National Median Building Type: Higher Education - Public
Source Energy Use Intensity (kBtu/ft ²)	242.9	262.6
Site Energy Use Intensity (kBtu/ft ²)	110.3	130.7

Implementation of all recommended measures in this report would improve the building’s estimated EUI significantly, as shown in the table below:

Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures

Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	Main Academic South	National Median Building Type: Higher Education - Public
Source Energy Use Intensity (kBtu/ft ²)	219.2	262.6
Site Energy Use Intensity (kBtu/ft ²)	102.8	130.7

Many types of commercial buildings are also eligible to receive an ENERGY STAR® score. This score is a percentile ranking from 1 to 100. It compares your building’s energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75 percent of all similar buildings nationwide and may be eligible for ENERGY STAR® certification.

This building is not eligible to receive an ENERGY STAR® score, because it shares electric and gas end usage with the other central campus buildings – which are all served by the Central Utility Plant’s main electric and gas accounts. Without individual submeters to measure each building’s actual electric and thermal energy usage, we cannot be certain that the assumptions on which we based our estimates of building performance are accurate for this building and other central campus buildings.

Because of this limitation, a Portfolio Manager Statement of Energy Performance (SEP) was generated for all of the BCC - Lincroft central campus buildings combined, based on the utility data provided for the master electric and gas accounts, see Appendix B: ENERGY STAR® Statement of Energy Performance.

For more information on ENERGY STAR® certification go to: <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.


A Portfolio Manager account has been created online for your facility and you will be provided with the login information for the account. We encourage you to update your utility information in Portfolio Manager regularly, so that you can keep track of your building's performance. Free online training is available to help you use ENERGY STAR® Portfolio Manager to track your building's performance at: <https://www.energystar.gov/buildings/training>.

3.5 Energy End-Use Breakdown

In order to provide a complete overview of energy consumption across building systems, an energy balance was performed at this facility. An energy balance utilizes standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building to determine their proportional contribution to overall building energy usage. The Central Utility Plant boilers are included in the analysis but that their operating hours were scaled to be consistent with the prorated historical energy use.

This chart of energy end uses highlights the relative contribution of each equipment category to total energy usage. This can help determine where the greatest benefits might be found from energy efficiency measures.

Figure 14 - Energy Balance (% and kBtu/SF)



4 ENERGY CONSERVATION MEASURES

Level of Analysis

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information to the Main Academic South regarding financial incentives for which they may qualify to implement the recommended measures. For this audit report, most measures have received only a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to demonstrate project cost-effectiveness and help prioritize energy measures. Savings are based on the New Jersey Clean Energy Program Protocols to Measure Resource Savings dated June 29, 2016, approved by the New Jersey Board of Public Utilities. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances. A higher level of investigation may be necessary to support any custom SmartStart or Pay for Performance, or Direct Install incentive applications. Financial incentives for the ECMs identified in this report have been calculated based the NJCEP prescriptive SmartStart program. Some measures and proposed upgrade projects may be eligible for higher incentives than those shown below through other NJCEP programs as described in Section 8.

The following sections describe the evaluated measures.

4.1 High Priority ECMs

The measures below have been evaluated by the auditor and are recommended for implementation at the facility.

Figure 15 – Summary of High Priority ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		223,412	46.3	0.0	\$25,094.79	\$115,349.27	\$15,440.00	\$99,909.27	4.0	224,974
ECM 1	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	136	0.1	0.0	\$15.24	\$234.00	\$20.00	\$214.00	14.0	137
ECM 2	Retrofit Fixtures with LED Lamps	222,561	46.2	0.0	\$24,999.20	\$114,577.49	\$15,420.00	\$99,157.49	4.0	224,117
ECM 3	Install LED Exit Signs	715	0.1	0.0	\$80.34	\$537.78	\$0.00	\$537.78	6.7	720
Lighting Control Measures		37,429	8.6	0.0	\$4,204.22	\$27,524.00	\$3,960.00	\$23,564.00	5.6	37,691
ECM 4	Install Occupancy Sensor Lighting Controls	37,429	8.6	0.0	\$4,204.22	\$27,524.00	\$3,960.00	\$23,564.00	5.6	37,691
Plug Load Equipment Control - Vending Machine		4,251	0.0	0.0	\$477.52	\$1,610.00	\$0.00	\$1,610.00	3.4	4,281
ECM 5	Vending Machine Control	4,251	0.0	0.0	\$477.52	\$1,610.00	\$0.00	\$1,610.00	3.4	4,281
TOTALS		265,092	54.9	0.0	\$29,776.53	\$144,483.27	\$19,400.00	\$125,083.27	4.2	266,946

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

4.1.1 Lighting Upgrades

Recommended upgrades to existing lighting fixtures are summarized in Figure 16 below.

Figure 16 – Summary of Lighting Upgrade ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		223,412	46.3	0.0	\$25,094.79	\$115,349.27	\$15,440.00	\$99,909.27	4.0	224,974
ECM 1	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	136	0.1	0.0	\$15.24	\$234.00	\$20.00	\$214.00	14.0	137
ECM 2	Retrofit Fixtures with LED Lamps	222,561	46.2	0.0	\$24,999.20	\$114,577.49	\$15,420.00	\$99,157.49	4.0	224,117
ECM 3	Install LED Exit Signs	715	0.1	0.0	\$80.34	\$537.78	\$0.00	\$537.78	6.7	720

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 1: Retrofit Fluorescent Fixtures with LED Lamps and Drivers

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	136	0.1	0.0	\$15.24	\$234.00	\$20.00	\$214.00	14.0	137
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

Measure Description

Most of the lighting at the facility is T8 or T5 linear fluorescents or compact fluorescents. However a few older T-12 fluorescent fixtures were found in some mechanical rooms. When retrofitting T12 fixtures with LEDs, it is best to replace the ballasts as well. We recommend retrofitting all existing T12 fluorescent fixtures by removing fluorescent tubes and ballasts and replacing them with LEDs and LED drivers, which are designed to be used retrofitted fluorescent fixtures. The measure uses the existing fixture housing but replaces the rest of the components with more efficient lighting technology. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tubes and more than ten times longer than many incandescent lamps.

ECM 2: Retrofit Fixtures with LED Lamps

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	221,095	46.0	0.0	\$24,834.54	\$113,901.71	\$15,420.00	\$98,481.71	4.0	222,641
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

Measure Description

We recommend retrofitting existing T8 and T5 fluorescent lighting technologies with LED lamps. Many LED tube lamps are direct replacements for existing fluorescent lamps and can be installed while leaving the fluorescent fixture ballast in place. LED bulbs can be used in existing fixtures as a direct replacement for most other lighting technologies. Recessed can lighting can be upgraded to LEDs using retrofit kits. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tubes and more than ten times longer than many incandescent lamps.

ECM 3: Install LED Exit Signs

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	715	0.1	0.0	\$80.34	\$537.78	\$0.00	\$537.78	6.7	720
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

Measure Description

We recommend replacing all compact fluorescent exit signs with LED exit signs. Existing exit signs could be retrofitted with LEDs instead, but simply replacing them with LED exit signs is often more cost-effective. Most of the building's exit signs are already LEDs, but a few of the older fluorescent type still remain.

LED exit signs require virtually no maintenance and have a life expectancy of at least 20 years. This measure saves energy by installing LED fixtures, which use less power than other technologies with an equivalent lighting output.

4.1.2 Lighting Control Measures

Figure 17 – Summary of Lighting Control ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures		37,429	8.6	0.0	\$4,204.22	\$27,524.00	\$3,960.00	\$23,564.00	5.6	37,691
ECM 4	Install Occupancy Sensor Lighting Controls	37,429	8.6	0.0	\$4,204.22	\$27,524.00	\$3,960.00	\$23,564.00	5.6	37,691

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 4: Install Occupancy Sensor Lighting Controls

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
37,429	8.6	0.0	\$4,204.22	\$27,524.00	\$3,960.00	\$23,564.00	5.6	37,691

Measure Description

We recommend installing occupancy sensors to control lighting fixtures that are currently controlled by manual switches in all restrooms, storage rooms, classrooms, and offices areas. Lighting sensors detect occupancy using ultrasonic and/or infrared sensors. For most spaces, we recommend lighting controls use dual technology sensors, which can eliminate the possibility of any lights turning off unexpectedly. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Some controls also provide dimming options and all modern occupancy controls can be easily over-ridden by room occupants to allow them to manually turn fixtures on or off, as desired. Energy savings results from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are recommended for single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in locations without local switching or where wall switches are not in the line-of-sight of the main work area and in large spaces. We recommend a comprehensive approach to lighting design that upgrades both the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

4.1.3 Plug Load Equipment Control - Vending Machines

ECM 5: Vending Machine Control

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
4,251	0.0	0.0	\$477.52	\$1,610.00	\$0.00	\$1,610.00	3.4	4,281

Measure Description

Vending machines operate continuously, even during non-business hours. It is recommended to install occupancy sensor controls to reduce the energy use. These controls power down vending machines when the vending machine area has been vacant for some time, then power up at regular intervals, as needed, to turn machine lights on or keep the product cool. Energy savings are a dependent on vending machine and activity level in the area surrounding the machines.

5 ENERGY EFFICIENT PRACTICES

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of many low cost or no-cost energy efficiency strategies. By employing certain behavioral and operational changes and performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and energy and O&M costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

Reduce Air Leakage

Air leakage, or infiltration, occurs when outside air enters a building uncontrollably through cracks and openings. Properly sealing such cracks and openings can significantly reduce heating and cooling costs, improve building durability, and create a healthier indoor environment. This includes caulking or installing weather stripping around leaky doors and windows allowing for better control of indoor air quality through controlled ventilation.

Close Doors and Windows

Ensure doors and windows are closed in conditioned spaces. Leaving doors and windows open leads to a significant increase in heat transfer between conditioned spaces and the outside air. Reducing a facility's air changes per hour (ACH) can lead to increased occupant comfort as well as significant heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

Ensure Lighting Controls Are Operating Properly

Lighting controls are very cost effective energy efficient devices, when installed and operating correctly. As part of a lighting maintenance schedule, lighting controls should be tested annually to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight sensors, maintenance involves cleaning of sensor lenses and confirming setpoints and sensitivity are appropriately configured.

Reduce Motor Short Cycling

Frequent stopping and starting of motors subjects rotors and other parts to substantial stress. This can result in component wear, reducing efficiency, and increasing maintenance costs. Adjust the load on the motor to limit the amount of unnecessary stopping and starting to improve motor performance.

Perform Routine Motor Maintenance

Motors consist of many moving parts whose collective degradation can contribute to a significant loss of motor efficiency. In order to prevent damage to motor components, routine maintenance should be performed. This maintenance consists of cleaning surfaces and ventilation openings on motors to prevent overheating, lubricating moving parts to reduce friction, inspecting belts and pulleys for wear and to ensure they are at proper alignment and tension, and cleaning and lubricating bearings. Consult a licensed technician to assess these and other motor maintenance strategies.

Practice Proper Use of Thermostat Schedules and Temperature Resets

Ensure thermostats are correctly set back. By employing proper set back temperatures and schedules, facility heating and cooling costs can be reduced dramatically during periods of low or no occupancy. As such, thermostats should be programmed for a setback of 5-10 °F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced further by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

Check for and Seal Duct Leakage

Duct leakage in commercial buildings typically accounts for 5% to 25% of the supply airflow. In the case of rooftop air handlers, duct leakage can occur to the outside of the building, significantly increasing cooling and heating costs. By sealing sources of leakage, cooling, heating, and ventilation energy use can be reduced significantly, depending on the severity of air leakage.

Perform Proper Water Heater Maintenance

At least once a year, drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Once a year check for any leaks or heavy corrosion on the pipes and valves. For gas water heaters, check the draft hood and make sure it is placed properly, with a few inches of air space between the tank and where it connects to the vent. Look for any corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional. For electric water heaters, look for any signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank. For water heaters over three to four years old have a technician inspect the sacrificial anode annually.

Plug Load Controls

There are a variety of ways to limit the energy use of plug loads including increasing occupant awareness, removing under-utilized equipment, installing hardware controls, and using software controls. Some control steps to take are to enable the most aggressive power settings on existing devices or install load sensing or occupancy sensing (advanced) power strips. For additional information refer to "Plug Load Best Practices Guide" <http://www.advancedbuildings.net/plug-load-best-practices-guide-offices>.

Replace Computer Monitors

Replacing old computer monitors or displays with efficient monitors will reduce energy use. ENERGY STAR® rated monitors have specific requirements for on mode power consumption as well as idle and sleep mode power. According to the ENERGY STAR® website monitors that have earned the ENERGY STAR® label are 25% more efficient than standard monitors.

Water Conservation

Installing low-flow faucets or faucet aerators, low-flow showerheads, and kitchen sink pre-rinse spray valves saves both energy and water. These devices save energy by reducing the overall amount of hot water used hence reducing the energy used to heat the water. The flow ratings for EPA WaterSense™ (<http://www3.epa.gov/watersense/products>) labeled devices are 1.5 gallons per minute (gpm) for bathroom faucets, 2.0 gpm for showerheads, and 1.28 gpm for pre-rinse spray valves.

Installing dual flush or low-flow toilets and low-flow or waterless urinals are additional ways to reduce the sites water use, however, these devices do not provide energy savings at the site level. Any reduction in water use does however ultimately reduce grid level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users. The EPA WaterSense™ ratings for urinals is 0.5 gallons per flush (gpf) and toilets that use as little as 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

6 ON-SITE GENERATION MEASURES

On-site generation measure options include both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey's Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State's electrical needs to be met by renewable sources by 2050.

Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before making a decision to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.

6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility's electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.


A preliminary screening based on the facility's electric demand, size and location of free area, and shading elements shows that the facility has a Low potential for cost-effective installation of a solar PV array.

In order to be cost-effective, a solar PV array needs certain minimum criteria, such as flat or south-facing rooftop or other unshaded space on which to place the PV panels. In our opinion, the facility does appear not meet these minimum criteria for cost-effective PV installation. The slope of the roof and its orientation would likely make this building's roof difficult to develop for solar PV electric generation.

For more information on solar PV technology and commercial solar markets in New Jersey, or to find a qualified solar installer, who can provide a more detailed assessment of the specific costs and benefits of solar develop of the site, please visit the following links below:

- **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- **NJ Solar Market FAQs:** <http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs>
- **Approved Solar Installers in the NJ Market:** http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1

Figure 18 - Photovoltaic Screening



7 DEMAND RESPONSE

Demand Response (DR) is a program designed to reduce the electric load of commercial facilities when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability.

By enabling grid operators to call upon Curtailment Service Providers and commercial facilities to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants receive payments whether or not their facility is called upon to curtail their electric usage. Typically an electric customer needs to be capable of reducing their electric demand, within minutes, by at least 100 kW or more in order to participate in a DR program. Customers with a greater capability to quickly curtail their demand during peak hours will receive higher payments. Customers with back-up generators onsite may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in a DR programs often find it to be a valuable source of revenue for their facility because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature set points on thermostats, so that air conditioning units run less frequently, or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, in order to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a demand response activity in most situations.

The first step toward participation in a DR program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business (<http://www.pjm.com/markets-and-operations/demand-response/csps.aspx>). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity (<http://www.pjm.com/training/training%20material.aspx>), along with a variety of other DR program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

In our opinion this building is not a good candidate for DR, because it is not separately metered. However, the college might benefit from participation in a DR program which might include DR measures at multiple building including this one. The college should consult with a DR service provider to determine eligibility requirements for campus participation.

8 PROJECT FUNDING / INCENTIVES

The NJCEP is able to provide the incentive programs described below, and other benefits to ratepayers, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey’s Electricity Restructuring Law (1999), which requires all customers of investor-owned electric and gas utilities to pay a surcharge on their monthly energy bills. As a customer of a state-regulated electric or gas utility and therefore a contributor to the fund your organization is eligible to participate in the LGEA program and also eligible to receive incentive payment for qualifying energy efficiency measures. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 19 for a list of the eligible programs identified for each recommended ECM.

Figure 19 - ECM Incentive Program Eligibility

Energy Conservation Measure		SmartStart Prescriptive	SmartStart Custom	Direct Install	Pay For Performance Existing Buildings
ECM 1	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	X			
ECM 2	Retrofit Fixtures with LED Lamps	X			
ECM 3	Install LED Exit Signs	X			
ECM 4	Install Occupancy Sensor Lighting Controls	X			
ECM 5	Vending Machine Control	X			

SmartStart is generally well-suited for implementation of individual measures or small group of measures. It provides flexibility to install measures at your own pace using in-house staff or a preferred contractor. Direct Install caters to small to mid-size facilities that can bundle multiple ECMs together. This can greatly simplify participation and may lead to higher incentive amounts, but requires the use of pre-approved contractors. The Pay for Performance (P4P) program is a “whole-building” energy improvement program designed for larger facilities. It requires implementation of multiple measures meeting minimum savings thresholds, as well as use of pre-approved consultants. This facility does not meet all of the criteria for participating in the P4P program based on the measures identified in this study.

Generally, the incentive values provided throughout the report assume the SmartStart program is utilized because it provides a consistent basis for comparison of available incentives for various measures, though in many cases incentive amounts may be higher through participation in other programs.

Brief descriptions of all relevant financing and incentive programs are located in the sections below. Further information, including most current program availability, requirements, and incentive levels can be found at: www.njcleanenergy.com/ci.

8.1 SmartStart

Overview

The SmartStart program offers incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives from year to year for various energy efficiency equipment based on market trends and new technologies.

Equipment with Prescriptive Incentives Currently Available:

Electric Chillers

Electric Unitary HVAC

Gas Cooling

Gas Heating

Gas Water Heating

Ground Source Heat Pumps

Lighting

Lighting Controls

Refrigeration Doors

Refrigeration Controls

Refrigerator/Freezer Motors

Food Service Equipment

Variable Frequency Drives

Most equipment sizes and types are served by this program. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades.

Incentives

The SmartStart prescriptive incentive program provides fixed incentives for specific energy efficiency measures, whereas the custom SmartStart program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentive offerings for specific devices.

Since your facility is an existing building, only the retrofit incentives have been applied in this report. Custom Measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at 50% of the total installed incremental project cost, or a project cost buy down to a one year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

How to Participate

To participate in the SmartStart program you will need to submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: www.njcleanenergy.com/SSB.

8.2 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) is an alternate method for New Jersey's government agencies to finance the implementation of energy conservation measures. An ESIP is a type of "performance contract," whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. This is done in a manner that ensures that annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive in year one, and every year thereafter. ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs can be leveraged to help further reduce the total project cost of eligible measures.

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an Energy Services Company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is utilized for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the Energy Savings Plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Entities should carefully consider all alternatives to develop an approach that best meets their needs. A detailed program description and application can be found at: www.njcleanenergy.com/ESIP.

Please note that ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you may utilize NJCEP incentive programs to help further reduce costs when developing the ESP. You should refer to the ESIP guidelines at the link above for further information and guidance on next steps.

8.3 Demand Response Energy Aggregator

The first step toward participation in a Demand Response (DR) program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business (<http://www.pjm.com/markets-and-operations/demand-response/csps.aspx>). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity (<http://www.pjm.com/training/training%20material.aspx>), along with a variety of other program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding the program rules and requirements for metering and controls, a facility's ability to temporarily reduce electric load, as well as the payments involved in participating in the program. Also, these providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment to help ensure compliance of all terms and conditions of a DR contract. See Section 7 for additional information.

9 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

9.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third party (i.e. non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third party supplier, consider shopping for a reduced rate from third party electric suppliers. If your facility is purchasing electricity from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

9.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate on a monthly basis. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third party supplier, consider shopping for a reduced rate from third party natural gas suppliers. If your facility is purchasing natural gas from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party natural gas suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

Appendix A: Equipment Inventory & Recommendations

Lighting Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Main Foyer	32	Compact Fluorescent: 17W CFL (recessed cans)	Wall Switch	17	5,356	Relamp	No	32	LED - Fixtures: Downlight Recessed	Wall Switch	10	5,356	0.18	1,478	0.0	\$166.05	\$1,840.32	\$0.00	11.08
Main Foyer	17	LED - Fixtures: LED Recessed cans	Wall Switch	10	5,356	None	No	17	LED - Fixtures: LED Recessed cans	Wall Switch	10	5,356	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Main Foyer	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Hallway South	32	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,356	Relamp	No	32	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,356	0.78	6,504	0.0	\$730.60	\$1,872.00	\$320.00	2.12
Hallway South	6	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	6	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Hallway South	1	Compact Fluorescent: 17W CFL (recessed cans)	Wall Switch	17	5,356	Relamp	No	1	LED - Fixtures: Downlight Recessed	Wall Switch	10	5,356	0.01	46	0.0	\$5.19	\$57.51	\$0.00	11.08
Hallway South	18	Linear Fluorescent - T5HO: 4' T5HO (54W) - 1L	Wall Switch	62	5,356	Relamp	No	18	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	25	5,356	0.49	4,102	0.0	\$460.78	\$1,249.38	\$0.00	2.71
Rm 100	28	Linear Fluorescent - T5HO: 4' T5HO (54W) - 1L	Wall Switch	62	3,000	Relamp	No	28	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	25	3,000	0.76	3,574	0.0	\$401.47	\$1,943.48	\$0.00	4.84
Rm 100	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rm 101	17	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	17	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.52	2,446	0.0	\$274.71	\$1,264.50	\$205.00	3.86
Rm 102	23	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	23	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.71	3,309	0.0	\$371.67	\$1,885.50	\$300.00	4.27
Rm 103	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	3,000	Relamp	Yes	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,100	0.09	432	0.0	\$48.48	\$266.40	\$50.00	4.46
Supply Closet	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,500	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,500	0.02	57	0.0	\$6.39	\$58.50	\$10.00	7.59
Rm 116	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	10	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.31	1,439	0.0	\$161.60	\$701.00	\$120.00	3.60
Rm 118	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	10	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.31	1,439	0.0	\$161.60	\$701.00	\$120.00	3.60
Rm 117	18	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	18	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.55	2,590	0.0	\$290.87	\$1,323.00	\$215.00	3.81
Rm 117	1	Compact Fluorescent: 17W CFL (recessed cans)	Wall Switch	17	3,000	Relamp	Yes	1	LED - Fixtures: Downlight Recessed	Occupancy Sensor	10	2,100	0.01	36	0.0	\$4.01	\$57.51	\$0.00	14.34
Rm 117 office 1	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,000	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,400	0.18	575	0.0	\$64.64	\$416.80	\$80.00	5.21
Rm 117 office 2	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,000	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.09	288	0.0	\$32.32	\$291.50	\$50.00	7.47
Rm 117 office 3	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,000	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.09	288	0.0	\$32.32	\$291.50	\$50.00	7.47
Rm 117 office 4	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,000	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.09	288	0.0	\$32.32	\$291.50	\$50.00	7.47
Rm 117 office 5	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,000	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.12	384	0.0	\$43.09	\$350.00	\$60.00	6.73
Rm 117 storage 1	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,500	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,050	0.09	216	0.0	\$24.24	\$291.50	\$50.00	9.96
Rm 117 storage 2	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,500	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,050	0.09	216	0.0	\$24.24	\$291.50	\$50.00	9.96
Rm 115	21	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	21	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.64	3,021	0.0	\$339.35	\$1,768.50	\$280.00	4.39

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Women's Rm	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,356	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,749	0.18	1,541	0.0	\$173.10	\$570.80	\$95.00	2.75
Men's Rm	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,356	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,749	0.18	1,541	0.0	\$173.10	\$570.80	\$95.00	2.75
Mech Rm 114	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,000	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,000	0.07	114	0.0	\$12.79	\$175.50	\$30.00	11.38
Rm 113	15	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	15	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.46	2,158	0.0	\$242.40	\$1,147.50	\$185.00	3.97
Rm 112	5	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	3,000	Relamp	Yes	5	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,100	0.23	1,079	0.0	\$121.20	\$492.00	\$95.00	3.28
Rm 112 storage	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,500	Relamp	Yes	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,050	0.09	216	0.0	\$24.24	\$266.40	\$50.00	8.93
Rm 107	30	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	30	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.92	4,316	0.0	\$484.79	\$2,295.00	\$370.00	3.97
Rm 108	16	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	16	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.49	2,302	0.0	\$258.55	\$1,206.00	\$195.00	3.91
Rm 108 comp. supply	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,500	Relamp	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,050	0.18	432	0.0	\$48.48	\$467.00	\$80.00	7.98
Rm 109	5	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	5	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.15	719	0.0	\$80.80	\$408.50	\$70.00	4.19
Rm 110	6	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	3,000	Relamp	Yes	6	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,100	0.28	1,295	0.0	\$145.44	\$567.20	\$110.00	3.14
Rm 110-A	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,000	Relamp	Yes	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,400	0.09	288	0.0	\$32.32	\$266.40	\$50.00	6.70
Rm 110-B	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,000	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,400	0.18	575	0.0	\$64.64	\$416.80	\$80.00	5.21
Rm 110-C	8	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,000	Relamp	Yes	8	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,400	0.37	1,151	0.0	\$129.28	\$717.60	\$140.00	4.47
Rm 106	21	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,000	Relamp	Yes	21	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.64	2,014	0.0	\$226.24	\$1,768.50	\$280.00	6.58
Mech Closet	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,000	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,000	0.07	114	0.0	\$12.79	\$175.50	\$30.00	11.38
Hallway (near Foyer)	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,356	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,356	0.10	813	0.0	\$91.32	\$234.00	\$40.00	2.12
Custodial Closet	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,000	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,000	0.02	38	0.0	\$4.26	\$58.50	\$10.00	11.38
Server Rm 122	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,000	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,000	0.05	76	0.0	\$8.53	\$117.00	\$20.00	11.38
Closet 121	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	600	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	600	0.05	46	0.0	\$5.12	\$117.00	\$20.00	18.96
Rm 120	18	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	62	1,400	Relamp	No	18	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.44	956	0.0	\$107.42	\$1,053.00	\$180.00	8.13
Rm 120	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	None	62	1,500	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	None	29	1,500	0.05	114	0.0	\$12.79	\$117.00	\$20.00	7.59
Rm 120-A	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Occupancy Sensor	93	1,400	Relamp	No	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,400	0.07	159	0.0	\$17.90	\$150.40	\$30.00	6.72
Rm 120-A	2	Linear Fluorescent - T8: 4' T8 (32W) - 1L	None	32	1,500	Relamp	No	2	LED - Linear Tubes: (1) 4' Lamp	None	15	1,500	0.03	60	0.0	\$6.78	\$71.80	\$10.00	9.11
Rm 120-B	5	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Occupancy Sensor	93	1,400	Relamp	No	5	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,400	0.18	398	0.0	\$44.76	\$376.00	\$75.00	6.72

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Rm 120-B	1	Linear Fluorescent - T8: 4' T8 (32W) - 1L	None	32	1,500	Relamp	No	1	LED - Linear Tubes: (1) 4' Lamp	None	15	1,500	0.01	30	0.0	\$3.39	\$35.90	\$5.00	9.11
Rm 120-C	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Occupancy Sensor	93	1,400	Relamp	No	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,400	0.15	319	0.0	\$35.81	\$300.80	\$60.00	6.72
Rm 120-C	1	Linear Fluorescent - T8: 4' T8 (32W) - 1L	None	32	1,500	Relamp	No	1	LED - Linear Tubes: (1) 4' Lamp	None	15	1,500	0.01	30	0.0	\$3.39	\$35.90	\$5.00	9.11
Rm 120-D	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,400	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	980	0.18	403	0.0	\$45.25	\$416.80	\$80.00	7.44
Rm 120-D	1	Linear Fluorescent - T8: 4' T8 (32W) - 1L	None	32	1,500	Relamp	No	1	LED - Linear Tubes: (1) 4' Lamp	None	15	1,500	0.01	30	0.0	\$3.39	\$35.90	\$5.00	9.11
Conf Rm	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,000	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,400	0.18	575	0.0	\$64.64	\$416.80	\$80.00	5.21
Storage Rm	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Occupancy Sensor	93	1,050	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	735	0.18	302	0.0	\$33.94	\$416.80	\$80.00	9.92
Rm 123	11	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,356	Relamp	Yes	11	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,749	0.34	2,825	0.0	\$317.35	\$913.50	\$145.00	2.42
Hallway North	29	Linear Fluorescent - T5HO: 4' T5HO (54W) - 1L	Wall Switch	62	5,356	Relamp	No	29	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	25	5,356	0.79	6,609	0.0	\$742.36	\$2,012.89	\$0.00	2.71
Hallway North	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,356	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,356	0.15	1,220	0.0	\$136.99	\$351.00	\$60.00	2.12
Hallway North	5	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	5	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Hallway North	4	Compact Fluorescent: 17W CFL (recessed cans)	Wall Switch	17	5,356	Relamp	No	4	LED - Fixtures: Downlight Recessed	Wall Switch	10	5,356	0.02	185	0.0	\$20.76	\$230.04	\$0.00	11.08
Men's Rm	3	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	3,000	Relamp	Yes	3	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,100	0.14	647	0.0	\$72.72	\$495.60	\$80.00	5.72
Women's Rm	3	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	3,000	Relamp	Yes	3	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,100	0.14	647	0.0	\$72.72	\$495.60	\$80.00	5.72
Nursing Area Rm 138	20	Linear Fluorescent - T5HO: 4' T5HO (54W) - 3L	Occupancy Sensor	179	1,400	Relamp	No	20	LED - Linear Tubes: (4) 3' Lamps	Occupancy Sensor	75	1,400	1.53	3,349	0.0	\$376.15	\$2,500.20	\$0.00	6.65
Nursing Area Rm 138	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rm 138-A	2	Linear Fluorescent - T5HO: 4' T5HO (54W) - 3L	Occupancy Sensor	179	1,400	Relamp	No	2	LED - Linear Tubes: (4) 3' Lamps	Occupancy Sensor	75	1,400	0.15	335	0.0	\$37.62	\$250.02	\$0.00	6.65
Rm 138-B	2	Linear Fluorescent - T5HO: 4' T5HO (54W) - 3L	Occupancy Sensor	179	1,400	Relamp	No	2	LED - Linear Tubes: (4) 3' Lamps	Occupancy Sensor	75	1,400	0.15	335	0.0	\$37.62	\$250.02	\$0.00	6.65
Rm 138-C	2	Linear Fluorescent - T5HO: 4' T5HO (54W) - 3L	Wall Switch	179	2,000	Relamp	Yes	2	LED - Linear Tubes: (4) 3' Lamps	Occupancy Sensor	75	1,400	0.19	582	0.0	\$65.36	\$366.02	\$20.00	5.29
Rm 138-D	2	Linear Fluorescent - T5HO: 4' T5HO (54W) - 3L	Occupancy Sensor	179	1,400	Relamp	No	2	LED - Linear Tubes: (4) 3' Lamps	Occupancy Sensor	75	1,400	0.15	335	0.0	\$37.62	\$250.02	\$0.00	6.65
Rm 138-E	2	Linear Fluorescent - T5HO: 4' T5HO (54W) - 3L	Occupancy Sensor	179	1,400	Relamp	No	2	LED - Linear Tubes: (4) 3' Lamps	Occupancy Sensor	75	1,400	0.15	335	0.0	\$37.62	\$250.02	\$0.00	6.65
Rm 138-F	2	Linear Fluorescent - T5HO: 4' T5HO (54W) - 3L	Wall Switch	179	2,000	Relamp	Yes	2	LED - Linear Tubes: (4) 3' Lamps	Occupancy Sensor	75	1,400	0.19	582	0.0	\$65.36	\$366.02	\$20.00	5.29
Rm 138-G	2	Linear Fluorescent - T5HO: 4' T5HO (54W) - 3L	Occupancy Sensor	179	1,400	Relamp	No	2	LED - Linear Tubes: (4) 3' Lamps	Occupancy Sensor	75	1,400	0.15	335	0.0	\$37.62	\$250.02	\$0.00	6.65
Bio Lab Rm 124	19	Linear Fluorescent - T5HO: 4' T5HO (54W) - 2L	Wall Switch	117	3,000	Relamp	Yes	19	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	75	2,100	0.90	4,228	0.0	\$474.91	\$2,491.19	\$210.00	4.80

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Rm 125	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,000	Relamp	Yes	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,400	0.09	288	0.0	\$32.32	\$266.40	\$50.00	6.70
Rm 126	22	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	22	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.68	3,165	0.0	\$355.51	\$1,827.00	\$290.00	4.32
Rm 127	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.25	1,151	0.0	\$129.28	\$584.00	\$100.00	3.74
Rm 127	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rm 127 storage	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,500	Relamp	Yes	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,050	0.09	216	0.0	\$24.24	\$266.40	\$50.00	8.93
Rm 129	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.25	1,151	0.0	\$129.28	\$584.00	\$100.00	3.74
Rm 129	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rm 130	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.18	863	0.0	\$96.96	\$467.00	\$80.00	3.99
Rm 131	9	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	3,000	Relamp	Yes	9	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,100	0.41	1,942	0.0	\$218.16	\$792.80	\$155.00	2.92
Rm 131	7	Linear Fluorescent - T8: 4' T8 (32W) - 1L	None	32	3,000	Relamp	Yes	2	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,100	0.15	703	0.0	\$78.94	\$187.80	\$30.00	2.00
Supply Rm	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,500	Relamp	Yes	3	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,050	0.07	163	0.0	\$18.34	\$341.60	\$65.00	15.08
Dark Rm	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	1,500	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Wall Switch	33	1,500	0.02	50	0.0	\$5.62	\$63.20	\$0.00	11.25
Rm 133	16	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	16	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.49	2,302	0.0	\$258.55	\$1,206.00	\$195.00	3.91
Rm 133	4	Compact Fluorescent: 17W CFL (recessed cans)	Wall Switch	17	3,000	Relamp	Yes	4	LED - Fixtures: Downlight Recessed	Occupancy Sensor	10	2,100	0.03	143	0.0	\$16.04	\$230.00	\$0.00	14.34
Rm 133	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rm 134	6	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.18	863	0.0	\$96.96	\$467.00	\$80.00	3.99
Rm 135	24	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	24	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.74	3,453	0.0	\$387.83	\$1,944.00	\$310.00	4.21
Rm 135	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rm 135 supply closet	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,500	Relamp	Yes	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,050	0.09	216	0.0	\$24.24	\$266.40	\$50.00	8.93
Men's Rm	3	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	3,000	Relamp	Yes	3	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,100	0.14	647	0.0	\$72.72	\$495.60	\$80.00	5.72
Men's Rm	2	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	3,000	Relamp	Yes	2	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,100	0.03	151	0.0	\$16.93	\$341.80	\$45.00	17.53
Women's Rm	3	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	3,000	Relamp	Yes	3	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,100	0.14	647	0.0	\$72.72	\$495.60	\$80.00	5.72
Women's Rm	2	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	3,000	Relamp	Yes	2	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,100	0.03	151	0.0	\$16.93	\$341.80	\$45.00	17.53
Handicapped Restroom	5	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	3,000	Relamp	Yes	5	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,100	0.23	1,079	0.0	\$121.20	\$646.00	\$110.00	4.42
Radiology	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	3,000	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,100	0.18	863	0.0	\$96.96	\$416.80	\$80.00	3.47

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Basement Hallway	28	Compact Fluorescent: 17W CFL (recessed cans)	Wall Switch	17	5,356	Relamp	No	28	LED - Fixtures: Downlight Recessed	Wall Switch	10	5,356	0.15	1,293	0.0	\$145.29	\$1,610.28	\$0.00	11.08
Basement Hallway	18	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,356	Relamp	No	18	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,356	0.44	3,669	0.0	\$410.96	\$1,053.00	\$180.00	2.12
Basement Hallway	8	Compact Fluorescent 2x 17W CFL (recessed cans)	Wall Switch	34	5,356	Relamp	No	8	LED - Fixtures: Downlight Recessed	Wall Switch	17	5,356	0.10	838	0.0	\$94.09	\$386.16	\$0.00	4.10
Basement Hallway	5	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	5	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rm 056	28	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	28	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.86	4,028	0.0	\$452.47	\$2,178.00	\$350.00	4.04
Rm 055	9	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	3,000	Relamp	Yes	9	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,100	0.41	1,942	0.0	\$218.16	\$792.80	\$155.00	2.92
Office Rm 054	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,000	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.09	288	0.0	\$32.32	\$291.50	\$50.00	7.47
Rm 053	9	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	3,000	Relamp	Yes	9	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,100	0.41	1,942	0.0	\$218.16	\$792.80	\$155.00	2.92
Rm 052	28	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	28	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.86	4,028	0.0	\$452.47	\$2,178.00	\$350.00	4.04
Rm 051	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.25	1,151	0.0	\$129.28	\$584.00	\$100.00	3.74
Conf Rm 050	8	Compact Fluorescent 2x 17W CFL (recessed cans)	Wall Switch	34	2,000	Relamp	Yes	8	LED - Fixtures: Downlight Recessed	Occupancy Sensor	17	1,400	0.13	407	0.0	\$45.68	\$502.16	\$20.00	10.56
Office Rm 049	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,000	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.37	1,151	0.0	\$129.28	\$972.00	\$155.00	6.32
Office Rm 049A	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,000	Relamp	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.18	575	0.0	\$64.64	\$467.00	\$80.00	5.99
Office Rm 049B	9	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,000	Relamp	Yes	9	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.28	863	0.0	\$96.96	\$642.50	\$110.00	5.49
Office Rm 049C	9	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,000	Relamp	Yes	9	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.28	863	0.0	\$96.96	\$642.50	\$110.00	5.49
Office Rm 049D	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,000	Relamp	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.18	575	0.0	\$64.64	\$467.00	\$80.00	5.99
Rm 047 / 041	26	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	26	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.80	3,740	0.0	\$420.15	\$2,061.00	\$330.00	4.12
Lab Rm 046	28	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	28	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.86	4,028	0.0	\$452.47	\$2,178.00	\$350.00	4.04
Rm 045	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	10	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.31	1,439	0.0	\$161.60	\$701.00	\$120.00	3.60
Rm 044	9	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	9	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.28	1,295	0.0	\$145.44	\$642.50	\$110.00	3.66
Rm 043	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.12	575	0.0	\$64.64	\$350.00	\$60.00	4.49
Rm 042	26	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,000	Relamp	Yes	26	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.80	2,494	0.0	\$280.10	\$2,061.00	\$330.00	6.18
Basement Foyer	91	Compact Fluorescent 2x 17W CFL (recessed cans)	Wall Switch	34	5,356	Relamp	No	91	LED - Fixtures: Downlight Recessed	Wall Switch	17	5,356	1.14	9,529	0.0	\$1,070.30	\$4,392.57	\$0.00	4.10
Basement Foyer	12	Compact Fluorescent 2x 17W CFL (sconces)	Wall Switch	34	5,356	Relamp	No	12	LED Screw-In Lamps: (2) 12W LED Bulbs	Wall Switch	24	5,356	0.09	739	0.0	\$83.02	\$1,054.87	\$0.00	12.71

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Basement Foyer	3	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	3	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
IT Closet	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,000	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,000	0.07	114	0.0	\$12.79	\$175.50	\$30.00	11.38
Rm 019	17	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	17	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.52	2,446	0.0	\$274.71	\$1,264.50	\$205.00	3.86
Rm 017	28	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	28	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.86	4,028	0.0	\$452.47	\$2,178.00	\$350.00	4.04
Core Hallway	37	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,356	Relamp	No	37	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,356	0.90	7,521	0.0	\$844.76	\$2,164.50	\$370.00	2.12
Core Hallway	14	Compact Fluorescent: 2x 17W CFL (recessed cans)	Wall Switch	34	5,356	Relamp	No	14	LED - Fixtures: Downlight Recessed	Wall Switch	17	5,356	0.18	1,466	0.0	\$164.66	\$675.78	\$0.00	4.10
Core Hallway	6	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	6	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Storage 037	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,500	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,050	0.06	144	0.0	\$16.16	\$233.00	\$40.00	11.94
Mech Rm 036	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,000	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,000	0.10	152	0.0	\$17.05	\$234.00	\$40.00	11.38
Closet	1	Compact Fluorescent: 2x 17W CFL (recessed cans)	Wall Switch	34	1,000	Relamp	No	1	LED - Fixtures: Downlight Recessed	Wall Switch	17	1,000	0.01	20	0.0	\$2.20	\$48.27	\$0.00	21.98
Office Rm 035	1	Compact Fluorescent: 2x 17W CFL (recessed cans)	Wall Switch	34	2,000	Relamp	Yes	1	LED - Fixtures: Downlight Recessed	Occupancy Sensor	17	1,400	0.02	51	0.0	\$5.71	\$164.27	\$20.00	25.27
Office Rm 033	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,000	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,400	0.18	575	0.0	\$64.64	\$416.80	\$80.00	5.21
Office Rm 032	7	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,000	Relamp	Yes	7	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.21	671	0.0	\$75.41	\$525.50	\$90.00	5.77
Office Rm 031	8	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,000	Relamp	Yes	8	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,400	0.37	1,151	0.0	\$129.28	\$717.60	\$140.00	4.47
Office Rm 031	4	Linear Fluorescent - T8: 4' T8 (32W) - 1L	None	32	2,000	Relamp	No	4	LED - Linear Tubes: (1) 4' Lamp	None	15	2,000	0.05	161	0.0	\$18.08	\$143.60	\$20.00	6.83
Office Rm 030	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,000	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.37	1,151	0.0	\$129.28	\$972.00	\$155.00	6.32
Center Corridor	9	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	5,356	Relamp	Yes	9	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,749	0.28	2,312	0.0	\$259.65	\$642.50	\$110.00	2.05
Office Rm 028	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,000	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.37	1,151	0.0	\$129.28	\$972.00	\$155.00	6.32
Office Rm 027	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,000	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.21	669	0.0	\$75.13	\$350.00	\$60.00	3.86
Office Rm 026	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,000	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.37	1,151	0.0	\$129.28	\$972.00	\$155.00	6.32
Office Rm 025	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,000	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,400	0.18	575	0.0	\$64.64	\$416.80	\$80.00	5.21
Mech Rm	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	1,000	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,000	0.09	136	0.0	\$15.24	\$234.00	\$20.00	14.04
Men's Rm	4	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.12	575	0.0	\$64.64	\$350.00	\$60.00	4.49
Men's Rm	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.09	432	0.0	\$48.48	\$291.50	\$50.00	4.98

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Women's Rm	4	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.12	575	0.0	\$64.64	\$350.00	\$60.00	4.49
Women's Rm	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.09	432	0.0	\$48.48	\$291.50	\$50.00	4.98
Stairwell	6	Compact Fluorescent: 17W CFL	Wall Switch	17	5,356	Relamp	No	6	LED Screw-In Lamps: 13W LED Bulb	Wall Switch	13	5,356	0.02	148	0.0	\$16.60	\$139.86	\$0.00	8.42
Stairwell	12	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	12	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Storage	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,500	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,050	0.06	144	0.0	\$16.16	\$233.00	\$40.00	11.94
Rm 012	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.06	288	0.0	\$32.32	\$233.00	\$40.00	5.97
Rm 014	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.25	1,151	0.0	\$129.28	\$584.00	\$100.00	3.74
Rm 016	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.12	575	0.0	\$64.64	\$350.00	\$60.00	4.49
Rm 001	21	Linear Fluorescent - T5HO: 4' T5HO (54W) - 2L	Wall Switch	117	3,000	Relamp	Yes	21	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	50	2,100	1.27	5,941	0.0	\$667.31	\$2,581.41	\$280.00	3.45
Stairwell	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,356	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,356	0.05	407	0.0	\$45.66	\$117.00	\$20.00	2.12
Stairwell	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
2nd Flr Stairwell	6	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	5,356	Relamp	No	6	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	5,356	0.22	1,829	0.0	\$205.48	\$451.20	\$90.00	1.76
Elevator	2	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	5,356	Relamp	No	2	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	5,356	0.03	216	0.0	\$24.21	\$71.80	\$10.00	2.55
2nd Flr Corridor	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	5,356	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	5,356	0.15	1,220	0.0	\$136.99	\$351.00	\$60.00	2.12
Mech Rm	7	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,000	Relamp	No	7	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,000	0.17	266	0.0	\$29.84	\$409.50	\$70.00	11.38
Rm 201	92	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	92	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	2.82	13,236	0.0	\$1,486.69	\$7,002.00	\$1,130.00	3.95
Rm 201	28	Linear Fluorescent - T8: 4' T8 (32W) - 1L	None	32	3,000	Relamp	No	28	LED - Linear Tubes: (1) 4' Lamp	None	15	3,000	0.36	1,691	0.0	\$189.89	\$1,005.20	\$140.00	4.56
Rm 201	4	Exit Signs: Fluorescent	None	9	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	2	8,760	0.03	343	0.0	\$38.47	\$107.56	\$0.00	2.80
Rm 202	6	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	3,000	Relamp	Yes	6	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,100	0.28	1,295	0.0	\$145.44	\$567.20	\$110.00	3.14
Rm 202	2	Linear Fluorescent - T8: 4' T8 (32W) - 1L	None	32	3,000	Relamp	No	2	LED - Linear Tubes: (1) 4' Lamp	None	15	3,000	0.03	121	0.0	\$13.56	\$71.80	\$10.00	4.56
Math Dept Chair	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,000	Relamp	Yes	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,400	0.09	288	0.0	\$32.32	\$266.40	\$50.00	6.70
Storage	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,500	Relamp	Yes	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,050	0.09	216	0.0	\$24.24	\$266.40	\$50.00	8.93
Rm 204	60	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	60	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	1.84	8,632	0.0	\$969.58	\$4,590.00	\$740.00	3.97
Rm 204	2	Exit Signs: Fluorescent	None	9	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	2	8,760	0.01	161	0.0	\$18.11	\$107.56	\$0.00	5.94

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Rm 205	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	10	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.31	1,439	0.0	\$161.60	\$855.00	\$135.00	4.46
Rm 206	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	10	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.31	1,439	0.0	\$161.60	\$855.00	\$135.00	4.46
Rm 206 office	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,000	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.09	288	0.0	\$32.32	\$291.50	\$50.00	7.47
Storage	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	1,500	Relamp	Yes	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,050	0.09	216	0.0	\$24.24	\$266.40	\$50.00	8.93
Quiet Rm	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,000	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.37	1,151	0.0	\$129.28	\$972.00	\$155.00	6.32
Men's Rm	5	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	3,000	Relamp	Yes	5	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,100	0.23	1,079	0.0	\$121.20	\$646.00	\$110.00	4.42
Women's Rm	5	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	3,000	Relamp	Yes	5	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,100	0.23	1,079	0.0	\$121.20	\$646.00	\$110.00	4.42
Mech Rm	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,000	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,000	0.07	114	0.0	\$12.79	\$175.50	\$30.00	11.38
2nd Flr Corridor	25	Compact Fluorescent: 32W CFL (recessed cans)	Wall Switch	32	5,356	Relamp	No	25	LED - Fixtures: Downlight Recessed	Wall Switch	17	5,356	0.28	2,310	0.0	\$259.45	\$1,206.75	\$0.00	4.65
2nd Flr Corridor	25	Linear Fluorescent - T5HO: 4' T5HO (54W) - 1L	Wall Switch	62	5,356	Relamp	No	25	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	25	5,356	0.68	5,697	0.0	\$639.97	\$1,735.25	\$125.00	2.52
2nd Flr Corridor	16	LED - Fixtures: Downlight Recessed	Wall Switch	10	5,356	None	No	16	LED - Fixtures: Downlight Recessed	Wall Switch	10	5,356	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
2nd Flr Corridor	1	Exit Signs: Fluorescent	None	9	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	2	8,760	0.01	71	0.0	\$7.92	\$107.56	\$0.00	13.58
Mech Rm	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,000	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,000	0.15	228	0.0	\$25.58	\$351.00	\$60.00	11.38
Class Rm 210	21	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	No	21	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,000	0.51	2,391	0.0	\$268.55	\$1,228.50	\$210.00	3.79
2nd Flr Corridor	32	Linear Fluorescent - T5HO: 4' T5HO (54W) - 1L	Wall Switch	62	5,356	Relamp	No	32	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	25	5,356	0.87	7,293	0.0	\$819.16	\$2,221.12	\$160.00	2.52
2nd Flr Corridor	4	Compact Fluorescent: 32W CFL (recessed cans)	Wall Switch	32	5,356	Relamp	No	4	LED - Fixtures: Downlight Recessed	Wall Switch	17	5,356	0.04	370	0.0	\$41.51	\$193.08	\$0.00	4.65
Rm 220	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	10	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.31	1,439	0.0	\$161.60	\$855.00	\$135.00	4.46
Rm 221	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	10	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.31	1,439	0.0	\$161.60	\$855.00	\$135.00	4.46
Mech Rm	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,000	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	700	0.25	384	0.0	\$43.09	\$584.00	\$100.00	11.23
Mech Rm	1	Exit Signs: Fluorescent	None	9	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	2	8,760	0.01	71	0.0	\$7.92	\$107.56	\$0.00	13.58
Rm 224	18	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	18	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.55	2,590	0.0	\$290.87	\$1,323.00	\$215.00	3.81
Rm 225	15	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	15	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.46	2,158	0.0	\$242.40	\$1,147.50	\$185.00	3.97
Rm 220	5	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,000	Relamp	Yes	5	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.15	480	0.0	\$53.87	\$408.50	\$70.00	6.28
Office Rm 230	14	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,000	Relamp	Yes	14	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,400	0.64	2,014	0.0	\$226.24	\$1,322.80	\$245.00	4.76
Office Rm 230	1	Exit Signs: Fluorescent	None	9	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	2	8,760	0.01	71	0.0	\$7.92	\$107.56	\$0.00	13.58

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Office Rm 230A	3	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,000	Relamp	Yes	3	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,400	0.14	432	0.0	\$48.48	\$341.60	\$65.00	5.71
Office Rm 230B	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,000	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,400	0.18	575	0.0	\$64.64	\$416.80	\$80.00	5.21
Conf Rm	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	2,000	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,400	0.18	575	0.0	\$64.64	\$416.80	\$80.00	5.21
Rm 229	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.37	1,726	0.0	\$193.92	\$972.00	\$155.00	4.21
Rm 228	18	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	18	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.55	2,590	0.0	\$290.87	\$1,323.00	\$215.00	3.81
Conf Rm	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	2,000	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,400	0.09	288	0.0	\$32.32	\$291.50	\$50.00	7.47
Rm 227	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.25	1,151	0.0	\$129.28	\$584.00	\$100.00	3.74
Rm 226	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.25	1,151	0.0	\$129.28	\$584.00	\$100.00	3.74
Rm 220	5	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	5	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.15	719	0.0	\$80.80	\$408.50	\$70.00	4.19
Rm 218	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	10	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.31	1,439	0.0	\$161.60	\$701.00	\$120.00	3.60
Rm 217	10	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	3,000	Relamp	Yes	10	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,100	0.31	1,439	0.0	\$161.60	\$701.00	\$120.00	3.60

Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Mech Rms	MAS Bldg	4	Supply Fan	50.0	93.0%	Yes	4,067	No	93.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mech Rms	MAS Bldg	4	Return Fan	25.0	93.0%	Yes	4,067	No	93.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mech Rms	MAS Bldg	2	Exhaust Fan	20.0	89.5%	Yes	3,000	No	89.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mech Rms	BioLab Fume Hoods	1	Process Fan	10.0	93.0%	Yes	8,760	No	93.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mech Rms	MAS Bldg	20	Ventilation Fan	1.5	84.0%	No	2,500	No	84.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mech Rms	Chem Lab Fume Hoods	1	Process Fan	10.0	93.0%	Yes	8,760	No	93.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Electric Chiller Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions				Proposed Conditions							Energy Impact & Financial Analysis					
		Chiller Quantity	System Type	Cooling Capacity per Unit (Tons)	Install High Efficiency Chillers?	Chiller Quantity	System Type	Constant/ Variable Speed	Cooling Capacity (Tons)	Full Load Efficiency (kW/Ton)	IPLV Efficiency (kW/Ton)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Central Utility Plant	MAS Bldg	3	Water-Cooled Centrifugal Chiller	740.00	No							0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Fuel Heating Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions			Proposed Conditions							Energy Impact & Financial Analysis						
		System Quantity	System Type	Output Capacity per Unit (MBh)	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years	
Central Utility Plant	MAS Bldg	8	Condensing Hot Water Boiler	2,850.00	No							0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Commercial Refrigerator/Freezer Inventory & Recommendations

Location	Existing Conditions			Proposed Condi	Energy Impact & Financial Analysis						
	Quantity	Refrigerator/ Freezer Type	ENERGY STAR Qualified?	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
MAS	5	Stand-Up Refrigerator, Solid Door (16 - 30 cu. ft.)	Yes	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
MAS	2	Stand-Up Refrigerator, Glass Door (16 - 30 cu. ft.)	No	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00


Plug Load Inventory

Location	Quantity	Existing Conditions		
		Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
MAS	305	Desktop Computers	120.0	Yes
MAS	305	Computer Monitors	28.0	Yes
MAS	14	Sm. Printers	13.0	Yes
MAS	4	Lg. Copiers	380.0	Yes
MAS	22	TVs (~27" ea.)	150.0	No
MAS	7	Sm. Microwaves	800.0	No

Vending Machine Inventory & Recommendations

Location	Existing Conditions		Proposed Conditions	Energy Impact & Financial Analysis						
	Quantity	Vending Machine Type	Install Controls?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
MAS	2	Refrigerated	Yes	0.00	3,224	0.0	\$362.10	\$460.00	\$0.00	1.27
MAS	3	Non-Refrigerated	Yes	0.00	1,028	0.0	\$115.42	\$690.00	\$0.00	5.98
MAS	1	Refrigerated	No	0.00	0	0.0	\$0.00	\$230.00	\$0.00	0.00
MAS	1	Non-Refrigerated	No	0.00	0	0.0	\$0.00	\$230.00	\$0.00	0.00

Appendix B: ENERGY STAR® Statement of Energy Performance



ENERGY STAR® Statement of Energy Performance

LEARN MORE AT energystar.gov

N/A

Brookdale Community College - Lincroft Campus

Primary Property Type: College/University
Gross Floor Area (ft²): 900,381
Built: 1967

For Year Ending: February 29, 2016
Date Generated: June 28, 2017

ENERGY STAR®
Score¹

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information

<p>Property Address Brookdale Community College - Lincroft Campus 765 Newman Springs Road Lincroft, New Jersey 07738</p>	<p>Property Owner Brookdale Community College 765 Newman Springs Road Lincroft, NJ 07738 (732) 224-2217</p>	<p>Primary Contact Timothy Drury 765 Newman Springs Road Lincroft, NJ 07738 (732) 224-2217 tdrury@brookdalecc.edu</p>
--	--	---

Property ID: 5733170

Energy Consumption and Energy Use Intensity (EUI)

Site EUI	Annual Energy by Fuel	National Median Comparison	
95.4 kBtu/ft²	Electric - Grid (kBtu) 48,132,581 (56%)	National Median Site EUI (kBtu/ft²)	118.2
	Natural Gas (kBtu) 37,799,044 (44%)	National Median Source EUI (kBtu/ft²)	262.6
		% Diff from National Median Source EUI	-19%
Source EUI		Annual Emissions	
211.9 kBtu/ft²		Greenhouse Gas Emissions (Metric Tons CO2e/year)	7,528

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: _____ Date: _____

Licensed Professional



Professional Engineer Stamp
(if applicable)