



# Local Government Energy Audit Report

Cherry Street School

September 6, 2019

*Prepared for:*

Bridgeton Public Schools  
20 Cherry Street  
Bridgeton, New Jersey 08302

*Prepared by:*

TRC Energy Services  
900 Route 9 North  
Woodbridge, New Jersey 07095

# Disclaimer

---

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information about financial incentives that may be available. Most energy conservation measures have received preliminary analysis of feasibility that identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to establish a basis for further discussion and to help prioritize energy measures.

TRC Energy Services (TRC) reviewed the energy conservation measures and estimates of energy savings were reviewed for technical accuracy. Actual, achieved energy savings depend on behavioral factors and other uncontrollable variables and, therefore, estimates of final energy savings are not guaranteed. TRC and the New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

TRC bases estimated installation costs on our experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from RS Means. We encourage the owner of the facility to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Actual installation costs can vary widely based on individual measures and conditions. TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

The New Jersey Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. Please review all available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

The customer and their respective contractor(s) are responsible to implement energy conservation measures in complete conformance with all applicable local, state and federal requirements.

Copyright ©2019 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

# Table of Contents

---


<b>1</b>	<b>Executive Summary.....</b>	<b>1</b>
1.1	<b>Planning Your Project .....</b>	<b>4</b>
	Pick Your Installation Approach .....	4
	More Options from Around the State.....	6
<b>2</b>	<b>Existing Conditions.....</b>	<b>7</b>
2.1	Site Overview.....	7
2.2	Building Occupancy .....	7
2.3	Building Envelope .....	8
2.4	Lighting Systems.....	9
2.5	Air Handling Systems .....	10
	Packaged Units .....	10
	Air Conditioners .....	10
2.6	Heating Hot Water Systems .....	11
2.7	Chilled Water Systems.....	12
2.8	Domestic Hot Water .....	13
2.9	Food Service Equipment.....	14
2.10	Refrigeration.....	15
2.11	Plug Load & Vending Machines.....	16
2.12	Water-Using Systems .....	16
<b>3</b>	<b>Energy Use and Costs .....</b>	<b>17</b>
3.1	Electricity .....	19
3.2	Natural Gas .....	20
3.3	Benchmarking.....	21
	Tracking Your Energy Performance.....	22
<b>4</b>	<b>Energy Conservation Measures .....</b>	<b>23</b>
4.1	Lighting .....	26
	ECM 1: Install LED Fixtures .....	26
	ECM 2: Retrofit Fixtures with LED Lamps.....	26
4.2	Lighting Controls.....	27
	ECM 3: Install Occupancy Sensor Lighting Controls .....	27
	ECM 4: Install High/Low Lighting Controls .....	27
4.3	Variable Frequency Drives (VFD).....	28
	ECM 5: Install VFDs on Constant Volume (CV) Fans.....	28
	ECM 6: Install VFDs on Chilled Water Pumps.....	29
	ECM 7: Install VFDs on Heating Water Pumps .....	29
4.4	Electric Unitary HVAC .....	29
	ECM 8: Install High-Efficiency Air Conditioning Units .....	30
4.5	Gas-Fired Heating.....	30

ECM 9: Install High-Efficiency Furnaces .....	30
4.6 Domestic Water Heating .....	31
ECM 10: Install Low-Flow DHW Devices.....	31
4.7 Food Service & Refrigeration Measures.....	31
ECM 11: Vending Machine Control .....	31
<b>5 Energy Efficient Best Practices .....</b>	<b>32</b>
Energy Tracking with ENERGY STAR® Portfolio Manager®.....	32
Doors and Windows .....	32
Window Treatments/Coverings .....	32
Lighting Controls .....	32
Motor Maintenance .....	32
AC System Evaporator/Condenser Coil Cleaning .....	33
Boiler Maintenance .....	33
Furnace Maintenance .....	33
Water Heater Maintenance .....	33
Plug Load Controls.....	34
Computer Power Management Software .....	34
Water Conservation .....	34
Procurement Strategies .....	34
<b>6 On-site Generation .....</b>	<b>35</b>
6.1 Solar Photovoltaic .....	36
6.2 Combined Heat and Power .....	37
<b>7 Project Funding and Incentives.....</b>	<b>38</b>
7.1 SmartStart .....	39
7.2 Direct Install .....	40
7.3 Pay for Performance - Existing Buildings.....	41
7.4 Combined Heat and Power .....	42
7.5 Energy Savings Improvement Program .....	43
7.6 SREC Registration Program.....	44
<b>8 Energy Purchasing and Procurement Strategies .....</b>	<b>45</b>
8.1 Retail Electric Supply Options.....	45
8.2 Retail Natural Gas Supply Options .....	45
<b>Appendix A: Equipment Inventory &amp; Recommendations .....</b>	<b>A-1</b>
<b>Appendix B: ENERGY STAR® Statement of Energy Performance .....</b>	<b>B-1</b>
<b>Appendix C: Glossary .....</b>	<b>C-1</b>


# 1 EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) report for Cherry Street School. This report provides you with information about your facility's energy use, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help make changes in your facility. TRC Energy Services (TRC) conducted this study as part of a comprehensive effort to assist New Jersey school districts and local governments in controlling their energy costs and to help protect our environment by reducing statewide energy consumption.

## BUILDING PERFORMANCE REPORT



ENERGY STAR® Benchmarking Score	46 <i>(1-100 scale)</i>	This building performs below the national average. This report contains suggestions about how to improve building performance and reduce energy costs.
------------------------------------	----------------------------	--



*Figure 1 - Energy Use by System*


## POTENTIAL IMPROVEMENTS



This energy audit considered a range of potential energy improvements in your building. Costs and savings will vary between improvements. Presented below are two potential scopes of work for your consideration.


### Scenario 1: Full Package (all evaluated measures)

Installation Cost	\$119,941
Potential Rebates & Incentives <sup>1</sup>	\$13,914
Annual Cost Savings	\$32,635
Annual Energy Savings	Electricity: 237,036 kWh
Greenhouse Gas Emission Savings	119 Tons
Simple Payback	3.2 Years
Site Energy Savings (all utilities)	20%



### Scenario 2: Cost Effective Package<sup>2</sup>

Installation Cost	\$101,947
Potential Rebates & Incentives	\$13,146
Annual Cost Savings	\$31,767
Annual Energy Savings	Electricity: 231,907 kWh
Greenhouse Gas Emission Savings	115 Tons
Simple Payback	2.8 Years
Site Energy Savings (all utilities)	20%



### On-site Generation Potential

Photovoltaic	High
Combined Heat and Power	None

<sup>1</sup> Incentives are based on current SmartStart Prescriptive incentives. Other Program incentives may apply.

<sup>2</sup> A cost-effective measure is defined as one where the simple payback does not exceed two-thirds of the expected proposed equipment useful life. Simple payback is based on the net measure cost after potential incentives.

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Lifetime Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>		<b>161,113</b>	<b>28.1</b>	<b>-31</b>	<b>\$21,918</b>	<b>\$328,769</b>	<b>\$51,242</b>	<b>\$9,336</b>	<b>\$41,906</b>	<b>1.9</b>	<b>158,616</b>
ECM 1	Install LED Fixtures	56,432	9.3	-9	\$7,695	\$115,422	\$21,023	\$1,450	\$19,573	2.5	55,730
ECM 2	Retrofit Fixtures with LED Lamps	104,681	18.8	-22	\$14,223	\$213,347	\$30,218	\$7,886	\$22,332	1.6	102,886
<b>Lighting Control Measures</b>		<b>32,843</b>	<b>5.9</b>	<b>-7</b>	<b>\$4,461</b>	<b>\$35,690</b>	<b>\$29,970</b>	<b>\$3,360</b>	<b>\$26,610</b>	<b>6.0</b>	<b>32,268</b>
ECM 3	Install Occupancy Sensor Lighting Controls	29,059	5.2	-6	\$3,947	\$31,578	\$25,920	\$3,360	\$22,560	5.7	28,551
ECM 4	Install High/Low Lighting Controls	3,783	0.7	-1	\$514	\$4,111	\$4,050	\$0	\$4,050	7.9	3,717
<b>Variable Frequency Drive (VFD) Measures</b>		<b>23,540</b>	<b>3.7</b>	<b>0</b>	<b>\$3,257</b>	<b>\$48,852</b>	<b>\$26,899</b>	<b>\$400</b>	<b>\$26,499</b>	<b>8.1</b>	<b>23,704</b>
ECM 5	Install VFDs on Constant Volume (CV) Fans	5,986	1.5	0	\$828	\$12,423	\$4,197	\$400	\$3,797	4.6	6,028
ECM 6	Install VFDs on Chilled Water Pumps	2,557	0.6	0	\$354	\$5,306	\$6,781	\$0	\$6,781	19.2	2,575
ECM 7	Install VFDs on Heating Water Pumps	14,997	1.7	0	\$2,075	\$31,122	\$15,920	\$0	\$15,920	7.7	15,102
<b>Electric Unitary HVAC Measures</b>		<b>2,571</b>	<b>1.3</b>	<b>0</b>	<b>\$356</b>	<b>\$5,336</b>	<b>\$9,076</b>	<b>\$368</b>	<b>\$8,708</b>	<b>24.5</b>	<b>2,589</b>
ECM 8	Install High Efficiency Air Conditioning Units	2,571	1.3	0	\$356	\$5,336	\$9,076	\$368	\$8,708	24.5	2,589
<b>Gas Heating (HVAC/Process) Replacement</b>		<b>0</b>	<b>0.0</b>	<b>13</b>	<b>\$159</b>	<b>\$3,182</b>	<b>\$2,137</b>	<b>\$400</b>	<b>\$1,737</b>	<b>10.9</b>	<b>1,548</b>
ECM 9	Install High Efficiency Furnaces	0	0.0	13	\$159	\$3,182	\$2,137	\$400	\$1,737	10.9	1,548
<b>Domestic Water Heating Upgrade</b>		<b>15,014</b>	<b>0.0</b>	<b>11</b>	<b>\$2,214</b>	<b>\$22,142</b>	<b>\$158</b>	<b>\$0</b>	<b>\$158</b>	<b>0.1</b>	<b>16,452</b>
ECM 10	Install Low-Flow DHW Devices	15,014	0.0	11	\$2,214	\$22,142	\$158	\$0	\$158	0.1	16,452
<b>Food Service &amp; Refrigeration Measures</b>		<b>1,954</b>	<b>0.2</b>	<b>0</b>	<b>\$270</b>	<b>\$1,352</b>	<b>\$460</b>	<b>\$50</b>	<b>\$410</b>	<b>1.5</b>	<b>1,968</b>
ECM 11	Vending Machine Control	1,954	0.2	0	\$270	\$1,352	\$460	\$50	\$410	1.5	1,968
<b>TOTALS (COST EFFECTIVE MEASURES)</b>		<b>231,907</b>	<b>37.4</b>	<b>-26</b>	<b>\$31,767</b>	<b>\$431,499</b>	<b>\$101,947</b>	<b>\$13,146</b>	<b>\$88,801</b>	<b>2.8</b>	<b>230,434</b>
<b>TOTALS (ALL MEASURES)</b>		<b>237,036</b>	<b>39.2</b>	<b>-13</b>	<b>\$32,635</b>	<b>\$445,323</b>	<b>\$119,941</b>	<b>\$13,914</b>	<b>\$106,027</b>	<b>3.2</b>	<b>237,146</b>

\* - All incentives presented in this table are based on NJ SmartStart equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 2 – Evaluated Energy Improvements

For more detail on each evaluated energy improvement and a break out of cost-effective improvements, see **Section 4: Energy Conservation Measures**.

## 1.1 Planning Your Project

Careful planning makes for a successful energy project. When considering this scope of work, you will have some decisions to make, such as:

- ◆ How will the project be funded and/or financed?
- ◆ Is it best to pursue individual ECMs, groups of ECMs, or use a comprehensive approach where all ECMs are installed together?
- ◆ Are there other facility improvements that should happen at the same time?

### Pick Your Installation Approach

New Jersey’s Clean Energy Programs give you the flexibility to do a little or a lot. Rebates, incentives, and financing are available to help reduce both your installation costs and your energy bills. If you are planning to take advantage of these programs, make sure to review incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives before purchasing materials or starting installation.

The potential ECMs identified for this building likely qualify for multiple incentive and funding programs. Based on current program rules and requirements, your measures are likely to qualify for the following programs:

Energy Conservation Measure		SmartStart	Direct Install	Pay For Performance
ECM 1	Install LED Fixtures	X		
ECM 2	Retrofit Fixtures with LED Lamps	X		
ECM 3	Install Occupancy Sensor Lighting Controls	X		
ECM 4	Install High/Low Lighting Controls			
ECM 5	Install VFDs on Constant Volume (CV) HVAC	X		
ECM 6	Install VFDs on Chilled Water Pumps	X		
ECM 7	Install VFDs on Hot Water Pumps			
ECM 8	Install High Efficiency Electric AC			
ECM 9	Install High Efficiency Furnaces	X		
ECM 10	Install Low-Flow Domestic Hot Water Devices	X		
ECM 11	Vending Machine Control			

*Figure 3 – Funding Options*





## New Jersey's Clean Energy Programs At-A-Glance

	<b>SmartStart</b> Flexibility to install at your own pace	<b>Direct Install</b> Turnkey installation	<b>Pay for Performance</b> Whole building upgrades
<b>Who should use it?</b>	Buildings installing individual measures or small group of measures.	Small to mid-size facilities that can bundle multiple measures together.  Average peak demand should be below 200 kW.  Not suitable for significant building shell issues.	Mid to large size facilities looking to implement as many measures as possible at one time.  Peak demand should be over 200 kW.
<b>How does it work?</b>	Use in-house staff or your preferred contractor.	Pre-approved contractors pass savings along to you via reduced material and labor costs.	Whole-building approach to energy upgrades designed to reduce energy use by at least 15%. The more you save, the higher the incentives.
<b>What are the Incentives?</b>	Fixed incentives for specific energy efficiency measures.	Incentives pay up to 70% of eligible costs, up to \$125,000 per project.  You pay the remaining 30% directly to the contractor.	Up to 25% of installation cost, calculated based on level of energy savings per square foot.
<b>How do I participate?</b>	Submit an application for the specific equipment to be installed.	Contact a participating contractor in your region.	Contact a pre-qualified partner to develop your energy reduction plan and set your energy savings targets.

Take the next step by visiting [www.njcleanenergy.com](http://www.njcleanenergy.com) for program details, applications, and to contact a qualified contractor.

### *Individual Measures with SmartStart*

For facilities wishing to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate, you can use internal resources or an outside firm or contractor to perform the final design of the ECM(s) and install the equipment. Program pre-approval is required for some SmartStart incentives, so only after receiving pre-approval should you proceed with ECM installation.

### *Turnkey Installation with Direct Install*

The Direct Install program provides turnkey installation of multiple measures through an authorized network of participating contractors. This program can provide substantially higher incentives than SmartStart, up to 70% of the cost of selected measures. Direct Install contractors will assess and verify individual measure eligibility and, in most cases, they perform the installation work. The Direct Install program is available to sites with an average peak demand of less than 200 kW.

### *Whole Building Approach with Pay for Performance*

Pay for Performance can be a good option for medium to large sized facilities to achieve deep energy savings. Pay for Performance allows you to install as many measures as possible under a single project as well as address measures that may not qualify for other programs. Many facilities pursuing an Energy Savings Improvement Program (ESIP) loan also use this program. Pay for Performance works for larger customers with a peak demand over 200 kW. The minimum installed scope of work must include at least two unique measures resulting in at least 15% energy savings, where lighting cannot make up the majority of the savings.

## **More Options from Around the State**

### *Financing and Planning Support with the Energy Savings Improvement Program (ESIP)*

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the ESIP. Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. You have already taken the first step as an LGEA customer, because this report is required to participate in ESIP.

### *Resiliency with Return on Investment through Combined Heat & Power (CHP)*

The CHP program provides incentives for combined heat and power (aka cogeneration) and waste heat to power projects. Combined heat and power systems generate power on-site and recover heat from the generation system to meet on-site thermal loads. Waste heat to power systems use waste heat to generate power. You will work with a qualified developer who will design a system that meets your building's heating and cooling needs.

### *Ongoing Electric Savings with Demand Response*

The Demand Response Energy Aggregator program reduces electric loads at commercial facilities when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. By enabling commercial facilities to reduce electric demand during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment service providers provide regular payments to medium and large consumers of electric power for their participation in demand response (DR) programs. Program participation is voluntary, and facilities receive payments regardless of whether they are called upon to curtail their load during times of peak demand.

## 2 EXISTING CONDITIONS

The New Jersey Board of Public Utilities (NJBPU) has sponsored this Local Government Energy Audit (LGEA) Report for Cherry Street School. This report provides information on how your facility uses energy, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help you implement the ECMs. This report also contains valuable information on financial incentives from New Jersey’s Clean Energy Program (NJCEP) for implementing ECMs.

TRC conducted this study as part of a comprehensive effort to assist New Jersey educational and local government facilities in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

For a detailed list of the locations and recommended energy conservation measures for all inventoried equipment, see **Appendix A: Equipment Inventory & Recommendations**.

### 2.1 Site Overview

On April 11, 2019, TRC performed an energy audit at Cherry Street School located in Bridgeton, New Jersey. TRC met with Louis Lavari to review the school operations and help focus our investigation on specific energy-using systems.

Cherry Street School is a one-story, 49,756 square foot building built in 1962. Spaces include: classrooms, a gymnasium, offices, a cafeteria, corridors, a commercial kitchen, and mechanical space.

Over the last several years the school has replaced all its existing T12 fluorescent fixtures with T8 fluorescent fixtures.

### 2.2 Building Occupancy

The school is occupied September through June. Typical weekday occupancy is 689, including staff and students.

Summer occupancy includes continuing maintenance activities. There are no weekend activities.

Building Name	Weekday/Weekend	Operating Schedule
Cherry Street School	Weekday	Operation - 6:30 AM - 11:00 PM; Classes - 8:15 AM - 3:30 PM
	Weekend	Closed

*Figure 4 - Building Occupancy Schedule*

## 2.3 Building Envelope

The walls are made of poured concrete with a brick veneer and painted CMU interior finish.

The flat roof is supported with steel trusses and pre-stressed concrete, and finished with an insulated layer and a covering of gravels in the old section and with modified bitumen with black membrane in the new section. The old section roof is in poor condition, whereas the new addition roof is in good condition.

Windows are double-paned and have aluminum frames with thermal break clear glass. The glass-to-frame seals are in good condition. The operable window weather seals are in good condition, showing no evidence of excessive wear. Exterior doors have aluminum frames and are in good condition with undamaged door seals.



*Exterior Walls*



*Windows*



*Doors*



*Roof*

## 2.4 Lighting Systems

The primary interior lighting system uses 32-Watt linear fluorescent T8 lamps with electronic ballasts. Additionally, there are some compact fluorescent lamps (CFL), incandescent, and LED general purpose lamps. Fixture types include 2-, 3-, and 4-lamp, 2- and 4-foot long troffers, and other recessed fixtures with 2-foot U-bend tube lamps. Most fixtures are in good condition.

Gymnasium fixtures have 400-watt metal halide lamps and are manually controlled. All exit signs are LED units. Interior lighting levels were generally sufficient. Most interior lighting fixtures are controlled by wall switches.



*Cafeteria Lighting*



*Gym Lighting*



*Classroom Lighting*



*Exterior Wall Pack*



*Exterior Pole Light*



*Wall-mounted Area Light*

Exterior fixtures include wall packs, recessed, and walkway fixtures with 250-watt and 400-watt metal halide and LED lamps. The parking lot pole-mounted flood fixtures have 160-watt LED lamps.

Exterior light fixtures are controlled by a time clock and wall switches.

## 2.5 Air Handling Systems

### Packaged Units

The Front Zone and main office are each served with a Daikin split system heat pump unit controlled by room thermostat. These units have a heating capacity of 27 MBh and 40 MBh with cooling capacities of 2-ton and 3-ton, respectively, with EER ratings of 10.20 and 12.20.

The copy room and computer lab are each served by split system cooling-only units with cooling capacities of 1.5-ton and 2.5-ton, respectively.

The annex area is served by two 4-ton outdoor ground-mounted Goodman gas-fired packaged units with DX cooling and gas heating. These units have heating capacities of 80 MBh and 94 MBh, respectively. These units are not equipped with economizers. One of the units is in fair condition, and the newer unit is in good condition.

The cafeteria is served by an air handling unit (AHU-1) equipped with both heating and cooling coils. This unit has a 5 hp supply fan motor, which circulates hot water from the boiler and chilled water from the chiller seasonally, as needed.

### Air Conditioners

The nurse's office and three classrooms are cooled by window air conditioning (AC) units. These vary in capacity between 1- and 2-ton. The units are in good condition. They range in efficiency between 9.5 EER to 9.8 EER. They are ENERGY STAR® labeled.

Chilled water is distributed to unit ventilators with fan coils, which provide cooling to the new wing. The HVAC system uses pneumatic controls. A 0.3 hp air compressor located in the boiler room serves the pneumatic system. No air leaks were observed during the inspection.



*Packaged AC*



*Window AC*



*Split System AC*



*Thermostat*

## 2.6 Heating Hot Water Systems

Four 724.5 MBh condensing hot water boilers serve the building heating load needs. The burners are fully-modulating with a nominal efficiency of 96.6%. The boilers are configured in a lead-lag control scheme. Multiple boilers are required under high load conditions. Installed in 2014, they are in good condition. There is a service contract in place.

The boilers serve a primary/secondary distribution system with two constant speed 3 hp pumps and two constant speed 0.5 hp pumps circulating the primary loop, as well as two constant speed 5 hp heating hot water pumps operating in lead/lag fashion on the secondary loop. A three-way valve controls the secondary loop temperature via an Aquastat.

The boiler loop provides hot water to unit ventilator heating coils, serving the classroom heating loads. Heating for the cafeteria is provided to AHU-1 heating coils by the boiler loop.



*Boilers*



*Heating Hot Water Pumps*

## 2.7 Chilled Water Systems

The chiller plant consists of one 84-ton, Carrier R-410A, air-cooled screw chiller. The chillers are configured in a primary distribution loop with two 1.5 hp constant flow primary pumps (CHWP1 and 2).

The chilled water supply temperature is reset based on outside air temperature. Chilled water is distributed at 42°F when the outside air temperature is above 60°F, and the setpoint is reset to 50°F when the outside air is below 55°F. The chiller plant is locked out when the outside air temperature is below 45°F, and it is turned off from mid-December through February.

The chiller plant supplies chilled water to air handler (AHU-1) to the cafeteria and classroom unit ventilators. The chiller plant is new and well maintained.



*. Chiller*



*Chilled Water Pumps*



## 2.8 Domestic Hot Water

Six natural gas and one electric Bradford white water heater provide domestic hot water to the building. Hot water is produced for the old section by an 80% efficient, 50-gallon 40 MBh gas-fired storage water heater, whereas three 4.5 kW electric water heaters with 50-gallon storage tanks serve the cafeteria and restrooms. The DHW for the new section is produced by three 30-gallon 1.5 kW electric storage water heaters.

Four 0.2 hp circulation pumps distribute water to end uses, typically operating continuously. The domestic hot water pipes are insulated, and the insulation is in good condition.



*Electric Water Heater*



*Gas Water Heater*

## 2.9 Food Service Equipment

The kitchen has all-electric equipment that is used to prepare meals for students. Most cooking is done using a convection electric oven. Bulk prepared foods are held in two electric holding cabinets. Equipment is high-efficiency and in good condition.

Visit [https://www.energystar.gov/products/commercial\\_food\\_service\\_equipment](https://www.energystar.gov/products/commercial_food_service_equipment) for the latest information on high-efficiency food service equipment.



*Electric Oven*



*Insulated Cabinet*


## 2.10 Refrigeration

The kitchen has four stand-up refrigerators with solid doors. There is also an energy-efficient stand-up solid door freezer, as well as two chest type milk coolers. All equipment is high-efficiency and in good condition.

Visit [https://www.energystar.gov/products/commercial\\_food\\_service\\_equipment](https://www.energystar.gov/products/commercial_food_service_equipment) for the latest information on high-efficiency food service equipment.



*Stand-up Refrigerator*



*Milk Cooler*

## 2.11 Plug Load & Vending Machines

The utility bill analysis indicates that plug loads consume approximately 3% percent of total building energy use. This is lower than a typical building.

You seem to already be doing a great job managing your electrical plug loads. This report makes additional suggestions for ECMs in this area, as well as Energy Efficient Best Practices.

There are approximately 131 computer work stations throughout the school. Plug loads throughout the building include general cafeteria and office equipment. There are classroom typical loads such as Smart Boards, projectors, and printers.

There are several residential-style refrigerators throughout the building that are used to store staff lunches and cold beverages. These vary in condition and efficiency.

There is one refrigerated beverage vending machine and one non-refrigerated vending machine. Vending machines are not equipped with occupancy-based controls.



*Copy Machines*



*Washer and Dryer Unit*


## 2.12 Water-Using Systems

There are 14 restrooms with toilets, urinals, and sinks. Faucet flow rates are at 2.2 gallons per minute (gpm) or higher. Toilets are rated at 1.6 gallons per flush (gpf) and urinals are rated at 1 gpf.

### 3 ENERGY USE AND COSTS

Twelve months of utility billing data are used to develop annual energy consumption and cost data. This information creates a profile of the annual energy consumption and energy costs.

Utility Summary		
Fuel	Usage	Cost
Electricity	632,947 kWh	\$87,570
Natural Gas	17,380 Therms	\$20,916
<b>Total</b>		<b>\$108,486</b>



An energy balance identifies and quantifies energy use in your various building systems. This can highlight areas with the most potential for improvement. This energy balance was developed using calculated energy use for each of the end uses noted in the figure.

The energy auditor collects information regarding equipment operating hours, capacity, efficiency and other operational parameters from facility staff, drawings, and on-site observations. This information is used as the inputs to calculate the existing conditions energy use for the site. The calculated energy use is then compared to the historical energy use and the initial inputs are revised, as necessary, to balance the calculated energy use to the historical energy use.





Figure 5 - Energy Balance

### 3.1 Electricity

Atlantic City Electric delivers electricity under rate class Monthly General Service Secondary, with electric production provided by South Jersey Energy, a third-party supplier.




Electric Billing Data					
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost
11/28/17	32	49,033	137	\$1,349	\$6,776
12/27/17	29	42,513	134	\$1,152	\$5,189
1/26/18	30	47,419	146	\$1,194	\$7,271
2/26/18	31	49,582	146	\$1,240	\$6,923
3/27/18	29	47,505	143	\$1,158	\$6,602
4/26/18	30	44,646	146	\$1,161	\$6,276
5/25/18	29	51,931	195	\$1,476	\$7,551
6/26/18	32	61,750	175	\$1,452	\$8,420
7/30/18	34	55,691	178	\$1,548	\$7,849
8/28/18	29	60,229	187	\$1,469	\$8,097
9/26/18	29	64,496	210	\$1,583	\$8,715
10/25/18	29	54,684	177	\$1,316	\$7,422
<b>Totals</b>	<b>363</b>	<b>629,479</b>	<b>210</b>	<b>\$16,098</b>	<b>\$87,090</b>
<b>Annual</b>	<b>365</b>	<b>632,947</b>	<b>210</b>	<b>\$16,187</b>	<b>\$87,570</b>

Notes:

- Peak demand of 210 kW occurred in September '18.
- The average electric cost over the past 12 months was \$0.138/kWh, which is the blended rate that includes energy supply, distribution, demand, and other charges. This report uses this blended rate to estimate energy cost savings.

### 3.2 Natural Gas

South Jersey Gas delivers natural gas under rate class General Service FT, with natural gas supply provided by South Jersey Energy, a third-party supplier.



Gas Billing Data			
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost
11/28/17	32	1,824	\$2,129
12/27/17	29	2,588	\$3,145
1/26/18	30	4,020	\$4,774
2/26/18	31	3,214	\$3,868
3/27/18	29	3,154	\$3,829
4/26/18	30	1,721	\$2,006
5/25/18	29	193	\$251
6/26/18	32	35	\$78
7/30/18	34	21	\$62
8/28/18	29	28	\$65
9/26/18	29	21	\$56
10/25/18	29	467	\$537
<b>Totals</b>	<b>363</b>	<b>17,284</b>	<b>\$20,801</b>
<b>Annual</b>	<b>365</b>	<b>17,380</b>	<b>\$20,916</b>

Notes:


- The average gas cost for the past 12 months is \$1.203/therm, which is the blended rate used throughout the analysis.



### 3.3 Benchmarking

Your building was benchmarked using the United States Environmental Protection Agency’s (EPA) *Portfolio Manager*® software. Benchmarking compares your building’s energy use to that of similar buildings across the county, while neutralizing variations due to location, occupancy and operating hours. Some building types can be scored with a 1-100 ranking of a building’s energy performance relative to the national building market. A score of 50 represents the national average and a score of 100 is best.

This ENERGY STAR® benchmarking score provides a comprehensive snapshot of your building’s energy performance. It assesses the building’s physical assets, operations, and occupant behavior, which is compiled into a quick and easy-to-understand score.



**Figure 6 - Energy Use Intensity Comparison**

This building performs at, or below the national average. This report contains suggestions about how to improve building performance and reduce energy costs.

Energy use intensity (EUI) measures energy consumption per square foot and is the standard metric for comparing buildings’ energy performance. A lower EUI means better performance and less energy consumed. A number of factors can cause as building to vary from the “typical” energy usage. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and occupant behavior all contribute to a building’s energy use and the benchmarking score.

## **Tracking Your Energy Performance**

Keeping track of your energy use on a monthly basis is one of the best ways to keep energy costs in check. Update your utility information in Portfolio Manager® regularly, so that you can keep track of your building's performance.

**We have created a Portfolio Manager® account for your facility and we have already entered the monthly utility data shown above for you. Account login information for your account will be sent via email.**

Free online training is available to help you use ENERGY STAR® Portfolio Manager® to track your building's performance at: <https://www.energystar.gov/buildings/training>.

For more information on ENERGY STAR® and Portfolio Manager®, visit their website<sup>3</sup>.

---

<sup>3</sup> <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>

## 4 ENERGY CONSERVATION MEASURES

---

The goal of this audit report is to identify and evaluate potential energy efficiency improvements, provide information about the cost effectiveness of those improvements, and recognize potential financial incentives from NJBPU. Most energy conservation measures have received preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is typically sufficient to demonstrate project cost-effectiveness and help prioritize energy measures.

Calculations of energy use and savings are based on the current version of the *New Jersey's Clean Energy Program Protocols to Measure Resource Savings*, which is approved by the New Jersey Board of Public Utilities. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances.

Operation and maintenance costs for the proposed new equipment will generally be lower than the current costs for the existing equipment—especially if the existing equipment is at or past its normal useful life. We have conservatively assumed there to be no impact on overall maintenance costs over the life of the equipment.

Financial incentives are based on the current NJCEP prescriptive SmartStart program. A higher level of investigation may be necessary to support any SmartStart Custom, Pay for Performance, or Direct Install incentive applications. Some measures and proposed upgrades may be eligible for higher incentives than those shown below through other NJCEP programs described in a following section of this report.

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>		<b>161,113</b>	<b>28.1</b>	<b>-31</b>	<b>\$21,918</b>	<b>\$51,242</b>	<b>\$9,336</b>	<b>\$41,906</b>	<b>1.9</b>	<b>158,616</b>
ECM 1	Install LED Fixtures	56,432	9.3	-9	\$7,695	\$21,023	\$1,450	\$19,573	2.5	55,730
ECM 2	Retrofit Fixtures with LED Lamps	104,681	18.8	-22	\$14,223	\$30,218	\$7,886	\$22,332	1.6	102,886
<b>Lighting Control Measures</b>		<b>32,843</b>	<b>5.9</b>	<b>-7</b>	<b>\$4,461</b>	<b>\$29,970</b>	<b>\$3,360</b>	<b>\$26,610</b>	<b>6.0</b>	<b>32,268</b>
ECM 3	Install Occupancy Sensor Lighting Controls	29,059	5.2	-6	\$3,947	\$25,920	\$3,360	\$22,560	5.7	28,551
ECM 4	Install High/Low Lighting Controls	3,783	0.7	-1	\$514	\$4,050	\$0	\$4,050	7.9	3,717
<b>Variable Frequency Drive (VFD) Measures</b>		<b>23,540</b>	<b>3.7</b>	<b>0</b>	<b>\$3,257</b>	<b>\$26,899</b>	<b>\$400</b>	<b>\$26,499</b>	<b>8.1</b>	<b>23,704</b>
ECM 5	Install VFDs on Constant Volume (CV) Fans	5,986	1.5	0	\$828	\$4,197	\$400	\$3,797	4.6	6,028
ECM 6	Install VFDs on Chilled Water Pumps	2,557	0.6	0	\$354	\$6,781	\$0	\$6,781	19.2	2,575
ECM 7	Install VFDs on Heating Water Pumps	14,997	1.7	0	\$2,075	\$15,920	\$0	\$15,920	7.7	15,102
<b>Electric Unitary HVAC Measures</b>		<b>2,571</b>	<b>1.3</b>	<b>0</b>	<b>\$356</b>	<b>\$9,076</b>	<b>\$368</b>	<b>\$8,708</b>	<b>24.5</b>	<b>2,589</b>
ECM 8	Install High Efficiency Air Conditioning Units	2,571	1.3	0	\$356	\$9,076	\$368	\$8,708	24.5	2,589
<b>Gas Heating (HVAC/Process) Replacement</b>		<b>0</b>	<b>0.0</b>	<b>13</b>	<b>\$159</b>	<b>\$2,137</b>	<b>\$400</b>	<b>\$1,737</b>	<b>10.9</b>	<b>1,548</b>
ECM 9	Install High Efficiency Furnaces	0	0.0	13	\$159	\$2,137	\$400	\$1,737	10.9	1,548
<b>Domestic Water Heating Upgrade</b>		<b>15,014</b>	<b>0.0</b>	<b>11</b>	<b>\$2,214</b>	<b>\$158</b>	<b>\$0</b>	<b>\$158</b>	<b>0.1</b>	<b>16,452</b>
ECM 10	Install Low-Flow DHW Devices	15,014	0.0	11	\$2,214	\$158	\$0	\$158	0.1	16,452
<b>Food Service &amp; Refrigeration Measures</b>		<b>1,954</b>	<b>0.2</b>	<b>0</b>	<b>\$270</b>	<b>\$460</b>	<b>\$50</b>	<b>\$410</b>	<b>1.5</b>	<b>1,968</b>
ECM 11	Vending Machine Control	1,954	0.2	0	\$270	\$460	\$50	\$410	1.5	1,968
<b>TOTALS</b>		<b>237,036</b>	<b>39.2</b>	<b>-13</b>	<b>\$32,635</b>	<b>\$119,941</b>	<b>\$13,914</b>	<b>\$106,027</b>	<b>3.2</b>	<b>237,146</b>

\* - All incentives presented in this table are based on NJ SmartStart equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 7 – All Evaluated ECMs

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>		<b>161,113</b>	<b>28.1</b>	<b>-31</b>	<b>\$21,918</b>	<b>\$51,242</b>	<b>\$9,336</b>	<b>\$41,906</b>	<b>1.9</b>	<b>158,616</b>
ECM 1	Install LED Fixtures	56,432	9.3	-9	\$7,695	\$21,023	\$1,450	\$19,573	2.5	55,730
ECM 2	Retrofit Fixtures with LED Lamps	104,681	18.8	-22	\$14,223	\$30,218	\$7,886	\$22,332	1.6	102,886
<b>Lighting Control Measures</b>		<b>32,843</b>	<b>5.9</b>	<b>-7</b>	<b>\$4,461</b>	<b>\$29,970</b>	<b>\$3,360</b>	<b>\$26,610</b>	<b>6.0</b>	<b>32,268</b>
ECM 3	Install Occupancy Sensor Lighting Controls	29,059	5.2	-6	\$3,947	\$25,920	\$3,360	\$22,560	5.7	28,551
ECM 4	Install High/Low Lighting Controls	3,783	0.7	-1	\$514	\$4,050	\$0	\$4,050	7.9	3,717
<b>Variable Frequency Drive (VFD) Measures</b>		<b>20,983</b>	<b>3.2</b>	<b>0</b>	<b>\$2,903</b>	<b>\$20,117</b>	<b>\$400</b>	<b>\$19,717</b>	<b>6.8</b>	<b>21,130</b>
ECM 5	Install VFDs on Constant Volume (CV) Fans	5,986	1.5	0	\$828	\$4,197	\$400	\$3,797	4.6	6,028
ECM 7	Install VFDs on Heating Water Pumps	14,997	1.7	0	\$2,075	\$15,920	\$0	\$15,920	7.7	15,102
<b>Domestic Water Heating Upgrade</b>		<b>15,014</b>	<b>0.0</b>	<b>11</b>	<b>\$2,214</b>	<b>\$158</b>	<b>\$0</b>	<b>\$158</b>	<b>0.1</b>	<b>16,452</b>
ECM 10	Install Low-Flow DHW Devices	15,014	0.0	11	\$2,214	\$158	\$0	\$158	0.1	16,452
<b>Food Service &amp; Refrigeration Measures</b>		<b>1,954</b>	<b>0.2</b>	<b>0</b>	<b>\$270</b>	<b>\$460</b>	<b>\$50</b>	<b>\$410</b>	<b>1.5</b>	<b>1,968</b>
ECM 11	Vending Machine Control	1,954	0.2	0	\$270	\$460	\$50	\$410	1.5	1,968
<b>TOTALS</b>		<b>231,907</b>	<b>37.4</b>	<b>-26</b>	<b>\$31,767</b>	<b>\$101,947</b>	<b>\$13,146</b>	<b>\$88,801</b>	<b>2.8</b>	<b>230,434</b>

\* - All incentives presented in this table are based on NJ SmartStart equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

*Figure 8 – Cost Effective ECMs*

## 4.1 Lighting

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>		<b>161,113</b>	<b>28.1</b>	<b>-31</b>	<b>\$21,918</b>	<b>\$51,242</b>	<b>\$9,336</b>	<b>\$41,906</b>	<b>1.9</b>	<b>158,616</b>
ECM 1	Install LED Fixtures	56,432	9.3	-9	\$7,695	\$21,023	\$1,450	\$19,573	2.5	55,730
ECM 2	Retrofit Fixtures with LED Lamps	104,681	18.8	-22	\$14,223	\$30,218	\$7,886	\$22,332	1.6	102,886

When considering lighting upgrades, we suggest using a comprehensive design approach that simultaneously upgrades lighting fixtures and controls to maximize energy savings and improve occupant lighting. Comprehensive design will also consider appropriate lighting levels for different space types to make sure that the right amount of light is delivered where needed. If conversion to LED light sources is proposed, we suggest converting all fixtures of a specific lighting type (e.g. linear fluorescent) to LED lamps to minimize the number of lamp types in use at the school, which should help reduce future maintenance costs.

### **ECM 1: Install LED Fixtures**

Replace existing fixtures containing metal halide lamps with new LED light fixtures. This measure saves energy by installing LEDs, which use less power than other technologies with a comparable light output.

In some cases, HID fixtures can be retrofit with screw-based LED lamps. Replacing an existing HID fixture with a new LED fixture will generally provide better overall lighting optics; however, replacing the HID lamp with a LED screw-in lamp is typically a less expensive retrofit. We recommend you work with your lighting contractor to determine which retrofit solution is best suited to your needs and will be compatible with the existing fixtures.

Maintenance savings may also be achieved as LED lamps last longer than other light sources and therefore do not need to be replaced as often.

**Affected building areas:** gymnasium, cafeteria, and exterior fixtures.

### **ECM 2: Retrofit Fixtures with LED Lamps**

Replace linear fluorescent, CFLs, and incandescent lamps with LED lamps. Many LED tubes are direct replacements for existing fluorescent tubes and can be installed while leaving the fluorescent fixture ballast in place. LED lamps can be used in existing fixtures as a direct replacement for most other lighting technologies.

This measure saves energy by installing LEDs, which use less power than other lighting technologies while providing equivalent lighting output for the space. Maintenance savings may also be available, as longer-lasting LEDs lamps will not need to be replaced as often as do the existing lamps.

**Affected building areas:** all areas with fluorescent fixtures with T8 tubes.

## 4.2 Lighting Controls

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Control Measures</b>		<b>32,843</b>	<b>5.9</b>	<b>-7</b>	<b>\$4,461</b>	<b>\$29,970</b>	<b>\$3,360</b>	<b>\$26,610</b>	<b>6.0</b>	<b>32,268</b>
ECM 3	Install Occupancy Sensor Lighting Controls	29,059	5.2	-6	\$3,947	\$25,920	\$3,360	\$22,560	5.7	28,551
ECM 4	Install High/Low Lighting Controls	3,783	0.7	-1	\$514	\$4,050	\$0	\$4,050	7.9	3,717

Lighting controls reduce energy use by turning off or lowering lighting fixture power levels when not in use. A comprehensive approach to lighting design should upgrade the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

### **ECM 3: Install Occupancy Sensor Lighting Controls**

Install occupancy sensors to control lighting fixtures in areas that are frequently unoccupied, even for short periods. For most spaces, we recommend lighting controls use dual technology sensors, which reduce the possibility of lights turning off unexpectedly.

Occupancy sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Most occupancy sensor lighting controls allow users to manually turn fixtures on/off, as needed. Some controls can also provide dimming options.

Occupancy sensors can be mounted on the wall at existing switch locations, on the ceiling, or in remote locations. In general, wall switch replacement sensors are best suited to single occupant offices and other small rooms. Ceiling-mounted or remote-mounted sensors are used in large spaces, locations without local switching, and where wall switches are not in the line-of-sight of the main work area.

This measure provides energy savings by reducing the lighting operating hours.

**Affected building areas:** offices, conference room, classrooms, gymnasium, library, restrooms, and storage rooms.

### **ECM 4: Install High/Low Lighting Controls**

Install occupancy sensors to provide dual level lighting control for lighting fixtures in spaces that are infrequently occupied but may require some level of continuous lighting for safety or security reasons.

Lighting fixtures with these controls operate at default low levels when the area is unoccupied to provide minimal lighting to meet security or safety requirements. Sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Fixtures automatically switch back to low level after a predefined period of vacancy. In parking lots and parking garages with significant ambient lighting, this control can sometimes be combined with photocell controls to turn the lights off when there is sufficient daylight.

The controller lowers the light level by dimming the fixture output. Therefore, the controlled fixtures need to have a dimmable ballast or driver. This will need to be taken into account when selecting retrofit lamps and bulbs for the areas proposed for high/low control.

This measure provides energy savings by reducing the light fixture power draw when reduced light output is appropriate.

**Affected building areas:** hallways.

For this type of measure the occupancy sensors will generally be ceiling- or fixture-mounted. Sufficient sensor coverage must be provided to ensure that lights turn on in each area as an occupant approaches.

### 4.3 Variable Frequency Drives (VFD)

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Reduction (lbs)
<b>Variable Frequency Drive (VFD) Measures</b>		<b>23,540</b>	<b>3.7</b>	<b>0</b>	<b>\$3,257</b>	<b>\$26,899</b>	<b>\$400</b>	<b>\$26,499</b>	<b>8.1</b>	<b>23,704</b>
ECM 5	Install VFDs on Constant Volume (CV) Fans	5,986	1.5	0	\$828	\$4,197	\$400	\$3,797	4.6	6,028
ECM 6	Install VFDs on Chilled Water Pumps	2,557	0.6	0	\$354	\$6,781	\$0	\$6,781	19.2	2,575
ECM 7	Install VFDs on Heating Water Pumps	14,997	1.7	0	\$2,075	\$15,920	\$0	\$15,920	7.7	15,102

Variable frequency drives (VFDs) control motors for fans, pumps, and process equipment based on the actual output required of the driven equipment. Energy savings result from more efficient control of motor energy usage when equipment operates at partial load. The magnitude of energy savings depends on the estimated amount of time that the motor would operate at partial load. For equipment with proposed VFDs, we have included replacing the controlled motor with a new motor—unless the existing motor meets or exceeds IHP 2014 standards—to conservatively account for the cost of an inverter duty rated motor.

#### **ECM 5: Install VFDs on Constant Volume (CV) Fans**

Install VFDs to control constant volume fan motor speeds. This converts a constant-volume, single-zone air handling system into a variable-air-volume (VAV) system. A separate VFD is usually required to control the return fan motor or dedicated exhaust fan motor, if the air handler has one.

Zone thermostats signal the VFD to adjust fan speed to maintain the appropriate temperature in the zone while maintaining a constant supply air temperature.

For air handlers with direct expansion (DX) cooling systems, the minimum air flow across the cooling coil required to prevent the coil from freezing must be determined during the final project design. The control system programming should maintain the minimum air flow whenever the compressor is operating.

Energy savings result from reducing the fan speed (and power) when conditions allow for reduced air flow.

**Affected air handlers:** AHU-1 cafeteria.



### **ECM 6: Install VFDs on Chilled Water Pumps**

Install VFDs to control chilled water pumps. Two-way valves must serve the chilled water coils being served and the chilled water loop must have a differential pressure sensor installed. If a bypass leg or three-way valves are used in the chilled water distribution, they will need to be modified when this measure is implemented. As the chilled water valves close, the differential pressure increases, and the VFD modulates the pump speed to maintain a differential pressure setpoint.

For systems with variable chilled water flow through the chiller, the minimum flow to prevent the chiller from tripping off will need to be determined during the final project design. The control system should be programmed to maintain the minimum flow through the chiller and to prevent pump cavitation.

Energy savings result from reducing the pump motor speed (and power) as chilled water valves close. The magnitude of energy savings is based on the estimated amount of time that the system operates at reduced loads.

**Affected pumps:** two CHWPs.

### **ECM 7: Install VFDs on Heating Water Pumps**

Install variable frequency drives (VFD) to control heating water pumps. Two-way valves must serve the hot water coils, and the hot water loop must have a differential pressure sensor installed. If a bypass leg or three-way valves are used in the hot water distribution, they will need to be modified when this measure is implemented. As the hot water valves close, the differential pressure increases, and the VFD modulates the pump speed to maintain a differential pressure setpoint.

Energy savings result from reducing pump motor speed (and power) as hot water valves close. The magnitude of energy savings is based on the estimated amount of time that the system will operate at reduced load.

**Affected pumps:** HHWP-1 and 2, and (2) additional hot water pumps.

## 4.4 Electric Unitary HVAC

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Electric Unitary HVAC Measures</b>		<b>2,571</b>	<b>1.3</b>	<b>0</b>	<b>\$356</b>	<b>\$9,076</b>	<b>\$368</b>	<b>\$8,708</b>	<b>24.5</b>	<b>2,589</b>
ECM 8	Install High Efficiency Air Conditioning Units	2,571	1.3	0	\$356	\$9,076	\$368	\$8,708	24.5	2,589

Replacing the unitary HVAC units has a long payback period and may not be justifiable based simply on energy considerations. However, most of the units at the school are nearing or have reached the end of their normal useful life. Typically, the marginal cost of purchasing a high-efficiency unit can be justified by the marginal savings from the improved efficiency. When the packaged AC unit serving the annex is eventually replaced, consider purchasing equipment that exceeds the minimum efficiency required by building codes.

### **ECM 8: Install High-Efficiency Air Conditioning Units**

Replace standard efficiency packaged air conditioning units with high-efficiency packaged air conditioning units. The magnitude of energy savings for this measure depends on the relative efficiency of the older unit versus the new high-efficiency unit, average cooling load, and estimated annual operating hours.

This measure is part of a measure to replace package units at this site and as such must be considered in combination with ECM 9.

**Affected systems:** older of the (2) package AC units serving the annex.

## 4.5 Gas-Fired Heating

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Gas Heating (HVAC/Process) Replacement</b>		<b>0</b>	<b>0.0</b>	<b>13</b>	<b>\$159</b>	<b>\$2,137</b>	<b>\$400</b>	<b>\$1,737</b>	<b>10.9</b>	<b>1,548</b>
ECM 9	Install High Efficiency Furnaces	0	0.0	13	\$159	\$2,137	\$400	\$1,737	10.9	1,548

### **ECM 9: Install High-Efficiency Furnaces**

Replace standard efficiency furnaces with condensing furnaces. Improved combustion technology and heat exchanger design optimize heat recovery from the combustion gases, which can significantly improve furnace efficiency. Savings result from improved system efficiency.

Note that these units produce acidic condensate that requires proper drainage.

This measure is part of a measure to replace package units at this site and as such, must be considered in combination with ECM 8.

**Affected systems:** older of the (2) package AC units serving the annex.

## 4.6 Domestic Water Heating

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Domestic Water Heating Upgrade</b>		<b>15,014</b>	<b>0.0</b>	<b>11</b>	<b>\$2,214</b>	<b>\$158</b>	<b>\$0</b>	<b>\$158</b>	<b>0.1</b>	<b>16,452</b>
ECM 10	Install Low-Flow DHW Devices	15,014	0.0	11	\$2,214	\$158	\$0	\$158	0.1	16,452

### **ECM 10: Install Low-Flow DHW Devices**

Install low-flow devices to reduce overall hot water demand. The following low-flow devices are recommended to reduce hot water usage:

Device	Flow Rate
Faucet aerators (lavatory)	0.5 gpm

Low-flow devices reduce the overall water flow from the fixture while still providing adequate pressure for washing. Additional cost savings may result from reduced water usage.

## 4.7 Food Service & Refrigeration Measures

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Food Service &amp; Refrigeration Measures</b>		<b>1,954</b>	<b>0.2</b>	<b>0</b>	<b>\$270</b>	<b>\$460</b>	<b>\$50</b>	<b>\$410</b>	<b>1.5</b>	<b>1,968</b>
ECM 11	Vending Machine Control	1,954	0.2	0	\$270	\$460	\$50	\$410	1.5	1,968

### **ECM 11: Vending Machine Control**

Vending machines operate continuously, even during unoccupied hours. Install occupancy sensor controls to reduce energy use. These controls power down vending machines when the vending machine area has been vacant for some time and power up the machines at necessary regular intervals or when the surrounding area is occupied. Energy savings are dependent on the vending machine and activity level in the area surrounding the machines.

## 5 ENERGY EFFICIENT BEST PRACTICES

---

A whole building maintenance plan will extend equipment life; improve occupant comfort, health, and safety; and reduce energy and maintenance costs. You may already be doing some of these things— see our list below for potential additions to your maintenance plan. Be sure to consult with qualified equipment specialists for details on proper maintenance and system operation.

### **Energy Tracking with ENERGY STAR® Portfolio Manager®**



You've heard it before - you can't manage what you don't measure. ENERGY STAR® Portfolio Manager® is an online tool that you can use to measure and track energy and water consumption, as well as greenhouse gas emissions.<sup>4</sup> Your account has already been established. Now you can continue to keep tabs on your energy performance every month.

### **Doors and Windows**

Close exterior doors and windows in heated and cooled areas. Leaving doors and windows open leads to a loss of heat during the winter and chilled air during the summer. Reducing air changes per hour (ACH) can lead to increased occupant comfort as well as heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

### **Window Treatments/Coverings**

Use high-reflectivity films or cover windows with shades or shutters to reduce solar heat gain and reduce the load on cooling and heating systems. Older, single pane windows and east or west-facing windows are especially prone to solar heat gain. In addition, use shades or shutters at night during cold weather to reduce heat loss.

### **Lighting Controls**

As part of a lighting maintenance schedule, test lighting controls to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight and photocell sensors, maintenance involves cleaning sensor lenses and confirming that setpoints and sensitivity are configured properly.

### **Motor Maintenance**

Motors have many moving parts. As these parts degrade over time, the efficiency of the motor is reduced. Routine maintenance prevents damage to motor components. Routine maintenance should include cleaning surfaces and ventilation openings on motors to prevent overheating, lubricating moving parts to reduce friction, inspecting belts and pulleys for wear and to ensure they are at proper alignment and tension, and cleaning and lubricating bearings. Consult a licensed technician to assess these and other motor maintenance strategies.

---

<sup>4</sup> <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/use-portfolio-manager>

## **AC System Evaporator/Condenser Coil Cleaning**

Dirty evaporator and condenser coils restrict air flow and restrict heat transfer. This increases the loads on the evaporator and condenser fan and decreases overall cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

## **Boiler Maintenance**

Many boiler problems develop slowly over time, so regular inspection and maintenance is essential to keeping the heating system running efficiently and preventing expensive repairs. Annual tune-ups should include a combustion analysis to analyze the exhaust from the boilers and to ensure the boiler is operating safely. Boilers should be cleaned according to the manufacturer's instructions to remove soot and scale from the water side or fire side of the boiler.

## **Furnace Maintenance**


Preventative maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. Following the manufacturer's instructions, a yearly tune-up should: check for gas / carbon monoxide leaks; change the air and fuel filters; check components for cracks, corrosion, dirt, or debris build-up; ensure the ignition system is working properly; test and adjust operation and safety controls; inspect electrical connections; and lubricate motors and bearings.

## **Water Heater Maintenance**

Preventative maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. At least once a year, follow manufacturer instructions to drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Annual checks should include checks for:

- Leaks or heavy corrosion on the pipes and valves.
- Corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot, or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional.
- For electric water heaters, look for signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank.
- For water heaters more than three years old, have a technician inspect the sacrificial anode annually.

## **Plug Load Controls**



Reducing plug loads is a common way to decrease your electrical use. Limiting the energy use of plug loads can include increasing occupant awareness, removing under-used equipment, installing hardware controls, and using software controls. Consider enabling the most aggressive power settings on existing devices or install load sensing or occupancy sensing (advanced) power strips<sup>5</sup>. Your local utility may offer incentives or rebates for this equipment.

## **Computer Power Management Software**

Many computers consume power during nights, weekends, and holidays. Screen savers are commonly confused as a power management strategy. This contributes to avoidable, excessive electrical energy consumption. There are innovative power management software packages available that are designed to deliver significant energy saving and provide ongoing tracking measurements. A central power management platform helps enforce energy savings policies as well as identify and eliminate underutilized devices

## **Water Conservation**



Installing dual flush or low-flow toilets and low-flow/waterless urinals are ways to reduce water use. The EPA WaterSense™ ratings for urinals is 0.5 gpf and for flush valve toilets is 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

For more information regarding water conservation go to the EPA's WaterSense™ website<sup>6</sup> or download a copy of EPA's "WaterSense™ at Work: Best Management Practices for Commercial and Institutional Facilities"<sup>7</sup> to get ideas for creating a water management plan and best practices for a wide range of water using systems.

Water conservation devices that do not reduce hot water consumption will not provide energy savings at the site level, but they may significantly affect your water and sewer usage costs. Any reduction in water use does however ultimately reduce grid-level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users.

If the facility has detached buildings with a master water meter for the entire campus, check for unnatural wet areas in the lawn or water seeping in the foundation at water pipe penetrations through the foundation. Periodically check overnight meter readings when the school is unoccupied, and there is no other scheduled water usage.

Manage irrigation systems to use water more effectively outside the building. Adjust spray patterns so that water lands on intended lawns and plantings and not on pavement and walls. Consider installing an evapotranspiration irrigation controller that will prevent over-watering.

## **Procurement Strategies**

Purchasing efficient products reduces energy costs without compromising quality. Consider modifying your procurement policies and language to require ENERGY STAR® or WaterSense™ products where available.

---

<sup>5</sup> For additional information refer to "Assessing and Reducing Plug and Process Loads in Office Buildings" <http://www.nrel.gov/docs/fy13osti/54175.pdf>, or "Plug Load Best Practices Guide" <http://www.advancedbuildings.net/plug-load-best-practices-guide-offices>

<sup>6</sup> <https://www.epa.gov/watersense>

<sup>7</sup> <https://www.epa.gov/watersense/watersense-work-0>

## 6 ON-SITE GENERATION

---

You don't have to look far in New Jersey to see one of the thousands of solar electric systems providing clean power to homes, businesses, schools, and government buildings. On-site generation includes both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) technologies that generate power to meet all or a portion of the school's electric energy needs. Also referred to as distributed generation, these systems contribute to greenhouse gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, which results in improved electric grid reliability through better use of transmission and distribution systems.

Preliminary screenings were performed to determine if an on-site generation measure could be a cost-effective solution for the school. Before deciding to install an on-site generation system, we recommend conducting a feasibility study to analyze existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.

## 6.1 Solar Photovoltaic

Photovoltaic (PV) panels convert sunlight into electricity. Individual panels are combined into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is then connected to the building’s electrical distribution system.

A preliminary screening based on the facility’s electric demand, size and location of free area, and shading elements shows that the facility has **high** potential for installing a PV array.

The amount of free area, ease of installation on roof, and the lack of shading elements contribute to the high potential. A PV array located on the roof may be feasible. If you are interested in pursuing the installation of PV, we recommend conducting a full feasibility study.

The graphic below displays the results of the PV potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.




Figure 9 - Photovoltaic Screening

### Solar Renewable Energy Credit (SREC) Registration Program

Rebates are not available for solar projects, but owners of solar projects MUST register their projects in the SREC Registration Program before starting construction. Once your PV system is up and running, you periodically earn credits, which can then be sold on the open market for up to 15 years.

If you are considering installing solar photovoltaics on your building, visit [www.njcleanenergy.com/srec](http://www.njcleanenergy.com/srec) for more information about the SREC Registration Program.

Get more information about solar power in New Jersey or find a qualified solar installer who can help you decide if solar is right for your building:

- **Basic Info on Solar PV in New Jersey:** [www.njcleanenergy.com/whysolar](http://www.njcleanenergy.com/whysolar)
- **New Jersey Solar Market FAQs:** [www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs](http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs)
- **Approved Solar Installers in the New Jersey Market:** [www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved\\_vendorsearch/?id=60&start=1](http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1)



## 6.2 Combined Heat and Power

Combined heat and power (CHP) generate electricity at the school and puts waste heat energy to good use. Common types of CHP systems are reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines.

CHP systems typically produce a portion of the electric power used on-site, with the balance of electric power needs supplied by the local utility company. The heat is used to supplement (or replace) existing boilers and provide space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for space cooling.

The key criteria used for screening is the amount of time that the CHP system would operate at full load and the school's ability to use the recovered heat. Facilities with a continuous need for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has **no** potential for installing a cost-effective CHP system.

Based on a preliminary analysis, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation. The lack of gas service, low or infrequent thermal load, and lack of space for siting the equipment are the most significant factors contributing to the lack of CHP potential.

The graphic below displays the results of the CHP potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.




Figure 10 - Combined Heat and Power Screening

Find a qualified firm that specializes in commercial CHP cost assessment and installation: [http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved\\_vendorsearch/](http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/)

## 7 PROJECT FUNDING AND INCENTIVES

Ready to improve your building’s performance? New Jersey’s Clean Energy Programs can help. Pick the program that works best for you. Incentive programs that may apply to the school are identified in the Executive Summary. This section provides an overview of currently available New Jersey’s Clean Energy Programs.

	<b>SmartStart</b> <i>Flexibility to install at your own pace</i>	<b>Direct Install</b> <i>Turnkey installation</i>	<b>Pay for Performance</b> <i>Whole building upgrades</i>
<b>Who should use it?</b>	Buildings installing individual measures or small group of measures.	Small to mid-size facilities that can bundle multiple measures together.  Average peak demand should be below 200 kW.  Not suitable for significant building shell issues.	Mid to large size facilities looking to implement as many measures as possible at one time.  Peak demand should be over 200 kW.
<b>How does it work?</b>	Use in-house staff or your preferred contractor.	Pre-approved contractors pass savings along to you via reduced material and labor costs.	Whole-building approach to energy upgrades designed to reduce energy use by at least 15%. The more you save, the higher the incentives.
<b>What are the Incentives?</b>	Fixed incentives for specific energy efficiency measures.	Incentives pay up to 70% of eligible costs, up to \$125,000 per project.  You pay the remaining 30% directly to the contractor.	Up to 25% of installation cost, calculated based on level of energy savings per square foot.
<b>How do I participate?</b>	Submit an application for the specific equipment to be installed.	Contact a participating contractor in your region.	Contact a pre-qualified Partner to develop your Energy Reduction Plan and set your energy savings targets.
<p>Take the next step by visiting <a href="http://www.njcleanenergy.com">www.njcleanenergy.com</a> for program details, applications, and to contact a qualified contractor.</p>			

## 7.1 SmartStart



SmartStart offers incentives for installing prescriptive and custom energy efficiency measures at the school. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades. This program serves most common equipment types and sizes.

SmartStart routinely adds, removes, or modifies incentives from year-to-year for various energy efficiency equipment based on market trends and new technologies.

### **Equipment with Prescriptive Incentives Currently Available:**

*Electric Chillers*

*Electric Unitary HVAC*

*Gas Cooling*

*Gas Heating*

*Gas Water Heating*

*Ground Source Heat Pumps*

*Lighting*

*Lighting Controls*

*Refrigeration Doors*

*Refrigeration Controls*

*Refrigerator/Freezer Motors*

*Food Service Equipment*

*Variable Frequency Drives*

### **Incentives**

The SmartStart Prescriptive program provides fixed incentives for specific energy efficiency measures. Prescriptive incentives vary by equipment type.

SmartStart Custom provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentives. Custom incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings. Incentives are capped at 50% of the total installed incremental project cost, or a project cost buy down to a one-year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

### **How to Participate**

Submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. You can work with your preferred contractor or use internal staff to install measures.

Visit [www.njcleanenergy.com/SSB](http://www.njcleanenergy.com/SSB) for a detailed program description, instructions for applying, and applications.

## 7.2 Direct Install



Direct Install is a turnkey program available to existing small to medium-sized facilities with an average peak electric demand that does not exceed 200 kW over the recent 12-month period. You work directly with a pre-approved contractor who will perform a free energy assessment at the school, identify specific eligible measures, and provide a clear scope of work for

installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives and controls.

### Incentives

The program pays up to 70% of the total installed cost of eligible measures, up to \$125,000 per project. Each entity is limited to incentives up to \$250,000 per fiscal year.

### How to Participate

To participate in Direct Install, you will need to contact the participating contractor assigned to the region of the state where the school is located. A complete list of Direct Install program partners is provided on the Direct Install website linked below. The contractor will be paid the measure incentives directly by the program which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the program, subject to program caps and eligibility, while the remaining 30% of the cost is paid to the contractor by the customer.

Detailed program descriptions and applications can be found at: [www.njcleanenergy.com/DI](http://www.njcleanenergy.com/DI).

### 7.3 Pay for Performance - Existing Buildings



Pay for Performance works for larger customers with a peak demand over 200 kW. The minimum installed scope of work must include at least two unique measures that results in at least 15% source energy savings, and lighting cannot make up the majority of the savings. P4P is a generally a good option for medium-to-large sized facilities looking to implement as many

measures as possible under a single project to achieve deep energy savings. This program has an added benefit of addressing measures that may not qualify for other programs. Many facilities pursuing an Energy Savings Improvement Program loan also use this program.

#### Incentives

Incentives are based on estimated and achieved energy savings ranging from \$0.18-\$0.22/kWh and \$1.80-\$2.50/therm, capped at the lesser of 50% total project cost, or \$1 million per electric account and \$1 million per natural gas account, per fiscal year, not to exceed \$2 million per project. An incentive of \$0.15/square foot is also available to offset the cost of developing the Energy Reduction Plan (see below) contingent on the project moving forward with measure installation.

#### How to Participate

Contact one of the pre-approved consultants and contractors (“Partners”). Under direct contract to you, they will help further evaluate the measures identified in this report through development of the energy reduction plan), assist you in implementing selected measures, and verify actual savings one year after the installation. Your Partner will also help you apply for incentives.

Approval of the final scope of work is required by the program prior to installation. Installation can be done by the contractor of your choice (some P4P Partners are also contractors) or by internal staff, but the Partner remains involved throughout construction to ensure compliance with the program requirements.

Detailed program descriptions, instructions for applying, applications and list of Partners can be found at: [www.njcleanenergy.com/P4P](http://www.njcleanenergy.com/P4P).

## 7.4 Combined Heat and Power

The Combined Heat & Power (CHP) program provides incentives for eligible CHP or waste heat to power (WHP) projects. Eligible CHP or WHP projects must achieve an annual system efficiency of at least 65% (lower heating value, or LHV), based on total energy input and total utilized energy output. Mechanical energy may be included in the efficiency evaluation.

### Incentives

Eligible Technologies	Size (Installed Rated Capacity) <sup>1</sup>	Incentive (\$/kW)	% of Total Cost Cap per Project <sup>3</sup>	\$ Cap per Project <sup>3</sup>
Powered by non-renewable or renewable fuel source <sup>4</sup>	≤500 kW	\$2,000	30-40% <sup>2</sup>	\$2 million
Gas Internal Combustion Engine	>500 kW - 1 MW	\$1,000		
Gas Combustion Turbine	> 1 MW - 3 MW	\$550	30%	\$3 million
Microturbine	>3 MW	\$350		
Fuel Cells with Heat Recovery				
Waste Heat to Power*	<1 MW	\$1,000	30%	\$2 million
	> 1MW	\$500		\$3 million

\*Waste Heat to Power: Powered by non-renewable fuel source, heat recovery or other mechanical recovery from existing equipment utilizing new electric generation equipment (e.g. steam turbine).

Check the NJCEP website for details on program availability, current incentive levels, and requirements.

### How to Participate

You work with a qualified developer or consulting firm to complete the CHP application. Once the application is approved the project can be installed. Information about the CHP program can be found at: [www.njcleanenergy.com/CHP](http://www.njcleanenergy.com/CHP).

## 7.5 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) serves New Jersey's government agencies by financing energy projects. An ESIP is a type of performance contract, whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. Annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive for the life of the contract.

ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs described above can also be used to help further reduce the total project cost of eligible measures.

### How to Participate

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an energy services company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is used for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the energy savings plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Carefully consider all alternatives to develop an approach that best meets your needs. A detailed program descriptions and application can be found at: [www.njcleanenergy.com/ESIP](http://www.njcleanenergy.com/ESIP).

*ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you can use NJCEP incentive programs to help further reduce costs when developing the energy savings plan. Refer to the ESIP guidelines at the link above for further information and guidance on next steps.*

## 7.6 SREC Registration Program

The SREC Registration Program (SRP) is used to register the intent to install solar projects in New Jersey. Rebates are not available for solar projects, but owners of solar projects *must* register their projects prior to the start of construction to establish the project's eligibility to earn SRECs. Registration of the intent to participate in New Jersey's solar marketplace provides market participants with information about the pipeline of anticipated new solar capacity and insight into future SREC pricing.

After the registration is accepted, construction is complete, and final paperwork has been submitted and is deemed complete, the project is issued a New Jersey certification number, which enables it to generate New Jersey SRECs. SREC's are generated once the solar project has been authorized to be energized by the Electric Distribution Company (EDC).

Each time a solar installation generates 1,000 kilowatt-hours (kWh) of electricity, an SREC is earned. Solar project owners report the energy production to the SREC Tracking System. This reporting allows SREC's to be placed in the customer's electronic account. SRECs can then be sold on the SREC Tracking System, providing revenue for the first 15 years of the project's life.

Electricity suppliers, the primary purchasers of SRECs, are required to pay a Solar Alternative Compliance Payment (SACP) if they do not meet the requirements of New Jersey's Solar Renewable Portfolio Standard. Purchasing SRECs can help them meet those requirements. As SRECs are traded in a competitive market, the price may vary significantly. The actual price of an SREC during a trading period fluctuates depending on supply and demand.

Information about the SRP can be found at: [www.njcleanenergy.com/srec](http://www.njcleanenergy.com/srec).



## 8 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

---

### 8.1 Retail Electric Supply Options

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for the school's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third-party supplier, consider shopping for a reduced rate from third-party electric suppliers. If your facility already buys electricity from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party electric suppliers is available at the NJBPU website<sup>8</sup>.

### 8.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey is also deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate monthly. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third-party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier typically depends on whether a customer prefers budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third-party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility does not already purchase natural gas from a third-party supplier, consider shopping for a reduced rate from third-party natural gas suppliers. If your facility already purchases natural gas from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party natural gas suppliers is available at the NJBPU website<sup>9</sup>.

---

<sup>8</sup> [www.state.nj.us/bpu/commercial/shopping.html](http://www.state.nj.us/bpu/commercial/shopping.html).

<sup>9</sup> [www.state.nj.us/bpu/commercial/shopping.html](http://www.state.nj.us/bpu/commercial/shopping.html)

# APPENDIX A: EQUIPMENT INVENTORY & RECOMMENDATIONS

## Lighting Inventory & Recommendations

Location	Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis								
	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Electric Room	1	LED Lamps: Corn Bulb - 1L	Wall Switch	S	20	3,630		None	No	1	LED Lamps: Corn Bulb - 1L	Wall Switch	20	3,630	0.0	0	0	\$0	\$0	\$0	0.0
Boiler Room	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.1	527	0	\$72	\$146	\$40	1.5
Boiler Room	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
A Hallway	19	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 4	Relamp	Yes	19	LED - Linear Tubes: (2) U-Lamp	High/Low Control	33	2,505	0.5	2,976	-1	\$404	\$2,277	\$190	5.2
A Hallway	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Receiving Room	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	264	0	\$36	\$73	\$20	1.5
Receiving Room	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Stage	3	LED Lamps: Corn Bulb - 1L	Wall Switch	S	20	3,630		None	No	3	LED Lamps: Corn Bulb - 1L	Wall Switch	20	3,630	0.0	0	0	\$0	\$0	\$0	0.0
Gym	15	Metal Halide: (1) 400W Lamp	Wall Switch	S	458	3,630	1, 3	Fixture Replacement	Yes	15	LED - Fixtures: Ceiling Mount	Occupancy Sensor	137	2,505	3.9	21,754	-5	\$2,955	\$4,996	\$220	1.6
Gym	4	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	4	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Closet	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	132	0	\$18	\$37	\$10	1.5
Storage Room	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	264	0	\$36	\$73	\$20	1.5
Main Entrance	6	Linear Fluorescent - T8: 2' T8 (17W) - 3L	Wall Switch	S	53	3,630	2, 4	Relamp	Yes	6	LED - Linear Tubes: (3) 2' Lamps	High/Low Control	26	2,505	0.2	848	0	\$115	\$518	\$54	4.0
Main Entrance	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Display Case	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	132	0	\$18	\$37	\$10	1.5
Nurse Office	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.2	1,006	0	\$137	\$489	\$95	2.9
Restroom	1	Incandescent: Bulb - 1L	Wall Switch	S	60	3,630	2	Relamp	No	1	LED Lamps: Bulb - 1L	Wall Switch	9	3,630	0.0	204	0	\$28	\$17	\$1	0.6
Main Office	9	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	3,630	2, 3	Relamp	Yes	9	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,505	0.4	2,263	0	\$307	\$763	\$170	1.9
Main Office	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Principal Office	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	3,630	2, 3	Relamp	Yes	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,505	0.1	503	0	\$68	\$380	\$65	4.6
Conference Room	1	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	3,630	2	Relamp	No	1	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	3,630	0.0	198	0	\$27	\$55	\$15	1.5
Assistant Principal	2	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	3,630	2, 3	Relamp	Yes	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,505	0.1	503	0	\$68	\$380	\$65	4.6
Restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	132	0	\$18	\$37	\$10	1.5
Room A2	16	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	16	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.5	2,683	-1	\$364	\$1,124	\$230	2.5
Closet	1	Incandescent: Bulb - 1L	Wall Switch	S	60	3,630	2	Relamp	No	1	LED Lamps: Bulb - 1L	Wall Switch	9	3,630	0.0	204	0	\$28	\$17	\$1	0.6

Existing Conditions							Proposed Conditions							Energy Impact & Financial Analysis							
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Restroom	1	Incandescent: Bulb - 1L	Wall Switch	S	60	3,630	2	Relamp	No	1	LED Lamps: Bulb - 1L	Wall Switch	9	3,630	0.0	204	0	\$28	\$17	\$1	0.6
Room A1	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
Room A3	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
Room A4	16	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	16	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.5	2,683	-1	\$364	\$1,124	\$230	2.5
Restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	132	0	\$18	\$37	\$10	1.5
Closet	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	132	0	\$18	\$37	\$10	1.5
Room A5	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
Restroom	1	Incandescent: Bulb - 1L	Wall Switch	S	60	3,630	2	Relamp	No	1	LED Lamps: Bulb - 1L	Wall Switch	9	3,630	0.0	204	0	\$28	\$17	\$1	0.6
Room A6	16	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	16	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.5	2,683	-1	\$364	\$1,124	\$230	2.5
Closet	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	132	0	\$18	\$37	\$10	1.5
Restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	132	0	\$18	\$37	\$10	1.5
Room A7	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
B Hallway	12	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 4	Relamp	Yes	12	LED - Linear Tubes: (2) U-Lamp	High/Low Control	33	2,505	0.3	1,880	0	\$255	\$1,320	\$120	4.7
B Hallway	3	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	3	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Boys Restroom	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	264	0	\$36	\$73	\$20	1.5
Boys Restroom	1	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	S	33	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	3,630	0.0	64	0	\$9	\$33	\$6	3.1
Custodian	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	132	0	\$18	\$37	\$10	1.5
Storage Room	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	132	0	\$18	\$37	\$10	1.5
Storage Room	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	132	0	\$18	\$37	\$10	1.5
Girls Restroom	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	264	0	\$36	\$73	\$20	1.5
Girls Restroom	1	Incandescent: Bulb - 1L	Wall Switch	S	60	3,630	2	Relamp	No	1	LED Lamps: Bulb - 1L	Wall Switch	9	3,630	0.0	204	0	\$28	\$17	\$1	0.6
Room B1	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
Room B2	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
Room B3	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
Room B4	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9

Location	Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis								
	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Room B5	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
Room B6	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
Room B7	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
Room B8	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
Kitchen	4	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	3,630	2, 3	Relamp	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	2,505	0.2	1,182	0	\$161	\$562	\$115	2.8
Cafeteria	20	Metal Halide: (1) 400W Lamp	Wall Switch	S	458	3,630	1, 3	Fixture Replacement	Yes	20	LED - Fixtures: Ceiling Mount	Occupancy Sensor	137	2,505	5.2	29,005	-6	\$3,940	\$6,482	\$270	1.6
Cafeteria	3	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	3	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Faculty Lounge	7	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	7	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.2	1,174	0	\$159	\$526	\$105	2.6
Women	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	132	0	\$18	\$37	\$10	1.5
Custodian	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	132	0	\$18	\$37	\$10	1.5
Men Restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	132	0	\$18	\$37	\$10	1.5
Room F1	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.1	671	0	\$91	\$416	\$75	3.7
Custodian	2	LED Lamps: Screw In Bulb	Wall Switch	S	10	3,630		None	No	2	LED Lamps: Screw In Bulb	Wall Switch	10	3,630	0.0	0	0	\$0	\$0	\$0	0.0
Copy Room	4	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	3,630	2, 3	Relamp	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	2,505	0.2	1,182	0	\$161	\$562	\$115	2.8
Copy Room	1	LED Lamps: Screw In Bulb	Wall Switch	S	10	3,630		None	No	1	LED Lamps: Screw In Bulb	Wall Switch	10	3,630	0.0	0	0	\$0	\$0	\$0	0.0
CHallway	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 4	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	2,505	0.2	1,341	0	\$182	\$742	\$80	3.6
B Hallway	14	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 4	Relamp	Yes	14	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	2,505	0.4	2,347	0	\$319	\$961	\$140	2.6
CHallway	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
CHallway	2	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	S	33	3,630	2, 4	Relamp	Yes	2	LED - Linear Tubes: (2) 2' Lamps	High/Low Control	17	2,505	0.0	170	0	\$23	\$290	\$12	12.0
Boys Restroom	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.1	503	0	\$68	\$380	\$65	4.6
Girls Restroom	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.1	503	0	\$68	\$380	\$65	4.6
Server Room	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	132	0	\$18	\$37	\$10	1.5
Storage Room C7	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	132	0	\$18	\$37	\$10	1.5
Room C1	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
Closet	1	LED Lamps: Screw In Bulb	Wall Switch	S	10	3,630		None	No	1	LED Lamps: Screw In Bulb	Wall Switch	10	3,630	0.0	0	0	\$0	\$0	\$0	0.0

Location	Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis								
	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Room C2	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
Room C2	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.0	168	0	\$23	\$37	\$10	1.2
Room C3	12	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,505	0.5	3,018	-1	\$410	\$1,197	\$250	2.3
Room C4	12	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,505	0.5	3,018	-1	\$410	\$1,197	\$250	2.3
Room C5	12	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,505	0.5	3,018	-1	\$410	\$1,197	\$250	2.3
Room C6	12	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,505	0.5	3,018	-1	\$410	\$1,197	\$250	2.3
Library	33	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	3,630	2, 3	Relamp	Yes	33	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,505	1.5	8,299	-2	\$1,127	\$2,887	\$635	2.0
Library	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Library Office	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	3,630	2, 3	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,505	0.2	1,006	0	\$137	\$489	\$95	2.9
Electric Room	1	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	3,630	2	Relamp	No	1	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	44	3,630	0.0	198	0	\$27	\$55	\$15	1.5
D Hallway	10	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	3,630	2, 4	Relamp	Yes	10	LED - Linear Tubes: (3) 4' Lamps	High/Low Control	44	2,505	0.5	2,515	-1	\$342	\$998	\$150	2.5
D Hallway	1	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	S	33	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	3,630	0.0	64	0	\$9	\$33	\$6	3.1
D Hallway	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Girls Restroom	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.1	503	0	\$68	\$380	\$65	4.6
Boys Restroom	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.1	503	0	\$68	\$380	\$65	4.6
D Hallway	1	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	3,630	2	Relamp	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	3,630	0.0	224	0	\$30	\$73	\$20	1.7
Storage Room D8	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	132	0	\$18	\$37	\$10	1.5
Room D7	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	132	0	\$18	\$37	\$10	1.5
Room D1	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
Room D2	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
Room D3	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
Room D4	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
Room D5	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
Room D6	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
E Hallway	2	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	S	33	3,630	2, 4	Relamp	Yes	2	LED - Linear Tubes: (2) 2' Lamps	High/Low Control	17	2,505	0.0	170	0	\$23	\$65	\$12	2.3

Existing Conditions							Proposed Conditions							Energy Impact & Financial Analysis							
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
E Hallway	8	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	3,630	2, 4	Relamp	Yes	8	LED - Linear Tubes: (3) 4' Lamps	High/Low Control	44	2,505	0.4	2,012	0	\$273	\$888	\$120	2.8
E Hallway	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Girls Restroom	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.1	503	0	\$68	\$380	\$65	4.6
Boys Restroom	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.1	503	0	\$68	\$380	\$65	4.6
Room E7	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	132	0	\$18	\$37	\$10	1.5
Room C8	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	132	0	\$18	\$37	\$10	1.5
Room E1	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
Room E2	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.4	2,012	0	\$273	\$978	\$190	2.9
Room E2	2	LED Lamps: Screw In Bulb	Wall Switch	S	10	3,630	3	None	Yes	2	LED Lamps: Screw In Bulb	Occupancy Sensor	10	2,505	0.0	25	0	\$3	\$0	\$0	0.0
Room E3	12	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,505	0.5	3,018	-1	\$410	\$1,197	\$250	2.3
Room E4	12	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,505	0.5	3,018	-1	\$410	\$1,197	\$250	2.3
Room E5	12	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,505	0.5	3,018	-1	\$410	\$1,197	\$250	2.3
Room E6	12	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	3,630	2, 3	Relamp	Yes	12	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,505	0.5	3,018	-1	\$410	\$1,197	\$250	2.3
F Hallway	9	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	3,630	2, 4	Relamp	Yes	9	LED - Linear Tubes: (3) 4' Lamps	High/Low Control	44	2,505	0.4	2,263	0	\$307	\$943	\$135	2.6
Office	4	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	3,630	2, 3	Relamp	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	2,505	0.2	1,182	0	\$161	\$562	\$115	2.8
Room F4	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	264	0	\$36	\$73	\$20	1.5
Office	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	264	0	\$36	\$73	\$20	1.5
Office	6	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	3,630	2, 3	Relamp	Yes	6	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	2,505	0.3	1,772	0	\$241	\$708	\$155	2.3
Wallpack	2	Metal Halide: (1) 400W Lamp	Photocell		458	4,380	1	Fixture Replacement	No	2	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Photocell	137	4,380	0.3	2,808	0	\$389	\$1,932	\$200	4.5
Wallpack	6	LED Lamps: Corn Bulb - 1L	Timeclock		20	4,745		None	No	6	LED Lamps: Corn Bulb - 1L	Timeclock	20	4,745	0.0	0	0	\$0	\$0	\$0	0.0
Wallpack	9	Metal Halide: (1) 250W Lamp	Timeclock		295	4,745	1	Fixture Replacement	No	9	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Timeclock	89	4,745	0.9	8,819	0	\$1,220	\$8,694	\$900	6.4
Recessed	4	Incandescent: Bulb - 1L	Wall Switch	S	60	4,745	2	Relamp	No	4	LED Lamps: Bulb - 1L	Wall Switch	9	4,745	0.1	968	0	\$134	\$69	\$4	0.5
Walkway Light	4	LED - Fixtures: Stairwell/Passageway Lighting	Timeclock		45	4,745		None	No	4	LED - Fixtures: Stairwell/Passageway Lighting	Timeclock	45	4,745	0.0	0	0	\$0	\$0	\$0	0.0
Parking Lot	10	LED - Fixtures: Outdoor Pole/Arm Mounted Area/Roadway Fixture	Timeclock		160	4,745		None	No	10	LED - Fixtures: Outdoor Pole/Arm Mounted Area/Roadway Fixture	Timeclock	160	4,745	0.0	0	0	\$0	\$0	\$0	0.0
Walkway Light	6	LED - Fixtures: Large Pole/Arm Mounted Area/Roadway Fixture	Timeclock		25	4,745		None	No	6	LED - Fixtures: Large Pole/Arm Mounted Area/Roadway Fixture	Timeclock	25	4,745	0.0	0	0	\$0	\$0	\$0	0.0

Location	Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis								
	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Front Entrance	4	LED - Fixtures: Track or Mono-Point Directional Lighting Fixtures	Timeclock		40	4,745		None	No	4	LED - Fixtures: Track or Mono-Point Directional Lighting Fixtures	Timeclock	40	4,745	0.0	0	0	\$0	\$0	\$0	0.0
Front Entrance Recessed	2	LED - Fixtures: Close to Ceiling Mount	Wall Switch	S	19	4,745		None	No	2	LED - Fixtures: Close to Ceiling Mount	Wall Switch	19	4,745	0.0	0	0	\$0	\$0	\$0	0.0
Wallpack	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Timeclock		21	4,745		None	No	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Timeclock	21	4,745	0.0	0	0	\$0	\$0	\$0	0.0
Annex Front	2	Incandescent: Bulb - 1L	Wall Switch	S	60	4,745	2	Relamp	No	2	LED Lamps: Bulb - 1L	Wall Switch	9	4,745	0.1	484	0	\$67	\$34	\$2	0.5
Room G4	16	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	16	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.5	2,683	-1	\$364	\$1,124	\$230	2.5
Restroom	2	LED Lamps: Screw In Bulb	Wall Switch	S	10	3,630		None	No	2	LED Lamps: Screw In Bulb	Wall Switch	10	3,630	0.0	0	0	\$0	\$0	\$0	0.0
Room G5	16	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2, 3	Relamp	Yes	16	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,505	0.5	2,683	-1	\$364	\$1,124	\$230	2.5
Restroom	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	3,630	2	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,630	0.0	264	0	\$36	\$73	\$20	1.5
Room G6	4	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	3,630	2, 3	Relamp	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	2,505	0.2	1,182	0	\$161	\$562	\$115	2.8

### Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions							Proposed Conditions					Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Remaining Useful Life	Annual Operating Hours	ECM #	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Roof	Receiving Room	1	Exhaust Fan	0.3	68.0%	No	W	2,745		No	68.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	Hallway	1	Exhaust Fan	0.3	68.0%	No	W	2,745		No	68.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	Restroom	1	Exhaust Fan	0.3	68.0%	No	W	2,745		No	68.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	Break Room	2	Exhaust Fan	0.3	68.0%	No	W	2,745		No	68.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	Cafeteria	1	Exhaust Fan	0.5	68.0%	No	W	2,745		No	68.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	Library	1	Exhaust Fan	0.8	73.4%	No	W	2,745		No	73.4%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	Restroom	3	Exhaust Fan	0.3	68.0%	No	W	2,745		No	68.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	Hallway	3	Exhaust Fan	0.5	68.0%	No	W	2,745		No	68.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	Copy Room	1	Exhaust Fan	0.3	68.0%	No	W	2,745		No	68.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Boiler Room	Air Compressor	2	Air Compressor	0.3	60.0%	No	W	6,978		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Boiler Room	HHWP-1	1	Heating Hot Water Pump	3.0	89.5%	No	W	2,745	7	No	89.5%	Yes	1	0.3	2,780	0	\$385	\$3,884	\$0	10.1
Boiler Room	HHWP-2	1	Heating Hot Water Pump	3.0	86.5%	No	W	2,745	7	No	89.5%	Yes	1	0.3	3,088	0	\$427	\$3,884	\$0	9.1
Boiler Room	DHW Recirculation Pump	4	Water Supply Pump	0.3	72.4%	No	W	2,745		No	72.4%	No		0.0	0	0	\$0	\$0	\$0	0.0
Boiler Room	HHWP	2	Heating Hot Water Pump	5.0	87.5%	No	W	2,745	7	No	89.5%	Yes	2	1.1	9,129	0	\$1,263	\$8,152	\$0	6.5
Boiler Room	CHWP	2	Chilled Water Pump	1.5	86.5%	No	W	2,745	6	No	86.5%	Yes	2	0.6	2,557	0	\$354	\$6,781	\$0	19.2
Boiler Room	HHWP	2	Heating Hot Water Pump	0.5	76.2%	No	W	2,745		No	76.2%	No		0.0	0	0	\$0	\$0	\$0	0.0
Ground Floor	Annex	1	Supply Fan	0.3	60.0%	No	B	2,745		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Ground Floor	Annex	1	Exhaust Fan	0.3	60.0%	No	B	2,745		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Ground Floor	Annex	1	Supply Fan	0.8	81.8%	No	W	2,745		No	81.8%	No		0.0	0	0	\$0	\$0	\$0	0.0
Ground Floor	Annex	1	Exhaust Fan	0.3	72.4%	No	W	2,745		No	72.4%	No		0.0	0	0	\$0	\$0	\$0	0.0



Location	Area(s)/System(s) Served	Existing Conditions							Proposed Conditions					Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Remaining Useful Life	Annual Operating Hours	ECM #	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Cafeteria	AHU-1	1	Supply Fan	5.0	87.5%	No	W	3,600	5	No	89.5%	Yes	1	1.5	5,986	0	\$828	\$4,197	\$400	4.6
Classrooms	Unit Ventilators	35	Supply Fan	0.3	70.0%	No	W	2,745		No	70.0%	No		0.0	0	0	\$0	\$0	\$0	0.0

### Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions							Energy Impact & Financial Analysis					
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (MBh)	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (MBh)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives
Roof	Front Zone	1	Split-System Air-Source HP	2.00	27.00	W		No						0.0	0	0	\$0	\$0	\$0	0.0
Roof	Main Office	1	Split-System Air-Source HP	3.00	40.00	W		No						0.0	0	0	\$0	\$0	\$0	0.0
Roof	Copy Room	1	Split-System AC	1.50		W		No						0.0	0	0	\$0	\$0	\$0	0.0
Roof	Electric Room	1	Electric Resistance Heat		9.36	W		No						0.0	0	0	\$0	\$0	\$0	0.0
Nurse Office	Nurse Office	1	Window AC	1.03		W		No						0.0	0	0	\$0	\$0	\$0	0.0
Room A4	Room A4	1	Window AC	2.00		W		No						0.0	0	0	\$0	\$0	\$0	0.0
Room A6	Room A6	1	Window AC	2.00		W		No						0.0	0	0	\$0	\$0	\$0	0.0
Room A7	Room A7	1	Window AC	1.00		W		No						0.0	0	0	\$0	\$0	\$0	0.0
Computer Lab	Computer Lab	1	Split-System AC	2.50		W		No						0.0	0	0	\$0	\$0	\$0	0.0
Ground Floor	Annex	1	Packaged AC	4.00		B	8	Yes	1	Packaged AC	4.00		14.00	1.3	2,571	0	\$356	\$9,076	\$368	24.5
Ground Floor	Annex	1	Packaged AC	4.00		W		No						0.0	0	0	\$0	\$0	\$0	0.0

### Electric Chiller Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
		Chiller Quantity	System Type	Cooling Capacity per Unit (Tons)	Remaining Useful Life	ECM #	Install High Efficiency Chillers?	Chiller Quantity	System Type	Constant/Variable Speed	Cooling Capacity (Tons)	Full Load Efficiency (kW/Ton)	IPLV Efficiency (kW/Ton)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Ground Floor	Cooling System	1	Air-Cooled Screw Chiller	84.00	W		No							0.0	0	0	\$0	\$0	\$0	0.0

### Fuel Heating Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions				Proposed Conditions							Energy Impact & Financial Analysis						
		System Quantity	System Type	Output Capacity per Unit (MBh)	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Boiler Room	Boiler-1	1	Condensing Hot Water Boiler	724.50	W		No						0.0	0	0	\$0	\$0	\$0	0.0
Boiler Room	Boiler-2	1	Condensing Hot Water Boiler	724.50	W		No						0.0	0	0	\$0	\$0	\$0	0.0
Boiler Room	Boiler-3	1	Condensing Hot Water Boiler	724.50	W		No						0.0	0	0	\$0	\$0	\$0	0.0
Boiler Room	Boiler-4	1	Condensing Hot Water Boiler	724.50	W		No						0.0	0	0	\$0	\$0	\$0	0.0
Ground Floor	Annex	1	Furnace	94.30	B	9	Yes	1	Furnace	94.30	95.00%	AFUE	0.0	0	13	\$159	\$2,137	\$400	10.9
Ground Floor	Annex	1	Furnace	80.00	W		No						0.0	0	0	\$0	\$0	\$0	0.0

### DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions				Proposed Conditions						Energy Impact & Financial Analysis						
		System Quantity	System Type	Remaining Useful Life	ECM #	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Boiler Room	DHW Heater	1	Storage Tank Water Heater (≤ 50 Gal)	W		No						0.0	0	0	\$0	\$0	\$0	0.0
Closet	DHW Heater	1	Storage Tank Water Heater (≤ 50 Gal)	W		No						0.0	0	0	\$0	\$0	\$0	0.0
Closet	DHW Heater	1	Storage Tank Water Heater (≤ 50 Gal)	W		No						0.0	0	0	\$0	\$0	\$0	0.0
Closet	DHW Heater	1	Storage Tank Water Heater (≤ 50 Gal)	W		No						0.0	0	0	\$0	\$0	\$0	0.0
Closet	DHW Heater	1	Storage Tank Water Heater (≤ 50 Gal)	W		No						0.0	0	0	\$0	\$0	\$0	0.0
Closet	DHW Heater	2	Storage Tank Water Heater (≤ 50 Gal)	W		No						0.0	0	0	\$0	\$0	\$0	0.0

### Low-Flow Device Recommendations

Location	Recommendation Inputs					Energy Impact & Financial Analysis						
	ECM #	Device Quantity	Device Type	Existing Flow Rate (gpm)	Proposed Flow Rate (gpm)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Restrooms	10	18	Faucet Aerator (Lavatory)	2.20	0.50	0.0	15,014	0	\$2,077	\$129	\$0	0.1
Restrooms	10	4	Faucet Aerator (Lavatory)	2.20	0.50	0.0	0	11	\$137	\$29	\$0	0.2

### Commercial Refrigerator/Freezer Inventory & Recommendations

Location	Existing Conditions			Proposed Conditions		Energy Impact & Financial Analysis						
	Quantity	Refrigerator/ Freezer Type	ENERGY STAR Qualified?	ECM #	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Gym	1	Stand-Up Refrigerator, Solid Door (31 - 50 cu. ft.)	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0
Gym	1	Stand-Up Refrigerator, Solid Door (>50 cu. ft.)	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0
Cafeteria	1	Stand-Up Refrigerator, Solid Door (31 - 50 cu. ft.)	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0
Cafeteria	1	Refrigerator Chest	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0
Cafeteria	1	Refrigerator Chest	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0
Cafeteria	1	Stand-Up Freezer, Solid Door (31 - 50 cu. ft.)	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0
Cafeteria	1	Stand-Up Refrigerator, Solid Door (>50 cu. ft.)	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0
Cafeteria	1	Stand-Up Freezer, Solid Door (16 - 30 cu. ft.)	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0

### Cooking Equipment Inventory & Recommendations

Location	Existing Conditions			Proposed Conditions		Energy Impact & Financial Analysis						
	Quantity	Equipment Type	High Efficiency Equipment?	ECM #	Install High Efficiency Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen	1	Electric Convection Oven (Full Size)	Yes		No	0.0	0	0	FALSE	\$0	\$0	#DIV/0!
Kitchen	1	Insulated Food Holding Cabinet (Full Size)	Yes		No	0.0	0	0	FALSE	\$0	\$0	#DIV/0!
Kitchen	1	Insulated Food Holding Cabinet (Full Size)	Yes		No	0.0	0	0	FALSE	\$0	\$0	#DIV/0!

### Plug Load Inventory

Location	Existing Conditions			
	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
Laundry Area	1	Washing/Drying Machine	5,250.0	Yes
Break Rooms	6	Microwave	800.0	No
Classrooms/Offices	131	Computers	120.0	Yes
Break Rooms	2	Small Refrigerator	120.0	No
Offices	8	Printer	55.0	Yes
Copy Room	4	Copy Machine	600.0	Yes
Break Rooms	1	Toaster	300.0	No
Break Rooms	1	Refrigerator	255.0	Yes
Break Rooms	1	Water Cooler	120.0	Yes
Kitchen	5	Serving Table	3,000.0	Yes
Kitchen	1	Serving Table	756.0	Yes

**Vending Machine Inventory & Recommendations**

Location	Existing Conditions		Proposed Conditions		Energy Impact & Financial Analysis						
	Quantity	Vending Machine Type	ECM #	Install Controls?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Teacher Lounge	1	Refrigerated	11	Yes	0.2	1,612	0	\$223	\$230	\$50	0.8
Teacher Lounge	1	Non-Refrigerated	11	Yes	0.0	343	0	\$47	\$230	\$0	4.9

# APPENDIX B: ENERGY STAR® STATEMENT OF ENERGY PERFORMANCE

EUI is presented in terms of *site energy* and *source energy*. Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

**46**  
ENERGY STAR®  
Score<sup>1</sup>

**Cherry Street School**  
Primary Property Type: K-12 School  
Gross Floor Area (ft<sup>2</sup>): 49,756  
Built: 1962

For Year Ending: September 30, 2018  
Date Generated: May 10, 2019

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

### Property & Contact Information

<b>Property Address</b> Cherry Street School 20 Cherry Street Bridgeton, New Jersey 08302	<b>Property Owner</b> Bridgeton Board of Education 41 Blank Street Bridgeton, NJ 8302 ( ) -	<b>Primary Contact</b> Nicole Albanese 41 Blank Street Bridgeton, NJ 8302 856-455-8030 x2040 nalbanese@bridgeton.k12.nj.us
--	---	---

Property ID: 6751390

### Energy Consumption and Energy Use Intensity (EUI)

<b>Site EUI</b> 77.1 kBtu/ft <sup>2</sup>	<b>Annual Energy by Fuel</b>		<b>National Median Comparison</b>	
	Electric - Grid (kBtu)	2,133,985 (56%)	National Median Site EUI (kBtu/ft <sup>2</sup> )	74.7
<b>Source EUI</b> 156 kBtu/ft <sup>2</sup>	Natural Gas (kBtu)	1,700,159 (44%)	National Median Source EUI (kBtu/ft <sup>2</sup> )	151.2
			% Diff from National Median Source EUI	3%
			<b>Annual Emissions</b>	
			Greenhouse Gas Emissions (Metric Tons CO <sub>2</sub> e/year)	306

### Signature & Stamp of Verifying Professional

I \_\_\_\_\_ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Licensed Professional

\_\_\_\_\_  
( ) -



Professional Engineer Stamp  
(if applicable)

## APPENDIX C: GLOSSARY

TERM	DEFINITION
<b>Blended Rate</b>	Used to calculate fiscal savings associated with measures. The blended rate is calculated by dividing the amount of your bill by the total energy use. For example, if your bill is \$22,217.22, and you used 266,400 kilowatt-hours, your blended rate is 8.3 cents per kilowatt-hour.
<b>Btu</b>	<i>British thermal unit</i> : a unit of energy equal to the amount of heat required to increase the temperature of one pound of water by one-degree Fahrenheit.
<b>CHP</b>	<i>Combined heat and power</i> . Also referred to as cogeneration.
<b>COP</b>	<i>Coefficient of performance</i> : a measure of efficiency in terms of useful energy delivered divided by total energy input.
<b>Demand Response</b>	Demand response reduces or shifts electricity usage at or among participating buildings/sites during peak energy use periods in response to time-based rates or other forms of financial incentives.
<b>DCV</b>	<i>Demand control ventilation</i> : a control strategy to limit the amount of outside air introduced to the conditioned space based on actual occupancy need.
<b>US DOE</b>	<i>United States Department of Energy</i>
<b>EC Motor</b>	<i>Electronically commutated motor</i>
<b>ECM</b>	<i>Energy conservation measure</i>
<b>EER</b>	<i>Energy efficiency ratio</i> : a measure of efficiency in terms of cooling energy provided divided by electric input.
<b>EUI</b>	<i>Energy Use Intensity</i> : measures energy consumption per square foot and is a standard metric for comparing buildings' energy performance.
<b>Energy Efficiency</b>	Reducing the amount of energy necessary to provide comfort and service to a building/area. Achieved through the installation of new equipment and/or optimizing the operation of energy use systems. Unlike conservation, which involves some reduction of service, energy efficiency provides energy reductions without sacrifice of service.
<b>ENERGY STAR®</b>	ENERGY STAR® is the government-backed symbol for energy efficiency. The ENERGY STAR® program is managed by the EPA.
<b>EPA</b>	<i>United States Environmental Protection Agency</i>
<b>Generation</b>	The process of generating electric power from sources of primary energy (e.g., natural gas, the sun, oil).
<b>GHG</b>	<i>Greenhouse gas</i> : gases that are transparent to solar (short-wave) radiation but opaque to long-wave (infrared) radiation, thus preventing long-wave radiant energy from leaving Earth's atmosphere. The net effect is a trapping of absorbed radiation and a tendency to warm the planet's surface.
<b>gpf</b>	<i>Gallons per flush</i>

<b>gpm</b>	<i>Gallon per minute</i>
<b>HID</b>	<i>High intensity discharge</i> : high-output lighting lamps such as high-pressure sodium, metal halide, and mercury vapor.
<b>hp</b>	<i>Horsepower</i>
<b>HPS</b>	<i>High-pressure sodium</i> : a type of HID lamp.
<b>HSPF</b>	<i>Heating seasonal performance factor</i> : a measure of efficiency typically applied to heat pumps. Heating energy provided divided by seasonal energy input.
<b>HVAC</b>	<i>Heating, ventilating, and air conditioning</i>
<b>IHP 2014</b>	US DOE Integral Horsepower rule. The current ruling regarding required electric motor efficiency.
<b>IPLV</b>	<i>Integrated part load value</i> : a measure of the part load efficiency usually applied to chillers.
<b>kBtu</b>	One thousand British thermal units
<b>kW</b>	<i>Kilowatt</i> : equal to 1,000 Watts.
<b>kWh</b>	<i>Kilowatt-hour</i> : 1,000 Watts of power expended over one hour.
<b>LED</b>	<i>Light emitting diode</i> : a high-efficiency source of light with a long lamp life.
<b>LGEA</b>	<i>Local Government Energy Audit</i>
<b>Load</b>	The total power a building or system is using at any given time.
<b>Measure</b>	A single activity, or installation of a single type of equipment, that is implemented in a building system to reduce total energy consumption.
<b>MH</b>	<i>Metal halide</i> : a type of HID lamp.
<b>MBh</b>	<i>Thousand Btu per hour</i>
<b>MBtu</b>	<i>One thousand British thermal units</i>
<b>MMBtu</b>	<i>One million British thermal units</i>
<b>MV</b>	<i>Mercury Vapor</i> : a type of HID lamp.
<b>NJBPU</b>	<i>New Jersey Board of Public Utilities</i>
<b>NJCEP</b>	<i>New Jersey Clean Energy Program</i> : NJCEP is a statewide program that offers financial incentives, programs and services for New Jersey residents, business owners and local governments to help them save energy, money and the environment.
<b>psig</b>	Pounds per square inch gauge
<b>Plug Load</b>	Refers to the amount of power used in a space by products that are powered by means of an ordinary AC plug.
<b>PV</b>	<i>Photovoltaic</i> : refers to an electronic device capable of converting incident light directly into electricity (direct current).



<b>SEER</b>	<i>Seasonal energy efficiency ratio</i> : a measure of efficiency in terms of annual cooling energy provided divided by total electric input.
<b>SEP</b>	<i>Statement of energy performance</i> : a summary document from the ENERGY STAR® Portfolio Manager®.
<b>Simple Payback</b>	The amount of time needed to recoup the funds expended in an investment or to reach the break-even point between investment and savings.
<b>SREC</b>	<i>Solar renewable energy credit</i> : a credit you can earn from the state for energy produced from a photovoltaic array.
<b>T5, T8, T12</b>	A reference to a linear lamp diameter. The number represents increments of 1/8 <sup>th</sup> of an inch.
<b>Temperature Setpoint</b>	The temperature at which a temperature regulating device (thermostat, for example) has been set.
<b>therm</b>	100,000 Btu. Typically used as a measure of natural gas consumption.
<b>tons</b>	A unit of cooling capacity equal to 12,000 Btu/hr.
<b>Turnkey</b>	Provision of a complete product or service that is ready for immediate use
<b>VAV</b>	<i>Variable air volume</i>
<b>VFD</b>	<i>Variable frequency drive</i> : a controller used to vary the speed of an electric motor.
<b>WaterSense™</b>	The symbol for water efficiency. The WaterSense™ program is managed by the EPA.
<b>Watt (W)</b>	Unit of power commonly used to measure electricity use.