

**SPRINGFIELD TOWNSHIP
MUNICIPAL BUILDING
ENERGY ASSESSMENT**

for

**NEW JERSEY
BUREAU OF PUBLIC UTILITIES**

CHA PROJECT NO. 20812

March 2010

Prepared by:

CLOUGH HARBOUR & ASSOCIATES LLP

2001 Route 46
Suite 107
Parsippany, NJ 07054

(973) 299-1100

TABLE OF CONTENTS

| | <u>Page</u> |
|---|-------------|
| 1.0 INTRODUCTION & BACKGROUND..... | 1 |
| 2.0 EXECUTIVE SUMMARY..... | 2 |
| 3.0 EXISTING CONDITIONS..... | 4 |
| 3.1 Building General | |
| 3.2 Utility Usage | |
| 3.3 HVAC Systems | |
| 3.4 Lighting/Electrical Systems | |
| 3.5 Control Systems | |
| 3.6 Plumbing Systems | |
| 4.0 ENERGY CONSERVATION MEASURES..... | 6 |
| 4.1 ECM-1 Lighting Replacements | |
| 4.2 ECM-2 Install Occupancy Sensors | |
| 4.3 ECM-3 Combined Lighting Replacements with Occupancy Sensors | |
| 4.4 ECM-4 Door Seal Replacement | |
| 4.5 ECM-5 Window Replacements | |
| 4.6 ECM-6 Night Setback | |
| 4.7 ECM-7 Condensing Boiler Installatin | |
| 4.8 ECM-8 Replace Domestic Hot Water Heater | |
| 4.9 ECM-9 Demand Control Ventilation | |
| 4.10 ECM-10 Install Economizer Controls | |
| 5.0 PROJECT INCENTIVES..... | 13 |
| 5.1 Incentives Overview | |
| 5.2 Building Incentives | |
| 6.0 ALTERNATIVE ENERGY EVALUATION..... | 15 |
| 6.1 Geothermal | |
| 6.2 Solar | |
| 6.3 Wind | |
| 6.4 Combined Heat and Power Generation (CHP) | |
| 6.5 Biomass Power Generation | |
| 6.6 Demand Response Curtailment | |
| 7.0 EPA PORTFOLIO MANAGER..... | 20 |
| 8.0 CONCLUSIONS & RECOMMENDATIONS..... | 21 |

APPENDICES

- A Utility Usage Analysis
 - B ECM-1 Lighting Replacements
 - C ECM-2 Install Occupancy Sensors
 - D ECM-3 Lighting Replacements and Occupancy Sensors
 - E ECM-4 Install Door Seals
 - F ECM-5 Replace Windows
 - G ECM-6 Night Setback Controls
 - H ECM-7 Replace Boiler
 - I ECM-8 Replace Domestic Hot Water Heater
 - J ECM-9 Demand Control Ventilation
 - K ECM-10 Install Economizers
 - L New Jersey Pay For Performance Incentive Program
 - M Photovoltaic (PV) Rooftop Solar Power Generation
 - N Solar Thermal Domestic Hot Water Plant
 - O Wind
 - P EPA Portfolio Manager
 - Q Equipment Inventory
-

1.0 INTRODUCTION & BACKGROUND

This report summarizes the energy audit performed at the Springfield Township municipal building located at 2159 Jackson-Jobstown Road, Jobstown, NJ. Constructed in 1980, the building is a 5,280 square foot, single story structure. In addition to the police department and court room, the building houses municipal offices including the treasurer, tax, building permits, court office, town clerk, and land zoning offices.

New Jersey's Clean Energy Program, funded by the New Jersey Board of Public Utilities, supports energy efficiency and sustainability for Municipal and Local Government Energy Audits. Through the support of a utility trust fund, New Jersey is able to assist state and local authorities in reducing energy consumption while increasing comfort.

2.0 EXECUTIVE SUMMARY

This report details the results of the 5,280 square foot, single story Springfield Township municipal building. The facility houses the police department and court room; and treasurer, tax, building permits, court office, town clerk, and zoning municipal offices. The following areas were evaluated for energy conservation measures:

- Lighting replacement with occupancy sensors
- Door seal replacement
- Night setback
- Domestic hot water heater replacement
- Demand control ventilation
- Economizers

Various potential Energy Conservation Measures (ECMs) were identified for the above categories. Measures which are recommended for implementation have a payback of 10 years or less. This threshold is considered a viable return on investment. Potential annual savings of \$5,800 for the recommended ECMs may be realized with a payback of 3.9 years.

The ECMs identified in this report will allow for the building to reduce its energy usage and if pursued has the opportunity to qualify for the New Jersey SmartStart Buildings Program. A summary of the costs, savings, and paybacks for the recommended ECMs follows:

ECM-3 Combined Lighting Replacements with Occupancy Sensors

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|----------------|------------------------|-------|-------------|-------|-----|----------------------|-----------------------------|--------------------------|
| | Electricity | | Natural Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 10,200 | 4.4 | 8,220 | 0 | 1,800 | 1.6 | 900 | 5.7 | 5.2 |

* Incentive shown is per the New Jersey Smart Start program's Prescriptive Lighting and Lighting Controls Applications.

ECM-4 Install Door Seals

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|----------------|------------------------|-----|-------------|-------|-----|----------------------|-----------------------------|--------------------------|
| | Electricity | | Natural Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 700 | 0 | 30 | 70 | 100 | 0.3 | NA | 7.0 | NA |

* There is no incentive available through the New Jersey Smart Start program for this ECM.

ECM-6 Night Setback

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|----------------|------------------------|-----|-------------|-------|-----|----------------------|-----------------------------|--------------------------|
| | Electricity | | Natural Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 2,000 | 0 | 280 | 630 | 800 | 5.2 | NA | 2.5 | NA |

* There is no incentive available through the New Jersey Smart Start program for this ECM.

ECM – 8 Replace Domestic Hot Water Heater

| Budgetary Cost | Annual Utility Savings | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) | |
|----------------|------------------------|-------|-------------|-------|----------------------|-----------------------------|--------------------------|-------|
| | Electricity | | Natural Gas | | | | | Total |
| \$ | kW | kWh | Therms | \$ | \$ | Years | Years | |
| 3,800 | 9 | 2,000 | (40) | 1,800 | 8.6 | 50 | 2.1 | 2.0 |

* Incentive shown is per the New Jersey Smart Start program's Gas Water Heating Application.

ECM-9 Demand Control Ventilation

| Budgetary Cost | Annual Utility Savings | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) | |
|----------------|------------------------|-------|-------------|-------|----------------------|-----------------------------|--------------------------|-------|
| | Electricity | | Natural Gas | | | | | Total |
| \$ | kW | kWh | Therms | \$ | \$ | Years | Years | |
| 7,100 | 0 | 1,000 | 900 | 1,300 | 1.7 | NA | 5.6 | NA |

* There is no incentive available through the New Jersey Smart Start program for this ECM.

3.0 EXISTING CONDITIONS

3.1 Building General

The Springfield Township municipal building, constructed in 1980, is a 5,280 square foot, single story structure. The building houses the police department, court room, and municipal offices for the treasurer, tax department, town clerk, building, and zoning.

The police department is operational 24 hours a day year round. Occupancy ranges from about eight people during peak hours to one person at off peak times. Municipal offices within the administrative area have specific hours during which they are open to the public. Typical average occupancy is about 13 people from 9:00 AM to 4:00 PM, Monday through Friday. In addition, the courtroom holds sessions starting at 5:15 PM for two hours twice per month. The court also serves as a large meeting room when required. Average occupancy of the courtroom is about 15 people.

The building's exterior shell appears to be in good condition. The walls consist of 4" face brick; 8" concrete block, 2.5" rigid board insulation, and are finished with 1/2" gypsum board. The roof is constructed of architectural shingles on top of felt paper, 3/4" sheathing, R-25 batt insulation, and finished with acoustical ceiling tiles. Exterior windows are wood frame double hung 1/4" pane glass and most are in good condition. Exterior doors are aluminum with tempered safety glass.

3.2 Utility Usage

Utilities include electricity, natural gas, and potable water. Electricity and natural gas are purchased from Public Service Electric & Gas Company (PSE&G); potable water is provided by an on-site well and filtration system.

During the period of October 2008 to September 2009, electric usage was approximately 73,600 kWh at a total cost of \$12,900. Review of electricity bills during this period determined the building was charged a supply unit cost of \$0.1235 per kWh, demand unit cost of \$15.09 per kW, and blended unit cost of \$0.175 per kWh. Electrical usage was highest in the summer months due to the use of cooling equipment. During the same 2008-2009 timeframe, the building heating produced by natural gas-fired equipment required 2,540 therms. Based on the annual cost of about \$3,150, the blended price for natural gas was \$1.24 per therm. Natural gas consumption is highest in the winter months required to produce building heat. Water consumption is not recorded; therefore, is not included in the utility analysis. Utility data can be found in Appendix A.

Electricity and natural gas commodity supply and delivery is presently purchased from PSE&G. The delivery component will always be the responsibility of the utility that connects the facility to the power grid or gas line; however, the supply can be purchased from a third party. The electricity or natural gas commodity supply entity will require submission of one to three years of past energy bills. Contract terms can vary among suppliers. A list of approved electrical and natural gas energy commodity suppliers can be found in Appendix A.

3.3. HVAC Systems

Ventilation and air conditioning are provided by three air handling units (AHUs) located in the attic area, which serve the main building, police department, and court area. Each AHU is coupled with a remote condenser located on grade along the side of the building. In total, the three units supply 7,200 CFM air, including 675 CFM of outdoor air (OA).

Hot water coil heating and direct expansion (DX) cooling are provided to the perimeter of the facility by eight wall penetrating unit ventilators with an estimated outdoor air inflow of 400 CFM.

Heat is primarily generated by one original 245,000 Btu natural gas fired Weil McLain boiler distributing hot water to heating coils to the three AHUs, seven unit ventilators, and one cabinet heater. Supplemental heating was added in the men's and women's restrooms. One 10 foot electric resistance wall mounted heater was added to each restroom and has an integral thermostat mounted on each unit.

There is one exhaust fan serving the restrooms.

3.4 Lighting/Electrical Systems

The lighting fixtures throughout the municipal building utilize two or four lamp inefficient T-12 fluorescent lamps with magnetic ballasts. All exit signs and traditional bulbs within the building are illuminated with inefficient incandescent lamps. Exterior lighting, located at the exterior doors at the underside of the roof overhang, consists of three fixtures using 75 watt incandescent lamps. The facility also includes six poles equipped with 250 watt metal halide lamps.

Emergency power is provided by a 60 kW, gas-fired, Kohler generator located outside at the northwest corner of the building.

3.5 Control Systems

3.5.1 HVAC Controls

Originally, the building utilized a Honeywell control system with the capability of controlling all AHU air dampers, boiler operation, as well as space temperatures throughout the facility. This system has been disabled for many years due to the cost of sustained maintenance.

Currently, AHUs, boiler, and finned tube radiant heating are controlled by wall-mounted, non-programmable thermostats. Thermostats controlling AHUs 1, 2, and 3 are standard proportional units. The ventilators serving the perimeter walls utilize hot water coil and DX cooling, and are manually controlled. There is no night setback capability available in the present system.

Exhaust fan serving the restrooms and holding area are operated by a wall-mounted controller.

3.5.2 Lighting Controls

Most lighting in the municipal building is controlled by manual wall switches. Additional controls include a manual dimmer switch for courtroom lighting, and a photocell or timers to operate exterior lighting.

3.6 Plumbing Systems

Domestic hot water is produced by a 30 gallon, 9 kW electric, Bradford White water heater located in the mechanical room. Plumbing fixtures include standard-flow toilets and wall-mounted restroom sinks and urinals.

4.0 ENERGY CONSERVATION MEASURES

4.1 ECM-1 Lighting Replacements

The lighting fixtures throughout the municipal building utilize two or four lamp inefficient T-12 fluorescent lamps with magnetic ballasts. All exit signs and bulbs are illuminated with inefficient incandescent lamps.

The following lighting upgrades were also considered where appropriate:

- T-12 34-watt 2 & 4 lamp with magnetic ballast retrofitted to T-8 28-watt lamps and electronic ballasts
- Incandescent lamps to efficient compact fluorescent lamps
- Incandescent exit signs replaced with LED high efficiency fixtures

Energy savings for this measure were calculated by applying the existing and proposed fixture wattages to the estimated time of operation. The difference resulted in an annual savings of 7,780 kWh per year, in addition to a 4.4 kW reduction in demand. Supporting calculations, including all assumptions for lighting hours and the annual energy usage for each fixture are provided in Appendix B.

Lighting has an expected life of 15 years, according to the manufacturer, and total energy savings over the life of the project are estimated at 116,700 kWh and \$25,900.

The implementation cost and savings related to this ECM are presented in Appendix B and summarized below:

ECM-1 Lighting Replacements

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|----------------|------------------------|-------|-------------|-------|------|----------------------|-----------------------------|--------------------------|
| | Electricity | | Natural Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 9,800 | 4.4 | 7,780 | 0 | 1,700 | 1.63 | 900 | 5.8 | 5.2 |

* Incentive shown is per the New Jersey Smart Start program's Prescriptive Lighting Application.

This measure is not recommended in lieu of ECM-3.

4.2 ECM-2 Install Occupancy Sensors

Currently, occupancy sensors are not utilized. It is proposed that occupancy sensors be installed in selected rooms to turn off the lights when the area is unoccupied. A lighting survey was conducted of all fixtures in the building to determine the average time that the lights are presently on in each space. An analysis was performed to determine the benefits of utilizing occupancy sensors to turn off lighting while the space is not in use. Occupancy sensors were not considered in mechanical areas and hallways due to safety concerns. Other areas were not considered due to the proposed location of the occupancy sensor. If the sensor would not have a clear view of the occupants in the space, it may darken even with people utilizing the space.

The weekly occupied times for each space was determined by taking into account typical traffic patterns for individual spaces. Applying the existing and proposed operating times to the combined wattage requirements for each room's lighting fixtures, it was determined that 520 kWh can be saved through

implementation of this ECM. Supporting calculations, including the proposed rooms to install occupancy sensors; assumptions for lighting hours in each space; annual energy usage for each fixture; and the type of occupancy sensor recommended is included in Appendix C.

Occupancy sensors have an expected life of 15 years, according to the manufacturer, and total energy savings over the life of the project are estimated at 7,770 kWh and \$900.

The implementation cost and savings related to this ECM are presented in Appendix C and summarized below:

ECM-2 Install Occupancy Sensors

| Budgetary Cost | Annual Utility Savings | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) | |
|----------------|------------------------|-----|-------------|-----|----------------------|-----------------------------|--------------------------|-------|
| | Electricity | | Natural Gas | | | | | Total |
| \$ | kW | kWh | Therms | \$ | | Years | Years | |
| 400 | 0 | 520 | 0 | 100 | 1.6 | 100 | 4.0 | 3.0 |

* Incentive shown is per the New Jersey Smart Start program’s Lighting Controls Application.

This measure is not recommended in lieu of ECM-3.

4.3 ECM-3 Combined Lighting Replacements with Occupancy Sensors

Due to interactive effects, the energy and cost savings for occupancy sensors and lighting upgrades are not cumulative. This measure is a combination of ECM-1 and ECM-2 to allow for maximum energy and demand reduction.

Lighting and occupancy sensors have an expected life of 15 years, according to the manufacturer, and total energy savings over the life of the project are estimated at 123,360 kWh and \$26,800.

The implementation cost and savings related to this ECM are presented in Appendix D and summarized below:

ECM-3 Combined Lighting Replacements with Occupancy Sensors

| Budgetary Cost | Annual Utility Savings | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) | |
|----------------|------------------------|-------|-------------|-------|----------------------|-----------------------------|--------------------------|-------|
| | Electricity | | Natural Gas | | | | | Total |
| \$ | kW | kWh | Therms | \$ | | Years | Years | |
| 10,200 | 4.4 | 8,220 | 0 | 1,800 | 1.6 | 900 | 5.7 | 5.2 |

* Incentive shown is per the New Jersey Smart Start program’s Prescriptive Lighting and Lighting Controls Applications.

This measure is recommended.

4.4 ECM-4 Door Seal Replacement

The door seals at the facility are in fair condition. Installing new door seals will reduce outdoor air infiltration and reduce heating and cooling costs.

This ECM calculation was developed by reducing the calculated infiltration CFM created by the existing door seals and reducing the amount of outdoor air bypassing the existing door seals by 80%. Following implementation of this measure, it is expected the building's annual natural gas and electricity consumption will be reduced by approximately 70 therms and 30 kWh, respectively.

Door seals an expected life of 10 years, according to ASHRAE, and total energy savings over the life of the project are estimated at 660 therms, 300 kWh, and \$900.

The implementation cost and savings related to this ECM are presented in Appendix E and summarized below:

ECM-4 Install Door Seals

| Budgetary Cost | Annual Utility Savings | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) | |
|----------------|------------------------|-----|-------------|-----|----------------------|-----------------------------|--------------------------|-------|
| | Electricity | | Natural Gas | | | | | Total |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 700 | 0 | 30 | 70 | 100 | 0.3 | NA | 7.0 | NA |

* There is no incentive available through the New Jersey Smart Start program for this ECM.

This measure is recommended.

4.5 ECM-5 Window Replacements

The windows at the Springfield municipal building are operable double hung, single pane 1/4” glass, wood frame and original to building construction. The windows are in good condition and most windows observed were tight and not excessively leaking. This style of window inherently has increased outdoor air infiltration creating cold drafts, and heating and cooling losses. This ECM evaluates replacement with new energy efficient windows that incorporate double pane argon filled low-e window glazing with wood frame construction.

This measure calculated the square footage and perimeter length of the single pane windows. The building has over 143 square feet of window area. Weather bin data determined heating and cooling hours and associated energy savings. Window replacement is not recommended due to the long payback; however, additional considerations may be improved comfort and appearance.

Windows have an expected life of 20 years, according to ASHRAE, and total energy savings over the life of the project are estimated at 1,000 kWh, 4,360 therms and \$5,600.

The implementation cost and savings related to this ECM are presented in Appendix F and summarized as follows:

ECM – 5 Replace Windows

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-----|--------------------------|-------|-------|-------------------------|--------------------------------|-----------------------------|
| | Electricity | | Natural Gas baton and | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 13,300 | 0.0 | 50 | 220 | 300 | (0.6) | NA | >25 | NA |

* There is no incentive available through the New Jersey Smart Start program for this ECM.

This measure is not recommended.

4.6 ECM-6 Night Setback

As previously noted, the original Honeywell control system was disabled many years ago due to the cost of maintenance. The AHUs, boiler, and finned tube radiant heating are controlled by a wall-mounted, nonprogrammable thermostat. Night setback is not utilized.

This ECM evaluates adjusting the unoccupied heating to 60°F and cooling setpoint to 80°F in all areas except the police department that is utilized 24 hours per day, seven days per week.

To calculate the benefits of night setback, a block load building model was created to approximate the existing energy load for the spaces served by each air handler. The block loads model the maximum overall cooling and heating loads for each space, taking into account various parameters such as roof, wall, and window construction; total envelope surface area; ventilation and infiltration loads; building occupancy; internal heat generation; and other sources of heat gain and loss. By entering these calculated maximum loads into a spreadsheet containing bin temperature data, the total accumulated year-round cooling and heating energy requirements were determined for each area. Bin data for Springfield, NJ was not available; therefore, data from nearby Newark, NJ was used. The bin temperature spreadsheets are included in Appendix F.

To determine the proposed energy usage in each area during temperature setback, a second bin spreadsheet was created for the new accumulated heating and cooling loads, which was identical to the existing usage spreadsheets except the unoccupied temperatures were adjusted. The difference in heating therms and cooling kWh between the two models is taken as the savings. Heating and cooling night setback in the police department was not considered. Following implementation of this measure, it is expected the building’s annual natural gas will be reduced by 630 therms and electricity by 280 kWh.

Programmable thermostats have an expected life of 15 years, according to ASHRAE, and total energy savings over the life of the project are estimated at 9,430 therms, 4,240 kWh and \$12,400.

The implementation cost and savings related to this ECM are presented in Appendix G and summarized as follows:

ECM-6 Night Setback

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|----------------|------------------------|-----|-------------|-------|-----|----------------------|-----------------------------|--------------------------|
| | Electricity | | Natural Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 2,000 | 0 | 280 | 630 | 800 | 5.2 | NA | 2.5 | NA |

* There is no incentive available through the New Jersey Smart Start program for this ECM.

This measure is recommended.

4.7 ECM-7 Condensing Boiler Installation

As previously noted, heat is primarily generated by one original 245,000 Btu natural gas fired Weil McLain boiler. There are currently more efficient units such as condensing boilers that can provide efficiencies of 93%. The energy saved is determined by comparing the difference in the energy used by the existing gas fired boiler and proposed condensing boiler for hot water heating.

Condensing boilers work on the principle of recovering as much waste heat as possible, which is normally ejected into the atmosphere from the flue of a conventional (non-condensing) boiler. This design maximizes the heat transfer from the burner and recovers useful heat which would normally be lost with the flue gases. When in condensing mode, (condensing boilers do not condense continually) the flue gases give up their latent heat which is then recovered by the heat exchanger within the boiler. As a result, the temperature of the gases exiting the flue of a condensing boiler is typically 120-140°F; the temperature in a current non-condensing boiler stack is higher.

Following implementation of this measure, it is expected the building's annual natural gas consumption will be reduced by approximately 470 therms.

Condensing boilers have an expected life of 20 years, according to ASHRAE, and total energy savings over the life of the project are estimated at 9,380 therms and \$11,600.

The implementation cost and savings related to this ECM are presented in Appendix H and summarized below:

ECM – 7 Condensing Boiler Installation

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|----------------|------------------------|-----|-------------|-------|-----|----------------------|-----------------------------|--------------------------|
| | Electricity | | Natural Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 7,200 | 0 | 0 | 470 | 600 | 0.6 | 400 | 12.3 | 11.6 |

* Incentive shown is per the New Jersey Smart Start program's Gas Heating Application.

This measure is not recommended.

4.8 ECM-8 Replace Domestic Hot Water Heater

Presently domestic hot water is produced utilizing electric hot water heater and storage tank. This unit has (2) 4.5 kW heating elements immersed in a 30 gallon storage tank. It is proposed this unit be replaced

with a tankless, instantaneous, condensing gas-fired domestic hot water heater. Gas line modification as well as flue gas modifications would be needed to consider this type of upgrade.

Following implementation of this measure, it is expected the building’s annual electrical energy consumption will be reduced by approximately 1,990 kWh and will need to consume about 40 therms of natural gas in the proposed natural gas burning configuration.

Condensing domestic hot water heaters have an expected life of 20 years, according to ASHRAE, and total energy savings over the life of the project are estimated at by approximately 39,830 kWh and will consume 860 therms, totaling \$36,500.

The implementation cost and savings related to this ECM are presented in Appendix I and summarized below:

ECM – 8 Replace Domestic Hot Water Heater

| Budgetary Cost | Annual Utility Savings | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) | |
|----------------|------------------------|-------|-------------|-------|----------------------|-----------------------------|--------------------------|-------|
| | Electricity | | Natural Gas | | | | | Total |
| \$ | kW | kWh | Therms | \$ | \$ | Years | Years | |
| 3,800 | 9 | 2,000 | (40) | 1,800 | 8.6 | 50 | 2.1 | 2.0 |

* Incentive shown is per the New Jersey Smart Start program’s Gas Water Heating Application.

This measure is recommended.

4.9 ECM-9 Demand Control Ventilation

As previously noted, the original Honeywell control system was disabled many years ago due to the cost of maintenance. The AHUs, boiler, and finned tube radiant heating are controlled by a wall-mounted, nonprogrammable thermostat. All air handlers were observed to have their outdoor air dampers permanently affixed in the minimum volume setting. The amount of outside air to the building does not vary based on occupancy and can potentially over-ventilate the building. Energy usage can be reduced by matching the amount of ventilation to the occupancy.

The facility is served by three air handling units; AHU-1 serves the police station, AHU-2 the main area, and AHU-3 the court room. The combined supply air rate is 7,200 CFM, including 675 CFM of outdoor air (OA). Each AHU draws fresh air in through an OA intake and blends it with return air prior to being treated and discharged into each space. Since there is no control on the fresh air intake, the same amount of OA is treated regardless of the ventilation demand determined by space occupancy. Utilizing demand control ventilation (DCV), the system would regulate the amount of OA induced into the space based on the CO₂ levels detected within the room or return air duct. A DCV system is based on the principle that the number of people within the space is proportional to the concentration of CO₂. This ECM evaluates providing only the required fresh air to the space, decreasing the amount of OA to be treated, and reducing the annual heating and cooling loads. Due to the fact that the present outdoor air louvers have been permanently set at the minimum outdoor air volume the savings derived from this ECM will be limited to the decrease in volume of the present minimum setting to reduced volume requirement based on CO₂ levels.

Implementation of this measure requires installation of OA controls on the three AHUs serving the facility. This includes installing a CO₂ sensor within the return air duct and upgrades to the OA damper

actuators for each unit. Additionally, a programmable logic controller (PLC) will be necessary to control the OA damper positions based on the CO₂ readings.

DCV equipment has an expected life of 15 years, according to ASHRAE, and total energy savings over the life of the project are estimated at 2,760 therms, 2,160 kWh and \$3,800.

The implementation cost and savings related to this ECM are presented in Appendix J and summarized below:

ECM-9 Demand Control Ventilation

| Budgetary Cost | Annual Utility Savings | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) | |
|----------------|------------------------|-------------|--------|-------|----------------------|-----------------------------|--------------------------|----|
| | Electricity | Natural Gas | Total | | | | | |
| \$ | kW | kWh | Therms | \$ | \$ | Years | Years | |
| 7,100 | 0 | 1,000 | 900 | 1,300 | 1.7 | NA | 5.6 | NA |

* There is no incentive available through the New Jersey Smart Start program for this ECM.

This measure is recommended.

4.10 ECM-10 Install Economizer Controls

The existing systems bring in the same amount of outside air regardless of occupancy or load. Economizers would utilize cooler outside air when possible. This ECM considers installing economizer controls on the existing AHUs. This will bring in outdoor air to cool the facility without the use of mechanical refrigeration equipment. The only energy required to take advantage of this free cooling would be to run the air handling unit fans. Presently the AHU outdoor air dampers are set at a minimum setting bring in 675 CFM continuously.

Implementation of this measure requires installation of OA controls on the three AHUs serving the facility. This includes installing enthalpy sensors within the outdoor air duct and upgrades to the OA damper actuators for each unit. Additionally, a programmable logic controller (PLC) will be necessary to control the OA damper positions based on outdoor air temperature and enthalpy readings.

Economizer control equipment has an expected life of 15 years, according to ASHRAE, and total energy savings over the life of the project are estimated at 12,250 kWh and \$2,100.

The implementation cost and savings related to this ECM are presented in Appendix K and summarized below:

ECM-10 Install Economizer Controls

| Budgetary Cost | Annual Utility Savings | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) | |
|----------------|------------------------|-------------|--------|-----|----------------------|-----------------------------|--------------------------|----|
| | Electricity | Natural Gas | Total | | | | | |
| \$ | kW | kWh | Therms | \$ | \$ | Years | Years | |
| 4,300 | 0 | 800 | 0 | 100 | (0.5) | NA | >25 | NA |

* There is no incentive available through the New Jersey Smart Start program for this ECM.

This measure is not recommended.

5.0 PROJECT INCENTIVES

5.1 Incentives Overview

The building will be eligible for incentives from the New Jersey Office of Clean Energy. The most significant incentives will be from the New Jersey Pay for Performance (P4P) Program. The P4P program is designed for qualified energy conservation projects in facilities whose demand in any of the preceding 12 months exceeds 200 kW. Facilities that meet this criterion must also achieve a minimum performance target of 15% by using the EPA Portfolio Manager benchmarking tool before and after construction. Incentives for this program are in three parts. Incentive #1 energy reduction plan pays \$0.05 per square foot to a maximum of \$25,000 or 50% of facility annual energy cost paid after approval of application. Incentive #2 is paid after installation of recommended measures; base incentives deliver \$0.11/kWh and \$1.10/therm not to exceed 30% of total project cost. Incentive #3 post-construction benchmarking is paid after acceptance of a report proving energy savings over one year utilizing the EPA Portfolio Manager benchmarking tool. Incentive #3 base incentives deliver \$0.07/ kWh and \$0.70/therm not to exceed 20% of total project cost. Combining incentives #2 and #3 will provide a total of \$0.18/ kWh and \$1.8/therm not to exceed 50% of total project cost. Additional incentives for #2 and #3 are increased by \$0.005/kWh and \$0.05/therm for each percentage increase above minimum performance target calculated with the EPA Portfolio Manager benchmarking tool not to exceed 50% of total project cost.

A new incentive structure is in place for projects exceeding 20% in energy savings, which doubles incentives #2 and #3 for a total of \$0.36/kWh and \$3.60/therm. For Incentive #1, the maximum incentive has been raised to 80% of project costs, or \$2 million per gas account and \$2 million per electric account. The 200 kW/month average minimum has been waived for buildings owned by local governments or municipalities and non-profit organizations. This new incentive structure has been extended to December 31, 2010.

Specific incentives for energy conservation measures were calculated on an individual basis utilizing the 2009 New Jersey Smart Start incentive program. This program provides incentives dependent upon mechanical and electrical equipment. If applicable, incentives from this program are reflected in the ECM summaries and attached appendices. If the building qualifies and enters into the New Jersey Pay for Performance Program, all energy savings will be included in the total building energy usage and savings to be applied towards the Pay for Performance incentive. A project is not applicable for incentives in both programs.

5.2 Building Incentives

The Springfield Township municipal building is eligible for several incentives available under New Jersey Smart Start Programs. The total amount of all qualified incentives is about \$1,400 and includes installing boiler replacement, DHW heater replacement, and upgrades to the lighting system.

When calculating the total incentive for the New Jersey Pay for Performance program, for all ECMs presented in this report all energy conservation measures are applicable as the amount received is based on building wide energy improvements. Since the overall energy reduction for the building is estimated to exceed the 15% minimum, the building is eligible for Incentives #2 and #3 as previously discussed. This would result in a total incentive of about \$12,451, reducing the total project payback from 7.1 years to 5.3 years. See Appendix L for calculations.

When calculating the total incentive for the New Jersey Pay for Performance program for only the recommended energy conservation measures all energy conservation measures are applicable as the amount received is based on building wide energy improvements. Since the overall energy reduction for

the building is estimated to exceed the 15% minimum, the building is eligible for Incentives #2 and #3 as previously discussed. This would result in a total incentive of about \$9,677, reducing the total project payback from 4.1 years to 2.4 years. See Appendix L for calculations.

6.0 ALTERNATIVE ENERGY SCREENING EVALUATION

6.1 Geothermal

Geothermal heat pumps (GHP) transfer heat between the constant temperature of the earth and the building to maintain the building's interior space conditions. Below the surface of the earth throughout New Jersey the temperature remains in the low 50°F range throughout the year. This stable temperature provides a source for heat in the winter and a means to reject excess heat in the summer. With GHP systems, water is circulated between the building and the piping buried in the ground. The ground heat exchanger in a GHP system is made up of a closed or open loop pipe system. Most common is the closed loop in which high density polyethylene pipe is buried horizontally at 4-6 feet deep or vertically at 100 to 400 feet deep. These pipes are filled with an environmentally friendly antifreeze/water solution that acts as a heat exchanger. In the summer, the water picks up heat from the building and moves it to the ground. In the winter the system reverses and fluid picks up heat from the ground and moves it to the building. Heat pumps make collection and transfer of this heat to and from the building possible.

The municipal building has one original 245,000 Btu natural gas fired Weil McLain boiler distributing hot water to heating coils in three air handling units, (7) unit ventilators, and one cabinet heater. Cooling is provided by (3) four ton condensing units serving DX coils inside each air handler. The exterior offices also have DX units in each unit ventilator to provide additional cooling. One window unit serves in the police department and is only utilized during the hottest days. To take advantage of a GHP system, the building would have to install a low temperature closed loop water source heat pump system to realize the benefit of the consistent temperature of the ground. This will also include removal of the existing heating and cooling system.

This measure is not recommended due to the high cost to replace the existing systems.

6.2 Solar

6.2.1 Photovoltaic Rooftop Solar Power Generation

The building was evaluated for the potential to install rooftop photovoltaic (PV) solar panels for power generation. Present technology incorporates the use of solar cell arrays that produce direct current (DC) electricity. This DC current is converted to alternating current (AC) with the use of an electrical device known as an inverter. The building's roof has sufficient room to install a large solar cell array. A structural analysis would be required to determine if the roof framing could support a cell array.

The PVWATTS solar power generation model was utilized to calculate PV power generation. The New Jersey Clean Power Estimator provided by the New Jersey Clean Energy Program is presently being updated; therefore, the site recommended use of the PVWAT solar grid analyzer version 1. The closest city available in the model is Newark, New Jersey and a fixed tilt array type was utilized to calculate energy production. The PVWAT solar power generation model is provided in Appendix K.

The State of New Jersey incentives for non-residential PV applications is \$1.00/watt up to 50 kW of installed PV array. Federal tax credits are also available for renewable energy projects up to 30% of installation cost. Municipalities do not pay federal taxes; therefore, would not be able to utilize the federal tax credit incentive.

Installation of (PV) arrays in the state New Jersey will allow the owner to participate in the New Jersey solar renewable energy certificates program (SREC). This is a program that has been set up to allow

entities with large amounts of environmentally unfriendly emissions to purchase credits from zero emission (PV) solar-producers. An alternative compliance penalty (ACP) is paid for by the high emission producers and is set each year on a declining scale of 3% per year. One SREC credit is equivalent to 1000 kilowatt hours of PV electrical production; these credits can be traded for period of 15 years from the date of installation. The cost of the ACP penalty for 2009 is \$689; this is the amount that must be paid per SERC by the high emission producers. The expected dollar amount that will be paid to the PV producer for 2009 is expected to be \$600/SREC credit. Payments that will be received from the PV producer will change from year to year dependent upon supply and demand. Renewable Energy Consultants is a third party SREC broker that has been approved by the New Jersey Clean Energy Program. As stated above there is no definitive way to calculate an exact price that will be received by the PV producer per SREC over the next 15 years. Renewable Energy Consultants estimated an average of \$487/ SERC per year and this number was utilized in the cash flow for this report.

The municipal building has a maximum kW demand of 25.2 kW and a minimum kW of 17.2 kW over the previous 12 months. The monthly average over the observed 12 month period was 20.9 kW. The facility's existing load should justify the use of 20 kW of installed PV solar array; therefore, a 20 kW system size was selected for the calculations. The system costs for PV installations were derived from the most recent NYSERDA (New York State Energy Research and Development Agency) estimates of total cost of system installation. It should be noted that the cost of installation is currently \$10 per watt or \$10,000 per kW of installed system. This has increased in the past few years due to the rise in national demand for PV power generator systems. Other cost considerations will also need to be considered. PV panels have an approximate 20 year life span; however, the inverter device that converts DC electricity to AC has a life span of 10 to 12 years and will need to be replaced multiple times during the useful life of the PV system.

ECM-6.2.1 Photovoltaic (PV) Rooftop Solar Power Generation – 20 kW System

| Budgetary Cost | Annual Utility Savings | | | | Total Savings | New Jersey Renewable Energy Incentive* | New Jersey Renewable SREC** | Payback (without incentive) | Payback (with incentives) |
|-------------------|------------------------|--------|-------------|-------|------------------|--|--------------------------------------|-----------------------------------|---------------------------------|
| | Electricity | | Natural Gas | Total | | | | | |
| \$ | kW | kWh | Therms | \$ | \$ | \$ | \$ | Years | Years |
| 200,000 | 0 | 23,660 | 0 | 4,100 | 4,100 | 20,000 | 11,500 | >25 | 11.5 |

*Incentive based on New Jersey Renewable Energy Program for non-residential applications of \$1.00 per Watt of installed capacity

** Estimated Solar Renewable Energy Certificate Program (SREC) for 15 years at \$487/1000 kWh

This measure is not recommended at this time due to the long payback period; however it could be a potentially viable renewable measure to be considered in the future if electricity rates continue to increase and if PV installation costs decline below \$10 per watt.

6.2.2 Solar Thermal Domestic Hot Water Plant

Active solar thermal systems use solar collectors to gather the sun's energy to heat water, another fluid, or air. An absorber in the collector converts the sun's energy into heat. The heat is then transferred by circulating water, antifreeze, or sometimes air to another location for immediate use or storage for later utilization. Applications for active solar thermal energy include providing hot water, heating swimming pools, space heating, and preheating air in residential and commercial buildings.

A standard solar hot water system is typically composed of solar collectors, heat storage vessel, piping, circulators, and controls. Systems are typically integrated to work alongside a conventional heating system that provides heat when solar resources are not sufficient. The solar collectors are usually placed

on the roof of the building, oriented south, and tilted around the site’s latitude, to maximize the amount of radiation collected on a yearly basis.

Several options exist for using active solar thermal systems for space heating. The most common method involves using glazed collectors to heat a liquid held in a storage tank (similar to an active solar hot water system). The most practical system for Springfield Municipal Building would transfer the heat from the panels to thermal storage tanks and transfer solar produced thermal energy to use for domestic hot water production.

As of the writing of this report, there are no incentives available for installation of thermal solar systems. Presently there is a Federal tax credit of 30% of installation cost for the thermal applications, however the Township of Springfield does not pay Federal taxes and, therefore, would not benefit from this program.

The implementation cost and savings related to this ECM are presented in Appendix L and summarized below:

ECM-6.2.2 Solar Thermal Domestic Hot Water Plant

| Budgetary | Annual Utility Savings | | | | Total Savings | New Jersey Renewable Energy Incentive | Payback (without incentive) | Payback (with incentive) |
|-----------|------------------------|-------|-------------|-------|---------------|---------------------------------------|-----------------------------|--------------------------|
| | Electricity | | Natural Gas | Total | | | | |
| Cost | kW | kWh | Therms | \$ | \$ | \$ | Years | Years |
| 27,100 | 0 | 1,280 | 0 | 200 | 200 | NA | >25 | NA |

* No incentive is available in New Jersey at this time.

This measure is not recommended.

6.3 Wind

Small wind turbines use a horizontal axis propeller, or rotor, to capture the kinetic energy of the wind and convert it into rotary motion to drive a generator which usually is designed specifically for the wind turbine. The rotor consists of two or three blades, usually made from wood or fiberglass. These materials give the turbine the needed strength and flexibility, and have the added advantage of not interfering with television signals. The structural backbone of the wind turbine is the mainframe, and includes the slip-rings that connect the wind turbine, which rotates as it points into changing wind directions, and the fixed tower wiring. The tail aligns the rotor into the wind.

To avoid turbulence and capture greater wind energy, turbines are mounted on towers. Turbines should be mounted at least 30 feet above any structure or natural feature within 300 feet of the installation. Smaller turbines can utilize shorter towers. For example, a 250-watt turbine may be mounted on a 30-50 foot tower, while a 10 kW turbine will usually need a tower of 80-120 feet. Tower designs include tubular or latticed, guyed or self-supporting. Wind turbine manufacturers also provide towers.

The New Jersey Clean Energy Program for small wind installations has designated numerous pre-approved wind turbines for installation in the State of New Jersey. Incentives for wind turbine installations are based on kilowatt hours saved in the first year. Systems sized under 16,000 kWh per year of production will receive a \$3.20 per kWh incentive. Systems producing over 16,000 kWh will receive \$51,200 for the first 16,000 kWh of production with an additional \$0.50 per kWh up to a maximum cap of 750,000 kWh per year. Federal tax credits are also available for renewable energy projects up to 30%

of installation cost for systems less than 100 kW. However, as noted previously, municipalities do not pay federal taxes and is, therefore, not eligible for the tax credit incentive.

The most important part of any small wind generation project is the mean annual wind speed at the height of which the turbine will be installed. In the Springfield New Jersey area, the map indicates a mean annual wind speed of below 10 miles per hour. For the building, there are site restrictions. Parking lots, radio communication towers, trees, and local residential housing would greatly affect a tower location.

An aerial satellite image of the municipal site and wind speed map is included in Appendix M.

This measure is not recommended due to the low mean annual wind speed.

6.4 Combined Heat and Power Generation (CHP)

Combined heat and power, cogeneration, is self-production of electricity on-site with beneficial recovery of the heat byproduct from the electrical generator. Common CHP equipment includes reciprocating engine-driven, micro turbines, steam turbines, and fuel cells. Typical CHP customers include industrial, commercial, institutional, educational institutions, and multifamily residential facilities. CHP systems that are commercially viable at the present time are sized approximately 50 kW and above, with numerous options in blocks grouped around 300 kW, 800 kW, 1,200 kW and larger. Typically, CHP systems are used to produce a portion of the electricity needed by a facility some or all of the time, with the balance of electric needs satisfied by purchase from the grid.

Any proposed CHP project will need to consider many factors, such as existing system load, use of thermal energy produced, system size, natural gas fuel availability, and proposed plant location.

The building has sufficient need for electrical generation and the ability to use most of the thermal byproduct during the winter. Thermal usage during the summer months is low, and thermal energy produced by the CHP plant will be wasted. An absorption chiller could be installed to utilize the heat to produce chilled water; however, there is no chilled water distribution system in the building.

The most viable option for a CHP plant would be a reciprocating engine natural gas-fired unit. However, since the building is located in a residential area, noise may be an issue.

This measure is not recommended due to not having access to use of summertime heat that will be produced by the cogeneration system.

6.5 Biomass Power Generation

Biomass power generation is a process in which waste organic materials are used to produce electricity or thermal energy. These materials would otherwise be sent to the landfill or expelled to the atmosphere. To participate in NJCEP's Customer On-Site Renewable Energy program, participants must install an on-site sustainable biomass or fuel cell energy generation system. Incentives for bio-power installations are available to support up to 1MW-dc of rated capacity.

*Class I organic residues are eligible for funding through the NJCEP CORE program. Class I wastes include the following renewable supply of organic material:
Wood wastes not adulterated with chemicals, glues or adhesives

Agricultural residues (corn stover, rice hulls or nut shells, manures, poultry litter, horse manure, etc) and/or methane gases from landfills

Food wastes

Municipal tree trimming and grass clipping wastes

Paper and cardboard wastes

Non adulterated construction wood wastes, pallets

The NJDEP evaluates biomass resources not identified in the RPS.

Examples of eligible facilities for a CORE incentive include:

Digestion of sewage sludge

Landfill gas facilities

Combustion of wood wastes to steam turbine

Gasification of wood wastes to reciprocating engine

Gasification or pyrolysis of bio-solid wastes to generation equipment

* from NJOCE Website

This measure is not recommended because the site does not have room to store the waste organic materials, noise issues, and potential emission and zoning issues.

6.6 Demand Response Curtailment

Presently, the municipal building's electricity is delivered and supplied by PSE&G. Utility curtailment is an agreement with the regional transmission organization and an approved Curtailment Service Providers (CSP) to shed electrical load by either turning major equipment off or energizing all or part of a facility utilizing an emergency generator, therefore reducing the electrical demand on the utility grid. This program is to benefit the utility company during high demand periods and PSE&G offers incentives to the CSP to participate in this program. Enrolling in the program will require program participants to drop electrical load or turn on their emergency generators during high electrical demand conditions or during emergencies. Part of the program also will require that program participants reduce their required load or run their emergency generators with notice to test the system. A minimum of 100 kW of curtailable load is required to enter the program. Discussions with the EnerNoc Corporation, an approved CSP, indicate that most if not all existing emergency generators will not pass the emissions requirements to enter the NJ program.

Presently, the municipal building has an average kW during the observed period of 20.9 kW per month well below the 100 kW minimum requested by CSP organizations. The bulk of the electricity usage is needed during any request to reduce electrical load.

This is not recommended because the building load cannot be substantially reduced during a planned Demand Response Curtailment event.

7.0 EPA PORTFOLIO MANAGER

The United State Energy Protection Agency (EPA) is a federal agency in charge of regulating environment waste and policy in the United States. The EPA has released the EPA Portfolio Manager for public use. The program is designed to allow property owners and managers to share, compare and improve upon their facility's energy consumption. Inputting such parameters as electricity, heating fuel, building characteristics and location into the website based program generates a naturalized energy rating score out of 100. Once an account is registered, monthly utility data can be entered to track the savings progress and retrieve an updated energy rating score on a monthly basis.

The building includes office areas. Since more than 10% of the space is Other (i.e., Police Department), the building does not fall under the listed space description categories needed to generate a full report and provide an energy star rating. The portfolio manager provided an Energy Use Intensity (EUI) rating of 96 kBtu/ft².

The building's performance, however, can be compared to national EUI averages. With an EUI of 96 kBTU/ft²/year, the building is considered a moderate energy consumer per the Portfolio Manager. Reducing energy loss associated will result in a more favorable score. If all the measures recommended in this report are fully implemented, it is projected that EUI of 66 kBTU/ft²/year can be obtained. The national average for buildings of similar type is 90.

A full EPA Energy Star Portfolio Manager Report is located in Appendix N.

The user name and password for the municipal building's EPA Portfolio Manager Account has been provided to Paul Keller of Springfield Township.

8.0 CONCLUSIONS & RECOMMENDATIONS

The energy audit conducted by CHA at the Springfield Township municipal building in Jobstown, New Jersey identified potential ECMs for lighting replacement with occupancy sensors, door seal replacement, night setback, demand control ventilation, and domestic hot water heater replacement. Potential annual savings of \$5,800 may be realized for the recommended ECMs, with a summary of the costs, savings, and paybacks as follows:

ECM-3 Combined Lighting Replacements with Occupancy Sensors

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|----------------|------------------------|-------|-------------|-------|-----|----------------------|-----------------------------|--------------------------|
| | Electricity | | Natural Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 10,200 | 4.4 | 8,220 | 0 | 1,800 | 1.6 | 900 | 5.7 | 5.2 |

* Incentive shown is per the New Jersey Smart Start program's Prescriptive Lighting and Lighting Controls Applications.

ECM-4 Install Door Seals

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|----------------|------------------------|-----|-------------|-------|-----|----------------------|-----------------------------|--------------------------|
| | Electricity | | Natural Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 700 | 0 | 30 | 70 | 100 | 0.3 | NA | 7.0 | NA |

* There is no incentive available through the New Jersey Smart Start program for this ECM.

ECM-6 Night Setback

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|----------------|------------------------|-----|-------------|-------|-----|----------------------|-----------------------------|--------------------------|
| | Electricity | | Natural Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 2,000 | 0 | 280 | 630 | 800 | 5.2 | NA | 2.5 | NA |

* There is no incentive available through the New Jersey Smart Start program for this ECM.

ECM - 8 Replace Domestic Hot Water Heater

| Budgetary Cost | Annual Utility Savings | | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|----------------|------------------------|-------|-------------|-------|-----|----------------------|-----------------------------|--------------------------|
| | Electricity | | Natural Gas | Total | | | | |
| \$ | kW | kWh | Therms | \$ | | \$ | Years | Years |
| 3,800 | 9 | 2,000 | (40) | 1,800 | 8.6 | 50 | 2.1 | 2.0 |

* Incentive shown is per the New Jersey Smart Start program's Gas Water Heating Application.

ECM-9 Demand Control Ventilation

| Budgetary Cost | Annual Utility Savings | | | ROI | Potential Incentive* | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|-------|-------------|-------|-------------------------|--------------------------------|-----------------------------|
| | Electricity | | Natural Gas | | | | |
| \$ | kW | kWh | Therms | \$ | \$ | Years | Years |
| 7,100 | 0 | 1,000 | 900 | 1,300 | 1.7 | NA | 5.6 |

* There is no incentive available through the New Jersey Smart Start program for this ECM.

APPENDIX A


Utility Usage Analysis

New Jersey BPU Energy Audit Program
 CHA Project No.: 20812
 Town of Springfield
 PSE&G - Electric Service


Town Hall - 2159 Jobstown Road.
 Account No.: 66 996 794 02
 Meter No.: 728001095

| Month | Charges | | | Unit Costs | | |
|----------------|-------------|-------------|------------------|-----------------------|----------------------|----------------|
| | Total (\$) | Demand (\$) | Consumption (\$) | Blended Rate (\$/kWh) | Consumption (\$/kWh) | Demand (\$/kW) |
| October-08 | \$1,027.18 | \$228.56 | \$798.62 | 0.1712 | 0.1331 | 10.39 |
| November-08 | \$905.28 | \$218.89 | \$686.40 | 0.1489 | 0.1129 | 11.64 |
| December-08 | \$883.85 | \$215.53 | \$668.32 | 0.1454 | 0.1099 | 12.53 |
| January-09 | \$902.26 | \$242.37 | \$659.89 | 0.1465 | 0.1071 | 11.65 |
| February-09 | \$941.12 | \$255.46 | \$685.66 | 0.2905 | 0.2116 | 11.40 |
| March-09 | \$928.12 | \$236.63 | \$691.49 | 0.1578 | 0.1176 | 10.76 |
| April-09 | \$1,042.61 | \$260.39 | \$782.22 | 0.1473 | 0.1105 | 14.47 |
| May-09 | \$902.00 | \$243.39 | \$658.61 | 0.1545 | 0.1128 | 11.08 |
| June-09 | \$1,119.45 | \$404.97 | \$714.48 | 0.1738 | 0.1109 | 23.54 |
| July-09 | \$1,233.82 | \$432.36 | \$801.46 | 0.2043 | 0.1327 | 20.79 |
| August-09 | \$1,534.24 | \$532.36 | \$1,001.86 | 0.2019 | 0.1318 | 21.13 |
| September-09 | \$1,451.38 | \$513.82 | \$937.56 | 0.2027 | 0.1309 | 21.06 |
| Most Recent Yr | \$12,871.31 | \$3,784.74 | \$9,086.57 | 0.1749 | 0.1235 | 15.09 |

Township of Springfield Municipal Building Electric Consumption



Township of Springfield Municipal Building Electric Demand




New Jersey BPU Energy Audit Program
CHA Project No.: 20812
Town of Springfield
PSE&G - Natural Gas Service

Town Hall - 2159 Jobstown Road.
Account No.: 66 986 794 02
Meter No.: 3152283

| Month | Therms | Charges (\$) | (\$/Therm) |
|-----------------------|--------------|--------------|--------------|
| October-08 | 12 | 26.17 | 2.274 |
| November-08 | 106 | 159.92 | 1.515 |
| December-08 | 300 | 406.13 | 1.352 |
| January-09 | 404 | 563.33 | 1.394 |
| February-09 | 566 | 742.18 | 1.311 |
| March-09 | 466 | 539.26 | 1.157 |
| April-09 | 445 | 446.63 | 1.003 |
| May-09 | 184 | 176.43 | 0.961 |
| June-09 | 30 | 36.59 | 1.215 |
| July-09 | 7 | 16.66 | 2.282 |
| August-09 | 0 | 10.12 | |
| September-09 | 19 | 26.53 | 1.414 |
| Most Recent Yr | 2,539 | 3,150 | 1.241 |

Township of Springfield Municipal Building Natural Gas Consumption



ELECTRIC MARKETERS LIST

The following is a listing of marketers/suppliers/brokers that have been licensed by the NJ Board of Public Utilities to sell electricity to residential, small commercial and industrial customers served by the Public Service Electric and Gas Company distribution system. **This listing is provided for informational purposes only and PSE&G makes no representations or warranties as to the competencies of the entities listed herein or to the completeness of this listing.**

American Powernet Management
867 Berkshire Blvd, Suite 101
Wyomissing, PA 19610
www.americanpowernet.com

Gerdau Ameristeel Energy Co.
North Crossman Road
Sayreville, NJ 08872

PPL EnergyPlus, LLC
Energy Marketing Center
Two North Ninth Street
Allentown, PA 18101
1-866-505-8825
<http://www.pplenergyplus.com>

BOC Energy Services
575 Mountain Avenue
Murray Hill, NJ 07974
www.boc-gas.com

Gesa Energy LLC New Jersey
20 Greenway Plaza, Suite 600
Houston, TX 77046
(866) 304-GEXA
Both_inflor@gesaenergy.com

Sempra Energy Solutions
The Mac-Cali Building
581 Main Street, 8th Floor
Woodbridge, NJ 07095
(877) 273-6772
www.SempraSolutions.com

Commerce Energy Inc.
535 Route 38, Suite 138
Cherry Hill, NJ 08002
(888) 817-8572 or
(858) 910-8099
www.commerceenergy.com

Glacial Energy of New Jersey
2602 McKinney Avenue, Suite 220
Dallas, TX 75204
www.glacialenergy.com

South Jersey Energy Company
1 South Jersey Plaza, Route 54
Folsom, NJ 08037
(800) 756-3749
www.sjenergy.com

Confidion Solutions
701 Westchester Avenue
Suite 201 West
White Plains, NY 10604
(800) 316-8011
www.ConfidSolutions.com

Hess Corporation
1 Hess Plaza
Woodbridge, NJ 07095
www.hess.com

Strategic Energy, LLC
6 East Main Street, Suite 6E
Ramsey, NJ 07446
(888) 925-9115
www.sel.com

Constellation NewEnergy, Inc.
1199 Route 22 East
Mountainside, NJ 07092
908 228-5100
www.constellation.com

Integrus Energy Services, Inc
99 Wood Avenue, Suite 802
Iselin, NJ 08830
www.integrusenergy.com

Suez Energy Resources NA
333 Thornall Street FL6
Edison, NJ 08818
866.999.8374 (toll free)
www.suezenergyresources.com

Credit Suisse (USA), Inc.
700 Collage Road East
Princeton, NJ 08450
www.uscredituisse.com

Liberty Power Delaware, LLC
1901 W Cypress Road, Suite 600
Fort Lauderdale, FL 33309
(866) Power-99
(866) 769-3799
www.libertypower.com

UGI Energy Services, Inc.
d/b/a POWERMARK
1 Meridian Blvd, Suite 2C01
Wyomissing, PA 19610
(800) 427-8545
www.ugieneryservices.com

Direct Energy Services, LLC
One Gateway Center, Suite 2600
Newark, NJ 07102
(973) 799-8568
www.directenergy.com

Liberty Power Holdings, LLC
1901 W Cypress Creek Road, Suite 600
Fort Lauderdale, FL 33309
(866) Power-99
(866) 769-3799
www.libertypower.com

FirstEnergy Solutions
395 Ghent Road Suite 407
Akron, OH 44333
(800) 977-0500
www.fes.com

Pepco Energy Services, Inc.
d/b/a Power Choice
23 S. Kinderkamack Rd Ste D
Montvale, NJ 07645
(800) 363-7499
www.pepco-services.com

GAS MARKETERS LIST

The following is a listing of marketers/suppliers/brokers that have been licensed by the NJ Board of Public Utilities to sell natural gas to residential, small commercial and industrial customers served by the Public Service Electric and Gas Company distribution system. **This listing is provided for informational purposes only and PSE&G makes no representations or warranties as to the competencies of the entities listed herein or to the completeness of this listing.**

Gateway Energy Services
44 Whispering Pines Lane
Lakewood, NJ 08701
(800) 805-8586
www.gesec.com

Metro Energy Group, LLC
14 Washington Place
Hackensack, NJ 07601
www.metroenergy.com

RPL Holdings, Inc
601 Carlson Pkwy
Minnetonka, MN 55305

Great Eastern Energy
3044 Coney Island Ave. PH
Brooklyn, NY 11235
888-651-4121
www.gevillcbeaternrgas.com

Metromedia Energy, Inc.
6 Industrial Way
Eatontown, NJ 07724
(800) 828-9427
www.metromediaenergy.com

South Jersey Energy Company
One South Jersey Plaza, Rte 54
Folsom, NJ 08037
(800) 756-3749
www.sjenergy.com/sje.htm

Hess Corporation
1 Hess Plaza
Woodbridge, NJ 07095
(800) 437-7872
www.hess.com

Mitchell- Supreme Fuel
(NATGASCO)
532 Freeman Street
Orange, NJ 07050
(800) 840-4GAS
www.mitchellsupreme.com

Sprague Energy Corp.
Two International Drive, Ste 200
Portsmouth, NH 03801
800-225-1560
www.spragueenergy.com

Hudson Energy Services, LLC
545 Route 17 South
Ridgewood, NJ 07450
(201) 251-2400
www.hudsonenergyservices.com

MxEnergy Inc.
P.O. Box 177
Annapolis Junction, MD 20701
800-375-1277
www.mxenergy.com

Stuyvesant Energy LLC
642 Southern Boulevard
Bronx, NY 10455
(718) 665-5700
www.stuyfuel.com

Intelligent Energy
7001 SW 24th Avenue
Gainesville, FL 32607
Sales: 1 877 I've Got Gas
(1 877 483-4684)
Customer Service:
1 800 927-9794
www.intelligentenergy.org

Pepeo Energy Services, Inc.
23 S Kinderkamack Rd, Suite D
Montvale, NJ 07645
(800) 363-7499
www.pepeo-services.com

Tiger Natural Gas, Inc.
1422 E. 71st Street, Suite J.
Tulsa, OK 74136
1-888-875-6122
www.tigernaturalgas.com

System Energy
877-SYSTRUM
(877-797-8786)
www.systemenergy.com

Plymouth Rock Energy, LLC
165 Remsen Street
Brooklyn, NJ 11201
866-539-6450
www.plymouthrockenergy.com

UGI Energy Services, Inc.
d/b/a GASMARK
704 E. Main Street, Suite 1
Moorestown, NJ 08057
856-273-9995
www.ugienergyservices.com

Macquarie Cook Energy, LLC
10100 Santa Monica Blvd, 18th
Fl
Los Angeles, CA 90067

PPL EnergyPlus, LLC
Energy Marketing Center
Two North Ninth Street
Allentown, PA 18101
1-866-505-8825
www.pplenergyplus.com/naturalgas

Woodruff Energy
73 Water Street
P.O. Box 777
Bridgeton, NJ 08302
(856) 455-1111
www.woodruffenergy.com

APPENDIX B

ECM-1 Lighting Replacements



APPENDIX C

ECM-2 Install Occupancy Sensors



APPENDIX D

**ECM-3 Lighting Replacements
And Occupancy Sensors**



APPENDIX E

ECM-4 Install Door Seals



APPENDIX F

ECM-5 Replace Windows



APPENDIX G

ECM-6 Night Setback Controls



Kaibito Energy Audit Program

CUA Project No. 20812

Building: Springfield Elementary Building

Audit Program:

Compliance with Title 24, Part 6.100

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

Energy Code:

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

100%

HEAT GAIN/LOSS WORKSHEET

Project Name: _____ Project No: _____ (Year) _____
 Location: _____ Date: _____
 Building Name: _____
 Building Address: _____

Building Height: _____
 Outdoor Winter Design DB Temperature: _____ °F
 Outdoor Summer Design DB Temperature: _____ °F
 Outdoor Summer Design WB Temperature: _____ °F
 Outdoor Summer Humidity Ratio: _____
 Indoor Winter Design DB Temperature: _____ °F
 Indoor Summer Design DB Temperature: _____ °F
 Indoor Summer Design WB Temperature: _____ °F
 Indoor RH (RH) Humidity Ratio: _____

EXCELLENCE DESCRIPTIONS (See comments on form return to Division)

Walls (Area: 202, 774 SF)

| Description | R Value | U-Factor | Area (SF) |
|---|---------|----------|-----------|
| 1.00" Concrete Block | 8.0 | 0.125 | 100 |
| 2.00" Concrete Block | 16.0 | 0.0625 | 100 |
| 1.00" Brick, 1/2" Gypsum 1/2" Insulation, Exterior Finish | 5.1 | 0.196 | 100 |
| 2.00" Brick, 1/2" Gypsum 1/2" Insulation, Exterior Finish | 10.2 | 0.098 | 100 |
| 1.00" Brick, 1/2" Gypsum, 2" RSI, 1/2" Face Brick | 11.3 | 0.088 | 100 |
| 1.00" Brick, 1/2" Gypsum, 2" RSI, 1/2" Face Brick | 11.3 | 0.088 | 100 |
| 1.00" Brick, 1/2" Gypsum, 2" RSI, 1/2" Face Brick | 11.3 | 0.088 | 100 |
| 1.00" Brick, 1/2" Gypsum, 2" RSI, 1/2" Face Brick | 11.3 | 0.088 | 100 |

Roofs (Area: 202, 774 SF)

| Description | R Value | U-Factor | Area (SF) |
|--|---------|----------|-----------|
| 1.00" Concrete Slab | 4.0 | 0.25 | 100 |
| 2.00" Concrete Slab | 8.0 | 0.125 | 100 |
| 1.00" Concrete Slab, 1/2" Gypsum, 1/2" Insulation, 1/2" Gypsum | 10.0 | 0.10 | 100 |
| 2.00" Concrete Slab, 1/2" Gypsum, 1/2" Insulation, 1/2" Gypsum | 20.0 | 0.05 | 100 |
| 1.00" Concrete Slab, 1/2" Gypsum, 1/2" Insulation, 1/2" Gypsum | 10.0 | 0.10 | 100 |
| 2.00" Concrete Slab, 1/2" Gypsum, 1/2" Insulation, 1/2" Gypsum | 20.0 | 0.05 | 100 |
| 1.00" Concrete Slab, 1/2" Gypsum, 1/2" Insulation, 1/2" Gypsum | 10.0 | 0.10 | 100 |
| 2.00" Concrete Slab, 1/2" Gypsum, 1/2" Insulation, 1/2" Gypsum | 20.0 | 0.05 | 100 |

Windows (Area: 202, 774 SF)

| Description | R Value | U-Factor | Area (SF) |
|---|---------|----------|-----------|
| 1.00" Single Glazed | 0.9 | 1.11 | 100 |
| 2.00" Double Glazed | 1.8 | 0.56 | 100 |
| 3.00" Triple Glazed | 2.7 | 0.37 | 100 |
| 1.00" Single Glazed, 1/2" Insulation, 1/2" Gypsum | 15.4 | 0.065 | 100 |
| 2.00" Double Glazed, 1/2" Insulation, 1/2" Gypsum | 16.5 | 0.061 | 100 |
| 3.00" Triple Glazed, 1/2" Insulation, 1/2" Gypsum | 17.7 | 0.056 | 100 |
| 1.00" Single Glazed, 1/2" Insulation, 1/2" Gypsum | 15.4 | 0.065 | 100 |
| 2.00" Double Glazed, 1/2" Insulation, 1/2" Gypsum | 16.5 | 0.061 | 100 |
| 3.00" Triple Glazed, 1/2" Insulation, 1/2" Gypsum | 17.7 | 0.056 | 100 |

| Window Type | U-Factor | SHGC | Visible Transmittance |
|---|----------|------|-----------------------|
| 1.00" Single Glazed | 1.10 | 0.76 | 0.86 |
| 2.00" Double Glazed | 0.55 | 0.64 | 0.76 |
| 3.00" Triple Glazed | 0.35 | 0.54 | 0.64 |
| 1.00" Single Glazed, 1/2" Insulation, 1/2" Gypsum | 0.065 | 0.16 | 0.32 |
| 2.00" Double Glazed, 1/2" Insulation, 1/2" Gypsum | 0.061 | 0.16 | 0.32 |
| 3.00" Triple Glazed, 1/2" Insulation, 1/2" Gypsum | 0.056 | 0.16 | 0.32 |

Subtotal: _____
 Total Area: _____
 Occupied Area: _____
 Service Floor: _____

| Area | Area (SF) | Average Window Height | Window Height | Window Area | Wall Area | Net Wall Area | Net Wall Area Above Ceiling |
|----------------|-----------|-----------------------|---------------|-------------|-----------|---------------|-----------------------------|
| North Exposure | 100 | 7.0 | 7.0 | 700 | 100 | 100 | 100 |
| East Exposure | 100 | 7.0 | 7.0 | 700 | 100 | 100 | 100 |
| South Exposure | 100 | 7.0 | 7.0 | 700 | 100 | 100 | 100 |
| West Exposure | 100 | 7.0 | 7.0 | 700 | 100 | 100 | 100 |
| Roof | 202 | 12.0 | 12.0 | 2424 | 202 | 202 | 202 |
| Interior | 100 | 8.0 | 8.0 | 800 | 100 | 100 | 100 |
| Column | 100 | 8.0 | 8.0 | 800 | 100 | 100 | 100 |
| Ceiling | 100 | 8.0 | 8.0 | 800 | 100 | 100 | 100 |
| Partition | 100 | 8.0 | 8.0 | 800 | 100 | 100 | 100 |
| Floor | 100 | 8.0 | 8.0 | 800 | 100 | 100 | 100 |

COOLING RELOAD GAINS TO THE ROOM - SCHEDULE

WORKING

| Area | Area (SF) | Work | Working Load | Working Load (W/L) | Working Load (W/L) | Working Load (W/L) |
|----------------|-----------|------|--------------|--------------------|--------------------|--------------------|
| North Exposure | 100 | 100 | 100 | 100 | 100 | 100 |
| East Exposure | 100 | 100 | 100 | 100 | 100 | 100 |
| South Exposure | 100 | 100 | 100 | 100 | 100 | 100 |
| West Exposure | 100 | 100 | 100 | 100 | 100 | 100 |

CONNECTIONS

| Area | Area (SF) | U-Factor | Working Load (W/L) | Working Load (W/L) | Working Load (W/L) | Working Load (W/L) |
|----------------|-----------|----------|--------------------|--------------------|--------------------|--------------------|
| North Exposure | 100 | 0.10 | 100 | 100 | 100 | 100 |
| East Exposure | 100 | 0.10 | 100 | 100 | 100 | 100 |
| South Exposure | 100 | 0.10 | 100 | 100 | 100 | 100 |
| West Exposure | 100 | 0.10 | 100 | 100 | 100 | 100 |
| Roof | 202 | 0.05 | 202 | 202 | 202 | 202 |
| Partition | 100 | 0.10 | 100 | 100 | 100 | 100 |
| Column | 100 | 0.10 | 100 | 100 | 100 | 100 |
| Ceiling | 100 | 0.10 | 100 | 100 | 100 | 100 |
| Partition | 100 | 0.10 | 100 | 100 | 100 | 100 |
| Floor | 100 | 0.10 | 100 | 100 | 100 | 100 |

INTERNAL HEAT GAINS

| Area | Area (SF) | Light | Light (W/L) | Light (W/L) | Light (W/L) | Light (W/L) |
|----------------|-----------|-------|-------------|-------------|-------------|-------------|
| North Exposure | 100 | 100 | 100 | 100 | 100 | 100 |
| East Exposure | 100 | 100 | 100 | 100 | 100 | 100 |
| South Exposure | 100 | 100 | 100 | 100 | 100 | 100 |
| West Exposure | 100 | 100 | 100 | 100 | 100 | 100 |

VENTILATION AND INfiltration

| Area | Area (SF) | U-Factor | Working Load (W/L) | Working Load (W/L) | Working Load (W/L) | Working Load (W/L) |
|----------------|-----------|----------|--------------------|--------------------|--------------------|--------------------|
| North Exposure | 100 | 0.10 | 100 | 100 | 100 | 100 |
| East Exposure | 100 | 0.10 | 100 | 100 | 100 | 100 |
| South Exposure | 100 | 0.10 | 100 | 100 | 100 | 100 |
| West Exposure | 100 | 0.10 | 100 | 100 | 100 | 100 |

HEAT GAIN/LOSS WORKSHEET

Project Name: [REDACTED] Model No. [REDACTED] Date [REDACTED] Year [REDACTED] Monthly Interval [REDACTED]

Building/Zone Description: [REDACTED]

COOLING HEAT GAIN TO THE RA PLenum - Scenario 2

CONDITION

| | NET AREA (SQ FT) | U VALUE | Cooling Load Temp. Diff. | Result Air Flow (CFM) | Room Heat Gain |
|----------------|------------------|---------|--------------------------|-----------------------|----------------|
| West Exposure | 175 | 0.27 | 45 | 1.0 | 100 Btu/h |
| East Exposure | 180 | 0.27 | 45 | 1.0 | 100 Btu/h |
| South Exposure | 175 | 0.27 | 45 | 1.0 | 100 Btu/h |
| North Exposure | 180 | 0.27 | 45 | 1.0 | 100 Btu/h |
| Floor | 1,000 | 0.14 | 15 | 0.1 | 150 Btu/h |

INTERNAL HEAT GAIN

| | Light | People | Equipment | Other | Room Heat Gain |
|--------|---------------|-----------------|-------------------|---------------|-----------------|
| Light | 175,000 Btu/h | 1,000,000 Btu/h | 110,000,000 Btu/h | 775,000 Btu/h | 1,080,000 Btu/h |
| People | | | | | 100 Btu/h |

SCHEDULE HEAT GAIN - TEMPERATURE INDEPENDENT

| | Room Heat Gain |
|--------------------------|----------------|
| Door | 1,000 Btu/h |
| Conduction to Room | 1,000 Btu/h |
| Conduction to Plenum | 1,000 Btu/h |
| Windows and Infiltration | 1,000 Btu/h |
| Sub Total | 4,000 Btu/h |

SCHEDULE HEAT GAIN - TEMPERATURE DEPENDENT

| | Room Heat Gain |
|--------------------------|----------------|
| Internal Gains to Room | 1,000 Btu/h |
| Internal Gains to Plenum | 1,000 Btu/h |
| Sub Total | 2,000 Btu/h |

LATEST COOLING LOADS

| | Area | Internal Floor | Air Gaining | Humidity Ratio Diff. | Room Heat Gain |
|------------|--------------|----------------|-------------|----------------------|----------------|
| Walls | 4,000 sq ft | 0.14 (CFM) 560 | 4,000 | 0.004 (lb) | 560 Btu/h |
| Doors | 100 sq ft | 0.30 (CFM) 120 | 1,000 | 0.002 (lb) | 120 Btu/h |
| Windows | 100 sq ft | 0.30 (CFM) 120 | 1,000 | 0.004 (lb) | 120 Btu/h |
| Partitions | 1,000 sq ft | 0.14 (CFM) 560 | 4,000 | 0.002 (lb) | 560 Btu/h |
| Floor | 10,000 sq ft | 0.14 (CFM) 560 | 4,000 | 0.002 (lb) | 560 Btu/h |

Cooling Load Summary



| | Building Cooling Load | Internal Heat Gain | Total Cooling Load |
|-----------------------|-----------------------|--------------------|--------------------|
| Building Cooling Load | 5,000 Btu/h | 1,080,000 Btu/h | 1,085,000 Btu/h |

HEATING CALCULATION

CONDITION

| | NET AREA (SQ FT) | U VALUE | Heating Load Temp. Diff. | Result Air Flow (CFM) | Room Heat Gain |
|----------------|------------------|---------|--------------------------|-----------------------|----------------|
| West Exposure | 175 | 0.27 | 15 | 1.0 | 100 Btu/h |
| East Exposure | 180 | 0.27 | 15 | 1.0 | 100 Btu/h |
| South Exposure | 175 | 0.27 | 15 | 1.0 | 100 Btu/h |
| North Exposure | 180 | 0.27 | 15 | 1.0 | 100 Btu/h |
| Partitions | 100 | 0.05 | 15 | 0.1 | 15 Btu/h |
| Floor | 1,000 | 0.05 | 15 | 0.1 | 150 Btu/h |

INTERNAL HEAT GAIN

| | Light | People | Equipment | Other | Room Heat Gain |
|------------|---------------|-----------------|-------------------|---------------|-----------------|
| Light | 175,000 Btu/h | 1,000,000 Btu/h | 110,000,000 Btu/h | 775,000 Btu/h | 1,080,000 Btu/h |
| People | | | | | 100 Btu/h |
| Windows | | | | | 100 Btu/h |
| Partitions | | | | | 100 Btu/h |
| Floor | | | | | 100 Btu/h |

| | Building Heating Load | Internal Heat Gain | Total Heating Load |
|-----------------------|-----------------------|--------------------|--------------------|
| Building Heating Load | 1,085,000 Btu/h | 1,080,000 Btu/h | 2,165,000 Btu/h |

NJBPU Energy Audit Program
CHA Project No. 20812
Building: Springfield Municipal Building

Walls

| | Width (ft) | Height (ft) | Quantity | Area (SF) | Lineal Feet | |
|-------|------------|-------------|----------|-----------|-------------|---------------------|
| North | 107.0 | 12.0 | 1 | 1284.0 | 238.0 | |
| | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | 107.0 | | | 1284.0 | 238.0 | Ave. height 12.0 |

| | | | | | | |
|------|------|------|---|-------|-------|---------------------|
| East | 47.0 | 12.0 | 1 | 564.0 | 118.0 | |
| | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | 47.0 | | | 564.0 | 118.0 | Ave. height 12.0 |

| | | | | | | |
|-------|-------|------|---|--------|-------|---------------------|
| South | 107.0 | 12.0 | 1 | 1284.0 | 238.0 | |
| | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | 107.0 | | | 1284.0 | 238.0 | Ave. height 12.0 |

| | | | | | | |
|------|------|------|---|-------|-------|---------------------|
| West | 47.0 | 12.0 | 1 | 564.0 | 118.0 | |
| | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | 47.0 | | | 564.0 | 118.0 | Ave. height 12.0 |

Windows

| | Width (ft) | Height (ft) | Quantity | Area (SF) | Lineal Feet | |
|-------|------------|-------------|-----------|-----------|-------------|------|
| North | 3.0 | 4.0 | 3 | 36.0 | 42.0 | |
| | 3.0 | 1.5 | 1 | 4.5 | 9.0 | |
| | 1.5 | 3.0 | 2 | 9.0 | 18.0 | |
| | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | | | Sub-total | 6 | 49.5 | 69.0 |

| | | | | | | |
|------|--|--|-----------|-----|-----|-----|
| East | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | | | Sub-total | 0 | 0.0 | 0.0 |

| | | | | | | |
|-------|-----|-----|-----------|------|------|-------|
| South | 3.0 | 4.0 | 5 | 60.0 | 70.0 | |
| | 2.0 | 3.0 | 2 | 12.0 | 20.0 | |
| | 1.5 | 3.0 | 2 | 9.0 | 18.0 | |
| | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | | | Sub-total | 9 | 81.0 | 108.0 |

| | | | | | | |
|------|-----|-----|-----------|------|------|------|
| West | 3.0 | 4.0 | 1 | 12.0 | 14.0 | |
| | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | | | | 0.0 | 0.0 | |
| | | | Sub-total | 1 | 12.0 | 14.0 |

| | | | | | | | |
|--|--|--|--------------|-----------|--------------|--------------|---------------|
| | | | Total | 16 | 142.5 | 191.0 | LF/SF 1.34 |
|--|--|--|--------------|-----------|--------------|--------------|---------------|

APPENDIX H

ECM-7 Replace Boiler



NJBPU Energy Audit Program
CHA Project No. 20812
Springfield Municipal Building

ECM-7 Replace Boiler

| | |
|---------------|---|
| Existing Fuel | ▼ |
| Proposed Fuel | ▼ |

| Item | Value | Units | Formula/Comments |
|----------------------------------|----------|---------|--|
| Baseline Fuel Cost | \$ 1.24 | | |
| Proposed Fuel Cost | \$ 1.24 | | |
| Baseline Fuel Use | 2,539 | Therms | |
| Existing Boiler Plant Efficiency | 75% | | Based on calculated historical utility costs Estimated by Metermaid |
| Baseline Boiler Load | 190,492 | Mbtu/yr | Baseline Fuel Use x Existing Efficiency x 100 Mbtu/Therms |
| Baseline Fuel Cost | \$ 3,150 | | |
| Proposed Boiler Plant Efficiency | 92% | | New Boiler Efficiency |
| Proposed Fuel Use | 2,070 | Therms | Baseline Boiler Load / Proposed Efficiency / 100 Mbtu/Therms |
| Proposed Fuel Cost | \$ 2,568 | | |
| Annual Savings | 469 | Therms | |
| Annual Savings | \$ 582 | /yr | |

*Note to engineer: Link savings back to summary sheet in appropriate column.

NJBPU Energy Audit Program:
 CHA Project No. 20812
 Springfield Municipal Building

ECM-7 Replace Boiler

| Multipliers | |
|-------------|------|
| Material | 0.98 |
| Labor | 1.21 |
| Equipment | 1.03 |

| Description | QTY | UNIT | UNIT COSTS | | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS | | |
|--|-----|------|------------|-------|--------|----------------|-------|--------|------------|---------|-------|--|
| | | | MAT. | LABOR | EQUIP. | MAT. | LABOR | EQUIP. | | | | |
| New high efficiency boilers (194 mBh Condensing Boiler) | 1 | ea. | 3600 | \$ | - | \$ | 3,430 | \$ | - | \$ | 3,430 | Historical boiler cost Data from recent CHA installations |
| Boiler Flues | 1 | ls | \$ 300 | \$ | 150 | \$ | 294 | \$ | 182 | \$ | 476 | |
| Electrical | 1 | ls | \$ 500 | \$ | 350 | \$ | 490 | \$ | 424 | \$ | 914 | |
| Hot water/gas piping | 1 | ls | \$ 500 | \$ | 300 | \$ | 490 | \$ | 363 | \$ | 853 | |
| | | | | | | \$ | - | \$ | - | \$ | - | |

| | | |
|----|-------|--------------------|
| \$ | 5,672 | Subtotal |
| \$ | 567 | 10% Contingency |
| \$ | 936 | 15% Contractor O&P |
| \$ | - | 0% Engineering |
| \$ | 7,175 | Total |

| Description | QTY | UNIT | \$ / UNIT | TOTAL SAVINGS | COST W/O INCENTIVE | COST W/ INCENTIVE |
|----------------------------------|-----|------|-----------|---------------|--------------------|-------------------|
| New Jersey Smart Start Incentive | | | | | \$ - | \$ - |
| MG Boilers < 300 MBH | 200 | MBH | \$2 | \$400 | \$ 3,430 | \$ 3,030 |
| | | | | | \$ - | \$ - |
| | | | | \$400 | \$3,430 | \$3,030 |

Total ECM Cost w/ Incentives: **\$6,775**

APPENDIX I

ECM-8 Replace Domestic Hot Water Heater



NJBPU Energy Audit Program
CHA Project No. 20812
Building: Springfield Municipal Building

SCM-B - Restroom DHW Issues

Summary:

• Replace 8 kW, 36" Gas-Fired DHW Heater w/ Transmission, Condensing, Blue-Fired DHW Heater

| Item | Value | Unit | Particulars/Comments |
|---|---------|---------------|---|
| Occupied time per week | 4 | Days/Week | |
| Water supply Temperature | 50 | F | Transmission of water entering our building. |
| Hot Water Temperature | 140 | F | |
| Hot Water Storage per day | 20 | gallons | Condensing water storage |
| Annual Hot Water Energy Demand | 2000 | MBTU/yr | Energy required to heat 8,000 gallons at 90 degrees to 140. |
| Existing Tank Size | 30 | Gallons | Per manufacturer's literature |
| Hot Water Temperature | 140 | F | Per manufacturer's literature |
| Average Room Temperature | 70 | F | Per manufacturer's literature |
| Standby Losses (% by Volume) | 3.5% | | (1.0% of water capacity per year, per U.S. Department of Energy.) |
| Standby Losses (Heat Loss) | 0.3 | MBTU | |
| Annual Standby Hot Water Load | 6.396 | MBTU/yr | |
| Total Annual Hot Water Demand (w/ standby losses) | 6.396 | MBTU/yr | Standby, storage hot water losses |
| Existing Water Heater Efficiency | 90% | | Per manufacturer |
| Total Annual Energy Required | 6.396 | MBTU/yr | |
| Total Annual Electric Required | 1.000 | kWh/yr | Electrical Standby |
| Average Annual Electric Demand | 2.25 | kW | |
| Peak Electric Demand | 8.0 | kW | The Manufacturer's Nameplate (Demand Savings) |
| Hot Water Tank Size | 30 | Gallons | |
| Hot Water Temperature | 140 | F | |
| Average Room Temperature | 70 | F | |
| Standby Losses (% by Volume) | 3.5% | | (1.0% of water capacity per year, per U.S. Department of Energy.) |
| Standby Losses (Heat Loss) | 0.3 | MBTU | |
| Annual Standby Hot Water Load | 6.396 | MBTU/yr | |
| Total Annual Hot Water Demand (w/ standby losses) | 6.396 | MBTU/yr | |
| Proposed Avg. hot water heater efficiency | 90% | | Based on Newer CHW transmission, condensing DHW heater |
| Proposed Total Annual Energy Required | 6.396 | MBTU/yr | |
| Proposed Total Electric Demand | 40 | Watt-hours/yr | Quantity Losses and Electrical Demand Savings |
| Electric Demand Unit Cost | \$11.78 | /kWh | |
| Electric Utility Supply Unit Cost | \$0.11 | /kWh | |
| NG Utility Unit Cost | \$1.24 | /therm | |
| Existing Operating Cost of DHW | \$1.168 | /yr | |
| Proposed Operating Cost of DHW | \$0.11 | /yr | |
| Annual Utility Cost Savings | \$1,052 | /yr | |

Daily Hot Water Demand

| Facility | Water Use (GPM) | Duration of Use (min) | Fluses per Day | | Full Time Occupants* | | Total Hot Water (Gallons) | Total Hot Water (% of Daily) |
|--------------|-----------------|-----------------------|----------------|--------|----------------------|-----------|---------------------------|------------------------------|
| | | | Male | Female | Male | Female | | |
| LAVATORY | 2.5 | 0:20 | 2 | 2 | 11 | 43 | 90% | 32 |
| SHOWER | 2.5 | 6 | 1 | 1 | 6 | 6 | 25% | 0 |
| KITCHEN SINK | 2.5 | 0:3 | 1 | 1 | 6 | 6 | 25% | 0 |
| MOP SINK | 2.5 | 2 | 1 | 1 | 6 | 6 | 25% | 0 |
| Refrigerator | 2.5 | 1 | 1 | 1 | 6 | 6 | 100% | 0 |
| TOTAL | | | | | | 43 | | 25 |

*GPM or per standard fixture, adjust as necessary if actual GPM is known.
 *Fluses are the occupied hot use hot fixtures. If fixture does not need change to fls.

NJBPU Energy Audit Program
 CHA Project No. 20812
 Building: Springfield Municipal Building

ECM-3 Replace DHW Heater

| Multipliers | |
|-------------|------|
| Material | 0.08 |
| Labor | 1.21 |
| Equipment | 1.08 |

| Description | QTY | UNIT | UNIT COSTS | | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS |
|------------------------------------|-----|------|------------|--------|--------|----------------|--------|----------|------------|---------------------------|
| | | | MAT. | LABOR | EQUIP. | MAT. | LABOR | EQUIP. | | |
| SLE DHW Heater Removal | 1 | LS | | \$ 50 | | | \$ 50 | | \$ 61 | 2009 Means |
| Instantaneous Gas-Fired DHW Heater | 1 | EA | \$ 1,189 | \$ 297 | | \$ 1,175 | \$ 359 | \$ 1,534 | | Unit cost from Home Depot |
| Miscellaneous Electrical | 1 | LS | \$ 500 | | | \$ 490 | | \$ 490 | | 2009 Means |
| Venting Kit | 1 | EA | \$ 450 | \$ 200 | | \$ 441 | \$ 242 | \$ 683 | | 2009 Means |
| Miscellaneous Piping 3/4 in | 10 | LS | \$ 6 | \$ 5 | | \$ 58 | \$ 52 | \$ 121 | | 2009 Means |
| Miscellaneous Valves 3/4 in | 3 | LS | \$ 17 | \$ 20 | | \$ 50 | \$ 73 | \$ 123 | | 2009 Means |
| | | | | | | \$ - | \$ - | \$ - | | |
| | | | | | | \$ - | \$ - | \$ - | | |
| | | | | | | \$ - | \$ - | \$ - | | |
| | | | | | | \$ - | \$ - | \$ - | | |

| | |
|----------|----------------------------|
| \$ 3,012 | Subtotal |
| \$ 301 | 10% Contingency Contractor |
| \$ 497 | 15% O&P |
| \$ - | 0% Engineering |
| \$ 3,810 | Total |

| Description | QTY | UNIT | \$ / UNIT | TOTAL SAVINGS | Com w/O INCENTIV | Cost w/ INCENTIV |
|----------------------------------|-----|------|-----------|---------------|------------------|------------------|
| New Jersey Smart Start Incentive | | | | | \$ - | \$ - |
| Gas Fired Water Heater | 1 | EA | \$50 | \$50 | \$ 1,534 | \$ 1,484 |
| | | | | | \$ - | \$ - |
| | | | | \$50 | \$1,534 | \$1,484 |

Total ECM Cost w/ Incentives \$3,760

APPENDIX J

ECM-9 Demand Control Ventilation



NIBPU Energy Audit Program
CHA Project No. 20012
Building - Springfield Municipal Building

ECM Demand Control Ventilation

Descriptions

Outside air can be significantly reduced for most of the time that the building is occupied. Savings will result from the avoided heating and cooling of excessive outside air.

Method

The outside air introduced into the spaces is currently constant based on design occupancy conditions.

This ECM proposes the reduction of CO2 sensors in the space to allow for reduced outdoor air flows when conditions allow for average reduction of 50% is assumed possible with the implementation of ECM.

The CO2 system will automatically adjust the outdoor air damper position through the EMS to reduce outdoor air flows based on ambient CO2 levels.

This ECM has been associated with the new boiler ECMs and accounts for the reduced operating hours of the unit via EMS scheduling.

| | Total CFM | O.A. CFM | O.A. % |
|----------------------|-----------|----------|--------|
| Org. scheduled CFM | 7,200 | 875 | 9% |
| Current CFM | 7,200 | 345 | 5% |
| SA Entailty | 25.4 | 871.0000 | |
| SA Set point, Winter | 74.0 | °F | |
| SA Set point, Summer | 73.0 | | |
| Cooling System SE | 5.32 | kWh/Ton | |
| Heating System EF | 8% | | |

OA from: Booth used above
 OA required Avg of 22 people @ 18 CFM/person

(includes ancillary equipment)
 (includes depreciation losses)

| Year | Avg. DB (db Temp) | DB Swb | HOURS | Factory | | | | Proposed Demand Ventilation | | | | Savings | | | | | |
|------|-------------------|--------|-------|---------|--------------------|--------------------|-----------|-----------------------------|--------------------|--------------------|-----------|---------|--------------------|--------------------|-----------|---|---|
| | | | | OA CFM | Cooling Load (MBH) | Heating Load (MBH) | CO2 (ppm) | OA CFM | Cooling Load (MBH) | Heating Load (MBH) | CO2 (ppm) | OA CFM | Cooling Load (MBH) | Heating Load (MBH) | CO2 (ppm) | | |
| 1999 | 65.1 | 8 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2000 | 67.0 | 8 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2001 | 67.0 | 34 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2002 | 67.0 | 121 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2003 | 67.0 | 34 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2004 | 67.0 | 620 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2005 | 67.0 | 664 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2006 | 67.0 | 21 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2007 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2008 | 67.0 | 214 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2009 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2010 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2011 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2012 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2013 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2014 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2015 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2016 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2017 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2018 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2019 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2020 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2021 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2022 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2023 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2024 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2025 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2026 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2027 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2028 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2029 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2030 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2031 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2032 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2033 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2034 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2035 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2036 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2037 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2038 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2039 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2040 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2041 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2042 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2043 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2044 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2045 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2046 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2047 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2048 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2049 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2050 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2051 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2052 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2053 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2054 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2055 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2056 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2057 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2058 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2059 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2060 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2061 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2062 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2063 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2064 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2065 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2066 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2067 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2068 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2069 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2070 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2071 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2072 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2073 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2074 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2075 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2076 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2077 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2078 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2079 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2080 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2081 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2082 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2083 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2084 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2085 | 67.0 | 187 | 875 | 88 | 0 | 0 | 345 | 25 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 2086 | 67.0 | 187 | 875 | 88 | | | | | | | | | | | | | |

NJBPU Energy Audit Program
 CHA Project No. 20012
 Springfield Municipal Building

ECM-9 Demand Control Ventilation

| Multipliers | |
|-------------|------|
| | 0.96 |
| Labor | 1.21 |
| Equipment | 1.09 |

| Description | QTY | UNIT | UNIT COSTS | | SUBTOTAL COSTS | | TOTAL COST | REMARKS | | | |
|--------------------------------|-----|------|------------|-------|----------------|----------|------------|---------|-------|----------|--|
| | | | MAT. | LABOR | EQUIP. | MAT. | | | LABOR | EQUIP. | |
| PLC Controller reprogramming | 1 | less | 1500 | 1000 | | \$ 1,470 | \$ 1,210 | \$ - | \$ - | \$ 2,680 | |
| Carbon Dioxide Sensor | 1 | less | 400 | 100 | | \$ 392 | \$ 121 | \$ - | \$ - | \$ 513 | |
| Replace damper actuator wiring | 1 | less | 200 | 50 | | \$ 198 | \$ 61 | \$ - | \$ - | \$ 257 | |
| | 1 | less | 1000 | 1000 | | \$ 960 | \$ 1,210 | \$ - | \$ - | \$ 2,190 | |
| | | less | | | | \$ - | \$ - | \$ - | \$ - | \$ - | |
| | | less | | | | \$ - | \$ - | \$ - | \$ - | \$ - | |

| | | |
|----|-------|--------------------|
| \$ | 5,640 | Subtotal |
| \$ | 564 | 10% Contingency |
| \$ | 831 | 15% Contractor O&P |
| \$ | - | 0% Engineering |
| \$ | 7,134 | Total |

APPENDIX K

ECM-10 Install Economizers



NABPO Energy Audit Program
CH&A Project No. 200812
Building: Springfield Municipal Building

ECM-33 Install Econometrics

| | |
|-------------------------------|----------------|
| Building Footprint | 6,188 SF |
| Heating Efficiency | 87% |
| Cooling Efficiency | 92% Utilize |
| Internal Gains | 13.022 MBtu/hr |
| Unoc. Internal Gain Factor | 0.02 |
| Avg Occ. Internal Gain Factor | 0.17 |
| Economizer available (Y/N) | Yes |

| | |
|-------------------------------|----------------|
| Ex. Occupied City Temp: | 72 °F |
| Ex. Unoccupied City Temp: | 67 °F |
| Occupied Cooling UA | 13,881 MBtu/°F |
| Unoccupied Cooling UA | 6,519 MBtu/°F |
| Cooling Occ. Entropy Support | 27.5 Btu/h |
| Cooling Unoc. Entropy Support | 27.3 Btu/h |

| | |
|---------------------------|-------------|
| Ex. Occupied Heating UA | 74 °F |
| Ex. Unoccupied Heating UA | 74 °F |
| Unoccupied Heating UA | 738 MBtu/°F |

EXISTING LOADS

| Avg Outdoor Air Temp, Bin | Avg Outdoor Air Entropy | Total Sys Hours | Occupied | | Unoccupied | | Envelope Load | | Internal Gains | | Ventilation Load | | Unoccupied Envelope Load | | Ventilation Load | | Internal Gain BTU/h | Available Economizer Cooling kWh | Necessary Cooling kWh | Existing Cooling Energy kWh | kWh/m² |
|---------------------------|-------------------------|-----------------|----------|---------------------|------------|---|---------------|--------|----------------|---------|------------------|---|--------------------------|---|------------------|---|---------------------|----------------------------------|-----------------------|-----------------------------|--------|
| | | | Hours | Equipment Bin Hours | Hours | E | F | G | H | I | J | K | L | M | | | | | | | |
| 60-70 | 43.1 | 8,782 | 3,128 | 3,831 | 0 | 0 | 144,182 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501 | 186,238 | 186,238 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 67-74 | 47.4 | 0 | 0 | 0 | 0 | 0 | 141,888 | 81,501 | 81,501</ | | | | | | | | | | | | |

NJBP Energy Audit Program
 CHA Project No. 20812
 Springfield Municipal Building
 ECM-10 Install Economizers

| Multipliers | |
|-------------|------|
| Labor | 1.21 |
| Equipment | 1.09 |

| Description | QTY | UNIT | UNIT COSTS | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS | |
|------------------|-----|------|------------|-------|----------------|----------|--------|------------|----------|--------|
| | | | MAT. | LABOR | EQUIP. | MAT. | LABOR | | | EQUIP. |
| Enthalpy Sensor | 4 | feet | 300 | 100 | 0 | \$ 1,176 | \$ 484 | \$ - | \$ 1,660 | |
| Damper Actuators | 3 | feet | 200 | 50 | 0 | \$ 588 | \$ 182 | \$ - | \$ 770 | |
| Controller | 3 | feet | 296 | 30 | 0 | \$ 853 | \$ 109 | \$ - | \$ 962 | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |
| | | | | | | \$ - | \$ - | \$ - | \$ - | |

| | |
|----------|--------------------|
| \$ 3,391 | Subtotal |
| \$ 339 | 10% Contingency |
| \$ 560 | 15% Contractor O&P |
| \$ - | 0% Engineering |
| \$ 4,290 | Total |

APPENDIX L

**New Jersey Pay For Performance
Incentive Program**

NJBPU Energy Audit Program
CHA Project No. 20812
Building: Springfield Municipal Building

New Jersey Pay For Performance Incentive Program

Note: The following calculation is based on the New Jersey Pay For Performance Incentive Program per December, 2009. Building must have a minimum average electric demand of 200 kW. This minimum is waived for buildings owned by local governments or non-profit organizations. The incentive values represented below are applicable through December 31, 2010.

| | Annual Utilities | |
|-------------------------------|------------------|--------|
| | kWh | Therms |
| Existing Usage (from utility) | 73,600 | 2,540 |
| Proposed Savings | 12,973 | 2,221 |
| Existing Total MMBtus | 505 | |
| Proposed Savings MMBtus | 284 | |
| % Reduction | 18% | 82.5% |
| Proposed Annual Savings | \$2,801 | |

| | ≥%15 - < 20% | |
|--------------|--------------|----------|
| | \$/kWh | \$/therm |
| Incentive #2 | \$0.11 | \$1.10 |
| Incentive #3 | \$0.07 | \$0.70 |

| | ≥20% | |
|--------------|--------|----------|
| | \$/kWh | \$/therm |
| Incentive #2 | \$0.22 | \$2.20 |
| Incentive #3 | \$0.14 | \$1.40 |

| | Incentives \$ | | |
|--------------|---------------|---------|----------|
| | Elec | Gas | Total |
| Incentive #2 | \$2,722 | \$4,887 | \$7,609 |
| Incentive #3 | \$1,732 | \$3,110 | \$4,842 |
| Totals | \$4,454 | \$7,997 | \$12,451 |

| | |
|-------------------------------|----------|
| Total Project Cost | \$48,585 |
| % Incentives of Project Cost* | 25.6% |
| Project Cost w/ Incentives* | \$36,144 |

| Project Payback (years) | |
|-------------------------|---------------|
| w/o Incentives | w/ Incentives |
| 7.1 | 5.9 |

* Maximum allowable incentive is 80% of total project cost, or \$2 million per gas account and \$2 million per electric account.

NJBPU Energy Audit Program
CHA Project No. 20812
Building: Springfield Municipal Building

New Jersey Pay For Performance Incentive Program Recommended Energy Conservation Measures (ECMs)

Note: The following calculation is based on the New Jersey Pay For Performance Incentive Program per December 2000. Building must have a minimum average electric demand of 200 kW. This minimum is waived for buildings owned by local governments or non-profit organizations. The incentive values represented below are applicable through December 31, 2010.

| | Annual Utilities | |
|-------------------------------|------------------|--------|
| | kWh | Therms |
| Existing Usage (from utility) | 73,600 | 2,540 |
| Proposed Savings | 11,930 | 1,534 |
| Existing Total MMBtus | 505 | |
| Proposed Savings MMBtus | 183 | |
| % Reduction | 36.2% | |
| Proposed Annual Savings | \$6,738 | |

| | ≥%15 - < 20% | |
|--------------|--------------|----------|
| | \$/kWh | \$/therm |
| Incentive #2 | \$0.11 | \$1.10 |
| Incentive #3 | \$0.07 | \$0.70 |

| | ≥20% | |
|--------------|--------|----------|
| | \$/kWh | \$/therm |
| Incentive #2 | \$0.22 | \$2.20 |
| Incentive #3 | \$0.14 | \$1.40 |

| | Incentives \$ | | |
|--------------|---------------|---------|---------|
| | Elec | Gas | Total |
| Incentive #2 | \$2,538 | \$3,376 | \$5,914 |
| Incentive #3 | \$1,615 | \$2,148 | \$3,763 |
| Totals | \$4,153 | \$5,524 | \$9,677 |

| | |
|-------------------------------|----------|
| Total Project Cost | \$23,832 |
| % Incentives of Project Cost* | 40.6% |
| Project Cost w/ Incentives* | \$14,155 |

| Project Payback (years) | |
|-------------------------|---------------|
| w/o Incentives | w/ Incentives |
| 4.1 | 2.4 |

* Maximum allowable incentive is 80% of total project cost, or \$2 million per gas account and \$2 million per electric account.

APPENDIX M

Photovoltaic (PV) Rooftop Solar Power Generation





AC Energy
&
Cost Savings



| Station Identification | |
|--------------------------|------------|
| City: | Newark |
| State: | New Jersey |
| Latitude: | 40.70° N |
| Longitude: | 74.17° W |
| Elevation: | 9 m |
| PV System Specifications | |
| DC Rating: | 20.0 kW |
| DC to AC Derate Factor: | 0.770 |
| AC Rating: | 15.4 kW |
| Array Type: | Fixed Tilt |
| Array Tilt: | 40.7° |
| Array Azimuth: | 180.0° |
| Energy Specifications | |
| Cost of Electricity: | 17.5 ¢/kWh |

| Results | | | |
|---------|---|-----------------|-------------------|
| Month | Solar Radiation (kWh/m ² /day) | AC Energy (kWh) | Energy Value (\$) |
| 1 | 3.36 | 1656 | 289.80 |
| 2 | 4.05 | 1788 | 312.90 |
| 3 | 4.58 | 2169 | 379.57 |
| 4 | 4.84 | 2119 | 370.82 |
| 5 | 5.30 | 2335 | 408.62 |
| 6 | 5.33 | 2202 | 385.35 |
| 7 | 5.27 | 2224 | 389.20 |
| 8 | 5.25 | 2201 | 385.18 |
| 9 | 5.06 | 2135 | 373.62 |
| 10 | 4.46 | 2011 | 351.93 |
| 11 | 3.15 | 1435 | 251.12 |
| 12 | 2.87 | 1384 | 242.20 |
| Year | 4.46 | 23660 | 4140.50 |

[Output Hourly Performance Data](#)

[Output Results as Text](#)



[About the Hourly Performance Data](#)

[Saving Text from a Browser](#)

Run PVWATTS v.1 for another US location or an International location
Run PVWATTS v.2 (US only)

Please send questions and comments regarding PVWATTS to Webmaster

Disclaimer and copyright notice



Cautions for Interpreting the Results

The monthly and yearly energy production are modeled using the PV system parameters you selected and weather data that are typical or representative of long-term averages. For reference, or comparison with local information, the solar radiation values modeled for the PV array are included in the performance results.

Because weather patterns vary from year-to-year, the values in the tables are better indicators of long-term performance than performance for a particular month or year. PV performance is largely proportional to the amount of solar radiation received, which may vary from the long-term average by $\pm 30\%$ for monthly values and $\pm 10\%$ for yearly values. How the solar radiation might vary for your location may be evaluated by examining the tables in the *Solar Radiation Data Manual for Flat-Plate and Concentrating Collectors* (http://rredc.nrel.gov/solar/old_data/nsrdb/redbook/).

For these variations and the uncertainties associated with the weather data and the model used to model the PV performance, future months and years may be encountered where the actual PV performance is less than or greater than the values shown in the table. The variations may be as much as 40% for individual months and up to 20% for individual years. Compared to long-term performance over many years, the values in the table are accurate to within 10% to 12%.

If the default overall DC to AC derate factor is used, the energy values in the table will overestimate the actual energy production if nearby buildings, objects, or other PV modules and array structure shade the PV modules; if tracking mechanisms for one- and two-axis tracking systems do not keep the PV arrays at the optimum orientation with respect to the sun's position; if soiling or snow cover related losses exceed 5%; or if the system performance has degraded from new. (PV performance typically degrades 1% per year.) If any of these situations exist, an overall DC to AC derate factor should be used with PVWATTS that was calculated using system specific component derate factors for *shading, sun-tracking, soiling, and age*.

The PV system size is the nameplate DC power rating. The energy production values in the table are valid only for crystalline silicon PV systems.

The cost savings are determined as the product of the number of kilowatt hours (kWh) and the cost of electricity per kWh. These cost savings occur if the owner uses all the electricity produced by the PV system, or if the owner has a net-metering agreement with the utility. With net-metering, the utility bills the owner for the net electricity consumed. When electricity flows from the utility to the owner, the meter spins forward. When electricity flows from the PV system to the utility, the meter spins backwards.

If net-metering isn't available and the PV system sends surplus electricity to the utility grid, the utility generally buys the electricity from the owner at a lower price than the owner pays the utility for electricity. In this case, the cost savings shown in the table should be reduced.

Besides the cost savings shown in the table, other benefits of PV systems include greater energy independence and a reduction in fossil fuel usage and air pollution. For commercial customers, additional cost savings may come from reducing demand charges. Homeowners can often include the cost of the PV system in their home mortgage as a way of accommodating the PV system's initial cost.

Township of Springfield
Townhall

Cost of Electricity \$0.175 \$/kWh

Photovoltaic (PV) Rooftop Solar Power Generation-20kW System

| Budgetary Cost | Annual Utility Savings | | | Estimated Maintenance Savings | Total Savings | New Jersey Renewable * Energy Incentive | New Jersey Renewable ** SREC | Payback (without incentive) | Payback (with incentive) |
|-------------------|------------------------|--------|----|-------------------------------------|------------------|--|------------------------------------|-----------------------------------|--------------------------------|
| | kWh | therms | \$ | | | | | | |
| \$ 200,000 | 0.0 | 23,660 | 0 | \$ 4,100 | 0 | \$ 20,000 | \$ 11,500 | 48.6 | 11.5 |

Note: Budgetary cost is based on \$10,000/kw.

* Incentive based on New Jersey renewable energy program for non-residential applications (PIV) = \$1.00/W of installed PV system.

** Estimated Solar Renewable Energy Certificate Program (SREC); SREC for 15 Years = \$487/1000kwh

Estimated Solar Renewable Energy Certificate Program (SREC) payments for 15 Years from RR Renewable Energy Consultants

| Year | SREC |
|------------|------------|
| 1 | 600 |
| 2 | 600 |
| 3 | 600 |
| 4 | 500 |
| 5 | 500 |
| 6 | 500 |
| 7 | 500 |
| 8 | 500 |
| 9 | 500 |
| 10 | 500 |
| 11 | 400 |
| 12 | 400 |
| 13 | 400 |
| 14 | 400 |
| 15 | 400 |
| AVG | 487 |

APPENDIX N

Solar Thermal Domestic Hot Water Plant


[Home](#)
[What Can I Do?](#)
[Energy Choice](#)
[Texas Energy](#)
[FAQs](#)
LEARN
[Fact Sheets](#)
[Lesson Plans](#)
PLAY
[Calculators](#)
NETWORK
[Organizations](#)
[Businesses](#)
[Events/Calendar](#)
BROWSE
[Resources](#)
[Solar](#)
[Wind](#)
[Biomass](#)
[Geothermal](#)
[Water](#)
[FINANCES](#)
[TX Energy /](#)
[TRD and TRDnet](#)
[Financial Tools](#)
[About Us](#)
[About IEEE](#)
[SABE](#)

Interactive Energy Calculators

RENEWABLE ENERGY
 THE INFINITE POWER
 OF TEXAS

Our calculators help you understand energy production and consumption in a whole new way. Use them to develop a personal profile of your own energy use.

[Carbon Pollution Calculator](#)
[Electric Power Pollution Calculator](#)
[PV System Economics](#)
[Solar Water Heating](#)
[What's a Watt?](#)

Solar Water Heating Calculator

Water heating is a major energy consumer. Although the energy consumed daily is often less than for air conditioning or heating, it is required year round, making it a good application of solar energy. Use this calculator to explore the energy usage of your water heater, and to estimate whether a solar water heater could save you money.

| Water Heater Characteristics | | | |
|------------------------------------|-----------------------------------|----------------------------------|---------------------------------------|
| Physical | | Thermal | |
| <input type="text" value="1.5"/> | Diameter (feet) | <input type="text" value="55"/> | Water Inlet Temperature (Degrees F) |
| <input type="text" value="30"/> | Capacity (gallons) | <input type="text" value="70"/> | Ambient Temperature (Degrees F) |
| <input type="text" value="14.23"/> | Surface Area (calculated - sq ft) | <input type="text" value="120"/> | Hot Water Temperature (Degrees F) |
| <input type="text" value="NaN"/> | Effective R-value | <input type="text" value="22"/> | Hot Water Usage (Gallons per Day) |
| Energy Use | | | |
| <input type="text" value="489.2"/> | | <input type="text" value=""/> | Heat Delivered in Hot Water (BTU/hr) |
| <input type="text" value="0"/> | | <input type="text" value=""/> | Heat loss through insulation (BTU/hr) |

| Gas vs. Electric Water Heating | | |
|---|-------------------------------|---|
| Gas | | Electric |
| <input type="text" value="0.8"/> | <input type="text" value=""/> | <input type="text" value="0.98"/> |
| <input type="text" value="0.8"/> | <input type="text" value=""/> | <input type="text" value="0.98"/> |
| <input type="text" value="611.5"/> | <input type="text" value=""/> | <input type="text" value="489.2"/> |
| BTU/hr | | BTU/hr |
| Cost | | |
| <input type="text" value="\$ 1.24"/> | <input type="text" value=""/> | <input type="text" value="\$.175"/> |
| /Therm | | /kWh |
| <input type="text" value="\$ 66.4235"/> | <input type="text" value=""/> | <input type="text" value="\$ 224.129"/> |
| | | |
| How Does Solar Compare? | | |
| <input type="text" value="\$ 27100"/> | <input type="text" value=""/> | <input type="text" value="70"/> |
| Solar Water Heater Cost: \$ | | Percentage Solar |
| <input type="text" value="582.839"/> | <input type="text" value=""/> | <input type="text" value="172.731"/> |
| years for gas | | years for electric |
| | <input type="text" value=""/> | |
| | Payback Time for Solar System | |

More information on solar water heating:

[Fact sheet - Solar Water Heaters](#)
[Fact sheet - Solar Water Heaters for Swimming Pools](#)
[Kids fact sheet - Heat from the Sun](#)

Kubong Energy Audits
 OMA 120812
 Building: Township of Springfield Township

| Multipliers | |
|-------------|------|
| Material | 0.96 |
| Labor | 1.21 |
| Equipment | 1.00 |

| Description | QTY | UNIT | UNIT COSTS | | | SUBTOTAL COSTS | | | TOTAL COST | REMARKS |
|------------------------------|-----|------|------------|----------|----------|----------------|----------|----------|------------|---------|
| | | | MAT. | LABOR | EQUIP. | MAT | LABOR | EQUIP | | |
| Synergy Solar Thermal System | 2 | ea | | | \$ 3,600 | \$ - | \$ - | \$ 7,848 | \$ 7,848 | |
| Piping modifications | 1 | lf | \$ 2,000 | \$ 3,500 | | \$ 1,960 | \$ 4,235 | \$ - | \$ 6,195 | |
| Electrical modifications | 1 | lf | \$ 1,000 | \$ 1,000 | | \$ 980 | \$ 1,210 | \$ - | \$ 2,190 | |
| 55 Gallon Storage Tanks | 2 | ea | \$ 200 | \$ 250 | | \$ 400 | \$ 500 | \$ - | \$ 900 | |
| 10 Gallon Drip Tank | 2 | ea | \$ 100 | \$ 78 | | \$ 200 | \$ 156 | \$ - | \$ 356 | |
| | | | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | |


| | |
|-----------------|--------------------|
| \$17,489 | Subtotal |
| \$ 2,623 | 15% Contingency |
| \$ 2,623 | 15% Contractor O&P |
| \$ 4,372 | 25% Engineering |
| \$27,108 | Total |

APPENDIX O

Wind



Wind Resource of New Jersey Mean Annual Wind Speed at 30 Meters



AWS Truewind
 Projection: Transverse Mercator
 UTM Zone 17 WGS84
 Spatial Resolution of Wind Resource Data: 200m
 This map was created by AWS Truewind using the MapInfo system and historical weather data. Although it is believed to represent an accurate overall picture of the wind energy resource, estimates at any location should be confirmed by measurement.
 The transportation line information was obtained by AWS Truewind from the Open Energy Database Velocity Data. AWS does not warrant the accuracy of the transportation line information.



2159 Jacksonville Jobstown Rd. Jobstown, NJ 08041

© 2008 Google

Image Map

Image Map and Street View

Google

© 2008 Google

40°02'19.41" N 74°42'03.04" W 160 500

© 2008 Google

APPENDIX P

EPA Portfolio Manager

STATEMENT OF ENERGY PERFORMANCE

Municipal Building

Building ID: 1994293
 For 12-month Period Ending: September 30, 2009¹
 Date SEP becomes ineligible: N/A

Date SEP Generated: January 08, 2010

Facility
 Municipal Building
 2159 Jacksonville-Jobstown Road
 Jobstown, NJ 08041

Facility Owner
 N/A

Primary Contact for this Facility
 N/A

Year Built: 1980
Gross Floor Area (ft²): 5,280

Energy Performance Rating² (1-100) N/A

Site Energy Use Summary³

| | |
|-----------------------------------|---------|
| Electricity - Grid Purchase(kBtu) | 251,123 |
| Natural Gas (kBtu) ⁴ | 253,896 |
| Total Energy (kBtu) | 505,019 |

Energy Intensity⁵

| | |
|-----------------------------------|-----|
| Site (kBtu/ft ² /yr) | 96 |
| Source (kBtu/ft ² /yr) | 209 |

Emissions (based on site energy use)

| | |
|---|----|
| Greenhouse Gas Emissions (MTCO ₂ e/year) | 52 |
|---|----|

Electric Distribution Utility

Public Service Elec & Gas Co

National Average Comparison

| | |
|---|-------|
| National Average Site EUI | 90 |
| National Average Source EUI | 189 |
| % Difference from National Average Source EUI | 11% |
| Building Type | Other |

| |
|--|
| |
| Stamp of Certifying Professional |
| Based on the conditions observed at the time of my visit to this building, I certify that the information contained within this statement is accurate. |

Meets Industry Standards⁶ for Indoor Environmental Conditions:

| | |
|---|-----|
| Ventilation for Acceptable Indoor Air Quality | N/A |
| Acceptable Thermal Environmental Conditions | N/A |
| Adequate Illumination | N/A |

Certifying Professional

N/A

Notes:

1. Application for the ENERGY STAR must be submitted to EPA within 4 months of the Period Ending date. Award of the ENERGY STAR is not final until approval is received from EPA.
2. The EPA Energy Performance Rating is based on total source energy. A rating of 75 is the minimum to be eligible for the ENERGY STAR.
3. Values represent energy consumption, annualized to a 12-month period.
4. Natural Gas values in units of volume (e.g. cubic feet) are converted to kBtu with adjustments made for elevation based on Facility zip code.
5. Values represent energy intensity, annualized to a 12-month period.
6. Based on Meeting ASHRAE Standard 62 for ventilation for acceptable indoor air quality, ASHRAE Standard 55 for thermal comfort, and IESNA Lighting Handbook for lighting quality.

ENERGY STAR® Data Checklist for Commercial Buildings

In order for a building to qualify for the ENERGY STAR, a Professional Engineer (PE) must validate the accuracy of the data underlying the building's energy performance rating. This checklist is designed to provide an at-a-glance summary of a property's physical and operating characteristics, as well as its total energy consumption, to assist the PE in double-checking the information that the building owner or operator has entered into Portfolio Manager.

Please complete and sign this checklist and include it with the stamped, signed Statement of Energy Performance.

NOTE: You must check each box to indicate that each value is correct, OR include a note.

| CRITERION | VALUE AS ENTERED IN PORTFOLIO MANAGER | VERIFICATION QUESTIONS | NOTES | |
|--------------------------------|---|--|-------|--------------------------|
| Building Name | Municipal Building | Is this the official building name to be displayed in the ENERGY STAR Registry of Labeled Buildings? | | <input type="checkbox"/> |
| Type | Other | Is this an accurate description of the space in question? | | <input type="checkbox"/> |
| Location | 2159 Jacksonville-Jobstown Road, Jobstown, NJ 08041 | Is this address accurate and complete? Correct weather normalization requires an accurate zip code. | | <input type="checkbox"/> |
| Single Structure | Single Facility | Does this SEP represent a single structure? SEPs cannot be submitted for multiple-building campuses (with the exception of acute care or children's hospitals) nor can they be submitted as representing only a portion of a building. | | <input type="checkbox"/> |
| Courthouse (Courthouse) | | | | |
| CRITERION | VALUE AS ENTERED IN PORTFOLIO MANAGER | VERIFICATION QUESTIONS | NOTES | |
| Gross Floor Area | 1,350 Sq. Ft. | Does this square footage include all supporting functions such as kitchens and break rooms used by staff, storage areas, administrative areas, elevators, stairwells, atria, vent shafts, etc. Also note that existing atriums should only include the base floor area that it occupies. Interstitial (plenum) space between floors should not be included in the total. Finally gross floor area is not the same as leasable space. Leasable space is a subset of gross floor area. | | <input type="checkbox"/> |
| Weekly operating hours | 20 Hours | Is this the total number of hours per week that the Courthouse is 75% occupied? This number should exclude hours when the facility is occupied only by maintenance, security, or other support personnel. For facilities with a schedule that varies during the year, "operating hours/week" refers to the total weekly hours for the schedule most often followed. | | <input type="checkbox"/> |
| Workers on Main Shift | 3 | Is this the number of employees present during the main shift? Note this is not the total number of employees or visitors who are in a building during an entire 24 hour period. For example, if there are two daily 8 hour shifts of 100 workers each, the Workers on Main Shift value is 100. | | <input type="checkbox"/> |
| Number of PCs | 0 | Is this the number of personal computers in the Courthouse? | | <input type="checkbox"/> |
| Percent Cooled | 50% or more | Is this the percentage of the total floor space within the facility that is served by mechanical cooling equipment? | | <input type="checkbox"/> |
| Percent Heated | 50% or more | Is this the percentage of the total floor space within the facility that is served by mechanical heating equipment? | | <input type="checkbox"/> |
| Office (Office) | | | | |
| CRITERION | VALUE AS ENTERED IN PORTFOLIO MANAGER | VERIFICATION QUESTIONS | NOTES | |

| | | | | |
|-------------------------------|--|--|--------------|--------------------------|
| Gross Floor Area | 1,930 Sq. Ft. | Does this square footage include all supporting functions such as kitchens and break rooms used by staff, storage areas, administrative areas, elevators, stairwells, atria, vent shafts, etc. Also note that existing atriums should only include the base floor area that it occupies. Interstitial (plenum) space between floors should not be included in the total. Finally gross floor area is not the same as leasable space. Leasable space is a subset of gross floor area. | | <input type="checkbox"/> |
| Weekly operating hours | 80 Hours | Is this the total number of hours per week that the Office space is 75% occupied? This number should exclude hours when the facility is occupied only by maintenance, security, or other support personnel. For facilities with a schedule that varies during the year, "operating hours/week" refers to the total weekly hours for the schedule most often followed. | | <input type="checkbox"/> |
| Workers on Main Shift | 10 | Is this the number of employees present during the main shift? Note this is not the total number of employees or visitors who are in a building during an entire 24 hour period. For example, if there are two daily 8 hour shifts of 100 workers each, the Workers on Main Shift value is 100. The normal worker density ranges between 0.3 and 10 workers per 1000 square feet (92.9 square meters) | | <input type="checkbox"/> |
| Number of PCs | 0 | Is this the number of personal computers in the Office? | | <input type="checkbox"/> |
| Percent Cooled | 50% or more | Is this the percentage of the total floor space within the facility that is served by mechanical cooling equipment? | | <input type="checkbox"/> |
| Percent Heated | 50% or more | Is this the percentage of the total floor space within the facility that is served by mechanical heating equipment? | | <input type="checkbox"/> |
| Police Dept (Other) | | | | |
| CRITERION | VALUE AS ENTERED IN PORTFOLIO MANAGER | VERIFICATION QUESTIONS | NOTES | |
| Gross Floor Area | 2,000 Sq. Ft. | Does this square footage include all supporting functions such as kitchens and break rooms used by staff, storage areas, administrative areas, elevators, stairwells, atria, vent shafts, etc. Also note that existing atriums should only include the base floor area that it occupies. Interstitial (plenum) space between floors should not be included in the total. Finally gross floor area is not the same as leasable space. Leasable space is a subset of gross floor area. | | <input type="checkbox"/> |
| Number of PCs | 3 (Optional) | Is this the number of personal computers in the space? | | <input type="checkbox"/> |
| Weekly operating hours | 166 Hours(Optional) | Is this the total number of hours per week that the space is 75% occupied? This number should exclude hours when the facility is occupied only by maintenance, security, or other support personnel. For facilities with a schedule that varies during the year, "operating hours/week" refers to the total weekly hours for the schedule most often followed. | | <input type="checkbox"/> |
| Workers on Main Shift | 3 (Optional) | Is this the number of employees present during the main shift? Note this is not the total number of employees or visitors who are in a building during an entire 24 hour period. For example, if there are two daily 8 hour shifts of 100 workers each, the Workers on Main Shift value is 100. | | <input type="checkbox"/> |

ENERGY STAR® Data Checklist for Commercial Buildings

Energy Consumption

Power Generation Plant or Distribution Utility: Public Service Elec & Gas Co

| Fuel Type: Electricity | | |
|---|------------|--|
| Meter: Electric (kWh (thousand Watt-hours)) Space(s): Entire Facility Generation Method: Grid Purchase | | |
| Start Date | End Date | Energy Use (kWh (thousand Watt-hours)) |
| 09/01/2009 | 09/30/2009 | 7,160.00 |
| 08/01/2009 | 08/31/2009 | 7,600.00 |
| 07/01/2009 | 07/31/2009 | 8,040.00 |
| 06/01/2009 | 06/30/2009 | 6,440.00 |
| 05/01/2009 | 05/31/2009 | 5,840.00 |
| 04/01/2009 | 04/30/2009 | 7,080.00 |
| 03/01/2009 | 03/31/2009 | 5,880.00 |
| 02/01/2009 | 02/28/2009 | 3,240.00 |
| 01/01/2009 | 01/31/2009 | 6,160.00 |
| 12/01/2008 | 12/31/2008 | 6,080.00 |
| 11/01/2008 | 11/30/2008 | 6,080.00 |
| 10/01/2008 | 10/31/2008 | 6,000.00 |
| Electric Consumption (kWh (thousand Watt-hours)) | | 73,600.00 |
| Electric Consumption (kBtu (thousand Btu)) | | 251,123.20 |
| Total Electricity (Grid Purchase) Consumption (kBtu (thousand Btu)) | | 251,123.20 |
| Is this the total Electricity (Grid Purchase) consumption at this building including all Electricity meters? | | <input type="checkbox"/> |
| Fuel Type: Natural Gas | | |
| Meter: Natural Gas (therms) Space(s): Entire Facility | | |
| Start Date | End Date | Energy Use (therms) |
| 09/01/2009 | 09/30/2009 | 18.70 |
| 08/01/2009 | 08/31/2009 | 0.01 |
| 07/01/2009 | 07/31/2009 | 7.30 |
| 06/01/2009 | 06/30/2009 | 30.12 |
| 05/01/2009 | 05/31/2009 | 183.63 |
| 04/01/2009 | 04/30/2009 | 445.34 |
| 03/01/2009 | 03/31/2009 | 406.10 |
| 02/01/2009 | 02/28/2009 | 566.10 |
| 01/01/2009 | 01/31/2009 | 404.18 |
| 12/01/2008 | 12/31/2008 | 300.32 |

| | | |
|---|------------|--------------------------|
| 11/01/2008 | 11/30/2008 | 105.69 |
| 10/01/2008 | 10/31/2008 | 11.51 |
| Natural Gas Consumption (therms) | | 2,538.96 |
| Natural Gas Consumption (kBtu (thousand Btu)) | | 253,896.00 |
| Total Natural Gas Consumption (kBtu (thousand Btu)) | | 253,896.00 |
| Is this the total Natural Gas consumption at this building including all Natural Gas meters? | | <input type="checkbox"/> |

Additional Fuels

| | |
|---|--------------------------|
| Do the fuel consumption totals shown above represent the total energy use of this building? Please confirm there are no additional fuels (district energy, generator fuel oil) used in this facility. | <input type="checkbox"/> |
|---|--------------------------|

On-Site Solar and Wind Energy

| | |
|---|--------------------------|
| Do the fuel consumption totals shown above include all on-site solar and/or wind power located at your facility? Please confirm that no on-site solar or wind installations have been omitted from this list. All on-site systems must be reported. | <input type="checkbox"/> |
|---|--------------------------|

Certifying Professional

(When applying for the ENERGY STAR, the Certifying Professional must be the same as the PE that signed and stamped the SEP.)

Name: _____ Date: _____

Signature: _____

Signature is required when applying for the ENERGY STAR.

FOR YOUR RECORDS ONLY. DO NOT SUBMIT TO EPA.

Please keep this Facility Summary for your own records; do not submit it to EPA. Only the Statement of Energy Performance (SEP), Data Checklist and Letter of Agreement need to be submitted to EPA when applying for the ENERGY STAR.

Facility
Municipal Building
2159 Jacksonville-Jobstown Road
Jobstown, NJ 08041

Facility Owner
N/A

Primary Contact for this Facility
N/A

General Information

| Municipal Building | |
|--|--------------------|
| Gross Floor Area Excluding Parking: (ft ²) | 5,280 |
| Year Built | 1980 |
| For 12-month Evaluation Period Ending Date: | September 30, 2009 |

Facility Space Use Summary

| Courthouse | | Police Dept | |
|------------------------------------|-------------|-------------------------------------|-------------------------------------|
| Space Type | Courthouse | Space Type | Other - Fire Station/Police Station |
| Gross Floor Area(ft ²) | 1,350 | Gross Floor Area(ft ²) | 2,000 |
| Weekly operating hours | 20 | Number of PCs ¹ | 3 |
| Workers on Main Shift | 3 | Weekly operating hours ² | 100 |
| Number of PCs | 0 | Workers on Main Shift ³ | 3 |
| Percent Cooled | 50% or more | | |
| Percent Heated | 50% or more | | |
| Office | | | |
| Space Type | Office | | |
| Gross Floor Area(ft ²) | 1,930 | | |
| Weekly operating hours | 60 | | |
| Workers on Main Shift | 10 | | |
| Number of PCs | 0 | | |
| Percent Cooled | 50% or more | | |
| Percent Heated | 50% or more | | |

Energy Performance Comparison

| Performance Metric | Evaluation Periods | | Comparisons | | |
|---|-------------------------------------|--------------------------------------|--------------|--------------|------------------|
| | Current (Ending Date 09/30/2009) | Baseline (Ending Date 09/30/2006) | Rating of 75 | Target | National Average |
| Energy Performance Rating | N/A | N/A | 75 | 27 | N/A |
| Energy Use Intensity | | | | | |
| Site (kBtu/ft ²) | 96 | 96 | 46 | 96 | 90 |
| Source (kBtu/ft ²) | 208 | 209 | 100 | 178 | 189 |
| Energy Cost | | | | | |
| \$/year | \$ 16,021.26 | \$ 16,021.26 | \$ 7,004.89 | \$ 13,420.00 | \$ 15,074.89 |
| \$/ft ² /year | \$ 3.03 | \$ 3.03 | \$ 1.46 | \$ 2.54 | \$ 2.85 |
| Greenhouse Gas Emissions | | | | | |
| MtCO ₂ e/year | 52 | 52 | 29 | 44 | 49 |
| kgCO ₂ e/ft ² /year | 10 | 10 | 5 | 8 | 9 |

More than 50% of your building is defined as Other. This building is currently ineligible for a rating. Please note the National Average column represents the CBECS national average data for Other. This building uses X% less energy per square foot than the CBECS national average for Other.

Notes:

0 - This attribute is optional.

9 - A default value has been supplied by Portfolio Manager.

APPENDIX Q

Equipment Inventory

MSRP Energy Audit Program
CHA Project No. 20612
Building: Springfield Municipal Building

HVAC Systems

| Type | Manufacturer | # Units | Model | Serial | Info | Equipment Condition | Non-Cooling Motor Name Plate | | | | | |
|---------------------------|---------------|---------|------------------|---------------------------------------|---|---------------------|------------------------------|------|-----------|---------------------|---------|--|
| | | | | | | | HP | kWh | kWh Total | Avg. kW Utilization | Avg. kW | |
| Emergency Generator | Kohler | 1 | 50 kW | Cabinet locked by maintenance company | Not Gas | Excellent | | | | | | |
| Boiler | Wall Union | 1 | CGA-4-PCH | N/A | 340 MBH Input, 204MBH output, 90% eff. | Good | | | | | | |
| Boiler Package AHJ-3 | Teco | 4 | 097-FS | N/A | 105 lbs | Excellent | 0.04 | 0.03 | 0.12 | 30.00% | 0.04 | |
| AHJ-2 | Goodman | 1 | APR486016A8 | 070145520 | Serves Court Area | Excellent | 0.90 | 0.97 | 0.37 | 30.00% | 0.11 | |
| AHJ-2 | Goodman | 1 | APR486016A9 | 070755518 | Serves Main Area | Excellent | 0.75 | 0.96 | 0.50 | 30.00% | 0.11 | |
| AHJ-1 | Teco | 1 | 000A84188 | #8,548,121,140 | Serves Police Station Area | Excellent | 1.60 | 1.74 | 1.12 | 100.00% | 1.10 | |
| Tip Unit Vent | Teco | 8 | 201130-AHJ-003 | N/A | Plumbing Walls | Good | 0.03 | 0.06 | 0.30 | 30.00% | 0.06 | |
| Load Handler | Teco | 1 | 18FA-0600-8A-AAG | 0920-08471 | Serves All AHJ Area 35,000 Btu | Excellent | | | 14.00 | 4.00% | 0.10 | |
| CHW Load Controlling Unit | Goodman White | 1 | M0370213 | T08001036 | 30 Dakota (2) 4.5 kW elements | Good | | | 6.00 | 16.00% | 3.20 | |
| Condensing Unit | Goodman | 1 | 020410828 | 08012061AC | Serves ERM 13.0 | Excellent | | | | | | |
| Condensing Unit | Goodman | 1 | 080130421AC | 004130048 | Serves Office Area ERM 13.1 | Excellent | | | | | | |
| Condensing Unit | Teco | 1 | H030703028 | ASA-M012413 | Serves Court Area ERM 13.2 | Excellent | | | | | | |
| Winter AC Unit | Ashok | 1 | See Access | See Access | Assume 7500 Btu. Only used during the hottest days for a few hours. | Run | | | | | | |
| Exhaust Fan | N/A | 1 | N/A | N/A | 100 CFM Serves Men's And Women's Room | Excellent | 0.08 | 0.03 | 0.08 | 100.00% | 0.08 | |

Average Estimated kW usage for use in the Block Load model: **4.76**