



Local Government Energy Audit Report

Rumson Fairhaven High School

April 26, 2023

Prepared for:

Rumson Fairhaven Regional HS
74 Ridge Rd.
Rumson, New Jersey 07760

Prepared by:

TRC
317 George Street
New Brunswick, New Jersey 08901

Disclaimer

The goal of this audit report is to identify potential energy efficiency opportunities and help prioritize specific measures for implementation. Most energy conservation measures have received preliminary analysis of feasibility that identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to establish a basis for further discussion and to help prioritize energy measures.

TRC reviewed the energy conservation measures and estimates of energy savings for technical accuracy. Actual, achieved energy savings depend on behavioral factors and other uncontrollable variables and, therefore, estimates of final energy savings are not guaranteed. TRC and the New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

TRC bases estimated material and labor costs primarily on RS Means cost manuals as well as on our experience at similar facilities. This approach is based on standard cost estimating manuals and is vendor neutral. Cost estimates include material and labor pricing associated with one for one equipment replacements. Cost estimates do not include demolition or removal of hazardous waste. The actual implementation costs for energy savings projects are anticipated to be significantly higher based on the specific conditions at your site(s). We strongly recommend that you work with your design engineer or contractor to develop actual project costs for your specific scope of work for the installation of high efficiency equipment. We encourage you to obtain multiple estimates when considering measure installations. Actual installation costs can vary widely based on selected products and installers. TRC and NJBPU do not guarantee cost estimates and shall in no event be held liable should actual installed costs vary from these material and labor estimates.

Incentive values provided in this report are estimated based on previously run state efficiency programs. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. Please review all available utility program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

The customer and their respective contractor(s) are responsible to implement energy conservation measures in complete conformance with all applicable local, state, and federal requirements.

Copyright ©2023 TRC. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Table of Contents

| | | |
|------------|---|-----------|
| 1 | Executive Summary..... | 1 |
| 1.1 | Planning Your Project | 4 |
| | Pick Your Installation Approach | 4 |
| | Options from Your Utility Company..... | 4 |
| | <i>Prescriptive and Custom Rebates</i> | 4 |
| | <i>Direct Install</i> | 4 |
| | <i>Engineered Solutions</i> | 4 |
| | Options from New Jersey's Clean Energy Program | 5 |
| 2 | Existing Conditions..... | 6 |
| 2.1 | Site Overview..... | 6 |
| | Recent improvements and Facility Concerns | 6 |
| 2.2 | Building Occupancy | 6 |
| 2.3 | Building Envelope | 7 |
| 2.4 | Lighting Systems..... | 9 |
| 2.5 | Air Handling Systems..... | 12 |
| | Unitary Electric HVAC Equipment | 12 |
| | Unitary Heating Equipment..... | 12 |
| | Packaged Units | 13 |
| | Building General Exhaust Air Systems..... | 14 |
| | Heat Recovery Units (HRUs)..... | 15 |
| 2.6 | Geothermal Water Source Heat Pumps | 16 |
| 2.7 | Building Automation System (BAS) | 19 |
| 2.8 | Domestic Hot Water | 19 |
| 2.9 | Food Service Equipment..... | 21 |
| 2.10 | Refrigeration..... | 22 |
| 2.11 | Plug Load and Vending Machines | 23 |
| 2.12 | Water-Using Systems | 23 |
| 3 | Energy Use and Costs | 24 |
| 3.1 | Electricity | 26 |
| 3.2 | Natural Gas | 27 |
| 3.3 | Benchmarking..... | 28 |
| | Tracking Your Energy Performance | 29 |
| 4 | Energy Conservation Measures | 30 |
| 4.1 | Lighting | 33 |
| | ECM 1: Install LED Fixtures | 33 |
| | ECM 2: Retrofit Fluorescent Fixtures with LED Lamps and Drivers | 33 |
| | ECM 3: Retrofit Fixtures with LED Lamps | 34 |
| 4.2 | Lighting Controls..... | 34 |
| | ECM 4: Install Occupancy Sensor Lighting Controls | 34 |
| 4.3 | Variable Frequency Drives (VFD) | 35 |

| | |
|---|-----------|
| ECM 5: Install VFDs on Constant Volume (CV) Fans | 35 |
| 4.4 Unitary HVAC..... | 36 |
| ECM 6: Install High Efficiency Heat Pumps..... | 36 |
| 4.5 HVAC Improvements | 36 |
| ECM 7: Install Pipe Insulation..... | 36 |
| 4.6 Domestic Water Heating | 37 |
| ECM 8: Install Low-Flow DHW Devices..... | 37 |
| 4.7 Food Service and Refrigeration | 37 |
| ECM 9: Food Service Equipment Replacement | 37 |
| ECM 10: Refrigerator/Freezer Case Electrically Commutated Motors | 38 |
| ECM 11: Refrigeration Controls..... | 38 |
| ECM 12: Vending Machine Control | 38 |
| 4.8 Custom Measures..... | 39 |
| ECM 13: Replace Electric Water Heater with Heat Pump Water Heater | 39 |
| 4.9 39 | |
| 4.10 Measures for Future Consideration | 40 |
| Retro-Commissioning Study..... | 40 |
| 5 Energy Efficient Best Practices | 41 |
| Energy Tracking with ENERGY STAR Portfolio Manager..... | 41 |
| Weatherization..... | 41 |
| Doors and Windows | 41 |
| Lighting Maintenance..... | 42 |
| Lighting Controls | 42 |
| Motor Maintenance | 42 |
| Fans to Reduce Cooling Load | 42 |
| Thermostat Schedules and Temperature Resets | 42 |
| Economizer Maintenance | 43 |
| AC System Evaporator/Condenser Coil Cleaning | 43 |
| HVAC Filter Cleaning and Replacement | 43 |
| Ductwork Maintenance..... | 43 |
| Label HVAC Equipment | 44 |
| Optimize HVAC Equipment Schedules | 44 |
| Water Heater Maintenance | 44 |
| Refrigeration Equipment Maintenance..... | 45 |
| Water Conservation | 45 |
| Procurement Strategies | 45 |
| 6 On-site Generation | 46 |
| 6.1 Solar Photovoltaic | 47 |
| 6.2 Combined Heat and Power | 50 |
| 7 Electric Vehicles (EV) | 51 |
| 7.1 Electric Vehicle Charging | 51 |
| 8 Project Funding and Incentives..... | 53 |
| 8.1 Utility Energy Efficiency Programs | 54 |

| | |
|---|------------|
| Prescriptive and Custom | 54 |
| Direct Install | 54 |
| Engineered Solutions | 55 |
| 8.2 New Jersey's Clean Energy Programs..... | 56 |
| Large Energy Users | 56 |
| Combined Heat and Power | 57 |
| Successor Solar Incentive Program (SuSI) | 58 |
| Energy Savings Improvement Program | 59 |
| 9 Project Development | 60 |
| 10 Energy Purchasing and Procurement Strategies | 61 |
| 10.1 Retail Electric Supply Options..... | 61 |
| 10.2 Retail Natural Gas Supply Options | 61 |
| Appendix A: Equipment Inventory & Recommendations | A-1 |
| Appendix B: ENERGY STAR Statement of Energy Performance..... | B-1 |
| Appendix C: Glossary | C-1 |
| Appendix D: PV Analysis..... | D-1 |

1 EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBPB) has sponsored this Local Government Energy Audit (LGEA) report for Rumson Fairhaven High School. This report provides you with information about your facility's energy use, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help make changes in your facility. TRC conducted this study as part of a comprehensive effort to assist New Jersey school districts and local governments in controlling their energy costs and to help protect our environment by reducing statewide energy consumption.


BUILDING PERFORMANCE REPORT



Costs: \$282,340

Annual Utilities Electricity:
2,206,520 kWh

Natural Gas:
6,434 Therms



ENERGY STAR® Benchmarking Score 67 (1-100 scale)

Congratulations, your building performs better than the national average. This report has suggestions about how to keep your building running efficiently, further improve performance, and lower your energy bills even more.




Figure 1 - Energy Use by System


POTENTIAL IMPROVEMENTS



This energy audit considered a range of potential energy improvements in your building. Costs and savings will vary between improvements. Presented below are two potential scopes of work for your consideration.


Scenario 1: Full Package (All Evaluated Measures)

| | |
|---|---|
| Installation Cost | \$1,173,170 |
| Potential Rebates & Incentives ¹ | \$66,590 |
| Annual Cost Savings | \$54,792 |
| Annual Energy Savings | Electricity: 434,898 kWh Natural Gas: 788 Therms |
| Greenhouse Gas Emission Savings | 224 Tons |
| Simple Payback | 20.2 Years |
| Site Energy Savings (All Utilities) | 19% |



Scenario 2: Cost Effective Package²

| | |
|-------------------------------------|---|
| Installation Cost | \$197,788 |
| Potential Rebates & Incentives | \$29,363 |
| Annual Cost Savings | \$47,352 |
| Annual Energy Savings | Electricity: 377,015 kWh Natural Gas: 600 Therms |
| Greenhouse Gas Emission Savings | 193 Tons |
| Simple Payback | 3.6 Years |
| Site Energy Savings (all utilities) | 16% |



On-site Generation Potential

| | |
|-------------------------|----------------------|
| Photovoltaic | See Additional Scope |
| Combined Heat and Power | None |

¹ Incentives are based on previously run state rebate programs. Contact your utility provider for current program incentives that may apply.

² A cost-effective measure is defined as one where the simple payback does not exceed two-thirds of the expected proposed equipment useful life. Simple payback is based on the net measure cost after potential incentives.

| # | Energy Conservation Measure | Cost Effective? | Annual Electric Savings (kWh) | Peak Demand Savings (kW) | Annual Fuel Savings (MMBtu) | Annual Energy Cost Savings (\$) | Estimated M&L Cost (\$) | Estimated Incentive (\$)* | Estimated Net M&L Cost (\$) | Simple Payback Period (yrs)** | CO ₂ e Emissions Reduction (lbs) |
|--|---|-----------------|-------------------------------|--------------------------|-----------------------------|---------------------------------|-------------------------|---------------------------|-----------------------------|-------------------------------|---|
| Lighting Upgrades | | | 236,184 | 38.0 | 0 | \$28,993 | \$60,483 | \$14,760 | \$45,723 | 1.6 | 237,835 |
| ECM 1 | Install LED Fixtures | Yes | 5,256 | 0.0 | 0 | \$645 | \$3,429 | \$450 | \$2,979 | 4.6 | 5,293 |
| ECM 2 | Retrofit Fluorescent Fixtures with LED Lamps and Drivers | Yes | 2,266 | 0.4 | 0 | \$278 | \$788 | \$106 | \$682 | 2.5 | 2,282 |
| ECM 3 | Retrofit Fixtures with LED Lamps | Yes | 228,662 | 37.5 | 0 | \$28,070 | \$56,265 | \$14,204 | \$42,061 | 1.5 | 230,261 |
| Lighting Control Measures | | | 2,738 | 0.5 | 0 | \$336 | \$1,890 | \$245 | \$1,645 | 4.9 | 2,757 |
| ECM 4 | Install Occupancy Sensor Lighting Controls | Yes | 2,738 | 0.5 | 0 | \$336 | \$1,890 | \$245 | \$1,645 | 4.9 | 2,757 |
| Variable Frequency Drive (VFD) Measures | | | 99,678 | 31.7 | 0 | \$12,236 | \$124,845 | \$13,300 | \$111,545 | 9.1 | 100,375 |
| ECM 5 | Install VFDs on Constant Volume (CV) Fans | Yes | 99,678 | 31.7 | 0 | \$12,236 | \$124,845 | \$13,300 | \$111,545 | 9.1 | 100,375 |
| Unitary HVAC Measures | | | 57,883 | 63.6 | 0 | \$7,106 | \$966,092 | \$36,727 | \$929,365 | 130.8 | 58,288 |
| ECM 6 | Install High Efficiency Heat Pumps | No | 57,883 | 63.6 | 0 | \$7,106 | \$966,092 | \$36,727 | \$929,365 | 130.8 | 58,288 |
| HVAC System Improvements | | | 0 | 0.0 | 22 | \$390 | \$2,824 | \$424 | \$2,400 | 6.2 | 2,558 |
| ECM 7 | Install Pipe Insulation | Yes | 0 | 0.0 | 22 | \$390 | \$2,824 | \$424 | \$2,400 | 6.2 | 2,558 |
| Domestic Water Heating Upgrade | | | 9,036 | 0.0 | 38 | \$1,790 | \$767 | \$379 | \$388 | 0.2 | 13,570 |
| ECM 8 | Install Low-Flow DHW Devices | Yes | 9,036 | 0.0 | 38 | \$1,790 | \$767 | \$379 | \$388 | 0.2 | 13,570 |
| Food Service & Refrigeration Measures | | | 4,760 | 0.3 | 19 | \$919 | \$12,319 | \$755 | \$11,564 | 12.6 | 6,994 |
| ECM 9 | Food Service Equipment Replacement | No | 0 | 0.0 | 19 | \$335 | \$9,290 | \$500 | \$8,790 | 26.2 | 2,200 |
| ECM 10 | Refrigerator/Freezer Case Electrically Commutated Motors | Yes | 983 | 0.1 | 0 | \$121 | \$607 | \$80 | \$527 | 4.4 | 990 |
| ECM 11 | Refrigeration Controls | Yes | 2,165 | 0.0 | 0 | \$266 | \$2,193 | \$125 | \$2,068 | 7.8 | 2,180 |
| ECM 12 | Vending Machine Control | Yes | 1,612 | 0.2 | 0 | \$198 | \$230 | \$50 | \$180 | 0.9 | 1,623 |
| Custom Measures | | | 24,619 | 0.0 | 0 | \$3,022 | \$3,950 | \$0 | \$3,950 | 1.3 | 24,791 |
| ECM 13 | Replace Electric Water Heater with Heat Pump Water Heater | Yes | 24,619 | 0.0 | 0 | \$3,022 | \$3,950 | \$0 | \$3,950 | 1.3 | 24,791 |
| TOTALS (COST EFFECTIVE MEASURES) | | | 377,015 | 70.5 | 60 | \$47,352 | \$197,788 | \$29,363 | \$168,425 | 3.6 | 386,680 |
| TOTALS (ALL MEASURES) | | | 434,898 | 134.1 | 79 | \$54,792 | \$1,173,170 | \$66,590 | \$1,106,580 | 20.2 | 447,168 |

* - All incentives presented in this table are included as placeholders for planning purposes and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 2 – Evaluated Energy Improvements

For more detail on each evaluated energy improvement and a break out of cost-effective improvements, see **Section 4: Energy Conservation Measures**.

1.1 Planning Your Project

Careful planning makes for a successful energy project. When considering this scope of work, you will have some decisions to make, such as:

- ◆ How will the project be funded and/or financed?
- ◆ Is it best to pursue individual ECMs, groups of ECMs, or use a comprehensive approach where all ECMs are installed together?
- ◆ Are there other facility improvements that should happen at the same time?

Pick Your Installation Approach

Utility-run energy efficiency programs and New Jersey's Clean Energy Programs, give you the flexibility to do a little or a lot. Rebates, incentives, and financing are available to help reduce both your installation costs and your energy bills. If you are planning to take advantage of these programs, make sure to review incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives before purchasing materials or starting installation.

Options from Your Utility Company

Prescriptive and Custom Rebates

For facilities wishing to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the Prescriptive and Custom Rebates program. To participate, you can use internal resources or an outside firm or contractor to perform the final design of the ECM(s) and install the equipment. Program pre-approval may be required for some incentives. Contact your utility company for more details prior to project installation.

Direct Install

The Direct Install program provides turnkey installation of multiple measures through an authorized contractor. This program can provide incentives up to 70% or 80% of the cost of selected measures. A Direct Install contractor will assess and verify individual measure eligibility and perform the installation work. The Direct Install program is available to sites with an average peak demand of less than 200 kW.

Engineered Solutions

The Engineered Solutions program provides tailored energy-efficiency assistance and turnkey engineering services to municipalities, universities, schools, hospitals, and healthcare facilities (MUSH), non-profit entities, and multifamily buildings. The program provides all professional services from audit, design, construction administration, to commissioning and measurement and verification for custom whole-building energy-efficiency projects. Engineered Solutions allows you to install as many measures as possible under a single project as well as address measures that may not qualify for other programs.

For more details on these programs please contact your utility provider.

Options from New Jersey's Clean Energy Program

Financing and Planning Support with the Energy Savings Improvement Program (ESIP)

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the ESIP. Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as attractive financing for implementing ECMs. You have already taken the first step as an LGEA customer, because this report is required to participate in ESIP.

Resiliency with Return on Investment through Combined Heat and Power (CHP)

The CHP program provides incentives for combined heat and power (i.e., cogeneration) and waste heat to power projects. Combined heat and power systems generate power on-site and recover heat from the generation system to meet on-site thermal loads. Waste heat to power systems use waste heat to generate power. You will work with a qualified developer who will design a system that meets your building's heating and cooling needs.

Successor Solar Incentive Program (SuSI)

New Jersey is committed to supporting solar energy. Solar projects help the state reach the renewable goals outlined in the state's Energy Master Plan. The SuSI program is used to register and certify solar projects in New Jersey. Rebates are not available, but certified solar projects are able to earn one SREC II (Solar Renewable Energy Certificates II) for each megawatt-hour of solar electricity produced from a qualifying solar facility.

Ongoing Electric Savings with Demand Response

The Demand Response Energy Aggregator program reduces electric loads at commercial facilities when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. By enabling commercial facilities to reduce electric demand during times of peak demand, the grid is made more reliable, and overall transmission costs are reduced for all ratepayers. Curtailment service providers provide regular payments to medium and large consumers of electric power for their participation in demand response (DR) programs. Program participation is voluntary, and facilities receive payments regardless of whether they are called upon to curtail their load during times of peak demand.

Large Energy User Program (LEUP)

LEUP is designed to promote self-investment in energy efficiency. It incentivizes owners/users of buildings to upgrade or install energy conserving measures in existing buildings to help offset the capital costs associated with the project. The efficiency upgrades are customized to meet the requirements of the customers' existing facilities, while advancing the State's energy efficiency, conservation, and greenhouse gas reduction goals.

For more details on these programs please visit [New Jersey's Clean Energy Program website](http://www.njcleanenergy.com) .



2 EXISTING CONDITIONS

The New Jersey Board of Public Utilities (NJBPUB) has sponsored this Local Government Energy Audit (LGEA) report for Rumson Fairhaven High School. This report provides information on how your facility uses energy, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help you implement the ECMs.

TRC conducted this study as part of a comprehensive effort to assist New Jersey educational and local government facilities in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

2.1 Site Overview

The Rumson-Fair Haven Regional High School located at 74 Ridge Road is a regional, four-year comprehensive public high school serving students in ninth through twelfth grades. The facility is comprised of a school building that includes typical educational, administrative, assembly and recreation spaces. The school building is a 180,000 square foot building originally built in 1936 and expanded in 1995 to accommodate additional spaces. Spaces include classrooms, administrative offices, gymnasiums, locker rooms, training rooms, auditorium, library, kitchen, cafeteria, conference rooms, corridors, lobbies, restrooms, storage, and mechanical spaces. Apart from the high school building, the facility also has a 7,500 square foot Pole Barn and a 1,375 square foot Concession Stand.

Facility lighting systems consist of a mix of linear fluorescent fixtures, LED lighting and compact fluorescent lamps (CFLs). The school building is 100% heated and cooled by geothermal water source heat pumps and rooftop units (RTUs).

Facility concerns include water source heat pumps that are operating near the end of their useful service life.

Recent improvements and Facility Concerns

Over the last two years, the facility has completed a partial interior lighting retrofit and replaced the library water source heat pumps with new RTUs and air source heat pumps.

2.2 Building Occupancy

The school operates on a 12-month schedule. The gymnasiums, locker rooms, team and training rooms are used after classes for sports and other events. There are some Saturday activities in the gymnasium. The entire facility is shut down around 11:00 PM after the cleaning process.

During a typical day, the facility is occupied by approximately 1500 students and 150 staff. It should be noted that the energy and economic analysis for this building is based on the use of the building during the utility billing period, and that results will vary based on changes to building use patterns.

| Building Name | Weekday/Weekend | Operating Schedule |
|---|-----------------|--------------------|
| Rumson Fairhaven Regional HS - General Operating Hours | Weekday | 6:00 AM - 11:00 PM |
| | Saturday | 7:00 AM - 2:00 PM |
| Rumson Fairhaven Regional HS - General Classes Hours | Weekday | 7:45 AM - 2:40 PM |
| | Weekend | Closed |

Figure 3 - Building Occupancy Schedule

2.3 Building Envelope

Building walls are constructed of concrete masonry units (CMU) over structural steel with a brick façade, with gypsum drywall painted and CMU interior finish. The level of exterior wall insulation is unknown. The building has both flat roof areas and pitched roof sections supported by steel trusses. The original building has a pitched roof covered with slate shingles that are in aging fair condition. The addition has a flat white rubber roof and pitched asphalt roof sections with shingles that are in good condition. Some areas of the flat roof have poor water drainage.

Most of the windows are double pane and have aluminum frames with a thermal break. The operable window weather seals are in good condition, showing little evidence of excessive wear. Exterior doors are mostly FRP (fiberglass-reinforced polymers) rated doors and are in good condition. Degraded window and door seals increase drafts and outside air infiltration.



School Building Walls



School Building flat & pitched roof Sections.



Concession Stand & Pole Barn



Windows – School Building



Main entrance & Exterior doors – School Building

2.4 Lighting Systems

The primary interior lighting systems use either 32-Watt linear fluorescent T8 lamps or LED fixtures and lamps. Additionally, there are several compact fluorescent lamps (CFL) linear T5 lamps and some incandescent and T12 lamps. Typically, T5 and T8 fluorescent lamps use electronic ballasts and T12 fluorescent lamps use magnetic ballasts. Fixture types include 2- 3- 4 or 6-lamp, 2- or 4-foot-long troffer, recessed, surface mounted fixtures and 2-foot fixtures with U-bend linear tube lamps.

Lighting in many spaces including hallways, stairs, lobbies, entrances, upper library, some offices, and classrooms have been retrofit with LED sources. The auditorium, gymnasium and fitness room are lit with high output linear T5 while a small number of linear T12 lamps provide illumination for custodial closets and storage areas. Compact fluorescent lamps (CFLs) are used in the cafeteria, auditorium lobby and a very few additional fixtures. Incandescent lighting is limited, mainly in closets and for the kitchen hood area. The remaining spaces are lit with linear fluorescent T8 fixtures. All exit signs are LED.

Most fixtures are in fair condition. Interior lighting levels were generally sufficient. Most lighting fixtures in the classrooms and offices are controlled by occupancy sensors while some are controlled by manual wall switch. The lights in the hallway and lobbies are controlled by the building automation system (BAS) system.

The Concession Stand and Pole Barn are mostly illuminated with 32-Watt linear fluorescent T8 lamps.


Exterior fixtures include LED wall packs, pole lighting fixtures with LED retrofit “corn” bulbs, compact fluorescent lamps (CFLs), and canopy fixtures with fluorescent lamps. Fixtures are controlled by timers.



Linear Fluorescent T8 & T5HO



2-Foot Long T8, U-Shape Fluorescent & LED Fixtures



LED & Recessed Can CFL Fixtures



Wall Mounted Occupancy Sensors & Switches.



Pole Fixture w/ LED Corn Bulb & LED pole fixtures



LED Wall Mounted Fixtures

Unitary Electric HVAC Equipment

The IT closet is cooled by a 1.5 Ton ductless mini split air conditioner (AC) that is in good condition. The 3rd floor elevator room, media center, and girl locker room office are heated and cooled using air source heat pumps. These vary from 11 MBh to 161 MBh in heating capacity cooling capacities ranging from 0.75 Tons to 12 Tons. The elevator room unit appears in fair condition and has been evaluated for replacement. The units serving the media center were recently installed. The unitary electric HVAC equipment is controlled by programmable thermostats.



Media Center Heat Pumps & Programmable Thermostat

Unitary Heating Equipment

The high school's main entrance and stairwells, the Pole Barn, the Concession Stand bathroom and a handful of other restrooms are heated by electric resistance heaters that range in capacity between 3 kW and 5 kW. The units are in good condition. Equipment is controlled by a manual dial thermostat.



Electric resistance heaters

Packaged Units


Heating and cooling for larger occupied areas including media center, woodshop, laboratories, and room 606 are provided by six roof mounted packaged units (RTUs) connected to ducted distribution systems. They are furnished with direct expansion coils for cooling and equipped with gas-fired furnace sections for heating. Units are also equipped with economizers to regulate outside air intake. The units vary between 4 tons and 10 tons in cooling capacity and have heating capacities ranging between 49 MBh and 320 MBh. Some of the fans are equipped with variable frequency drives (VFDs).

They are in good working condition and controlled by the BAS.

| Unit ID | Area Served | Cooling Capacity (tons) | Supply Fan(hp) | Exhaust Fan (hp) | Condition |
|---------|--------------------|-------------------------|----------------|------------------|-----------|
| RTU-606 | Room 606 | 5 | 3.0 | | Good |
| MUA-1 | Lab 601,608 & 609 | 10 | 5.0 | | Good |
| RTU-210 | Media Center | 10 | 3.0 | | Good |
| DOAS-1 | Media Center | 4 | 2.0 | 1.0 | Good |
| RTU-1 | Woodshop | 10 | 3.0 | | Good |
| RTU-420 | Girl's Locker Room | 9 | 2.0 | | Good |



Package roof top units (RTUs)



BAS Screenshot - RTU-1

Building General Exhaust Air Systems


The restrooms are exhausted by motor driven roof mounted exhaust fans. Some classrooms including science rooms have specialty exhaust and fume-hood exhaust fans. There are also general exhaust fans throughout the building which exhaust corridors and miscellaneous rooms. Equipment is in good condition and is controlled by manual switches.




General exhaust fan & Classroom Fume Hood (EF-1).

Heat Recovery Units (HRUs)

The high school building uses 14 SEMCO series (FV) heat recovery units or energy recovery ventilators, labeled as "HRU". These outdoor air pre-conditioners are designed to reduce the energy required to heat or cool outdoor air. They are equipped with varying sizes of constant speed supply and exhaust fans. The units are 19 years old and appear in fair condition. They are controlled by the BAS.



Typical HRU - HRU-9



BAS Screenshot - HRU-14

| Location | Unit ID | Supply Fan (hp) | Exhaust Fan (hp) |
|----------|---------|-----------------|------------------|
| Roof | HRU-1 | 1.5 | 1.5 |
| Roof | HRU-2 | 1.5 | 1.5 |
| Roof | HRU-3 | 0.8 | 0.8 |
| Roof | HRU-4 | 5.0 | 5.0 |
| Roof | HRU-5 | 5.0 | 7.5 |
| Roof | HRU-6 | 0.8 | 0.8 |
| Roof | HRU-7 | 5.0 | 5.0 |
| Roof | HRU-8 | 10 | 10 |
| Roof | HRU-9 | 7.5 | 7.5 |
| Roof | HRU-10 | 1.5 | 1.5 |
| Roof | HRU-11 | 3.0 | 3.0 |
| Roof | HRU-12 | 3.0 | 3.0 |
| Roof | HRU-13 | 5.0 | 5.0 |
| Roof | HRU-14 | 1.5 | 1.5 |

2.6 Geothermal Water Source Heat Pumps

The building is mainly heated and cooled by 132 geothermal water source heat pumps (WSHPs) that use the relatively constant temperature of the earth as the heat exchanger medium as opposed to using the outside air temperature differential, like an air source heat pump.


There are 117 FHP WSHPs equipped with compressors that use R22 refrigerant, and 15 Geo Excel WSHPs that use R410A refrigerant. The WSHPs vary in cooling capacities between 1.5 to 10 Tons and heating capacities between 13 to 174 MBh. They are equipped with blower motors that vary in size between 0.1 to 5 hp. The units are 19 years old and have reached the end of their useful life. They have been evaluated for replacement. The WSHPs are controlled by the BAS.

During the cooling mode, the WSHP unit's refrigerant-to-water heat exchanger acts as a condenser and its refrigerant-to-air coil acts as an evaporator. The reversing valve is energized for cooling.

During the heating mode, the WSHP unit's refrigerant-to-water heat exchanger acts as an evaporator and its refrigerant to air coil acts as a condenser. The reversing valve is deenergized for heating.

Condenser water from a well is circulated to WSHP units by two 100 hp variable flow base mounted pumps (P1A & P2B) located in pump room 417. The pumps are configured in an automated lead-lag control scheme.

At the time of the audit, the building condenser water loop supply and return temperature were respectively 69.8°F and 69.2°F with an outside air temperature of 45°F. The space cooling and heating temperature setpoints are 72°F and 75°F respectively when occupied, and 64°F and 78°F respectively when unoccupied.




Typical FHP WSHP



BAS Screenshot - Typical WSHP




Variable Flow Condenser Water Pumps



BAS Screenshot - Condenser Water Loop

2.7 Building Automation System (BAS)

A Niagara BAS installed in 2004 controls the HVAC equipment, the heat recovery units (HRUs), the WSHPs, the package units, and some interior lights. The BAS provides equipment scheduling control, monitors and controls space temperatures, supply air temperatures, humidity, and condenser water loop temperatures.



Main Screen - BAS Controls

2.8 Domestic Hot Water

Domestic hot water is produced by three storage tank water heaters. Two 100 gallon 199 MBh condensing water heaters with an efficiency rating of 97% are located in the custodial closet and serve most of the high school's domestic hot water needs. At the time of the audit both the tank temperature and operating setpoint temperature were 140°F. The high school senior section is served by a 100-gallon 18 kW electric water heater located in the storage room. The heaters are in good condition. Two fractional horsepower pumps circulate water to the end users.

The condensing storage tank water heaters domestic hot water pipes are not insulated, and the insulation is in poor condition.

The concession stand has a dedicated 60-gallon 199 MBh storage tank water heater with an efficiency rating of 80%. The high temperature dishwasher has a 45-kW booster water heater.



Condensing Storage Tank Water Heaters



Touch Screen (Condensing Water Heater) & Booster Water Heater

2.9 Food Service Equipment

The kitchen has a mix of gas and electric equipment that is used to prepare breakfasts and lunches for students. Most cooking is done using a gas-fired oven. Bulk prepared foods are held in two electric holding cabinets. Equipment is not high efficiency and is in fair condition.

The main kitchen dishwasher is a non-ENERGY STAR high temperature, rack type unit. A 45-kW booster is connected.

Visit https://www.energystar.gov/products/commercial_food_service_equipment for the latest information on high efficiency food service equipment.



Oven, fryer & dishwasher

2.10 Refrigeration

The kitchen has five stand-up refrigerators and one stand-up freezer with solid doors. There are six refrigerator chests. Most equipment is standard efficiency and in fair condition.

The walk-in medium temperature freezer has a 0.32-ton compressor located outside the kitchen and a 2-fan evaporator.

There two self-contained ice machines located in the ice room and in room 609. They are not ENERGY STAR rated equipment.

Visit https://www.energystar.gov/products/commercial_food_service_equipment for the latest information on high efficiency food service equipment.



Stand up refrigerators & walk in freezer.



Evaporator fans, freezer & refrigerator temperatures

2.11 Plug Load and Vending Machines

There are approximately 168 desktops throughout the facility. Plug loads include general café and office equipment. There are school typical loads such as smart boards, projectors, scanner/copier, small printer, microwaves, min-fridges, television, and laptops. Workshops and STEM classrooms have plug loads that include pottery equipment, 3D printers, and wood shop equipment.

There are several residential style refrigerators, and these vary in condition and efficiency.

There is one refrigerated beverage vending machine and handful of ice machines. The vending machine is not equipped with occupancy-based controls.



Scanner/Copier & Residential Refrigerator

2.12 Water-Using Systems

There are several restrooms with sinks, toilets and/or urinals. Faucet flow rates are at 2.2 gallons per minute (gpm) or higher. Some restrooms have low flow devices. Girl's and boy's locker rooms are used frequently and have showerheads that are equipped with low flow devices.




Lavatory & Kitchen Sinks

3 ENERGY USE AND COSTS

Twelve months of utility billing data are used to develop annual energy consumption and cost data. This information creates a profile of the annual energy consumption and energy costs.

| Utility Summary | | |
|-----------------|---------------|-----------|
| Fuel | Usage | Cost |
| Electricity | 2,206,520 kWh | \$270,867 |
| Natural Gas | 6,434 Therms | \$11,474 |
| Total | | \$282,340 |



An energy balance identifies and quantifies energy use in your various building systems. This can highlight areas with the most potential for improvement. This energy balance was developed using calculated energy use for each of the end uses noted in the figure.

The energy auditor collects information regarding equipment operating hours, capacity, efficiency, and other operational parameters from facility staff, drawings, and on-site observations. This information is used as the inputs to calculate the existing conditions energy use for the site. The calculated energy use is then compared to the historical energy use and the initial inputs are revised, as necessary, to balance the calculated energy use to the historical energy use.





Figure 4 - Energy Balance

3.1 Electricity

JCP&L delivers electricity under rate class General Service Secondary 3 Phase, with electric production provided by EDF Energy, a third-party supplier.




| Electric Billing Data | | | | | |
|-----------------------|----------------|----------------------|-------------|-----------------|---------------------|
| Period Ending | Days in Period | Electric Usage (kWh) | Demand (kW) | Demand Cost | Total Electric Cost |
| 11/5/21 | 31 | 150,000 | 463 | \$3,665 | \$16,300 |
| 12/3/21 | 28 | 152,000 | 463 | \$3,665 | \$16,517 |
| 1/4/22 | 32 | 211,120 | 423 | \$3,120 | \$22,651 |
| 2/2/22 | 29 | 209,520 | 460 | \$3,396 | \$22,779 |
| 3/3/22 | 29 | 199,520 | 460 | \$3,396 | \$21,857 |
| 4/4/22 | 32 | 204,400 | 431 | \$3,181 | \$22,092 |
| 5/4/22 | 30 | 166,560 | 390 | \$2,880 | \$18,305 |
| 6/3/22 | 30 | 185,520 | 440 | \$3,482 | \$20,672 |
| 7/5/22 | 32 | 188,960 | 463 | \$3,665 | \$21,172 |
| 8/4/22 | 30 | 174,080 | 463 | \$3,665 | \$19,800 |
| 9/2/22 | 29 | 176,520 | 340 | \$2,694 | \$32,365 |
| 10/5/22 | 33 | 188,320 | 441 | \$3,252 | \$36,356 |
| Totals | 365 | 2,206,520 | 463 | \$40,062 | \$270,867 |
| Annual | 365 | 2,206,520 | 463 | \$40,062 | \$270,867 |

Notes:

- Peak demand of 463 kW occurred in October '21 and at other times.
- Average demand over the past 12 months was 436 kW.
- The average electric cost over the past 12 months was \$0.123/kWh, which is the blended rate that includes energy supply, distribution, demand, and other charges. This report uses this blended rate to estimate energy cost savings.
- Heat pumps provide most of the heating and cooling at this facility, therefore, electricity use is relatively constant through the calendar year.

3.2 Natural Gas

NJ Natural Gas delivers natural gas under Monthly 057M rate class.



| Gas Billing Data | | | |
|------------------|----------------|----------------------------|------------------|
| Period Ending | Days in Period | Natural Gas Usage (Therms) | Natural Gas Cost |
| 11/16/21 | 29 | 500 | \$848 |
| 12/17/21 | 31 | 785 | \$1,281 |
| 1/20/22 | 34 | 870 | \$1,300 |
| 2/18/22 | 29 | 784 | \$1,287 |
| 3/21/22 | 31 | 826 | \$1,299 |
| 4/21/22 | 31 | 772 | \$1,229 |
| 5/19/22 | 28 | 550 | \$1,028 |
| 6/20/22 | 32 | 402 | \$902 |
| 7/20/22 | 30 | 190 | \$538 |
| 8/17/22 | 28 | 201 | \$566 |
| 9/19/22 | 33 | 201 | \$587 |
| 10/18/22 | 29 | 351 | \$610 |
| Totals | 365 | 6,434 | \$11,474 |
| Annual | 365 | 6,434 | \$11,474 |

Notes:

- The average gas cost for the past 12 months is \$1.783/therm, which is the blended rate used throughout the analysis.
- Gas use is seasonally higher in the colder months due to limited gas heating. Domestic hot water and cooking contribute to a relatively high baseline of gas use across the calendar year.

3.3 Benchmarking

Your building was benchmarked using the United States Environmental Protection Agency's (EPA) *Portfolio Manager*® software. Benchmarking compares your building's energy use to that of similar buildings across the country, while neutralizing variations due to location, occupancy, and operating hours. Some building types can be scored with a 1-100 ranking of a building's energy performance relative to the national building market. A score of 50 represents the national average and a score of 100 is best.

This ENERGY STAR benchmarking score provides a comprehensive snapshot of your building's energy performance. It assesses the building's physical assets, operations, and occupant behavior, which is compiled into a quick and easy-to-understand score.

| | |
|---------------------------|-----------|
| Benchmarking Score | 67 |
|---------------------------|-----------|




Figure 5 - Energy Use Intensity Comparison³

Congratulations, your building performs better than the national average. This report has suggestions about how to keep your building running efficiently, further improve performance, and lower your energy bills even more.

Energy use intensity (EUI) measures energy consumption per square foot and is the standard metric for comparing buildings' energy performance. A lower EUI means better performance and less energy consumed. Several factors can cause a building to vary from typical energy usage. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and occupant behavior all contribute to a building's energy use and the benchmarking score.

³ Based on all evaluated ECMs



Tracking Your Energy Performance

Keeping track of your energy use on a monthly basis is one of the best ways to keep energy costs in check. Update your utility information in Portfolio Manager regularly, so that you can keep track of your building's performance.

We have created a Portfolio Manager account for your facility and have already entered the monthly utility data shown above for you. Account login information for your account will be sent via email.

Free online training is available to help you use ENERGY STAR Portfolio Manager to track your building's performance at: <https://www.energystar.gov/buildings/training>.

For more information on ENERGY STAR and Portfolio Manager, visit their [website](#).

4 ENERGY CONSERVATION MEASURES

The goal of this audit report is to identify and evaluate potential energy efficiency improvements and provide information about the cost effectiveness of those improvements. Most energy conservation measures have received preliminary analysis of feasibility, which identifies expected ranges of savings. This level of analysis is typically sufficient to demonstrate project cost-effectiveness and help prioritize energy measures.

Calculations of energy use and savings are based on the current version of the *New Jersey's Clean Energy Program Protocols to Measure Resource Savings*, which is approved by the NJBPU. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances.

Operation and maintenance costs for the proposed new equipment will generally be lower than the current costs for the existing equipment—especially if the existing equipment is at or past its normal useful life. We have conservatively assumed there to be no impact on overall maintenance costs over the life of the equipment.

Financial incentives in this report are based on the previously run state rebate program SmartStart, which has been retired. Now, all investor-owned gas and electric utility companies are offering complementary energy efficiency programs directly to their customers. Some measures and proposed upgrades may be eligible for higher incentives than those shown below. The incentives in the summary tables should be used for high-level planning purposes. To verify incentives, reach out to your utility provider or visit the [NJCEP website](#) for more information.

For a detailed list of the locations and recommended energy conservation measures for all inventoried equipment, see Appendix A: Equipment Inventory & Recommendations.

| # | Energy Conservation Measure | Cost Effective? | Annual Electric Savings (kWh) | Peak Demand Savings (kW) | Annual Fuel Savings (MMBtu) | Annual Energy Cost Savings (\$) | Estimated M&L Cost (\$) | Estimated Incentive (\$) * | Estimated Net M&L Cost (\$) | Simple Payback Period (yrs) ** | CO ₂ e Emissions Reduction (lbs) |
|--|---|-----------------|-------------------------------|--------------------------|-----------------------------|---------------------------------|-------------------------|----------------------------|-----------------------------|--------------------------------|---|
| Lighting Upgrades | | | 236,184 | 38.0 | 0 | \$28,993 | \$60,483 | \$14,760 | \$45,723 | 1.6 | 237,835 |
| ECM 1 | Install LED Fixtures | Yes | 5,256 | 0.0 | 0 | \$645 | \$3,429 | \$450 | \$2,979 | 4.6 | 5,293 |
| ECM 2 | Retrofit Fluorescent Fixtures with LED Lamps and Drivers | Yes | 2,266 | 0.4 | 0 | \$278 | \$788 | \$106 | \$682 | 2.5 | 2,282 |
| ECM 3 | Retrofit Fixtures with LED Lamps | Yes | 228,662 | 37.5 | 0 | \$28,070 | \$56,265 | \$14,204 | \$42,061 | 1.5 | 230,261 |
| Lighting Control Measures | | | 2,738 | 0.5 | 0 | \$336 | \$1,890 | \$245 | \$1,645 | 4.9 | 2,757 |
| ECM 4 | Install Occupancy Sensor Lighting Controls | Yes | 2,738 | 0.5 | 0 | \$336 | \$1,890 | \$245 | \$1,645 | 4.9 | 2,757 |
| Variable Frequency Drive (VFD) Measures | | | 99,678 | 31.7 | 0 | \$12,236 | \$124,845 | \$13,300 | \$111,545 | 9.1 | 100,375 |
| ECM 5 | Install VFDs on Constant Volume (CV) Fans | Yes | 99,678 | 31.7 | 0 | \$12,236 | \$124,845 | \$13,300 | \$111,545 | 9.1 | 100,375 |
| Unitary HVAC Measures | | | 57,883 | 63.6 | 0 | \$7,106 | \$966,092 | \$36,727 | \$929,365 | 130.8 | 58,288 |
| ECM 6 | Install High Efficiency Heat Pumps | No | 57,883 | 63.6 | 0 | \$7,106 | \$966,092 | \$36,727 | \$929,365 | 130.8 | 58,288 |
| HVAC System Improvements | | | 0 | 0.0 | 22 | \$390 | \$2,824 | \$424 | \$2,400 | 6.2 | 2,558 |
| ECM 7 | Install Pipe Insulation | Yes | 0 | 0.0 | 22 | \$390 | \$2,824 | \$424 | \$2,400 | 6.2 | 2,558 |
| Domestic Water Heating Upgrade | | | 9,036 | 0.0 | 38 | \$1,790 | \$767 | \$379 | \$388 | 0.2 | 13,570 |
| ECM 8 | Install Low-Flow DHW Devices | Yes | 9,036 | 0.0 | 38 | \$1,790 | \$767 | \$379 | \$388 | 0.2 | 13,570 |
| Food Service & Refrigeration Measures | | | 4,760 | 0.3 | 19 | \$919 | \$12,319 | \$755 | \$11,564 | 12.6 | 6,994 |
| ECM 9 | Food Service Equipment Replacement | No | 0 | 0.0 | 19 | \$335 | \$9,290 | \$500 | \$8,790 | 26.2 | 2,200 |
| ECM 10 | Refrigerator/Freezer Case Electrically Commutated Motors | Yes | 983 | 0.1 | 0 | \$121 | \$607 | \$80 | \$527 | 4.4 | 990 |
| ECM 11 | Refrigeration Controls | Yes | 2,165 | 0.0 | 0 | \$266 | \$2,193 | \$125 | \$2,068 | 7.8 | 2,180 |
| ECM 12 | Vending Machine Control | Yes | 1,612 | 0.2 | 0 | \$198 | \$230 | \$50 | \$180 | 0.9 | 1,623 |
| Custom Measures | | | 24,619 | 0.0 | 0 | \$3,022 | \$3,950 | \$0 | \$3,950 | 1.3 | 24,791 |
| ECM 13 | Replace Electric Water Heater with Heat Pump Water Heater | Yes | 24,619 | 0.0 | 0 | \$3,022 | \$3,950 | \$0 | \$3,950 | 1.3 | 24,791 |
| TOTALS | | | 434,898 | 134.1 | 79 | \$54,792 | \$1,173,170 | \$66,590 | \$1,106,580 | 20.2 | 447,168 |

* - All incentives presented in this table are included as placeholders for planning purposes and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 6 – All Evaluated ECMs

| # | Energy Conservation Measure | Annual Electric Savings (kWh) | Peak Demand Savings (kW) | Annual Fuel Savings (MMBtu) | Annual Energy Cost Savings (\$) | Estimated M&L Cost (\$) | Estimated Incentive (\$)* | Estimated Net M&L Cost (\$) | Simple Payback Period (yrs)** | CO ₂ e Emissions Reduction (lbs) |
|--|---|-------------------------------|--------------------------|-----------------------------|---------------------------------|-------------------------|---------------------------|-----------------------------|-------------------------------|---|
| Lighting Upgrades | | 236,184 | 38.0 | 0 | \$28,993 | \$60,483 | \$14,760 | \$45,723 | 1.6 | 237,835 |
| ECM 1 | Install LED Fixtures | 5,256 | 0.0 | 0 | \$645 | \$3,429 | \$450 | \$2,979 | 4.6 | 5,293 |
| ECM 2 | Retrofit Fluorescent Fixtures with LED Lamps and Drivers | 2,266 | 0.4 | 0 | \$278 | \$788 | \$106 | \$682 | 2.5 | 2,282 |
| ECM 3 | Retrofit Fixtures with LED Lamps | 228,662 | 37.5 | 0 | \$28,070 | \$56,265 | \$14,204 | \$42,061 | 1.5 | 230,261 |
| Lighting Control Measures | | 2,738 | 0.5 | 0 | \$336 | \$1,890 | \$245 | \$1,645 | 4.9 | 2,757 |
| ECM 4 | Install Occupancy Sensor Lighting Controls | 2,738 | 0.5 | 0 | \$336 | \$1,890 | \$245 | \$1,645 | 4.9 | 2,757 |
| Variable Frequency Drive (VFD) Measures | | 99,678 | 31.7 | 0 | \$12,236 | \$124,845 | \$13,300 | \$111,545 | 9.1 | 100,375 |
| ECM 5 | Install VFDs on Constant Volume (CV) Fans | 99,678 | 31.7 | 0 | \$12,236 | \$124,845 | \$13,300 | \$111,545 | 9.1 | 100,375 |
| HVAC System Improvements | | 0 | 0.0 | 22 | \$390 | \$2,824 | \$424 | \$2,400 | 6.2 | 2,558 |
| ECM 7 | Install Pipe Insulation | 0 | 0.0 | 22 | \$390 | \$2,824 | \$424 | \$2,400 | 6.2 | 2,558 |
| Domestic Water Heating Upgrade | | 9,036 | 0.0 | 38 | \$1,790 | \$767 | \$379 | \$388 | 0.2 | 13,570 |
| ECM 8 | Install Low-Flow DHW Devices | 9,036 | 0.0 | 38 | \$1,790 | \$767 | \$379 | \$388 | 0.2 | 13,570 |
| Food Service & Refrigeration Measures | | 4,760 | 0.3 | 0 | \$584 | \$3,029 | \$255 | \$2,774 | 4.7 | 4,793 |
| ECM 10 | Refrigerator/Freezer Case Electrically Commutated Motors | 983 | 0.1 | 0 | \$121 | \$607 | \$80 | \$527 | 4.4 | 990 |
| ECM 11 | Refrigeration Controls | 2,165 | 0.0 | 0 | \$266 | \$2,193 | \$125 | \$2,068 | 7.8 | 2,180 |
| ECM 12 | Vending Machine Control | 1,612 | 0.2 | 0 | \$198 | \$230 | \$50 | \$180 | 0.9 | 1,623 |
| Custom Measures | | 24,619 | 0.0 | 0 | \$3,022 | \$3,950 | \$0 | \$3,950 | 1.3 | 24,791 |
| ECM 13 | Replace Electric Water Heater with Heat Pump Water Heater | 24,619 | 0.0 | 0 | \$3,022 | \$3,950 | \$0 | \$3,950 | 1.3 | 24,791 |
| TOTALS | | 377,015 | 70.5 | 60 | \$47,352 | \$197,788 | \$29,363 | \$168,425 | 3.6 | 386,680 |

* - All incentives presented in this table are included as placeholders for planning purposes and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 7 – Cost Effective ECMs

4.1 Lighting

| # | Energy Conservation Measure | Annual Electric Savings (kWh) | Peak Demand Savings (kW) | Annual Fuel Savings (MMBtu) | Annual Energy Cost Savings (\$) | Estimated M&L Cost (\$) | Estimated Incentive (\$)* | Estimated Net M&L Cost (\$) | Simple Payback Period (yrs)** | CO ₂ e Emissions Reduction (lbs) |
|--------------------------|--|-------------------------------|--------------------------|-----------------------------|---------------------------------|-------------------------|---------------------------|-----------------------------|-------------------------------|---|
| Lighting Upgrades | | 236,184 | 38.0 | 0 | \$28,993 | \$60,483 | \$14,760 | \$45,723 | 1.6 | 237,835 |
| ECM 1 | Install LED Fixtures | 5,256 | 0.0 | 0 | \$645 | \$3,429 | \$450 | \$2,979 | 4.6 | 5,293 |
| ECM 2 | Retrofit Fluorescent Fixtures with LED Lamps and Drivers | 2,266 | 0.4 | 0 | \$278 | \$788 | \$106 | \$682 | 2.5 | 2,282 |
| ECM 3 | Retrofit Fixtures with LED Lamps | 228,662 | 37.5 | 0 | \$28,070 | \$56,265 | \$14,204 | \$42,061 | 1.5 | 230,261 |

When considering lighting upgrades, we suggest using a comprehensive design approach that simultaneously upgrades lighting fixtures and controls to maximize energy savings and improve occupant lighting. Comprehensive design will also consider appropriate lighting levels for different space types to make sure that the right amount of light is delivered where needed. If conversion to LED light sources is proposed, we suggest converting all of a specific lighting type (e.g., linear fluorescent) to LED lamps to minimize the number of lamp types in use at the facility, which should help reduce future maintenance costs.

ECM 1: Install LED Fixtures

Replace existing fixtures containing metal halide lamps with new LED light fixtures. This measure saves energy by installing LEDs, which use less power than other technologies with a comparable light output.

In some cases, HID fixtures can be retrofit with screw-based LED lamps. Replacing an existing HID fixture with a new LED fixture will generally provide better overall lighting optics; however, replacing the HID lamp with a LED screw-in lamp is typically a less expensive retrofit. We recommend you work with your lighting contractor to determine which retrofit solution is best suited to your needs and will be compatible with the existing fixture(s).

Maintenance savings may also be achieved since LED lamps last longer than other light sources and therefore do not need to be replaced as often.

Affected Building Areas: exterior fixtures.

ECM 2: Retrofit Fluorescent Fixtures with LED Lamps and Drivers

Retrofit fluorescent T12 fixtures by removing the fluorescent tubes and ballasts and replacing them with LED tubes and LED drivers (if necessary), which are designed to be used in retrofitted fluorescent fixtures.

The measure uses the existing fixture housing but replaces the electric components with more efficient lighting technology, which use less power than other lighting technologies but provides equivalent lighting output. Maintenance savings may also be achieved since LED tubes last longer than fluorescent tubes and, therefore, do not need to be replaced as often.

Affected Building Areas: maintenance shop and custodial storages.

ECM 3: Retrofit Fixtures with LED Lamps

Replace fluorescent T5HO, T8, CFLs, and incandescent lamps with LED lamps. Many LED tubes are direct replacements for existing fluorescent tubes and can be installed while leaving the fluorescent fixture ballast in place. LED lamps can be used in existing fixtures as a direct replacement for most other lighting technologies. Be sure to specify replacement lamps that are compatible with existing dimming controls, where applicable. In some circumstances, you may need to upgrade your dimming system for optimum performance.

This measure saves energy by installing LEDs, which use less power than other lighting technologies yet provide equivalent lighting output for the space. Maintenance savings may also be available, as longer-lasting LEDs lamps will not need to be replaced as often as the existing lamps.

Affected Building Areas: all areas with fluorescent fixtures with T8 tubes, T5HO in auditorium and gymnasium, CFLs in various spaces and incandescent lamps in small spaces.

4.2 Lighting Controls

| # | Energy Conservation Measure | Annual Electric Savings (kWh) | Peak Demand Savings (kW) | Annual Fuel Savings (MMBtu) | Annual Energy Cost Savings (\$) | Estimated M&L Cost (\$) | Estimated Incentive (\$)* | Estimated Net M&L Cost (\$) | Simple Payback Period (yrs)** | CO ₂ e Emissions Reduction (lbs) |
|----------------------------------|--|-------------------------------|--------------------------|-----------------------------|---------------------------------|-------------------------|---------------------------|-----------------------------|-------------------------------|---|
| Lighting Control Measures | | 2,738 | 0.5 | 0 | \$336 | \$1,890 | \$245 | \$1,645 | 4.9 | 2,757 |
| ECM 4 | Install Occupancy Sensor Lighting Controls | 2,738 | 0.5 | 0 | \$336 | \$1,890 | \$245 | \$1,645 | 4.9 | 2,757 |

Lighting controls reduce energy use by turning off or lowering lighting fixture power levels when not in use. A comprehensive approach to lighting design should upgrade the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

ECM 4: Install Occupancy Sensor Lighting Controls

Install occupancy sensors to control lighting fixtures in areas that are frequently unoccupied, even for short periods. For most spaces, we recommend that lighting controls use dual technology sensors, which reduce the possibility of lights turning off unexpectedly.

Occupancy sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Most occupancy sensor lighting controls allow users to manually turn fixtures on/off, as needed. Some controls can also provide dimming options.

Occupancy sensors can be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are best suited to single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in large spaces, locations without local switching, and where wall switches are not in the line-of-sight of the main work area.

This measure provides energy savings by reducing the lighting operating hours.

Affected Building Areas: High School fitness area, senior building bathrooms, senior building slop sink, concession stand bathrooms.

4.3 Variable Frequency Drives (VFD)

| # | Energy Conservation Measure | Annual Electric Savings (kWh) | Peak Demand Savings (kW) | Annual Fuel Savings (MMBtu) | Annual Energy Cost Savings (\$) | Estimated M&L Cost (\$) | Estimated Incentive (\$)* | Estimated Net M&L Cost (\$) | Simple Payback Period (yrs)** | CO ₂ e Emissions Reduction (lbs) |
|--|---|-------------------------------|--------------------------|-----------------------------|---------------------------------|-------------------------|---------------------------|-----------------------------|-------------------------------|---|
| Variable Frequency Drive (VFD) Measures | | 99,677 | 31.7 | 0 | \$12,236 | \$124,845 | \$13,300 | \$111,545 | 9.1 | 100,374 |
| ECM 5 | Install VFDs on Constant Volume (CV) Fans | 99,677 | 31.7 | 0 | \$12,236 | \$124,845 | \$13,300 | \$111,545 | 9.1 | 100,374 |

Variable frequency drives control motors for fans, pumps, and process equipment based on the actual output required of the driven equipment. Energy savings result from more efficient control of motor energy usage when equipment operates at partial load. The magnitude of energy savings depends on the estimated amount of time that the motor would operate at partial load. For equipment with proposed VFDs, we have included replacing the controlled motor with a new inverter duty rated motor to conservatively account for the cost of an inverter duty rated motor.

ECM 5: Install VFDs on Constant Volume (CV) Fans

Install VFDs to control constant volume fan motor speeds. This converts a constant-volume, single-zone air handling system into a variable-air-volume (VAV) system. A separate VFD is usually required to control the return fan motor or dedicated exhaust fan motor if the air handler has one.

Zone thermostats signal the VFD to adjust fan speed to maintain the appropriate temperature in the zone, while maintaining a constant supply air temperature.

For air handlers with direct expansion (DX) cooling systems, the minimum air flow across the cooling coil required to prevent the coil from freezing must be determined during the final project design. The control system programming should maintain the minimum air flow whenever the compressor is operating. Prior to implementation, verify minimum fan speed in cooling mode with the manufacturer. Note that savings will vary depending on the operating characteristics of each AHU.

Energy savings result from reducing the fan speed (and power) when conditions allow for reduced air flow.

Affected Air Handlers: RTU-1, RTU-210, HRUs & some exhaust fans.

4.4 Unitary HVAC

| # | Energy Conservation Measure | Annual Electric Savings (kWh) | Peak Demand Savings (kW) | Annual Fuel Savings (MMBtu) | Annual Energy Cost Savings (\$) | Estimated M&L Cost (\$) | Estimated Incentive (\$)* | Estimated Net M&L Cost (\$) | Simple Payback Period (yrs)** | CO ₂ e Emissions Reduction (lbs) |
|------------------------------|------------------------------------|-------------------------------|--------------------------|-----------------------------|---------------------------------|-------------------------|---------------------------|-----------------------------|-------------------------------|---|
| Unitary HVAC Measures | | 57,883 | 63.6 | 0 | \$7,106 | \$966,092 | \$36,727 | \$929,365 | 130.8 | 58,288 |
| ECM 6 | Install High Efficiency Heat Pumps | 57,883 | 63.6 | 0 | \$7,106 | \$966,092 | \$36,727 | \$929,365 | 130.8 | 58,288 |

Replacing the unitary HVAC units has a long payback period and may not be justifiable based simply on energy considerations. However, most of the units are nearing or have reached the end of their normal useful life. Typically, the marginal cost of purchasing a high efficiency unit can be justified by the marginal savings from the improved efficiency. When the unitary HVAC units are eventually replaced, consider purchasing equipment that exceeds the minimum efficiency required by building codes.

ECM 6: Install High Efficiency Heat Pumps

We evaluated replacing old standard efficiency water source heat pumps with high efficiency water source heat pumps. A higher EER or SEER rating indicates a more efficient cooling system, and a higher HSPF rating indicates more efficient heating mode. The magnitude of energy savings for this measure depends on the relative efficiency of the older unit versus the new high efficiency unit, the average heating and cooling loads, and the estimated annual operating hours.

Affected Units: all water source heat pumps and the IT closet air source heat pump.

4.5 HVAC Improvements

| # | Energy Conservation Measure | Annual Electric Savings (kWh) | Peak Demand Savings (kW) | Annual Fuel Savings (MMBtu) | Annual Energy Cost Savings (\$) | Estimated M&L Cost (\$) | Estimated Incentive (\$)* | Estimated Net M&L Cost (\$) | Simple Payback Period (yrs)** | CO ₂ e Emissions Reduction (lbs) |
|---------------------------------|-----------------------------|-------------------------------|--------------------------|-----------------------------|---------------------------------|-------------------------|---------------------------|-----------------------------|-------------------------------|---|
| HVAC System Improvements | | 0 | 0.0 | 22 | \$390 | \$2,824 | \$424 | \$2,400 | 6.2 | 2,558 |
| ECM 7 | Install Pipe Insulation | 0 | 0.0 | 22 | \$390 | \$2,824 | \$424 | \$2,400 | 6.2 | 2,558 |

ECM 7: Install Pipe Insulation

Install insulation on domestic hot water system piping. Distribution system losses are dependent on system fluid temperature, the size of the distribution system, and the level of insulation of the piping. Significant energy savings can be achieved when insulation has not been well maintained. When the insulation is exposed to water, when the insulation has been removed from some areas of the pipe, or when valves have not been properly insulated system efficiency can be significantly reduced. This measure saves energy by reducing heat transfer in the distribution system.

Affected Systems: condensing storage tank water heaters domestic hot water piping.

4.6 Domestic Water Heating

| # | Energy Conservation Measure | Annual Electric Savings (kWh) | Peak Demand Savings (kW) | Annual Fuel Savings (MMBtu) | Annual Energy Cost Savings (\$) | Estimated M&L Cost (\$) | Estimated Incentive (\$)* | Estimated Net M&L Cost (\$) | Simple Payback Period (yrs)** | CO ₂ e Emissions Reduction (lbs) |
|---------------------------------------|------------------------------|-------------------------------|--------------------------|-----------------------------|---------------------------------|-------------------------|---------------------------|-----------------------------|-------------------------------|---|
| Domestic Water Heating Upgrade | | 9,036 | 0.0 | 38 | \$1,790 | \$767 | \$379 | \$388 | 0.2 | 13,570 |
| ECM 8 | Install Low-Flow DHW Devices | 9,036 | 0.0 | 38 | \$1,790 | \$767 | \$379 | \$388 | 0.2 | 13,570 |

ECM 8: Install Low-Flow DHW Devices

Install low-flow devices to reduce overall hot water demand. The following low-flow devices are recommended to reduce hot water usage:

| Device | Flow Rate |
|---------------------------------|-----------|
| Faucet aerators (lavatory) | 0.5 gpm |
| Faucet aerator (kitchen) | 1.5 gpm |
| Showerhead | 2.0 gpm |
| Pre-rinse spray valve (kitchen) | 1.28 gpm |

Low-flow devices reduce the overall water flow from the fixture, while still providing adequate pressure for washing. Pre-rinse spray valves (PRSVs), often used in commercial and institutional kitchens, remove food waste from dishes prior to dishwashing.

Additional cost savings may result from reduced water usage.

4.7 Food Service and Refrigeration

| # | Energy Conservation Measure | Annual Electric Savings (kWh) | Peak Demand Savings (kW) | Annual Fuel Savings (MMBtu) | Annual Energy Cost Savings (\$) | Estimated M&L Cost (\$) | Estimated Incentive (\$)* | Estimated Net M&L Cost (\$) | Simple Payback Period (yrs)** | CO ₂ e Emissions Reduction (lbs) |
|--|--|-------------------------------|--------------------------|-----------------------------|---------------------------------|-------------------------|---------------------------|-----------------------------|-------------------------------|---|
| Food Service & Refrigeration Measures | | 4,760 | 0.3 | 19 | \$919 | \$12,319 | \$755 | \$11,564 | 12.6 | 6,994 |
| ECM 9 | Food Service Equipment Replacement | 0 | 0.0 | 19 | \$335 | \$9,290 | \$500 | \$8,790 | 26.2 | 2,200 |
| ECM 10 | Refrigerator/Freezer Case Electrically Commutated Motors | 983 | 0.1 | 0 | \$121 | \$607 | \$80 | \$527 | 4.4 | 990 |
| ECM 11 | Refrigeration Controls | 2,165 | 0.0 | 0 | \$266 | \$2,193 | \$125 | \$2,068 | 7.8 | 2,180 |
| ECM 12 | Vending Machine Control | 1,612 | 0.2 | 0 | \$198 | \$230 | \$50 | \$180 | 0.9 | 1,623 |

ECM 9: Food Service Equipment Replacement

Buildings that use a lot of food service equipment are often among the most energy-intensive commercial buildings. Replace existing food service equipment with new, high-efficiency equipment.

Consider replacing the following equipment with high efficiency or ENERGY STAR labeled versions:

| Location | Quantity | Equipment Type | Manufacturer | Model |
|----------|----------|---------------------------------|--------------|-------|
| Kitchen | 1 | Gas Convection Oven (Full Size) | | |

Visit https://www.energystar.gov/products/commercial_food_service_equipment for the latest information on high efficiency food service equipment.

ECM 10: Refrigerator/Freezer Case Electrically Commutated Motors

Replace shaded pole or permanent split capacitor (PSC) motors with electronically commutated (EC) motors in walk-in coolers. Fractional horsepower EC motors are significantly more efficient than mechanically commutated, brushed motors, particularly at low speeds or partial load. By using variable-speed technology, EC motors can optimize fan usage. Because these motors are brushless and use DC power, losses due to friction and phase shifting are eliminated.

Savings for this measure consider both the increased efficiency of the motor as well as the reduction in refrigeration load due to motor heat loss.

ECM 11: Refrigeration Controls

Install additional controls to optimize the operation of walk-in cooler.

Many walk-in coolers and freezers have continuously operating electric heaters on the doors to prevent condensation formation. This measure adds a control system feature to shut off the door heaters when the humidity level is low enough that condensation will not occur if the heaters are off. This is done by measuring the ambient humidity and temperature of the store, comparing that to the dewpoint, and using pulse width modulation to control the anti-sweat door heaters.

Defrost controllers can be used to override defrost of evaporator fans when the defrost operation is not necessary, which reduces annual energy consumption. This measure is applicable to existing evaporator fans with a traditional electric de-frost mechanism.

Many walk-in coolers and freezers have evaporator fans that run continuously. The measure adds a control system feature to automatically shut off evaporator fans when not needed.

Energy savings for each of the control measures account for reduction in compressor and fan operating hours as well as reduction in the refrigeration heat load as appropriate.

ECM 12: Vending Machine Control

Vending machines operate continuously, even during unoccupied hours. Install occupancy sensor controls to reduce energy use. These controls power down vending machines when the vending machine area has been vacant for some time, and they power up the machines at necessary regular intervals or when the surrounding area is occupied. Energy savings are dependent on the vending machine and activity level in the area surrounding the machines.

4.8 Custom Measures

| # | Energy Conservation Measure | Annual Electric Savings (kWh) | Peak Demand Savings (kW) | Annual Fuel Savings (MMBtu) | Annual Energy Cost Savings (\$) | Estimated M&L Cost (\$) | Estimated Incentive (\$)* | Estimated Net M&L Cost (\$) | Simple Payback Period (yrs)** | CO ₂ e Emissions Reduction (lbs) |
|------------------------|---|-------------------------------|--------------------------|-----------------------------|---------------------------------|-------------------------|---------------------------|-----------------------------|-------------------------------|---|
| Custom Measures | | 24,619 | 0.0 | 0 | \$3,022 | \$3,950 | \$0 | \$3,950 | 1.3 | 24,791 |
| ECM 13 | Replace Electric Water Heater with Heat Pump Water Heater | 24,619 | 0.0 | 0 | \$3,022 | \$3,950 | \$0 | \$3,950 | 1.3 | 24,791 |

ECM 13: Replace Electric Water Heater with Heat Pump Water Heater

A typical electric water heater uses electric resistance coils to heat water at a coefficient of performance (COP) of 1. Air source heat pump water heaters (HPWH) use a refrigeration cycle to transfer heat from the surrounding air to the domestic water. The typical average COP for a HPWH is about 2.5, so they require significantly less electricity to produce the same amount of hot water as a traditional electric water heater. There are two types of HPWH, those integrated with the heat pump and storage tank in the same unit, and those that are split into two sections (with the storage tank separate from the heat pump). The following addresses integrated HPWH.

HPWH reject cold air. As such, they need to be installed in an unconditioned space of about 750 cubic feet with good ventilation. Ideal locations are garages, large enclosed, unconditioned storage areas, or areas with excess heat such as a furnace or boiler room.⁴ The HPWH will also produce condensate so accommodations for draining the condensate need to be provided.

Most HPWH operate effectively down to an air temperature of 40 °F. Below that temperature, an electric resistance booster heater is typically required to achieve full heating capacity. It is critical that the HPWH controls are set up so that the electric resistance heat only engages when the air temperature is too cold for the HPWH to extract heat from it. HPWHs have a slow recovery. During periods of high demand, the electric resistance heating element, if enabled, may be energized to maintain set point, thus reducing the overall efficiency of the unit. It is recommended that a careful analysis of the hot water demand be conducted to determine if the application makes economic sense, and the HPWH heating capacity and storage are properly sized.

HPWH operate most effectively when the temperature difference between the incoming and outgoing water is high. Generally, this means that cold make-up water should be piped to the bottom of the tank and return water should be piped to the top of the tank in order to maintain stratification within the storage tank. Water should be drawn from the bottom of the tank to be heated. If there is a DHW recirculation pump, it should only be operated during high hot water demand periods.

4.9

⁴<https://basc.pnnl.gov/code-compliance/heat-pump-water-heaters-code-compliance-brief#:~:text=HPWH%20must%20have%20unrestricted%20airflow,depending%20on%20size%20of%20system>

4.10 Measures for Future Consideration

There are additional opportunities for improvement that Rumson Fairhaven Regional HS may wish to consider. These potential upgrades typically require further analysis, involve substantial capital investment, and/or include significant system reconfiguration. These measure(s) are therefore beyond the scope of this energy audit. These measure(s) are described here to support a whole building approach to energy efficiency and sustainability.

Rumson Fairhaven Regional HS may wish to consider the Energy Savings Improvement Program (ESIP) or other whole building approach. With interest in implementing comprehensive, largescale and/or complex system wide projects, these measures may be pursued during development of a future energy savings plan. We recommend that you work with your energy service company (ESCO) and/or design team to:

- Evaluate these measures further.
- Develop firm costs.
- Determine measure savings.
- Prepare detailed implementation plans.

Other modernization or capital improvement funds may be leveraged for these types of refurbishments. As you plan for capital upgrades, be sure to consider the energy impact of the building systems and controls being specified.

Retro-Commissioning Study

Due to the complexity of today's HVAC systems and controls, a thorough analysis and rebalance of heating, ventilation, and cooling systems should periodically be conducted. There are indications at this site that systems may not be operating correctly or as efficiently as they could be. One important tool available to building operators to ensure proper system operation is retro-commissioning.

Retro-commissioning is a common practice recommended by the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE) to be implemented every few years. We recommend that you contact a reputable engineering firm that specializes in energy control systems and retro-commissioning. Ask them to propose a scope of work and an outline of the procedures and processes to be implemented, including a schedule and the roles of all responsible parties.

Once goals and responsibilities are established, the objective of the investigation process is to understand how the building is currently operating, identify the issues, and determine the most cost-effective way to improve performance. The retro-commissioning agent will review building documentation, interview building occupants, and inspect and test the equipment. Information is then compiled into a report and shared with facility staff, who will select which recommendations to implement after reviewing the findings.

The implementation phase puts the selected processes into place. Typical measures may include sensor calibration, equipment schedule changes, damper linkage repair and similar relatively low-cost adjustments—although more expensive sophisticated programming and building control system upgrades may be warranted. Approved measures may be implemented by the agent, the building staff, or by subcontractors. Typically, a combination of these individuals makes up the retro-commissioning team.

After the approved measures are implemented, the team will verify that the changes are working as expected. Baseline and post-case measurements will allow building staff to monitor equipment and ensure that the benefits are maintained.

5 ENERGY EFFICIENT BEST PRACTICES

A whole building maintenance plan will extend equipment life; improve occupant comfort, health, and safety; and reduce energy and maintenance costs.

Operation and maintenance (O&M) plans enhance the operational efficiency of HVAC and other energy intensive systems and could save 5%–20% of the energy usage in your building without substantial capital investment. A successful plan includes your records of energy usage trends and costs, building equipment lists, current maintenance practices, and planned capital upgrades, and it incorporates your ideas for improved building operation. Your plan will address goals for energy-efficient operation, provide detail on how to reach the goals, and outline procedures for measuring and reporting whether goals have been achieved.

You may already be doing some of these things—see our list below for potential additions to your maintenance plan. Be sure to consult with qualified equipment specialists for details on proper maintenance and system operation.

Energy Tracking with ENERGY STAR Portfolio Manager



You've heard it before—you cannot manage what you do not measure. ENERGY STAR Portfolio Manager is an online tool that you can use to measure and track energy and water consumption, as well as greenhouse gas emissions⁵. Your account has already been established. Now you can continue to keep tabs on your energy performance every month.

Weatherization

Caulk or weather strip leaky doors and windows to reduce drafts and loss of heated or cooled air. Sealing cracks and openings can reduce heating and cooling costs, improve building durability, and create a healthier indoor environment. Materials used may include caulk, polyurethane foam, and other weather-stripping materials. There is an energy savings opportunity by reducing the uncontrolled air exchange between the outside and inside of the building. Blower door assisted comprehensive building air sealing will reduce the amount of air exchange, which will in turn reduce the load on the buildings heating and cooling equipment, providing energy savings and increased occupant comfort.

Doors and Windows

Close exterior doors and windows in heated and cooled areas. Leaving doors and windows open leads to a loss of heat during the winter and chilled air during the summer. Reducing air changes per hour can lead to increased occupant comfort as well as heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

⁵ <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/use-portfolio-manager>.

Lighting Maintenance



- Clean lamps, reflectors and lenses of dirt, dust, oil, and smoke buildup every six to twelve months. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust. Together, this can reduce total light output by up to 60% while still drawing full power.
- In addition to routine cleaning, developing a maintenance schedule can ensure that maintenance is performed regularly, and it can reduce the overall cost of fixture re-lamping and re-ballasting. Group re-lamping and re-ballasting maintains lighting levels and minimizes the number of site visits by a lighting technician or contractor, decreasing the overall cost of maintenance.

Lighting Controls

As part of a lighting maintenance schedule, test lighting controls to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight and photocell sensors, maintenance involves cleaning sensor lenses and confirming that setpoints and sensitivity are configured properly. Adjust exterior lighting time clock controls seasonally as needed to match your lighting requirements.

Motor Maintenance

Motors have many moving parts. As these parts degrade over time, the efficiency of the motor is reduced. Routine maintenance prevents damage to motor components. Routine maintenance should include cleaning surfaces and ventilation openings on motors to prevent overheating, lubricating moving parts to reduce friction, inspecting belts and pulleys for wear and to ensure they are at proper alignment and tension, and cleaning and lubricating bearings. Consult a licensed technician to assess these and other motor maintenance strategies.

Fans to Reduce Cooling Load

Install ceiling fans to supplement your cooling system. Thermostat settings can typically be increased by 4°F with no change in overall occupant comfort due to the wind chill effect of moving air.

Thermostat Schedules and Temperature Resets



Use thermostat setback temperatures and schedules to reduce heating and cooling energy use during periods of low or no occupancy. Thermostats should be programmed for a setback of 5-10°F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

Economizer Maintenance

Economizers can significantly reduce cooling system load. A malfunctioning economizer can increase the amount of heating and mechanical cooling required by introducing excess amounts of cold or hot outside air. Common economizer malfunctions include broken outdoor thermostat or enthalpy control or dampers that are stuck or improperly adjusted.

Periodic inspection and maintenance will keep economizers working in sync with the heating and cooling system. This maintenance should be part of annual system maintenance, and it should include proper setting of the outdoor thermostat/enthalpy control, inspection of control and damper operation, lubrication of damper connections, and adjustment of minimum damper position.

AC System Evaporator/Condenser Coil Cleaning

Dirty evaporator and condenser coils restrict air flow and restrict heat transfer. This increases the loads on the evaporator and condenser fan and decreases overall cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

HVAC Filter Cleaning and Replacement

Air filters should be checked regularly (often monthly) and cleaned or replaced when appropriate. Air filters reduce indoor air pollution, increase occupant comfort, and help keep equipment operating efficiently. If the building has a building management system, consider installing a differential pressure switch across filters to send an alarm about premature fouling or overdue filter replacement. Over time, filters become less and less effective as particulate buildup increases. Dirty filters also restrict air flow through the air conditioning or heat pump system, which increases the load on the distribution fans.

Ductwork Maintenance

Duct maintenance has two primary goals: keep the ducts clean to avoid air quality problems and seal leaks to save energy. Check for cleanliness, obstructions that block airflow, water damage, and leaks. Ducts should be inspected at least every two years.

The biggest symptoms of clogged air ducts are differing temperatures throughout the building and areas with limited airflow from supply registers. If a particular air duct is clogged, then air flow will only be cut off to some rooms in the building—not all of them. The reduced airflow will make it more difficult for those areas to reach the temperature setpoint, which will cause the HVAC system to run longer to cool or heat that area properly. If you suspect clogged air ducts, ensure that all areas in front of supply registers are clear of items that may block or restrict air flow, and you should check for fire dampers or balancing dampers that have failed closed.

Duct leakage in commercial buildings can account for 5%–25% of the supply airflow. In the case of rooftop air handlers, duct leakage can occur to the outside of the building wasting conditioned air. Check ductwork for leakage. Eliminating duct leaks can improve ventilation system performance and reduce heating and cooling system operation.

Distribution system losses are dependent on-air system temperature, the size of the distribution system, and the level of insulation of the ductwork. Significant energy savings can be achieved when insulation has not been well maintained. When the insulation is missing or worn, the system efficiency can be significantly reduced. This measure saves energy by reducing heat transfer in the distribution system.

Label HVAC Equipment

For improved coordination in maintenance practices, we recommend labeling or re-labeling the site HVAC equipment. Maintain continuity in labeling by following labeling conventions as indicated in the facility drawings or BAS building equipment list. Use weatherproof or heatproof labeling or stickers for permanence, but do not cover over original equipment nameplates, which should be kept clean and readable whenever possible. Besides equipment, label piping for service and direction of flow when possible. Ideally, maintain a log of HVAC equipment, including nameplate information, asset tag designation, areas served, installation year, service dates, and other pertinent information.

This investment in your equipment will enhance collaboration and communication between your staff and your contracted service providers and may help you with regulatory compliance.

Optimize HVAC Equipment Schedules

Energy management systems (BAS) typically provide advanced controls for building HVAC systems, including chillers, boilers, air handling units, rooftop units and exhaust fans. The BAS monitors and reports operational status, schedules equipment start and stop times, locks out equipment operation based on outside air or space temperature, and often optimizes damper and valve operation based on complex algorithms. These BAS features, when in proper adjustment, can improve comfort for building occupants and save substantial energy.

Know your BAS scheduling capabilities. Regularly monitor HVAC equipment operating schedules and match them to building operating hours in order to eliminate unnecessary equipment operation and save energy. Monitoring should be performed often at sites with frequently changing usage patterns – daily in some cases. We recommend using the *optimal start* feature of the BAS (if available) to optimize the building warmup sequence. Most BAS scheduling programs provide for holiday schedules, which can be used during reduced use or shutdown periods. Finally, many systems are equipped with a one-time override function, which can be used to provide additional space conditioning due to a one-time, special event. When available this override feature should be used rather than changing the base operating schedule.

Water Heater Maintenance

The lower the supply water temperature that is used for hand washing sinks, the less energy is needed to heat the water. Reducing the temperature results in energy savings and the change is often unnoticeable to users. Be sure to review the domestic water temperature requirements for sterilizers and dishwashers as you investigate reducing the supply water temperature.

Also, preventative maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. At least once a year, follow manufacturer instructions to drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Annual checks should include checks for:

- Leaks or heavy corrosion on the pipes and valves.
- Corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot, or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional.
- For electric water heaters, look for signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank.
- For water heaters more than three years old, have a technician inspect the sacrificial anode annually.

Refrigeration Equipment Maintenance

Preventative maintenance keeps commercial refrigeration equipment running reliably and efficiently. Commercial refrigerators and freezers are mission-critical equipment that can cost a fortune when they go down. Even when they appear to be working properly, refrigeration units can be consuming too much energy. Have walk-in refrigeration and freezer and other commercial systems serviced at least annually. This practice will allow systems to perform to their highest capabilities and will help identify system issues if they exist.

Maintaining your commercial refrigeration equipment can save between five and ten percent on energy costs. When condenser coils are dirty, your commercial refrigerators and freezers work harder to maintain the temperature inside. Worn gaskets, hinges, door handles, or faulty seals cause cold air to leak from the unit, forcing the unit to run longer and use more electricity.

Regular cleaning and maintenance also help your commercial refrigeration equipment to last longer.

Water Conservation



Installing dual flush or low-flow toilets and low-flow/waterless urinals are ways to reduce water use. The EPA WaterSense® ratings for urinals is 0.5 gallons per flush (gpf) and for flush valve toilets is 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

For more information regarding water conservation go to the EPA's WaterSense website⁶ or download a copy of EPA's "WaterSense at Work: Best Management Practices for Commercial and Institutional Facilities"⁷ to get ideas for creating a water management plan and best practices for a wide range of water using systems.

Water conservation devices that do not reduce hot water consumption will not provide energy savings at the site level, but they may significantly affect your water and sewer usage costs. Any reduction in water use does however ultimately reduce grid-level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users.

If the facility has detached buildings with a master water meter for the entire campus, check for unnatural wet areas in the lawn or water seeping in the foundation at water pipe penetrations through the foundation. Periodically check overnight meter readings when the facility is unoccupied, and there is no other scheduled water usage.

Manage irrigation systems to use water more effectively outside the building. Adjust spray patterns so that water lands on intended lawns and plantings and not on pavement and walls. Consider installing an evapotranspiration irrigation controller that will prevent over-watering.

Procurement Strategies

Purchasing efficient products reduces energy costs without compromising quality. Consider modifying your procurement policies and language to require ENERGY STAR or WaterSense products where available.

⁶ <https://www.epa.gov/watersense>.

⁷ <https://www.epa.gov/watersense/watersense-work-0>.

6 ON-SITE GENERATION

You don't have to look far in New Jersey to see one of the thousands of solar electric systems providing clean power to homes, businesses, schools, and government buildings. On-site generation includes both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) technologies that generate power to meet all or a portion of the facility's electric energy needs. Also referred to as distributed generation, these systems contribute to greenhouse gas (GHG) emission reductions, demand reductions, and reduced customer electricity purchases, which results in improved electric grid reliability through better use of transmission and distribution systems.

Preliminary screenings were performed to determine if an on-site generation measure could be a cost-effective solution for your facility. Before deciding to install an on-site generation system, we recommend conducting a feasibility study to analyze existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.

6.1 Solar Photovoltaic


Photovoltaic (PV) panels convert sunlight into electricity. Individual panels are combined into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is then connected to the building's electrical distribution system.

A preliminary screening based on the facility's electric demand, size and location of free area, and shading elements shows that the facility has high potential for installing a PV array.

Methodology

Helioscope software was used to develop a conceptual PV design and Energy Toolbase software was used to develop the annual energy usage and project cost savings. For this analysis we considered the parking lot and rooftop areas. We assumed 10 degrees tilt angle for PV modules to maximize generation during summer months.

Please refer to the images below for possible locations to install a PV system



Proposed PV Module

Findings

Solar PV Equipment Description

Solar Panels: (2,216) LG Electronics LG400Q1C-46

Inverters: (48) Fronius USA Fronius Symo 15.0-3 (480V)

Annual Estimated Generation: 1,389,025 kWh

Solar PV System Cost: \$4,697,061

Solar PV System Rating Power Rating: 886,400 W-DC or 868,672 W-AC-CEC


Energy Consumption Mix



Utility 1,020,532 kWh (46.25%)

Solar PV 1,185,988 kWh (53.75%)

MONTHLY ENERGY USE VS SOLAR GENERATION



Please refer to Appendix D-1 "PV Analysis" for the Energy Toolbase report for additional information.

Successor Solar Incentive Program (SuSI)

The SuSI program replaces the SREC Registration Program (SRP) and the Transition Incentive (TI) program. The SuSI program is used to register and certify solar projects in New Jersey. Rebates are not available for solar projects. Solar projects may qualify to earn SREC- IIs (Solar Renewable Energy Certificates-II), however, the project owners *must* register their solar projects prior to the start of construction to establish the project's eligibility.

Get more information about solar power in New Jersey or find a qualified solar installer who can help you decide if solar is right for your building:

Successor Solar Incentive Program (SuSI): <https://www.njcleanenergy.com/renewable-energy/programs/susi-program>

- **Basic Info on Solar PV in NJ:** www.njcleanenergy.com/whysolar
- **NJ Solar Market FAQs:** www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs.
- **Approved Solar Installers in the NJ Market:** www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1

6.2 Combined Heat and Power

Combined heat and power (CHP) generates electricity at the facility and puts waste heat energy to good use. Common types of CHP systems are reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines.

CHP systems typically produce a portion of the electric power used on-site, with the balance of electric power needs supplied by the local utility company. The heat is used to supplement (or replace) existing boilers and provide space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for space cooling.

The key criteria used for screening is the amount of time that the CHP system would operate at full load and the facility's ability to use the recovered heat. Facilities with a continuous need for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has no potential for installing a cost-effective CHP system.

Based on a preliminary analysis, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation. The low or infrequent thermal load, and lack of space for siting the equipment are the most significant factors contributing to the lack of CHP potential.

The graphic below displays the results of the CHP potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.




Figure 8 - Combined Heat and Power Screening

Find a qualified firm that specializes in commercial CHP cost assessment and installation:
http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/

7 ELECTRIC VEHICLES (EV)

All electric vehicles (EVs) have an electric motor instead of an internal combustion engine. EVs function by plugging into a charge point, taking electricity from the grid, and then storing it in rechargeable batteries. Although electricity production may contribute to air pollution, the U.S. EPA categorizes all-electric vehicles as zero-emission vehicles because they produce no direct exhaust or tailpipe emissions.

EVs are typically more expensive than similar conventional and hybrid vehicles, although some cost can be recovered through fuel savings, federal tax credit, or state incentives.

7.1 Electric Vehicle Charging

EV charging stations provide a means for electric vehicle operators to recharge their batteries at a facility. While many EV drivers charge at home, others do not have access to regular home charging, and the ability to charge at work or in public locations is critical to making EVs practical for more drivers. Charging can also be used for electric fleet vehicles, which can reduce fuel and maintenance costs for fleets that replace gas or diesel vehicles with EVs.

EV charging comes in three main types. For this assessment, the screening considers addition of Level 2 charging, which is most common at workplaces and other public locations. Depending on the site type and usage, other levels of charging power may be more appropriate.

The preliminary assessment of EV charging at the facility shows that there is medium potential for adding EV chargers to the facility's parking, based on potential costs of installation and other site factors.

The primary costs associated with installing EV charging are the charger hardware and the cost to extend power from the facility to parking spaces. This may include upgrades to electric panels to serve increased loads.

The type and size of the parking area impact the costs and feasibility of adding EV charging. Parking structure installations can be less costly than surface lot installations as power may be readily available, and equipment and wiring can be surface mounted. Parking lot installations often require trenching through concrete or asphalt surface. Large parking areas provide greater flexibility in charger siting than smaller lots.

The location and capacity of facility electric panels also impact charger installation costs. A Level 2 charger generally requires a dedicated 208-240V, 40 Amp circuit. The electric panel nearest the planned installation may not have available capacity and may need to be upgraded to serve new EV charging loads. Alternatively, chargers could be powered from a more distant panel. The distance from the panel to the location of charging stations ties directly to costs, as conduits, cables, and potential trenching costs all increase on a per-foot basis. The more charging stations planned, the more likely it is that additional electrical capacity will be needed.

Other factors to consider when planning for EV charging at a facility include who the intended users are, how long they park vehicles at the site, and whether they will need to pay for the electricity they use.



The graphic below displays the results of the EV charging assessment conducted as part of this audit. The position of each slider indicates the impact each factor has on the feasibility of installing EV charging at the site.




Figure 9 – EV Charger Screening

Electric Vehicle Programs Available

New Jersey is leading the way on electric vehicle (EV) adoption on the East Coast. There are several programs designed to encourage EV adoption in New Jersey, which is crucial to reaching a 100% clean energy future.

NJCEP offers a variety of EV programs for vehicles, charging stations, and fleets. Certain EV charging stations that receive electric utility service from Atlantic City Electric Company (ACE) or Public Service Electric & Gas Company (PSE&G), may be eligible for additional electric vehicle charging incentives directly from the utility. Projects may be eligible for both the incentives offered by this BPU program and incentives offered by ACE or PSE&G, up to 90% of the combined charger purchase and installation costs. Please check ACE or PSE&G program eligibility requirements before purchasing EV charging equipment, as additional conditions on types of eligible chargers may apply for utility incentives.

Both Jersey Central Power & Light (JCP&L) and Rockland Electric (RECO) have filed proposals for EV charging programs. BPU staff is currently reviewing those proposals.

For more information and to keep up to date on all EV programs please visit <https://www.njcleanenergy.com/commercial-industrial/programs/electric-vehicle-programs>

8 PROJECT FUNDING AND INCENTIVES

Ready to improve your building's performance? New Jersey's Clean Energy Programs and Utility Energy Efficiency Programs can help. Pick the program that works best for you. This section provides an overview of currently available incentive programs in.



Program areas to be served by the Utilities:

- Existing Buildings (residential, commercial, industrial, government)
- Efficient Products
 - HVAC
 - Appliance Rebates
 - Appliance Recycling

Proposed New Programs & Features:

- Dedicated multi-family program
- More financing options
- Quick home energy check-ups



Program areas staying with NJCEP:

- New Construction (residential, commercial, industrial, government)
- Large Energy Users
- Combined Heat & Power & Fuel Cells
- State Facilities
- Local Government Energy Audits
- Energy Savings Improvement Program
- Solar & Community Solar

8.1 Utility Energy Efficiency Programs

The Clean Energy Act, signed into law by Governor Murphy in 2018, requires New Jersey's investor-owned gas and electric utilities to reduce their customers' use by set percentages over time. To help reach these targets the New Jersey Board of Public Utilities approved a comprehensive suite of energy efficiency programs to be run by the utility companies.

Prescriptive and Custom

The Prescriptive and Custom rebate program through your utility provider offers incentives for installing prescriptive and custom energy efficiency measures at your facility. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades. This program serves most common equipment types and sizes.

Equipment Examples

Lighting

Lighting Controls

HVAC Equipment

Refrigeration

Gas Heating

Gas Cooling

Commercial Kitchen Equipment

Food Service Equipment

Variable Frequency Drives

Electronically Commutate Motors

Variable Frequency Drives

Plug Loads Controls

Washers and Dryers

Agricultural

Water Heating

The Prescriptive program provides fixed incentives for specific energy efficiency measures. Prescriptive incentives vary by equipment type. The Custom program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentives.

Direct Install

Direct Install is a turnkey program available to existing small to medium-sized facilities with an average peak electric demand that does not exceed 200 kW or less over the recent 12-month period. You work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives, and controls.

Incentives

The program pays up to 70% of the total installed cost of eligible measures.

How to Participate

To participate in Direct Install, you will work with a participating contractor. The contractor will be paid the measure incentives directly by the program, which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the Direct Install program, subject to program rules and eligibility, while the remaining percent of the cost is paid to the contractor by the customer.

Engineered Solutions

The Engineered Solutions Program provides tailored energy-efficiency assistance and services to municipalities, universities, schools, hospitals and healthcare facilities (MUSH), non-profit entities, and multifamily buildings. Customers receive expert guided services, including investment-grade energy auditing, engineering design, installation assistance, construction administration, commissioning, and measurement and verification (M&V) services to support the implementation of cost-effective and comprehensive efficiency projects. Engineered Solutions is generally a good option for medium to large sized facilities with a peak demand over 200 kW looking to implement as many measures as possible under a single project to achieve deep energy savings. Engineered Solutions has an added benefit of addressing measures that may not qualify for other programs. Many facilities pursuing an Energy Savings Improvement Program loan also use this program. Incentives for this program are based on project scope and energy savings achieved.

For more information on any of these programs, contact your local utility provider or visit <https://www.njcleanenergy.com/transition>.

8.2 New Jersey's Clean Energy Programs

Save money while saving the planet! New Jersey's Clean Energy Program is a statewide program that offers incentives, programs, and services that benefit New Jersey residents, businesses, educational, non-profit, and government entities to help them save energy, money, and the environment.

Large Energy Users

The Large Energy Users Program (LEUP) is designed to foster self-directed investment in energy projects. This program is offered to New Jersey's largest energy customers that annually contribute at least \$200,000 to the NJCEP aggregate of all buildings/sites. This equates to roughly \$5 million in energy costs in the prior fiscal year.

Incentives

Incentives are based on the specifications below. The maximum incentive per entity is the lesser of:

- \$4 million
- 75% of the total project(s) cost
- 90% of total NJCEP fund contribution in previous year
- \$0.33 per projected kWh saved; \$3.75 per projected Therm saved annually

How to Participate

To participate in LEUP, you will first need submit an enrollment application. This program requires all qualified and approved applicants to submit an energy plan that outlines the proposed energy efficiency work for review and approval. Applicants may submit a Draft Energy Efficiency Plan (DEEP), or a Final Energy Efficiency Plan (FEEP). Once the FEEP is approved, the proposed work can begin.

Detailed program descriptions, instructions for applying, and applications can be found at www.njcleanenergy.com/LEUP.

Combined Heat and Power

The Combined Heat & Power (CHP) program provides incentives for eligible CHP or waste heat to power (WHP) projects. Eligible CHP or WHP projects must achieve an annual system efficiency of at least 65% (lower heating value, or LHV), based on total energy input and total utilized energy output. Mechanical energy may be included in the efficiency evaluation.

Incentives

| Eligible Technologies | Size (Installed Rated Capacity) ¹ | Incentive (\$/kW) | % of Total Cost Cap per Project ³ | \$ Cap per Project ³ | | |
|--|--|-------------------|--|---------------------------------|--|--|
| Powered by non-renewable or renewable fuel source ⁴ | ≤500 kW | \$2,000 | 30-40% ² | \$2 million | | |
| Gas Internal Combustion Engine | >500 kW - 1 MW | \$1,000 | | | | |
| Gas Combustion Turbine | > 1 MW - 3 MW | \$550 | 30% | \$3 million | | |
| Microturbine | >3 MW | \$350 | | | | |
| Fuel Cells with Heat Recovery | | | | | | |
| | | | | | | |
| Waste Heat to Power* | <1 MW | \$1,000 | 30% | \$2 million | | |
| | > 1MW | \$500 | | \$3 million | | |

*Waste Heat to Power: Powered by non-renewable fuel source, heat recovery or other mechanical recovery from existing equipment utilizing new electric generation equipment (e.g. steam turbine).

Check the NJCEP website for details on program availability, current incentive levels, and requirements.

How to Participate

You will work with a qualified developer or consulting firm to complete the CHP application. Once the application is approved the project can be installed. Information about the CHP program can be found at www.njcleanenergy.com/CHP.

Successor Solar Incentive Program (SuSI)

The SuSI program replaces the SREC Registration Program (SRP) and the Transition Incentive (TI) program. The program is used to register and certify solar projects in New Jersey. Rebates are not available for solar projects, but owners of solar projects *must* register their projects prior to the start of construction to establish the project's eligibility to earn SREC-IIs (Solar Renewable Energy Certificates-II). SuSI consists of two sub-programs. The Administratively Determined Incentive (ADI) Program and the Competitive Solar Incentive (CSI) Program.

Administratively Determined Incentive (ADI) Program

The ADI Program provides administratively set incentives for net metered residential projects, net metered non-residential projects 5 MW or less, and all community solar projects.

After the registration is accepted, construction is complete, and a complete final as-built packet has been submitted, the project is issued a New Jersey certification number, which enables it to generate New Jersey SREC- IIs.

| Market Segments | Size MW dc | Incentive Value (\$/SREC II) | Public Entities Incentive Value - \$20 Adder (\$/SRECII) |
|--|----------------------------|------------------------------|--|
| Net Metered Residential | All types and sizes | \$90 | N/A |
| Small Net Metered Non-Residential located on Rooftop, Carport, Canopy and Floating Solar | Projects smaller than 1 MW | \$100 | \$120 |
| Large Net Metered Non-Residential located on Rooftop, Carport, Canopy and Floating Solar | Projects 1 MW to 5 MW | \$90 | \$110 |
| Small Net Metered Non-Residential Ground Mount | Projects smaller than 1 MW | \$85 | \$105 |
| Large Net Metered Non-Residential Ground Mount | Projects 1 MW to 5 MW | \$80 | \$100 |
| LMI Community Solar | Up to 5 MW | \$90 | N/A |
| Non-LMI Community Solar | Up to 5 MW | \$70 | N/A |
| Interim Subsection (t) | All types and sizes | \$100 | N/A |

Eligible projects may generate SREC-IIs for 15 years following the commencement of commercial operations which is defined as permission to operate (PTO) from the Electric Distribution Company. After 15 years, projects may be eligible for a NJ Class I REC.

SREC-IIs will be purchased monthly by the SREC-II Program Administrator who will allocate the SREC-IIs to the Load Serving Entities (BGS Providers and Third-Party Suppliers) annually based on their market share of retail electricity sold during the relevant Energy Year.

The ADI Program online portal is now open to new registrations.

Competitive Solar Incentive Program

The Competitive Solar Incentive (CSI) Program will provide competitively set incentives for grid supply projects and net metered non-residential projects greater than 5MW (dc). The program is currently under development. For updates, please continue to check the [Solar Proceedings](#) page on the New Jersey's Clean Energy Program website.

Solar projects help the State of New Jersey reach renewable energy goals outlined in the state's Energy Master Plan.

If you are considering installing solar photovoltaics on your building, visit the following link for more information: <https://njcleanenergy.com/renewable-energy/programs/susi-program>.

Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) serves New Jersey's government agencies by financing energy projects. An ESIP is a type of performance contract, whereby school districts, counties, municipalities, housing authorities, and other public and state entities enter into contracts to help finance building energy upgrades. Annual payments are lower than the savings projected from the energy conservation measures (ECMs), ensuring that ESIP projects are cash flow positive for the life of the contract.

ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs described above can also be used to help further reduce the total project cost of eligible measures.

How to Participate

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an energy services company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is used for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the energy savings plan can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Carefully consider all alternatives to develop an approach that best meets your needs. A detailed program descriptions and application can be found at www.njcleanenergy.com/ESIP.

ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you can use NJCEP incentive programs to help further reduce costs when developing the energy savings plan. Refer to the ESIP guidelines at the link above for further information and guidance on next steps.

9 PROJECT DEVELOPMENT

Energy conservation measures (ECMs) have been identified for your site, and their energy and economic analyses are provided within this LGEA report. Note that some of the identified projects may be mutually exclusive, such as replacing equipment versus upgrading motors or controls. The next steps with project development are to set goals and create a comprehensive project plan. The graphic below provides an overview of the process flow for a typical energy efficiency or renewable energy project. We recommend implementing as many ECMs as possible prior to undertaking a feasibility study for a renewable project. The cyclical nature of this process flow demonstrates the ongoing work required to continually improve building energy efficiency over time. If your building(s) scope of work is relatively simple to implement or small in scope, the measurement and verification (M&V) step may not be required. It should be noted through a typical project cycle, there will be changes in costs based on specific scopes of work, contractor selections, design considerations, construction, etc. The estimated costs provided throughout this LGEA report demonstrate the unburdened turn-key material and labor cost only. There will be contingencies and additional costs at the time of implementation. We recommend comprehensive project planning that includes the review of multiple bids for project work, incorporates potential operations and maintenance (O&M) cost savings, and maximizes your incentive potential.




Figure 10 – Project Development Cycle

10 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

10.1 Retail Electric Supply Options

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. Though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third-party supplier, consider shopping for a reduced rate from third-party electric suppliers. If your facility already buys electricity from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party electric suppliers is available at the NJBPU website⁸.

10.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey is also deregulated. Most customers that remain with the utility for natural gas service pay rates that are market based and fluctuate monthly. The utility provides basic gas supply service to customers who choose not to buy from a third-party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier typically depends on whether a customer prefers budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third-party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility does not already purchase natural gas from a third-party supplier, consider shopping for a reduced rate from third-party natural gas suppliers. If your facility already purchases natural gas from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party natural gas suppliers is available at the NJBPU website⁹.

⁸ www.state.nj.us/bpu/commercial/shopping.html.

⁹ www.state.nj.us/bpu/commercial/shopping.html.

APPENDIX A: EQUIPMENT INVENTORY & RECOMMENDATIONS

Lighting Inventory & Recommendations

| Location | Existing Conditions | | | | | | Proposed Conditions | | | | | | | | Energy Impact & Financial Analysis | | | | | | |
|------------------------------------|---------------------|--|------------------|-------------|-------------------|------------------------|---------------------|------------------------|---------------|------------------|--|------------------|-------------------|------------------------|------------------------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| | Fixture Quantity | Fixture Description | Control System | Light Level | Watts per Fixture | Annual Operating Hours | ECM # | Fixture Recommendation | Add Controls? | Fixture Quantity | Fixture Description | Control System | Watts per Fixture | Annual Operating Hours | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| HS - 1st Floor Hallway | 3 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 3 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - 1st Floor Hallway | 25 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Other | S | 114 | 4,940 | 3 | Relamp | No | 25 | LED - Linear Tubes: (4) 4' Lamps | Other | 58 | 4,940 | 1.0 | 6,639 | 0 | \$815 | \$1,826 | \$500 | 1.6 |
| HS - 1st Elevator lobby | 2 | Linear Fluorescent - T8: 4' T8 (32W) - 1L | Other | S | 32 | 4,940 | 3, 4 | Relamp | Yes | 2 | LED - Linear Tubes: (1) 4' Lamp | Occupancy Sensor | 15 | 3,409 | 0.0 | 209 | 0 | \$26 | \$153 | \$30 | 4.8 |
| HS - 1st Floor Elevator Lobby | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - 1st Floor Elevator Lobby | 7 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Other | S | 93 | 4,940 | 3 | Relamp | No | 7 | LED - Linear Tubes: (3) 4' Lamps | Other | 44 | 4,940 | 0.2 | 1,643 | 0 | \$202 | \$383 | \$105 | 1.4 |
| HS - 1st Floor Female Bath | 6 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 3,301 | 3 | Relamp | No | 6 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 3,301 | 0.2 | 941 | 0 | \$116 | \$329 | \$90 | 2.1 |
| HS - 1st Floor Flag Closet | 2 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 1,000 | 3 | Relamp | No | 2 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 1,000 | 0.0 | 63 | 0 | \$8 | \$73 | \$20 | 6.8 |
| HS - 1st Floor Men Bath | 5 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 5 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.1 | 782 | 0 | \$96 | \$183 | \$50 | 1.4 |
| HS - 2nd Floor Custodial Closet | 1 | Incandescent: (4) 25W G19 Screw-In Lamps | Occupancy Sensor | S | 100 | 1,000 | 3 | Relamp | No | 1 | LED Lamps: LED Lamps | Occupancy Sensor | 15 | 1,000 | 0.1 | 82 | 0 | \$10 | \$69 | \$4 | 6.5 |
| HS - 2nd Floor Elevator Lobby | 4 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Other | S | 93 | 4,940 | 3 | Relamp | No | 4 | LED - Linear Tubes: (3) 4' Lamps | Other | 44 | 4,940 | 0.1 | 939 | 0 | \$115 | \$219 | \$60 | 1.4 |
| HS - 2nd Floor Hallway | 4 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 4 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - 2nd Floor Hallway | 24 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Other | S | 114 | 4,940 | 3 | Relamp | No | 24 | LED - Linear Tubes: (4) 4' Lamps | Other | 58 | 4,940 | 1.0 | 6,374 | 0 | \$782 | \$1,753 | \$480 | 1.6 |
| HS - 2nd Floor Male Bath | 4 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 4 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.1 | 939 | 0 | \$115 | \$219 | \$60 | 1.4 |
| HS - 2nd Floor Senior Storage Room | 3 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 1,000 | 3 | Relamp | No | 3 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 1,000 | 0.1 | 143 | 0 | \$18 | \$164 | \$45 | 6.8 |
| HS - 2nd Floor Teachers Bath | 1 | Incandescent: (4) 25W G19 Screw-In Lamps | Occupancy Sensor | S | 100 | 4,940 | 3 | Relamp | No | 1 | LED Lamps: LED Lamps | Occupancy Sensor | 15 | 4,940 | 0.1 | 403 | 0 | \$49 | \$69 | \$4 | 1.3 |
| HS - 2nd Floor Women Bath | 4 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 4 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.1 | 939 | 0 | \$115 | \$219 | \$60 | 1.4 |
| HS - 3rd Floor Hallway | 3 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 3 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - 3rd Floor Hallway | 29 | LED - Fixtures: Ambient - 6' - Direct/Indirect Fixture | Other | S | 36 | 4,940 | | None | No | 29 | LED - Fixtures: Ambient - 6' - Direct/Indirect Fixture | Other | 36 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 307 | 15 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 15 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 315 | 1 | Incandescent: (6) 25W A Lamps | Occupancy Sensor | S | 150 | 4,940 | 3 | Relamp | No | 1 | LED Lamps: LED Lamps | Occupancy Sensor | 23 | 4,940 | 0.1 | 602 | 0 | \$74 | \$103 | \$6 | 1.3 |
| HS - Room 315 | 4 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 4 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.1 | 626 | 0 | \$77 | \$146 | \$40 | 1.4 |
| HS - 3rd Floor Attic | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - 3rd Floor Attic | 18 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 18 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.4 | 2,817 | 0 | \$346 | \$657 | \$180 | 1.4 |
| HS - 3rd Floor Attic Foyer | 2 | Linear Fluorescent - T8: 2' T8 (17W) - 4L | Occupancy Sensor | S | 63 | 4,940 | 3 | Relamp | No | 2 | LED - Linear Tubes: (4) 2' Lamps | Occupancy Sensor | 34 | 4,940 | 0.0 | 275 | 0 | \$34 | \$130 | \$24 | 3.1 |
| HS - 3rd Floor Attic Foyer | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.0 | 156 | 0 | \$19 | \$37 | \$10 | 1.4 |

| Existing Conditions | | | | | | | Proposed Conditions | | | | | | | Energy Impact & Financial Analysis | | | | | | | |
|--------------------------------|------------------|--|------------------|-------------|-------------------|------------------------|---------------------|------------------------|---------------|------------------|--|------------------|-------------------|------------------------------------|-----------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Fixture Quantity | Fixture Description | Control System | Light Level | Watts per Fixture | Annual Operating Hours | ECM # | Fixture Recommendation | Add Controls? | Fixture Quantity | Fixture Description | Control System | Watts per Fixture | Annual Operating Hours | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| HS - 3rd Floor Attic Foyer | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.0 | 156 | 0 | \$19 | \$37 | \$10 | 1.4 |
| HS - 3rd Floor Elevator Lobby | 4 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Other | S | 93 | 4,940 | 3 | Relamp | No | 4 | LED - Linear Tubes: (3) 4' Lamps | Other | 44 | 4,940 | 0.1 | 939 | 0 | \$115 | \$219 | \$60 | 1.4 |
| HS - 3rd Floor Men bath | 1 | Linear Fluorescent - T8: 2' T8 (17W) - 2L | Occupancy Sensor | S | 33 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (2) 2' Lamps | Occupancy Sensor | 17 | 4,940 | 0.0 | 76 | 0 | \$9 | \$33 | \$6 | 2.8 |
| HS - 3rd Floor Men bath | 5 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 5 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.1 | 782 | 0 | \$96 | \$183 | \$50 | 1.4 |
| HS - 3rd Floor Storage | 3 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 1,000 | | None | No | 3 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 1,000 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - 3rd Floor Women bath | 6 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 6 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.1 | 939 | 0 | \$115 | \$219 | \$60 | 1.4 |
| HS - 400 Lobby | 3 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 3 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - 400 Lobby | 7 | LED - Fixtures: Ambient - 6' - Direct/Indirect Fixture | Other | S | 36 | 4,940 | | None | No | 7 | LED - Fixtures: Ambient - 6' - Direct/Indirect Fixture | Other | 36 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - 400 West Wing Hallway | 3 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 3 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - 400 West Wing Hallway | 23 | LED - Fixtures: Ambient - 8' - Direct/Indirect Fixture | Other | S | 40 | 4,940 | | None | No | 23 | LED - Fixtures: Ambient - 8' - Direct/Indirect Fixture | Other | 40 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - 400 Wing All Gender Bath | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 1L | Occupancy Sensor | S | 32 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (1) 4' Lamp | Occupancy Sensor | 15 | 4,940 | 0.0 | 83 | 0 | \$10 | \$18 | \$5 | 1.3 |
| HS - 400 Wing Attic on Roof | 13 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 13 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.3 | 2,034 | 0 | \$250 | \$475 | \$130 | 1.4 |
| HS - 400 Wing Custodial Closet | 1 | Linear Fluorescent - T8: 2' T8 (17W) - 4L | Occupancy Sensor | S | 63 | 1,000 | 3 | Relamp | No | 1 | LED - Linear Tubes: (4) 2' Lamps | Occupancy Sensor | 34 | 1,000 | 0.0 | 28 | 0 | \$3 | \$65 | \$12 | 15.5 |
| HS - 400 Wing Custodial Closet | 2 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Occupancy Sensor | S | 114 | 1,000 | 3 | Relamp | No | 2 | LED - Linear Tubes: (4) 4' Lamps | Occupancy Sensor | 58 | 1,000 | 0.1 | 108 | 0 | \$13 | \$146 | \$40 | 8.0 |
| HS - 400 Wing Female Bath | 4 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 4 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.1 | 939 | 0 | \$115 | \$219 | \$60 | 1.4 |
| HS - 400 Wing Men Bath | 4 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 4 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.1 | 939 | 0 | \$115 | \$219 | \$60 | 1.4 |
| HS - 400 Wing Slop Sink | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.0 | 156 | 0 | \$19 | \$37 | \$10 | 1.4 |
| HS - 400 Wing Utility Closet | 2 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 1,000 | 3 | Relamp | No | 2 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 1,000 | 0.0 | 63 | 0 | \$8 | \$73 | \$20 | 6.8 |
| HS - 500 Hallway | 6 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 6 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - 500 Hallway | 22 | LED - Fixtures: Ambient - 6' - Indirect/Direct Fixture | Other | S | 36 | 4,940 | | None | No | 22 | LED - Fixtures: Ambient - 6' - Indirect/Direct Fixture | Other | 36 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - 500 Hallway | 2 | LED - Fixtures: Ambient - 8' - Direct/Indirect Fixture | Other | S | 40 | 4,940 | | None | No | 2 | LED - Fixtures: Ambient - 8' - Direct/Indirect Fixture | Other | 40 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - 600 Hallway | 2 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 2 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - 600 Hallway | 12 | LED - Fixtures: Ambient - 6' - Direct/Indirect Fixture | Other | S | 36 | 4,940 | | None | No | 12 | LED - Fixtures: Ambient - 6' - Direct/Indirect Fixture | Other | 36 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - 600 Stair A | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - 600 Stair A | 3 | LED - Fixtures: Ambient - 4' - Direct/Indirect Fixture | Other | | 32 | 4,940 | | None | No | 3 | LED - Fixtures: Ambient - 4' - Direct/Indirect Fixture | Other | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |

| Existing Conditions | | | | | | | Proposed Conditions | | | | | | | Energy Impact & Financial Analysis | | | | | | | |
|-------------------------------|------------------|---|------------------|-------------|-------------------|------------------------|---------------------|------------------------|---------------|------------------|--|------------------|-------------------|------------------------------------|-----------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Fixture Quantity | Fixture Description | Control System | Light Level | Watts per Fixture | Annual Operating Hours | ECM # | Fixture Recommendation | Add Controls? | Fixture Quantity | Fixture Description | Control System | Watts per Fixture | Annual Operating Hours | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| HS - 600 Stair B | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - 600 Stair B | 3 | LED - Fixtures: Ambient - 4' - Direct/Indirect Fixture | Other | | 32 | 4,940 | | None | No | 3 | LED - Fixtures: Ambient - 4' - Direct/Indirect Fixture | Other | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - 6th Floor Supply Closet | 3 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 1,000 | 3 | Relamp | No | 3 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 1,000 | 0.1 | 143 | 0 | \$18 | \$164 | \$45 | 6.8 |
| HS - Auditorium | 5 | Exit Signs: LED - 2 W Lamp | Occupancy Sensor | | 6 | 8,760 | | None | No | 5 | Exit Signs: LED - 2 W Lamp | Occupancy Sensor | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Auditorium | 53 | LED - Fixtures: Downlight Recessed | Occupancy Sensor | S | 10 | 4,940 | | None | No | 53 | LED - Fixtures: Downlight Recessed | Occupancy Sensor | 10 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Auditorium | 10 | Linear Fluorescent - T5HO: 4' T5HO (54W) - 6L | Occupancy Sensor | S | 358 | 4,940 | 3 | Relamp | No | 10 | LED - Linear Tubes: (6) 4' T5HO (25W) Lamps | Occupancy Sensor | 153 | 4,940 | 1.5 | 9,722 | 0 | \$1,193 | \$1,242 | \$300 | 0.8 |
| HS - Auditorium Attic | 12 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 12 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.3 | 1,878 | 0 | \$231 | \$438 | \$120 | 1.4 |
| HS - Auditorium Lobby | 8 | Compact Fluorescent: (2) 26W Plug-In Lamps | Other | S | 52 | 4,940 | 3 | Relamp | No | 8 | LED Lamps: LED Lamps | Other | 37 | 4,940 | 0.1 | 569 | 0 | \$70 | \$200 | \$16 | 2.6 |
| HS - Auditorium Lobby | 19 | Compact Fluorescent: (2) 26W Plug-In Lamps | Other | S | 52 | 4,940 | 3 | Relamp | No | 19 | LED Lamps: LED Lamps | Other | 37 | 4,940 | 0.2 | 1,352 | 0 | \$166 | \$475 | \$38 | 2.6 |
| HS - Auditorium Lobby | 3 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 3 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Auditorium Lobby | 32 | LED - Linear Tubes: (1) 2' Lamp | Other | S | 9 | 4,940 | | None | No | 32 | LED - Linear Tubes: (1) 2' Lamp | Other | 9 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Back Gym Hallway | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Back Gym Hallway | 11 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Other | S | 114 | 4,940 | 3 | Relamp | No | 11 | LED - Linear Tubes: (4) 4' Lamps | Other | 58 | 4,940 | 0.4 | 2,921 | 0 | \$359 | \$803 | \$220 | 1.6 |
| HS - Basement Restroom | 1 | LED Lamps: (3) 8W A19 Screw-In Lamps | Occupancy Sensor | S | 24 | 4,940 | | None | No | 1 | LED Lamps: (3) 8W A19 Screw-In Lamps | Occupancy Sensor | 24 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Basement Restroom | 1 | U-Bend Fluorescent - T8: U T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (2) U-Lamp | Occupancy Sensor | 33 | 4,940 | 0.0 | 138 | 0 | \$17 | \$72 | \$10 | 3.7 |
| HS - Basement Restroom Foyer | 2 | Linear Fluorescent - T8: 4' T8 (32W) - 1L | Occupancy Sensor | S | 32 | 4,940 | 3 | Relamp | No | 2 | LED - Linear Tubes: (1) 4' Lamp | Occupancy Sensor | 15 | 4,940 | 0.0 | 166 | 0 | \$20 | \$37 | \$10 | 1.3 |
| HS - Basement Storage | 3 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 1,000 | 3 | Relamp | No | 3 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 1,000 | 0.1 | 143 | 0 | \$18 | \$164 | \$45 | 6.8 |
| HS - Basement Walkthrough | 6 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 6 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.1 | 939 | 0 | \$115 | \$219 | \$60 | 1.4 |
| HS - Basement Walkthrough | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.0 | 235 | 0 | \$29 | \$55 | \$15 | 1.4 |
| HS - Booster Club Closet | 3 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 1,000 | 3 | Relamp | No | 3 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 1,000 | 0.1 | 95 | 0 | \$12 | \$110 | \$30 | 6.8 |
| HS - Boys Locker Room Storage | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Wall Switch | S | 114 | 1,000 | 3 | Relamp | No | 1 | LED - Linear Tubes: (4) 4' Lamps | Wall Switch | 58 | 1,000 | 0.0 | 54 | 0 | \$7 | \$73 | \$20 | 8.0 |
| HS - Boys Shower Room | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Wall Switch | S | 114 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (4) 4' Lamps | Wall Switch | 58 | 4,940 | 0.0 | 266 | 0 | \$33 | \$73 | \$20 | 1.6 |
| HS - Breezeway Hallway | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Breezeway Hallway | 6 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Other | S | 114 | 4,940 | 3 | Relamp | No | 6 | LED - Linear Tubes: (4) 4' Lamps | Other | 58 | 4,940 | 0.2 | 1,593 | 0 | \$196 | \$438 | \$120 | 1.6 |
| HS - Cafeteria | 24 | Compact Fluorescent: (3) 40W Double Biaxial Plug-In Lamps | Occupancy Sensor | S | 120 | 4,940 | 3 | Relamp | No | 24 | LED Lamps: LED Lamps | Occupancy Sensor | 84 | 4,940 | 0.6 | 4,097 | 0 | \$503 | \$972 | \$72 | 1.8 |

| Existing Conditions | | | | | | | Proposed Conditions | | | | | | | Energy Impact & Financial Analysis | | | | | | | |
|---------------------------------|------------------|--|------------------|-------------|-------------------|------------------------|---------------------|------------------------|---------------|------------------|--|------------------|-------------------|------------------------------------|-----------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Fixture Quantity | Fixture Description | Control System | Light Level | Watts per Fixture | Annual Operating Hours | ECM # | Fixture Recommendation | Add Controls? | Fixture Quantity | Fixture Description | Control System | Watts per Fixture | Annual Operating Hours | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| HS - Cafeteria | 26 | Compact Fluorescent: (2) 26W Plug-In Lamps | Occupancy Sensor | S | 52 | 4,940 | 3 | Relamp | No | 26 | LED Lamps: LED Lamps | Occupancy Sensor | 37 | 4,940 | 0.3 | 1,850 | 0 | \$227 | \$650 | \$52 | 2.6 |
| HS - Cafeteria | 2 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 2 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Cafeteria | 18 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 18 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.6 | 4,225 | 0 | \$519 | \$986 | \$270 | 1.4 |
| HS - Cafeteria Hallway | 2 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 2 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Cafeteria Hallway | 31 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Other | S | 114 | 4,940 | 3 | Relamp | No | 31 | LED - Linear Tubes: (4) 4' Lamps | Other | 58 | 4,940 | 1.2 | 8,233 | 0 | \$1,011 | \$2,264 | \$620 | 1.6 |
| HS - Canopy HID | 1 | Metal Halide: (1) 175W Lamp | Occupancy Sensor | | 215 | 4,380 | 1 | Fixture Replacement | No | 1 | LED - Fixtures: Fuel Pump Canopy | Occupancy Sensor | 65 | 4,380 | 0.0 | 657 | 0 | \$81 | \$383 | \$100 | 3.5 |
| HS - Corridor Small Locker Room | 3 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 3 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.1 | 469 | 0 | \$58 | \$110 | \$30 | 1.4 |
| HS - Custodial Storage Area | 6 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 1,000 | 3 | Relamp | No | 6 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 1,000 | 0.1 | 190 | 0 | \$23 | \$219 | \$60 | 6.8 |
| HS - Custodial Storage Area | 3 | Linear Fluorescent - T12: 4' T12 (40W) - 2L | Occupancy Sensor | S | 88 | 1,000 | 2 | Relamp & Reballast | No | 3 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 1,000 | 0.1 | 170 | 0 | \$21 | \$206 | \$30 | 8.5 |
| HS - Custodial supply room | 9 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 1,000 | 3 | Relamp | No | 9 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 1,000 | 0.2 | 285 | 0 | \$35 | \$329 | \$90 | 6.8 |
| HS - Custodial Supply Room | 6 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Occupancy Sensor | S | 114 | 1,000 | 3 | Relamp | No | 6 | LED - Linear Tubes: (4) 4' Lamps | Occupancy Sensor | 58 | 1,000 | 0.2 | 323 | 0 | \$40 | \$438 | \$120 | 8.0 |
| HS - Custodial Supply Room | 3 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 1,000 | 3 | Relamp | No | 3 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 1,000 | 0.1 | 95 | 0 | \$12 | \$110 | \$30 | 6.8 |
| HS - Custodial Supply Room | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Occupancy Sensor | S | 114 | 1,000 | 3 | Relamp | No | 1 | LED - Linear Tubes: (4) 4' Lamps | Occupancy Sensor | 58 | 1,000 | 0.0 | 54 | 0 | \$7 | \$73 | \$20 | 8.0 |
| HS - Dishwasher Room | 2 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 2 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.1 | 469 | 0 | \$58 | \$110 | \$30 | 1.4 |
| HS - Display case next to 101 | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.0 | 156 | 0 | \$19 | \$37 | \$10 | 1.4 |
| HS - East Stair | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - East Stair | 6 | LED - Fixtures: Ambient - 4' - Direct/Indirect Fixture | Other | | 32 | 4,940 | | None | No | 6 | LED - Fixtures: Ambient - 4' - Direct/Indirect Fixture | Other | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - East Wing Wall Pack | 8 | Compact Fluorescent: (2) 26W Plug-In Lamps | Timedclock | S | 52 | 4,380 | 3 | Relamp | No | 8 | LED Lamps: LED Lamps | Timedclock | 37 | 4,380 | 0.1 | 505 | 0 | \$62 | \$200 | \$16 | 3.0 |
| HS - East Wing Wall Pack | 7 | Metal Halide: (1) 175W Lamp | Timedclock | S | 215 | 4,380 | 1 | Fixture Replacement | No | 7 | LED - Fixtures: Outdoor Wall-Mounted Area Fixture | Timedclock | 65 | 4,380 | 0.0 | 4,599 | 0 | \$565 | \$3,047 | \$350 | 4.8 |
| HS - Electrical Room 111 | 3 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 3 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.1 | 469 | 0 | \$58 | \$110 | \$30 | 1.4 |
| HS - Exterior LED Pole | 15 | LED Lamps: (1) 1W Corn Bulb Screw-In Lamps | Timedclock | | 40 | 4,380 | | None | No | 15 | LED Lamps: (1) 1W Corn Bulb Screw-In Lamps | Timedclock | 40 | 4,380 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Exterior Canopy | 3 | Compact Fluorescent: (2) 26W Plug-In Lamps | Timedclock | | 52 | 4,380 | 3 | Relamp | No | 3 | LED Lamps: LED Lamps | Timedclock | 37 | 4,380 | 0.0 | 197 | 0 | \$24 | \$75 | \$6 | 2.9 |
| HS - Exterior East Pole | 1 | LED - Fixtures: Cobrahead Pole Mount | Timedclock | | 45 | 4,380 | | None | No | 1 | LED - Fixtures: Cobrahead Pole Mount | Timedclock | 45 | 4,380 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Exterior East Pole | 1 | LED - Fixtures: Cobrahead Pole Mount | Timedclock | | 90 | 4,380 | | None | No | 1 | LED - Fixtures: Cobrahead Pole Mount | Timedclock | 90 | 4,380 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Fitness Area | 3 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 3 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |

| Existing Conditions | | | | | | | Proposed Conditions | | | | | | | Energy Impact & Financial Analysis | | | | | | | |
|-------------------------------------|------------------|---|------------------|-------------|-------------------|------------------------|---------------------|------------------------|---------------|------------------|---|------------------|-------------------|------------------------------------|-----------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Fixture Quantity | Fixture Description | Control System | Light Level | Watts per Fixture | Annual Operating Hours | ECM # | Fixture Recommendation | Add Controls? | Fixture Quantity | Fixture Description | Control System | Watts per Fixture | Annual Operating Hours | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| HS - Fitness Area | 1 | Incandescent: (1) 65W A19 Screw-In Lamp | Occupancy Sensor | S | 65 | 3,301 | 3 | Relamp | No | 1 | LED Lamps: LED Lamps | Occupancy Sensor | 10 | 3,301 | 0.0 | 174 | 0 | \$21 | \$17 | \$1 | 0.8 |
| HS - Fitness Area | 16 | Linear Fluorescent - T5HO: 4' T5HO (54W) - 4L | Occupancy Sensor | S | 234 | 4,940 | 3, 4 | Relamp | Yes | 16 | LED - Linear Tubes: (4) 4' T5HO (25W) Lamps | Occupancy Sensor | 102 | 3,409 | 1.9 | 12,415 | 0 | \$1,524 | \$2,229 | \$390 | 1.2 |
| HS - Fitness Center Staircase | 2 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Other | | 62 | 4,940 | 3 | Relamp | No | 2 | LED - Linear Tubes: (2) 4' Lamps | Other | 29 | 4,940 | 0.0 | 313 | 0 | \$38 | \$73 | \$20 | 1.4 |
| HS - Fitness Center Staircase | 2 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Other | | 114 | 4,940 | 3 | Relamp | No | 2 | LED - Linear Tubes: (4) 4' Lamps | Other | 58 | 4,940 | 0.1 | 531 | 0 | \$65 | \$146 | \$40 | 1.6 |
| HS - Girls Locker Room Entrance | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Girls Locker Room Entrance | 1 | LED - Fixtures: Ambient - 8' - Direct Fixture | Occupancy Sensor | S | 40 | 3,301 | | None | No | 1 | LED - Fixtures: Ambient - 8' - Direct Fixture | Occupancy Sensor | 40 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Girls Locker Room Restroom | 5 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 5 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Girls Shower Room | 1 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 1 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Girls Shower Room | 3 | LED - Fixtures: Downlight Recessed | Occupancy Sensor | S | 10 | 3,301 | | None | No | 3 | LED - Fixtures: Downlight Recessed | Occupancy Sensor | 10 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Gym Boys Locker Room Storage | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Occupancy Sensor | S | 114 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (4) 4' Lamps | Occupancy Sensor | 58 | 4,940 | 0.0 | 266 | 0 | \$33 | \$73 | \$20 | 1.6 |
| HS - Gym Boys Locker Room Storage | 3 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Occupancy Sensor | S | 114 | 4,940 | 3 | Relamp | No | 3 | LED - Linear Tubes: (4) 4' Lamps | Occupancy Sensor | 58 | 4,940 | 0.1 | 797 | 0 | \$98 | \$219 | \$60 | 1.6 |
| HS - Gym Storage | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Occupancy Sensor | S | 114 | 1,000 | 3 | Relamp | No | 1 | LED - Linear Tubes: (4) 4' Lamps | Occupancy Sensor | 58 | 1,000 | 0.0 | 54 | 0 | \$7 | \$73 | \$20 | 8.0 |
| HS - Gymnasium | 3 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 3 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Gymnasium | 30 | Linear Fluorescent - T5HO: 4' T5HO (54W) - 6L | Occupancy Sensor | S | 358 | 4,940 | 3 | Relamp | No | 30 | LED - Linear Tubes: (6) 4' T5HO (25W) Lamps | Occupancy Sensor | 153 | 4,940 | 4.4 | 29,166 | 0 | \$3,580 | \$3,725 | \$900 | 0.8 |
| HS - Gymnasium Boys Locker Restroom | 1 | Linear Fluorescent - T8: 2' T8 (17W) - 4L | Occupancy Sensor | S | 63 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (4) 2' Lamps | Occupancy Sensor | 34 | 4,940 | 0.0 | 138 | 0 | \$17 | \$65 | \$12 | 3.1 |
| HS - Gymnasium Boys Locker Restroom | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Occupancy Sensor | S | 114 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (4) 4' Lamps | Occupancy Sensor | 58 | 4,940 | 0.0 | 266 | 0 | \$33 | \$73 | \$20 | 1.6 |
| HS - Gymnasium Boys Locker Room | 14 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Occupancy Sensor | S | 114 | 4,940 | 3 | Relamp | No | 14 | LED - Linear Tubes: (4) 4' Lamps | Occupancy Sensor | 58 | 4,940 | 0.6 | 3,718 | 0 | \$456 | \$1,022 | \$280 | 1.6 |
| HS - Gymnasium Boys Locker Room | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.0 | 156 | 0 | \$19 | \$37 | \$10 | 1.4 |
| HS - Gymnasium Girls Locker Room | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Gymnasium Girls Locker Room | 28 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 28 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Ice Room | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 1L | Occupancy Sensor | S | 32 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (1) 4' Lamp | Occupancy Sensor | 15 | 4,940 | 0.0 | 83 | 0 | \$10 | \$18 | \$5 | 1.3 |
| HS - Ice Room | 2 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 2 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.0 | 313 | 0 | \$38 | \$73 | \$20 | 1.4 |
| HS - Kitchen | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Kitchen | 14 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Occupancy Sensor | S | 114 | 4,940 | 3 | Relamp | No | 14 | LED - Linear Tubes: (4) 4' Lamps | Occupancy Sensor | 58 | 4,940 | 0.6 | 3,718 | 0 | \$456 | \$1,022 | \$280 | 1.6 |
| HS - Kitchen Hood | 6 | Incandescent: (1) 65W A19 Screw-In Lamp | Occupancy Sensor | S | 65 | 4,940 | 3 | Relamp | No | 6 | LED Lamps: LED Lamps | Occupancy Sensor | 10 | 4,940 | 0.2 | 1,565 | 0 | \$192 | \$103 | \$6 | 0.5 |

| Existing Conditions | | | | | | | Proposed Conditions | | | | | | | Energy Impact & Financial Analysis | | | | | | | |
|---|------------------|--|------------------|-------------|-------------------|------------------------|---------------------|------------------------|---------------|------------------|--|------------------|-------------------|------------------------------------|-----------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Fixture Quantity | Fixture Description | Control System | Light Level | Watts per Fixture | Annual Operating Hours | ECM # | Fixture Recommendation | Add Controls? | Fixture Quantity | Fixture Description | Control System | Watts per Fixture | Annual Operating Hours | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| HS - Kitchen Office | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.0 | 156 | 0 | \$19 | \$37 | \$10 | 1.4 |
| HS - Library Stairs | 11 | LED - Fixtures: Decorative: Other | Other | | 5 | 4,940 | | None | No | 11 | LED - Fixtures: Decorative: Other | Other | 5 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Library Stairs | 5 | LED - Fixtures: Downlight Recessed | Other | | 20 | 4,940 | | None | No | 5 | LED - Fixtures: Downlight Recessed | Other | 20 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Lower Library | 4 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 4 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Lower Library | 50 | LED - Fixtures: Ambient - 2' - Indirect/Direct Fixture | Occupancy Sensor | S | 7 | 3,301 | | None | No | 50 | LED - Fixtures: Ambient - 2' - Indirect/Direct Fixture | Occupancy Sensor | 7 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Lower Library | 7 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 7 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Lower Library Kitchen | 2 | LED - Fixtures: Ambient - 2' - Indirect/Direct Fixture | Occupancy Sensor | S | 7 | 3,301 | | None | No | 2 | LED - Fixtures: Ambient - 2' - Indirect/Direct Fixture | Occupancy Sensor | 7 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Main School Entrance | 1 | Incandescent: (10) 40W Candelabra Screw-In Lamps | Occupancy Sensor | S | 400 | 4,940 | 3 | Relamp | No | 1 | LED Lamps: LED Lamps | Occupancy Sensor | 60 | 4,940 | 0.2 | 1,612 | 0 | \$198 | \$242 | \$10 | 1.2 |
| HS - Main School Entrance | 4 | LED Lamps: (1) 5.5W Plug-In Lamp | Occupancy Sensor | S | 6 | 4,940 | | None | No | 4 | LED Lamps: (1) 5.5W Plug-In Lamp | Occupancy Sensor | 6 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Main School Entrance | 2 | LED - Fixtures: Ambient - 4' - Direct Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 2 | LED - Fixtures: Ambient - 4' - Direct Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Maintenance Shop | 3 | Linear Fluorescent - T12: 4' T12 (40W) - 2L | Occupancy Sensor | S | 88 | 4,940 | 2 | Relamp & Reballast | No | 3 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.1 | 839 | 0 | \$103 | \$206 | \$30 | 1.7 |
| HS - Maintenance Shop | 6 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 6 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.1 | 939 | 0 | \$115 | \$219 | \$60 | 1.4 |
| HS - Maintenance Shop | 20 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 20 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.7 | 4,695 | 0 | \$576 | \$1,095 | \$300 | 1.4 |
| HS - Maintenance Shop | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Occupancy Sensor | S | 114 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (4) 4' Lamps | Occupancy Sensor | 58 | 4,940 | 0.0 | 266 | 0 | \$33 | \$73 | \$20 | 1.6 |
| HS - Middle Staircase | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Middle Staircase | 4 | LED - Fixtures: Ambient - 4' - Direct/Indirect Fixture | Other | | 32 | 4,940 | | None | No | 4 | LED - Fixtures: Ambient - 4' - Direct/Indirect Fixture | Other | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Office - Boys Locker Room | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Occupancy Sensor | S | 114 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (4) 4' Lamps | Occupancy Sensor | 58 | 4,940 | 0.0 | 266 | 0 | \$33 | \$73 | \$20 | 1.6 |
| HS - Office - IT | 4 | Compact Fluorescent: (2) 40W Biax Lamps | Occupancy Sensor | S | 80 | 3,301 | 3 | Relamp | No | 4 | LED Lamps: LED Lamps | Occupancy Sensor | 56 | 3,301 | 0.1 | 304 | 0 | \$37 | \$108 | \$8 | 2.7 |
| HS - Office - Training | 6 | U-Bend Fluorescent - T8: U T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 6 | LED - Linear Tubes: (2) U-Lamp | Occupancy Sensor | 33 | 4,940 | 0.1 | 825 | 0 | \$101 | \$435 | \$60 | 3.7 |
| HS - Office Boys Locker Room | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Occupancy Sensor | S | 114 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (4) 4' Lamps | Occupancy Sensor | 58 | 4,940 | 0.0 | 266 | 0 | \$33 | \$73 | \$20 | 1.6 |
| HS - Pump Room 417 | 5 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 5 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.1 | 782 | 0 | \$96 | \$183 | \$50 | 1.4 |
| HS - Restroom | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Occupancy Sensor | S | 114 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (4) 4' Lamps | Occupancy Sensor | 58 | 4,940 | 0.0 | 266 | 0 | \$33 | \$73 | \$20 | 1.6 |
| HS - Restroom | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Occupancy Sensor | S | 114 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (4) 4' Lamps | Occupancy Sensor | 58 | 4,940 | 0.0 | 266 | 0 | \$33 | \$73 | \$20 | 1.6 |
| HS - Female Bath 2nd fl Senior Building | 1 | LED Lamps: (2) 5.5W A19 Screw-In Lamps | Occupancy Sensor | S | 6 | 4,940 | | None | No | 1 | LED Lamps: (2) 5.5W A19 Screw-In Lamps | Occupancy Sensor | 6 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Female Bath 2nd fl Senior Building | 3 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 3 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.1 | 469 | 0 | \$58 | \$110 | \$30 | 1.4 |

| | Existing Conditions | | | | | | Proposed Conditions | | | | | | | | Energy Impact & Financial Analysis | | | | | | | |
|---|---------------------|---|------------------|-------------|-------------------|------------------------|---------------------|------------------------|---------------|------------------|---------------------------------------|------------------|-------------------|------------------------|------------------------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|--|
| Location | Fixture Quantity | Fixture Description | Control System | Light Level | Watts per Fixture | Annual Operating Hours | ECM # | Fixture Recommendation | Add Controls? | Fixture Quantity | Fixture Description | Control System | Watts per Fixture | Annual Operating Hours | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years | |
| HS - Restroom - Female Auditorium lobby | 1 | LED Lamps: (4) 5.5W Plug-In Lamps | Occupancy Sensor | S | 6 | 4,940 | | None | No | 1 | LED Lamps: (4) 5.5W Plug-In Lamps | Occupancy Sensor | 6 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 | |
| HS - Restroom - Female Auditorium lobby | 2 | Linear Fluorescent - T8: 2' T8 (17W) - 2L | Occupancy Sensor | S | 33 | 4,940 | 3 | Relamp | No | 2 | LED - Linear Tubes: (2) 2' Lamps | Occupancy Sensor | 17 | 4,940 | 0.0 | 152 | 0 | \$19 | \$65 | \$12 | 2.8 | |
| HS - Male Bath 2nd Fl Senior Building | 1 | LED Lamps: (1) 5.5W A19 Screw-In Lamp | Occupancy Sensor | S | 6 | 4,940 | | None | No | 1 | LED Lamps: (1) 5.5W A19 Screw-In Lamp | Occupancy Sensor | 6 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 | |
| HS - Male Bath 2nd Fl Senior Building | 3 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 3 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.1 | 469 | 0 | \$58 | \$110 | \$30 | 1.4 | |
| HS - Restroom 420E | 1 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 1 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 | |
| HS - Room 101 | 12 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 12 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.4 | 2,817 | 0 | \$346 | \$657 | \$180 | 1.4 | |
| HS - Room 102 | 16 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 16 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.6 | 3,756 | 0 | \$461 | \$876 | \$240 | 1.4 | |
| HS - Room 103 | 16 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 16 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.6 | 3,756 | 0 | \$461 | \$876 | \$240 | 1.4 | |
| HS - Room 104 / auto bay | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Occupancy Sensor | S | 114 | 3,301 | 3 | Relamp | No | 1 | LED - Linear Tubes: (4) 4' Lamps | Occupancy Sensor | 58 | 3,301 | 0.0 | 177 | 0 | \$22 | \$73 | \$20 | 2.4 | |
| HS - Room 104 / auto bay | 12 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 3,301 | 3 | Relamp | No | 12 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 3,301 | 0.4 | 1,882 | 0 | \$231 | \$657 | \$180 | 2.1 | |
| HS - Room 105 | 27 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 3,301 | 3 | Relamp | No | 27 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 3,301 | 1.0 | 4,235 | 0 | \$520 | \$1,479 | \$405 | 2.1 | |
| HS - Room 106 | 14 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 14 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 | |
| HS - Room 107 | 15 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 3,301 | 3 | Relamp | No | 15 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 3,301 | 0.5 | 2,353 | 0 | \$289 | \$822 | \$225 | 2.1 | |
| HS - Room 109 | 3 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 3 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.1 | 469 | 0 | \$58 | \$110 | \$30 | 1.4 | |
| HS - Room 112 | 2 | U-Bend Fluorescent - T8: U T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 2 | LED - Linear Tubes: (2) U-Lamp | Occupancy Sensor | 33 | 4,940 | 0.0 | 275 | 0 | \$34 | \$145 | \$20 | 3.7 | |
| HS - Room 114 | 9 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 9 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.3 | 2,113 | 0 | \$259 | \$493 | \$135 | 1.4 | |
| HS - Room 114 | 1 | U-Bend Fluorescent - T8: U T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (2) U-Lamp | Occupancy Sensor | 33 | 4,940 | 0.0 | 138 | 0 | \$17 | \$72 | \$10 | 3.7 | |
| HS - Room 114 bath | 1 | Linear Fluorescent - T12: 2' T12 (20W) - 2L | Occupancy Sensor | S | 50 | 4,940 | 2 | Relamp & Reballast | No | 1 | LED - Linear Tubes: (2) 2' Lamps | Occupancy Sensor | 17 | 4,940 | 0.0 | 156 | 0 | \$19 | \$65 | \$6 | 3.1 | |
| HS - Room 201 | 12 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 12 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.4 | 2,817 | 0 | \$346 | \$657 | \$180 | 1.4 | |
| HS - Room 202 | 9 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 9 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.3 | 2,113 | 0 | \$259 | \$493 | \$135 | 1.4 | |
| HS - Room 203 | 12 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 12 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.4 | 2,817 | 0 | \$346 | \$657 | \$180 | 1.4 | |
| HS - Room 204 | 12 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 12 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.4 | 2,817 | 0 | \$346 | \$657 | \$180 | 1.4 | |
| HS - Room 205 | 12 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 12 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.4 | 2,817 | 0 | \$346 | \$657 | \$180 | 1.4 | |
| HS - Room 206 | 4 | Linear Fluorescent - T8: 2' T8 (17W) - 4L | Occupancy Sensor | S | 63 | 3,301 | 3 | Relamp | No | 4 | LED - Linear Tubes: (4) 2' Lamps | Occupancy Sensor | 34 | 3,301 | 0.1 | 368 | 0 | \$45 | \$260 | \$48 | 4.7 | |
| HS - Room 206 | 15 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Occupancy Sensor | S | 114 | 4,940 | 3 | Relamp | No | 15 | LED - Linear Tubes: (4) 4' Lamps | Occupancy Sensor | 58 | 4,940 | 0.6 | 3,984 | 0 | \$489 | \$1,095 | \$300 | 1.6 | |

| Existing Conditions | | | | | | | Proposed Conditions | | | | | | | Energy Impact & Financial Analysis | | | | | | | |
|--------------------------|------------------|--|------------------|-------------|-------------------|------------------------|---------------------|------------------------|---------------|------------------|--|------------------|-------------------|------------------------------------|-----------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Fixture Quantity | Fixture Description | Control System | Light Level | Watts per Fixture | Annual Operating Hours | ECM # | Fixture Recommendation | Add Controls? | Fixture Quantity | Fixture Description | Control System | Watts per Fixture | Annual Operating Hours | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| HS - Room 207 | 4 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 4 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.1 | 939 | 0 | \$115 | \$219 | \$60 | 1.4 |
| HS - Room 208 | 10 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 10 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.4 | 2,347 | 0 | \$288 | \$548 | \$150 | 1.4 |
| HS - Room 209 | 6 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 3,301 | 3 | Relamp | No | 6 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 3,301 | 0.2 | 941 | 0 | \$116 | \$329 | \$90 | 2.1 |
| HS - Room 211 | 12 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 12 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.4 | 2,817 | 0 | \$346 | \$657 | \$180 | 1.4 |
| HS - Room 212 # 1 | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 212- #2 | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 212 - 212C | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 212 - 212E | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 212 - Bathroom | 1 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 1 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 212 - Kitchen | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 212- 212 F | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 212- 212D | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 212- 212G | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 212- 214A | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 212- 214B | 4 | Compact Fluorescent: (1) 13W A15 Screw-In Lamp | Occupancy Sensor | S | 13 | 4,940 | 3 | Relamp | No | 4 | LED Lamps: LED Lamps | Occupancy Sensor | 9 | 4,940 | 0.0 | 76 | 0 | \$9 | \$50 | \$4 | 4.9 |
| HS - Room 212- 214B | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 212- 214C | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 2 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 212- 214F | 1 | LED - Fixtures: Ambient - 4' - Indirect/Direct Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 1 | LED - Fixtures: Ambient - 4' - Indirect/Direct Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 212- Entrance | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 212- Entrance | 8 | LED - Fixtures: Ambient - 2' - Indirect/Direct Fixture | Occupancy Sensor | S | 7 | 4,940 | | None | No | 8 | LED - Fixtures: Ambient - 2' - Indirect/Direct Fixture | Occupancy Sensor | 7 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 212- Entrance | 1 | LED - Fixtures: Ambient - 6' - Indirect/Direct Fixture | Occupancy Sensor | S | 36 | 4,940 | | None | No | 1 | LED - Fixtures: Ambient - 6' - Indirect/Direct Fixture | Occupancy Sensor | 36 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 212- Entrance | 2 | LED - Fixtures: Ambient - 4' - Indirect/Direct Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 2 | LED - Fixtures: Ambient - 4' - Indirect/Direct Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 212 Hallway | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 212 Hallway | 4 | LED - Fixtures: Ambient - 2' - Indirect/Direct Fixture | Other | S | 7 | 4,940 | | None | No | 4 | LED - Fixtures: Ambient - 2' - Indirect/Direct Fixture | Other | 7 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 212 Hallway | 9 | LED - Fixtures: Ambient - 6' - Indirect/Direct Fixture | Other | S | 36 | 4,940 | | None | No | 9 | LED - Fixtures: Ambient - 6' - Indirect/Direct Fixture | Other | 36 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |

| Existing Conditions | | | | | | | Proposed Conditions | | | | | | | Energy Impact & Financial Analysis | | | | | | | |
|--------------------------------|------------------|--|------------------|-------------|-------------------|------------------------|---------------------|------------------------|---------------|------------------|--|------------------|-------------------|------------------------------------|-----------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Fixture Quantity | Fixture Description | Control System | Light Level | Watts per Fixture | Annual Operating Hours | ECM # | Fixture Recommendation | Add Controls? | Fixture Quantity | Fixture Description | Control System | Watts per Fixture | Annual Operating Hours | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| HS - Room 213 | 7 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 7 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.2 | 1,643 | 0 | \$202 | \$383 | \$105 | 1.4 |
| HS - Room 215 Hallway | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Other | S | 114 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (4) 4' Lamps | Other | 58 | 4,940 | 0.0 | 266 | 0 | \$33 | \$73 | \$20 | 1.6 |
| HS - Room 215 Hallway | 1 | U-Bend Fluorescent - T8: U T8 (32W) - 2L | Other | S | 62 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (2) U-Lamp | Other | 33 | 4,940 | 0.0 | 138 | 0 | \$17 | \$72 | \$10 | 3.7 |
| HS - Room 215 IT | 2 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 3,301 | 3 | Relamp | No | 2 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 3,301 | 0.1 | 314 | 0 | \$39 | \$110 | \$30 | 2.1 |
| HS - Room 215 Main area | 6 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 3,301 | 3 | Relamp | No | 6 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 3,301 | 0.2 | 941 | 0 | \$116 | \$329 | \$90 | 2.1 |
| HS - Room 215 Marianne Office | 2 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 3,301 | 3 | Relamp | No | 2 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 3,301 | 0.1 | 314 | 0 | \$39 | \$110 | \$30 | 2.1 |
| HS - Room 215 Men Bath | 1 | LED Lamps: (3) 15.5W A19 Screw-In Lamps | Occupancy Sensor | S | 47 | 4,940 | | None | No | 1 | LED Lamps: (3) 15.5W A19 Screw-In Lamps | Occupancy Sensor | 47 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 215 Principle Office | 4 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 4 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.1 | 939 | 0 | \$115 | \$219 | \$60 | 1.4 |
| HS - Room 215 Supply Room | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 1,000 | 3 | Relamp | No | 1 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 1,000 | 0.0 | 32 | 0 | \$4 | \$37 | \$10 | 6.8 |
| HS - Room 215 Women Bathroom | 1 | LED Lamps: (2) 15.5W A19 Screw-In Lamps | Occupancy Sensor | S | 31 | 4,940 | | None | No | 1 | LED Lamps: (2) 15.5W A19 Screw-In Lamps | Occupancy Sensor | 31 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 217 | 3 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 3 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.1 | 704 | 0 | \$86 | \$164 | \$45 | 1.4 |
| HS - Room 301 | 15 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 15 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 302 | 15 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 15 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 303 | 15 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 15 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 304 | 15 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 15 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 305 | 6 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 3,301 | 3 | Relamp | No | 6 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 3,301 | 0.1 | 627 | 0 | \$77 | \$219 | \$60 | 2.1 |
| HS - Room 306 | 15 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 15 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 308 | 9 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 9 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 309 | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 311 | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 312 | 8 | LED - Fixtures: Ambient - 6' - Indirect/Direct Fixture | Occupancy Sensor | S | 36 | 3,301 | | None | No | 8 | LED - Fixtures: Ambient - 6' - Indirect/Direct Fixture | Occupancy Sensor | 36 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 312 | 20 | LED - Fixtures: Downlight Pendant | Occupancy Sensor | S | 7 | 3,301 | | None | No | 20 | LED - Fixtures: Downlight Pendant | Occupancy Sensor | 7 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 313 | 6 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 6 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 314 | 15 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 15 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 316 | 15 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 15 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |

| Existing Conditions | | | | | | | Proposed Conditions | | | | | | | Energy Impact & Financial Analysis | | | | | | | |
|-----------------------|------------------|---|------------------|-------------|-------------------|------------------------|---------------------|------------------------|---------------|------------------|-------------------------------------|------------------|-------------------|------------------------------------|-----------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Fixture Quantity | Fixture Description | Control System | Light Level | Watts per Fixture | Annual Operating Hours | ECM # | Fixture Recommendation | Add Controls? | Fixture Quantity | Fixture Description | Control System | Watts per Fixture | Annual Operating Hours | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| HS - Room 317 | 9 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 9 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 319 | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 321 | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 401 | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 402 | 10 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 10 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 402 Kitchen | 4 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 4 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 403 | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 404 | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 405 | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 406 | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 407 | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 408 | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 409 | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 410 | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 411 | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 412 | 11 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 11 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 413 | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 12 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 414 | 4 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 4 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.1 | 939 | 0 | \$115 | \$219 | \$60 | 1.4 |
| HS - Room 414 Bath | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 1L | Occupancy Sensor | S | 32 | 3,301 | 3 | Relamp | No | 1 | LED - Linear Tubes: (1) 4' Lamp | Occupancy Sensor | 15 | 3,301 | 0.0 | 55 | 0 | \$7 | \$18 | \$5 | 1.9 |
| HS - Room 415 | 15 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 15 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 415 storage | 2 | U-Bend Fluorescent - T8: U T8 (32W) - 2L | Occupancy Sensor | S | 62 | 1,000 | 3 | Relamp | No | 2 | LED - Linear Tubes: (2) U-Lamp | Occupancy Sensor | 33 | 1,000 | 0.0 | 56 | 0 | \$7 | \$145 | \$20 | 18.3 |
| HS - Room 420D | 6 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 6 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 421 | 18 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 18 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.4 | 2,817 | 0 | \$346 | \$657 | \$180 | 1.4 |
| HS - Room 423 | 38 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 38 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.9 | 5,947 | 0 | \$730 | \$1,388 | \$380 | 1.4 |
| HS - Room 423 office | 3 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Occupancy Sensor | S | 114 | 4,940 | 3 | Relamp | No | 3 | LED - Linear Tubes: (4) 4' Lamps | Occupancy Sensor | 58 | 4,940 | 0.1 | 797 | 0 | \$98 | \$219 | \$60 | 1.6 |

| | Existing Conditions | | | | | | Proposed Conditions | | | | | | | | Energy Impact & Financial Analysis | | | | | | | |
|-------------------------------------|---------------------|---|------------------|-------------|-------------------|------------------------|---------------------|------------------------|---------------|------------------|-------------------------------------|------------------|-------------------|------------------------|------------------------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|--|
| Location | Fixture Quantity | Fixture Description | Control System | Light Level | Watts per Fixture | Annual Operating Hours | ECM # | Fixture Recommendation | Add Controls? | Fixture Quantity | Fixture Description | Control System | Watts per Fixture | Annual Operating Hours | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years | |
| HS - Room 429 | 8 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Occupancy Sensor | S | 114 | 4,940 | 3 | Relamp | No | 8 | LED - Linear Tubes: (4) 4' Lamps | Occupancy Sensor | 58 | 4,940 | 0.3 | 2,125 | 0 | \$261 | \$584 | \$160 | 1.6 | |
| HS - Room 501 | 17 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 17 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 | |
| HS - Room 502 | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 | |
| HS - Room 502 | 16 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 16 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 | |
| HS - Room 503 | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 | |
| HS - Room 503 | 21 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 21 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.7 | 4,930 | 0 | \$605 | \$1,150 | \$315 | 1.4 | |
| HS - Room 504 | 6 | LED - Fixtures: Ambient 2x4 Fixture | Occupancy Sensor | S | 40 | 4,940 | | None | No | 6 | LED - Fixtures: Ambient 2x4 Fixture | Occupancy Sensor | 40 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 | |
| HS - Room 505 | 4 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 4 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.1 | 939 | 0 | \$115 | \$219 | \$60 | 1.4 | |
| HS - Room 506 | 4 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 4 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.1 | 939 | 0 | \$115 | \$219 | \$60 | 1.4 | |
| HS - Room 507 | 4 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 4 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.1 | 626 | 0 | \$77 | \$146 | \$40 | 1.4 | |
| HS - Room 508 | 3 | Linear Fluorescent - T12: 4' T12 (40W) - 2L | Occupancy Sensor | S | 88 | 4,940 | 2 | Relamp & Reballast | No | 3 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.1 | 839 | 0 | \$103 | \$206 | \$30 | 1.7 | |
| HS - Room 508 | 6 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 6 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.1 | 939 | 0 | \$115 | \$219 | \$60 | 1.4 | |
| HS - Room 509 | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 | |
| HS - Room 509 | 26 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 26 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 | |
| HS - Room 509A | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 | |
| HS - Room 509A | 4 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 4 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 | |
| HS - Room 510 | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 | |
| HS - Room 510 | 19 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 19 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 | |
| HS - Room 511 | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 | |
| HS - Room 511 | 16 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 16 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 | |
| HS - Room 512 Superintendent Office | 5 | LED - Fixtures: Ambient 2x4 Fixture | Occupancy Sensor | S | 40 | 4,940 | | None | No | 5 | LED - Fixtures: Ambient 2x4 Fixture | Occupancy Sensor | 40 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 | |
| HS - Room 512 Superintendent Office | 4 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 4 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.1 | 939 | 0 | \$115 | \$219 | \$60 | 1.4 | |
| HS - Room 601 | 24 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 24 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 | |
| HS - Room 602 | 4 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 4 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.1 | 939 | 0 | \$115 | \$219 | \$60 | 1.4 | |
| HS - Room 603 / prep room | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 | |

| Existing Conditions | | | | | | | Proposed Conditions | | | | | | | Energy Impact & Financial Analysis | | | | | | | |
|--|------------------|---|------------------|-------------|-------------------|------------------------|---------------------|------------------------|---------------|------------------|---|------------------|-------------------|------------------------------------|-----------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Fixture Quantity | Fixture Description | Control System | Light Level | Watts per Fixture | Annual Operating Hours | ECM # | Fixture Recommendation | Add Controls? | Fixture Quantity | Fixture Description | Control System | Watts per Fixture | Annual Operating Hours | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| HS - Room 603 / prep room | 27 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 27 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 604 | 1 | U-Bend Fluorescent - T12: U T12 (40W) - 2L | Occupancy Sensor | S | 88 | 4,940 | 2 | Relamp & Reballast | No | 1 | LED - Linear Tubes: (2) U-Lamp | Occupancy Sensor | 33 | 4,940 | 0.0 | 261 | 0 | \$32 | \$105 | \$10 | 3.0 |
| HS - Room 604 | 2 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Occupancy Sensor | S | 114 | 4,940 | 3 | Relamp | No | 2 | LED - Linear Tubes: (4) 4' Lamps | Occupancy Sensor | 58 | 4,940 | 0.1 | 531 | 0 | \$65 | \$146 | \$40 | 1.6 |
| HS - Room 605 | 10 | Linear Fluorescent - T8: 4' T8 (32W) - 3L | Occupancy Sensor | S | 93 | 4,940 | 3 | Relamp | No | 10 | LED - Linear Tubes: (3) 4' Lamps | Occupancy Sensor | 44 | 4,940 | 0.4 | 2,347 | 0 | \$288 | \$548 | \$150 | 1.4 |
| HS - Room 606 | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 606 | 18 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 18 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 607 / prep room | 33 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 4,940 | | None | No | 33 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 4,940 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 608 | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 608 | 21 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 21 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 609 / prep room | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 609 / prep room | 25 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 25 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Senior Building Custodial Closet | 1 | LED Lamps: (1) 5.5W A19 Screw-In Lamp | Occupancy Sensor | S | 6 | 1,000 | | None | No | 1 | LED Lamps: (1) 5.5W A19 Screw-In Lamp | Occupancy Sensor | 6 | 1,000 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Senior Building Elevator | 2 | Linear Fluorescent - T8: 4' T8 (32W) - 1L | None | S | 32 | 4,784 | 3 | Relamp | No | 2 | LED - Linear Tubes: (1) 4' Lamp | None | 15 | 4,784 | 0.0 | 161 | 0 | \$20 | \$37 | \$10 | 1.3 |
| HS - Senior Building Elevator Machine Room | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 1 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.0 | 156 | 0 | \$19 | \$37 | \$10 | 1.4 |
| HS - Senior Building Female Bath | 1 | LED - Fixtures: Ambient 2x2 Fixture | Wall Switch | S | 32 | 4,940 | 4 | None | Yes | 1 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 32 | 3,409 | 0.0 | 47 | 0 | \$6 | \$0 | \$0 | 0.0 |
| HS - Senior Building Female Bath | 2 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Wall Switch | S | 62 | 4,940 | 3, 4 | Relamp | Yes | 2 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 3,409 | 0.1 | 398 | 0 | \$49 | \$343 | \$55 | 5.9 |
| HS - Senior Building Male Bath | 1 | LED Lamps: (1) 5.5W A19 Screw-In Lamp | Wall Switch | S | 6 | 4,940 | 4 | None | Yes | 1 | LED Lamps: (1) 5.5W A19 Screw-In Lamp | Occupancy Sensor | 6 | 3,409 | 0.0 | 8 | 0 | \$1 | \$0 | \$0 | 0.0 |
| HS - Senior Building Male Bath | 3 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Wall Switch | S | 62 | 4,940 | 3, 4 | Relamp | Yes | 3 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 3,409 | 0.1 | 597 | 0 | \$73 | \$380 | \$65 | 4.3 |
| HS - Senior Building Slop Sink | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Wall Switch | S | 62 | 4,940 | 3, 4 | Relamp | Yes | 1 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 3,409 | 0.0 | 199 | 0 | \$24 | \$307 | \$45 | 10.7 |
| HS - Small Locker Room | 5 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 4,940 | 3 | Relamp | No | 5 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 4,940 | 0.1 | 782 | 0 | \$96 | \$183 | \$50 | 1.4 |
| HS - Storage Girl Locker Room | 3 | LED - Fixtures: Ambient - 4' - Direct Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 3 | LED - Fixtures: Ambient - 4' - Direct Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Supply Room | 6 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Wall Switch | S | 62 | 1,000 | 3 | Relamp | No | 6 | LED - Linear Tubes: (2) 4' Lamps | Wall Switch | 29 | 1,000 | 0.1 | 190 | 0 | \$23 | \$219 | \$60 | 6.8 |
| HS - Supply Room | 5 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Wall Switch | S | 114 | 1,000 | 3 | Relamp | No | 5 | LED - Linear Tubes: (4) 4' Lamps | Wall Switch | 58 | 1,000 | 0.2 | 269 | 0 | \$33 | \$365 | \$100 | 8.0 |
| HS - Upper Library | 4 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 4 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Upper Library | 5 | LED - Fixtures: LED-A8ID-36W-1L-HC-SM-HW | Occupancy Sensor | S | 36 | 3,301 | | None | No | 5 | LED - Fixtures: LED-A8ID-36W-1L-HC-SM-HW | Occupancy Sensor | 36 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |

| Existing Conditions | | | | | | | Proposed Conditions | | | | | | | Energy Impact & Financial Analysis | | | | | | | |
|--------------------------------------|------------------|---|------------------|-------------|-------------------|------------------------|---------------------|------------------------|---------------|------------------|---|------------------|-------------------|------------------------------------|-----------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Fixture Quantity | Fixture Description | Control System | Light Level | Watts per Fixture | Annual Operating Hours | ECM # | Fixture Recommendation | Add Controls? | Fixture Quantity | Fixture Description | Control System | Watts per Fixture | Annual Operating Hours | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| HS - Upper Library | 9 | LED - Fixtures: Ambient - 4' - Indirect/Direct Fixture | Occupancy Sensor | S | 32 | 3,301 | | None | No | 9 | LED - Fixtures: Ambient - 4' - Indirect/Direct Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Upper Library | 4 | LED - Fixtures: Decorative: Other | Occupancy Sensor | S | 28 | 3,301 | | None | No | 4 | LED - Fixtures: Decorative: Other | Occupancy Sensor | 28 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Upper Library | 6 | LED - Fixtures: Decorative: Other | Occupancy Sensor | S | 34 | 3,301 | | None | No | 6 | LED - Fixtures: Decorative: Other | Occupancy Sensor | 34 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Upper Library | 21 | LED Lamps: (1) 10W MR16 Plug-In Lamp | Occupancy Sensor | S | 10 | 3,301 | | None | No | 21 | LED Lamps: (1) 10W MR16 Plug-In Lamp | Occupancy Sensor | 10 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Upper Library | 10 | LED Lamps: (1) 10W PAR16 Screw-In Lamp | Occupancy Sensor | S | 10 | 3,301 | | None | No | 10 | LED Lamps: (1) 10W PAR16 Screw-In Lamp | Occupancy Sensor | 10 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - West Gym Hallway | 4 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 4 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - West Gym Hallway | 14 | Linear Fluorescent - T8: 4' T8 (32W) - 4L | Other | S | 114 | 4,940 | 3 | Relamp | No | 14 | LED - Linear Tubes: (4) 4' Lamps | Other | 58 | 4,940 | 0.6 | 3,718 | 0 | \$456 | \$1,022 | \$280 | 1.6 |
| HS - West Staircase | 1 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 1 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - West Staircase | 4 | LED - Fixtures: Ambient - 4' - Direct/Indirect Fixture | Occupancy Sensor | | 32 | 3,301 | | None | No | 4 | LED - Fixtures: Ambient - 4' - Direct/Indirect Fixture | Occupancy Sensor | 32 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - West Wing Parking Lot | 8 | LED - Fixtures: Cobrahead Pole Mount | Timedclock | S | 60 | 4,380 | | None | No | 8 | LED - Fixtures: Cobrahead Pole Mount | Timedclock | 60 | 4,380 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - West Wing Wall Pack | 10 | LED - Fixtures: Outdoor Wall-Mounted Area Fixture | Timedclock | S | 45 | 4,380 | | None | No | 10 | LED - Fixtures: Outdoor Wall-Mounted Area Fixture | Timedclock | 45 | 4,380 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Wood Shop 01 | 24 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Wall Switch | S | 62 | 4,940 | 3 | Relamp | No | 24 | LED - Linear Tubes: (2) 4' Lamps | Wall Switch | 29 | 4,940 | 0.6 | 3,756 | 0 | \$461 | \$876 | \$240 | 1.4 |
| HS - WS02 | 5 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | S | 64 | 3,301 | | None | No | 5 | LED - Fixtures: Ambient 2x2 Fixture | Occupancy Sensor | 64 | 3,301 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - WS03 | 1 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 3,301 | 3 | Relamp | No | 1 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 3,301 | 0.0 | 105 | 0 | \$13 | \$37 | \$10 | 2.1 |
| Concession Stand Exterior Can | 12 | Compact Fluorescent: (1) 26W Plug-In Lamp | Timedclock | | 26 | 4,380 | 3 | Relamp | No | 12 | LED Lamps: LED Lamps | Timedclock | 9 | 4,380 | 0.0 | 894 | 0 | \$110 | \$150 | \$12 | 1.3 |
| Concession Stand Exterior Pole | 1 | LED - Fixtures: Outdoor Pole/Arm-Mounted Decorative Fixture | Timedclock | | 80 | 4,380 | | None | No | 1 | LED - Fixtures: Outdoor Pole/Arm-Mounted Decorative Fixture | Timedclock | 80 | 4,380 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Concession Stand Exterior Pole | 1 | LED - Fixtures: Outdoor Pole/Arm-Mounted Decorative Fixture | Timedclock | | 40 | 4,380 | | None | No | 1 | LED - Fixtures: Outdoor Pole/Arm-Mounted Decorative Fixture | Timedclock | 40 | 4,380 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Concession Stand Exterior Short Pole | 7 | LED - Fixtures: Downlight Recessed | Timedclock | | 30 | 4,380 | | None | No | 7 | LED - Fixtures: Downlight Recessed | Timedclock | 30 | 4,380 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Concession Stand Exterior Wall Packs | 4 | LED Lamps: (1) 5.5W Plug-In Lamp | Timedclock | | 6 | 4,380 | | None | No | 4 | LED Lamps: (1) 5.5W Plug-In Lamp | Timedclock | 6 | 4,380 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Concession Stand Main Area | 9 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 350 | 3 | Relamp | No | 9 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 350 | 0.2 | 100 | 0 | \$12 | \$329 | \$90 | 19.5 |
| Concession Stand Main Area | 2 | U-Bend Fluorescent - T8: U T8 (32W) - 2L | Occupancy Sensor | S | 62 | 350 | 3 | Relamp | No | 2 | LED - Linear Tubes: (2) U-Lamp | Occupancy Sensor | 33 | 350 | 0.0 | 19 | 0 | \$2 | \$145 | \$20 | 52.2 |
| Concession Stand Men's Bathroom | 4 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 400 | 3 | Relamp | No | 4 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 400 | 0.1 | 51 | 0 | \$6 | \$146 | \$40 | 17.0 |
| Concession Stand Utility Closet | 2 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Occupancy Sensor | S | 62 | 1,000 | 3 | Relamp | No | 2 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 1,000 | 0.0 | 63 | 0 | \$8 | \$73 | \$20 | 6.8 |
| Concession Stand Women's Bathroom | 4 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Wall Switch | S | 62 | 400 | 3, 4 | Relamp | Yes | 4 | LED - Linear Tubes: (2) 4' Lamps | Occupancy Sensor | 29 | 276 | 0.1 | 64 | 0 | \$8 | \$416 | \$75 | 43.1 |
| Pole Barn Exterior Wall Packs | 11 | LED Lamps: (1) 5.5W Plug-In Lamp | Timedclock | | 6 | 4,380 | | None | No | 11 | LED Lamps: (1) 5.5W Plug-In Lamp | Timedclock | 6 | 4,380 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |

| Existing Conditions | | | | | | | Proposed Conditions | | | | | | | | Energy Impact & Financial Analysis | | | | | | |
|----------------------------|------------------|---|----------------|-------------|-------------------|------------------------|---------------------|------------------------|---------------|------------------|---|----------------|-------------------|------------------------|------------------------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Fixture Quantity | Fixture Description | Control System | Light Level | Watts per Fixture | Annual Operating Hours | ECM # | Fixture Recommendation | Add Controls? | Fixture Quantity | Fixture Description | Control System | Watts per Fixture | Annual Operating Hours | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| Pole Barn Main Area | 2 | Exit Signs: LED - 2 W Lamp | None | | 6 | 8,760 | | None | No | 2 | Exit Signs: LED - 2 W Lamp | None | 6 | 8,760 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Pole Barn Main Area | 14 | Linear Fluorescent - T8: 4' T8 (32W) - 2L | Timeclock | S | 62 | 4,940 | 3 | Relamp | No | 14 | LED - Linear Tubes: (2) 4' Lamps | Timeclock | 29 | 4,940 | 0.3 | 2,191 | 0 | \$269 | \$511 | \$140 | 1.4 |
| Pole Barn Parking Lot Pole | 9 | LED - Fixtures: Cobrahead Pole Mount | Timeclock | | 30 | 4,380 | | None | No | 9 | LED - Fixtures: Cobrahead Pole Mount | Timeclock | 30 | 4,380 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Pole Barn Parking Lot Pole | 6 | LED - Fixtures: Cobrahead Pole Mount | Timeclock | | 40 | 4,380 | | None | No | 6 | LED - Fixtures: Cobrahead Pole Mount | Timeclock | 40 | 4,380 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Exterior LED Pole | 15 | LED Lamps: (1) 40W Corn Bulb Screw-In Lamps | Timeclock | | 40 | 3,380 | | None | No | 15 | LED Lamps: (1) 40W Corn Bulb Screw-In Lamps | Timeclock | 40 | 3,380 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Exterior Canopy | 3 | Compact Fluorescent: (2) 26W Plug-In Lamps | Timeclock | | 52 | 3,380 | | None | No | 3 | Compact Fluorescent: (2) 26W Plug-In Lamps | Timeclock | 52 | 3,380 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Exterior East Pole | 1 | LED - Fixtures: Cobrahead Pole Mount | Timeclock | | 40 | 3,380 | | None | No | 1 | LED - Fixtures: Cobrahead Pole Mount | Timeclock | 40 | 3,380 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Exterior East Pole | 1 | LED - Fixtures: Cobrahead Pole Mount | Timeclock | | 40 | 3,380 | | None | No | 1 | LED - Fixtures: Cobrahead Pole Mount | Timeclock | 40 | 3,380 | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |

Motor Inventory & Recommendations

| | | Existing Conditions | | | | | | | | | Proposed Conditions | | | | | Energy Impact & Financial Analysis | | | | | | |
|------------------------|-------------------------------------|---------------------|----------------------|--------------|----------------------|--------------|--------------|-------|-----------------------|------------------------|---------------------|---------------------------------|----------------------|---------------|----------------|------------------------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Area(s)/System(s) Served | Motor Quantity | Motor Application | HP Per Motor | Full Load Efficiency | VFD Control? | Manufacturer | Model | Remaining Useful Life | Annual Operating Hours | ECM # | Install High Efficiency Motors? | Full Load Efficiency | Install VFDs? | Number of VFDs | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| Custodial Storage Area | Compressed Air System - Maintenance | 2 | Air Compressor | 5.0 | 87.5% | No | | | W | 390 | | No | 87.5% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Pump Room 417 | Condensar Pump | 2 | Condenser Water Pump | 100.0 | 95.4% | Yes | | | W | 4,380 | | No | 95.4% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| 500-600 Roof Area | EF-1 - Science Classroom Fume Hood | 1 | Exhaust Fan | 7.5 | 89.5% | Yes | | | W | 3,000 | | No | 89.5% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| 500-600 Roof Area | Exhaust Fan | 1 | Exhaust Fan | 0.3 | 65.0% | No | | | W | 2,745 | | No | 65.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| 500-600 Roof Area | Exhaust Fan | 1 | Exhaust Fan | 0.3 | 65.0% | No | | | W | 2,745 | | No | 65.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Roof 400 wing | Exhaust Fan | 1 | Exhaust Fan | 0.3 | 65.0% | No | | | W | 2,745 | | No | 65.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Custodial supply room | DHW Circulating Pumps - HS Building | 2 | DHW Circulation Pump | 0.3 | 65.0% | No | | | W | 6,000 | | No | 65.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 21 | Supply Fan | 0.5 | 65.0% | No | | | W | 3,000 | | No | 65.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 7 | Supply Fan | 0.5 | 65.0% | No | | | W | 3,000 | | No | 65.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 4 | Supply Fan | 0.1 | 65.0% | No | | | W | 3,000 | | No | 65.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 2 | Supply Fan | 0.1 | 65.0% | No | | | W | 3,000 | | No | 65.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 7 | Supply Fan | 0.3 | 65.0% | No | | | W | 3,000 | | No | 65.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 8 | Supply Fan | 0.3 | 65.0% | No | | | W | 3,000 | | No | 65.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 2 | Supply Fan | 0.3 | 65.0% | No | | | W | 3,000 | | No | 65.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 11 | Supply Fan | 0.3 | 65.0% | No | | | W | 3,000 | | No | 65.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 3 | Supply Fan | 0.3 | 65.0% | No | | | W | 3,000 | | No | 65.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 12 | Supply Fan | 0.5 | 70.0% | No | | | W | 3,000 | | No | 70.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 17 | Supply Fan | 0.5 | 70.0% | No | | | W | 3,000 | | No | 70.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 2 | Supply Fan | 0.5 | 70.0% | No | | | W | 3,000 | | No | 70.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 4 | Supply Fan | 0.5 | 70.0% | No | | | W | 3,000 | | No | 70.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |



| | | Existing Conditions | | | | | | | | | Proposed Conditions | | | | | Energy Impact & Financial Analysis | | | | | | |
|-------------------|--------------------------|---------------------|-------------------|--------------|----------------------|--------------|--------------|-----------------|-----------------------|------------------------|---------------------|---------------------------------|----------------------|---------------|----------------|------------------------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Area(s)/System(s) Served | Motor Quantity | Motor Application | HP Per Motor | Full Load Efficiency | VFD Control? | Manufacturer | Model | Remaining Useful Life | Annual Operating Hours | ECM # | Install High Efficiency Motors? | Full Load Efficiency | Install VFDs? | Number of VFDs | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| Various Locations | WSHP - Various Spaces | 3 | Supply Fan | 0.8 | 70.0% | No | | | W | 3,000 | | No | 70.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 8 | Supply Fan | 0.8 | 70.0% | No | | | W | 3,000 | | No | 70.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 1 | Supply Fan | 0.8 | 70.0% | No | | | W | 3,000 | | No | 70.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 5 | Supply Fan | 0.8 | 70.0% | No | | | W | 3,000 | | No | 70.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 2 | Supply Fan | 1.5 | 84.0% | No | | | W | 3,000 | | No | 84.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 3 | Supply Fan | 3.0 | 86.0% | No | | | W | 3,000 | | No | 86.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 5 | Supply Fan | 5.0 | 89.5% | No | | | W | 3,000 | | No | 89.5% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 2 | Supply Fan | 3.0 | 89.5% | No | | | W | 3,000 | | No | 89.5% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Various Locations | WSHP - Various Spaces | 3 | Supply Fan | 1.5 | 84.0% | No | | | W | 3,000 | | No | 84.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Roof | HR-1 - Rumson RHS | 1 | Exhaust Fan | 1.5 | 84.0% | No | Semco | FV2000V-6RN4AB | W | 3,000 | 5 | No | 86.5% | Yes | 1 | 0.5 | 1,577 | 0 | \$194 | \$3,887 | \$75 | 19.7 |
| Roof | HR-1 - Rumson RHS | 1 | Supply Fan | 1.5 | 84.0% | No | Semco | FV2000V-6RN4AB | W | 3,000 | 5 | No | 86.5% | Yes | 1 | 0.4 | 1,577 | 0 | \$194 | \$3,887 | \$75 | 19.7 |
| Roof | HR-2 - Rumson RHS | 1 | Exhaust Fan | 1.5 | 84.0% | No | Semco | FV2000V-6RN4AB | W | 3,000 | 5 | No | 86.5% | Yes | 1 | 0.5 | 1,577 | 0 | \$194 | \$3,887 | \$75 | 19.7 |
| Roof | HR-2 - Rumson RHS | 1 | Supply Fan | 1.5 | 84.0% | No | Semco | FV2000V-6RN4AB | W | 3,000 | 5 | No | 86.5% | Yes | 1 | 0.4 | 1,577 | 0 | \$194 | \$3,887 | \$75 | 19.7 |
| Roof | HR-3 - Rumson RHS | 1 | Exhaust Fan | 0.8 | 70.0% | No | Semco | FV-1000HS | W | 3,000 | | No | 70.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Roof | HR-3 - Rumson RHS | 1 | Supply Fan | 0.8 | 70.0% | No | Semco | FV-1000HS | W | 3,000 | | No | 70.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Roof | HR-4 - Rumons RHS | 1 | Exhaust Fan | 5.0 | 89.5% | No | Semco | FV-7500V-6RN4AA | W | 3,000 | 5 | No | 89.5% | Yes | 1 | 1.5 | 4,689 | 0 | \$576 | \$5,028 | \$900 | 7.2 |
| Roof | HR-4 - Rumson RHS | 1 | Supply Fan | 5.0 | 89.5% | No | Semco | FV-7500V-6RN4AA | W | 3,000 | 5 | No | 89.5% | Yes | 1 | 1.4 | 4,689 | 0 | \$576 | \$5,028 | \$900 | 7.2 |
| Roof | HR-5 - Rumson RHS | 1 | Exhaust Fan | 7.5 | 91.7% | No | Semco | FV7500V-6RN4AA | W | 3,000 | 5 | No | 91.7% | Yes | 1 | 2.2 | 6,864 | 0 | \$843 | \$5,945 | \$1,000 | 5.9 |
| Roof | HR-5 - Rumson RHS | 1 | Supply Fan | 5.0 | 89.5% | No | Semco | FV7500V-6RN4AA | W | 3,000 | 5 | No | 89.5% | Yes | 1 | 1.4 | 4,689 | 0 | \$576 | \$5,028 | \$900 | 7.2 |
| Roof | HR-6 - Rumons RHS | 1 | Exhaust Fan | 0.8 | 70.0% | No | Semco | FV1000V-6RN4AB | W | 3,000 | | No | 70.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |

| | | Existing Conditions | | | | | | | | | Proposed Conditions | | | | | Energy Impact & Financial Analysis | | | | | | |
|----------|--------------------------|---------------------|-------------------|--------------|----------------------|--------------|--------------|----------------|-----------------------|------------------------|---------------------|---------------------------------|----------------------|---------------|----------------|------------------------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Area(s)/System(s) Served | Motor Quantity | Motor Application | HP Per Motor | Full Load Efficiency | VFD Control? | Manufacturer | Model | Remaining Useful Life | Annual Operating Hours | ECM # | Install High Efficiency Motors? | Full Load Efficiency | Install VFDs? | Number of VFDs | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| Roof | HR-6 - Rumson RHS | 1 | Supply Fan | 0.8 | 70.0% | No | Semco | FV1000V-6RN4AB | W | 3,000 | | No | 70.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Attic | HR-7 - Rumson RHS | 1 | Exhaust Fan | 5.0 | 89.5% | No | Semco | FV7500H-6RN4AA | W | 3,000 | 5 | No | 89.5% | Yes | 1 | 1.5 | 4,689 | 0 | \$576 | \$5,028 | \$900 | 7.2 |
| Attic | HR-7 - Rumson RHS | 1 | Supply Fan | 5.0 | 89.5% | No | Semco | FV7500H-6RN4AA | W | 3,000 | 5 | No | 89.5% | Yes | 1 | 1.4 | 4,689 | 0 | \$576 | \$5,028 | \$900 | 7.2 |
| Attic | HR-8 - Rumson RHS | 1 | Exhaust Fan | 10.0 | 91.7% | No | Semco | FV7500H-6NN4AA | W | 3,000 | 5 | No | 91.7% | Yes | 1 | 3.0 | 9,152 | 0 | \$1,123 | \$6,697 | \$1,100 | 5.0 |
| Attic | HR-8 - Rumson RHS | 1 | Supply Fan | 10.0 | 91.7% | No | Semco | FV7500H-6NN4AA | W | 3,000 | 5 | No | 91.7% | Yes | 1 | 2.9 | 9,152 | 0 | \$1,123 | \$6,697 | \$1,100 | 5.0 |
| Roof | HR-9 - Rumson RHS | 1 | Exhaust Fan | 7.5 | 91.7% | No | Semco | FV7500H-6NN4AA | W | 3,000 | 5 | No | 91.7% | Yes | 1 | 2.2 | 6,864 | 0 | \$843 | \$5,945 | \$1,000 | 5.9 |
| Roof | HR-9 - Rumson RHS | 1 | Supply Fan | 7.5 | 91.7% | No | Semco | FV7500H-6NN4AA | W | 3,000 | 5 | No | 91.7% | Yes | 1 | 2.1 | 6,864 | 0 | \$843 | \$5,945 | \$1,000 | 5.9 |
| Roof | HR-10 - Rumson RHS | 1 | Exhaust Fan | 1.5 | 84.0% | No | Semco | FV7500H-6NN4AA | W | 3,000 | 5 | No | 86.5% | Yes | 1 | 0.5 | 1,577 | 0 | \$194 | \$3,887 | \$75 | 19.7 |
| Roof | HR-10 - Rumson RHS | 1 | Supply Fan | 1.5 | 84.0% | No | Semco | FV7500H-6NN4AA | W | 3,000 | 5 | No | 86.5% | Yes | 1 | 0.4 | 1,577 | 0 | \$194 | \$3,887 | \$75 | 19.7 |
| Roof | HR-11 - Rumson RHS | 1 | Exhaust Fan | 3.0 | 86.0% | No | Semco | FV5000V-6RN4AB | W | 3,000 | 5 | No | 89.5% | Yes | 1 | 0.9 | 3,134 | 0 | \$385 | \$4,555 | \$200 | 11.3 |
| Roof | HR-11 - Rumson RHS | 1 | Supply Fan | 3.0 | 86.0% | No | Semco | FV5000V-6RN4AB | W | 3,000 | 5 | No | 89.5% | Yes | 1 | 0.9 | 3,134 | 0 | \$385 | \$4,555 | \$200 | 11.3 |
| Roof | HR-12 - Rumson RHS | 1 | Exhaust Fan | 3.0 | 86.0% | No | Semco | FV3000V-6RN4AB | W | 3,000 | 5 | No | 89.5% | Yes | 1 | 0.9 | 3,134 | 0 | \$385 | \$4,555 | \$200 | 11.3 |
| Roof | HR-12 - Rumson RHS | 1 | Supply Fan | 3.0 | 86.0% | No | Semco | FV3000V-6RN4AB | W | 3,000 | 5 | No | 89.5% | Yes | 1 | 0.9 | 3,134 | 0 | \$385 | \$4,555 | \$200 | 11.3 |
| Roof | HR-13 - Rumson RHS | 1 | Exhaust Fan | 5.0 | 89.5% | No | Semco | FV7500H-6RN4AA | W | 3,000 | 5 | No | 89.5% | Yes | 1 | 1.5 | 4,689 | 0 | \$576 | \$5,028 | \$900 | 7.2 |
| Roof | HR-13 - Rumson RHS | 1 | Supply Fan | 5.0 | 89.5% | No | Semco | FV7500H-6RN4AA | W | 3,000 | 5 | No | 89.5% | Yes | 1 | 1.4 | 4,689 | 0 | \$576 | \$5,028 | \$900 | 7.2 |
| Roof | HR-14 - Rumson RHS | 1 | Exhaust Fan | 1.5 | 84.0% | No | Semco | FV3000V-6RN4AB | W | 3,000 | 5 | No | 86.5% | Yes | 1 | 0.5 | 1,577 | 0 | \$194 | \$3,887 | \$75 | 19.7 |
| Roof | HR-14 - Rumson RHS | 1 | Supply Fan | 1.5 | 84.0% | No | Semco | FV3000V-6RN4AB | W | 3,000 | 5 | No | 86.5% | Yes | 1 | 0.4 | 1,577 | 0 | \$194 | \$3,887 | \$75 | 19.7 |
| Roof | MUA-1 - Lb 601,608,609 | 1 | Supply Fan | 5.0 | 89.5% | Yes | VALENT | PVG400 | W | 3,000 | | No | 89.5% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Roof | RTU-210 - Media Center | 1 | Supply Fan | 3.0 | 86.0% | No | AAON | RN01030EA193KB | W | 0 | 5 | No | 89.5% | Yes | 1 | 0.9 | 0 | 0 | \$0 | \$4,555 | \$200 | 0.0 |
| Roof | DOAS-1 - Media Center | 1 | Supply Fan | 2.0 | 86.5% | Yes | AAON | RQ0043VEA1931B | W | 0 | | No | 86.5% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |

| | | Existing Conditions | | | | | | | | | Proposed Conditions | | | | | Energy Impact & Financial Analysis | | | | | | |
|----------|-----------------------------|---------------------|-------------------|--------------|----------------------|--------------|--------------|----------------|-----------------------|------------------------|---------------------|---------------------------------|----------------------|---------------|----------------|------------------------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Area(s)/System(s) Served | Motor Quantity | Motor Application | HP Per Motor | Full Load Efficiency | VFD Control? | Manufacturer | Model | Remaining Useful Life | Annual Operating Hours | ECM # | Install High Efficiency Motors? | Full Load Efficiency | Install VFDs? | Number of VFDs | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| Roof | DOAS-1 - Media Center | 1 | Exhaust Fan | 1.0 | 84.0% | No | AAON | RQ0043VEA1931B | W | 0 | | No | 84.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Roof | RTU-420 - Girls Locker Room | 1 | Supply Fan | 2.0 | 86.5% | Yes | AAON | RN00930EB093F9 | W | 3,000 | | No | 86.5% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Roof | RTU-606 - Room 606 | 1 | Supply Fan | 3.0 | 89.5% | Yes | VALENT | PVG100 | W | 3,000 | | No | 89.5% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Roof | RTU-1 - Woodshop | 1 | Supply Fan | 3.0 | 89.5% | No | VALENT | PVG150 | W | 3,000 | 5 | No | 89.5% | Yes | 1 | 0.9 | 2,813 | 0 | \$345 | \$4,555 | \$200 | 12.6 |
| Woodshop | Dust Collector | 1 | Other | 3.0 | 86.5% | No | | | W | 780 | | No | 86.5% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Woodshop | Dust Collector | 1 | Other | 0.5 | 70.0% | No | | | W | 780 | | No | 70.0% | No | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |

Packaged HVAC Inventory & Recommendations

| | | Existing Conditions | | | | | | | | | Proposed Conditions | | | | | | | | Energy Impact & Financial Analysis | | | | | | |
|-------------------|--------------------------|---------------------|-----------------|----------------------------------|---------------------------------|--|-------------------------|-------------------|------------|-----------------------|---------------------|---------------------------------|-----------------|-----------------|----------------------------------|---------------------------------|--|-------------------------|------------------------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Area(s)/System(s) Served | System Quantity | System Type | Cooling Capacity per Unit (Tons) | Heating Capacity per Unit (MBh) | Cooling Mode Efficiency (SEER/IEER/ EER) | Heating Mode Efficiency | Manufacturer | Model | Remaining Useful Life | ECM # | Install High Efficiency System? | System Quantity | System Type | Cooling Capacity per Unit (Tons) | Heating Capacity per Unit (MBh) | Cooling Mode Efficiency (SEER/IEER/ EER) | Heating Mode Efficiency | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| Various Locations | WSHP - Various Spaces | 21 | Water Source HP | 0.80 | 13.00 | 12.70 | 3.8 COP | FHP MANUFACTURING | G010-2HZC | W | 6 | Yes | 21 | Water Source HP | 0.80 | 13.00 | 14.00 | 4.8 COP | 3.3 | 2,636 | 0 | \$324 | \$64,615 | \$756 | 197.4 |
| Various Locations | WSHP - Various Spaces | 7 | Water Source HP | 0.80 | 13.00 | 12.80 | 3.8 COP | FHP MANUFACTURING | GT010-2VTC | W | 6 | Yes | 7 | Water Source HP | 0.80 | 13.00 | 14.00 | 4.8 COP | 1.1 | 866 | 0 | \$106 | \$21,538 | \$252 | 200.2 |
| Various Locations | WSHP - Various Spaces | 4 | Water Source HP | 1.50 | 16.00 | 14.50 | 4 COP | FHP MANUFACTURING | GT018-2HVC | W | 6 | Yes | 4 | Water Source HP | 1.50 | 16.00 | 15.00 | 4.5 COP | 0.1 | 310 | 0 | \$38 | \$15,809 | \$408 | 404.5 |
| Various Locations | WSHP - Various Spaces | 2 | Water Source HP | 1.50 | 16.00 | 14.50 | 4 COP | FHP MANUFACTURING | GT018-2VTC | W | 6 | Yes | 2 | Water Source HP | 1.50 | 16.00 | 15.00 | 4.5 COP | 0.0 | 155 | 0 | \$19 | \$7,904 | \$204 | 404.5 |
| Various Locations | WSHP - Various Spaces | 7 | Water Source HP | 2.00 | 28.00 | 12.90 | 3.7 COP | FHP MANUFACTURING | GT024-2HZC | W | 6 | Yes | 7 | Water Source HP | 2.00 | 28.00 | 15.00 | 4.5 COP | 2.2 | 1,927 | 0 | \$237 | \$32,041 | \$952 | 131.4 |
| Various Locations | WSHP - Various Spaces | 8 | Water Source HP | 2.50 | 33.00 | 12.00 | 4.4 COP | FHP MANUFACTURING | GT030-2VTC | W | 6 | Yes | 8 | Water Source HP | 2.50 | 33.00 | 15.00 | 4.5 COP | 2.0 | 1,395 | 0 | \$171 | \$52,560 | \$1,360 | 298.9 |
| Various Locations | WSHP - Various Spaces | 2 | Water Source HP | 2.50 | 33.00 | 12.00 | 4.4 COP | FHP MANUFACTURING | GT030-2HZC | W | 6 | Yes | 2 | Water Source HP | 2.50 | 33.00 | 15.00 | 4.5 COP | 0.5 | 349 | 0 | \$43 | \$13,140 | \$340 | 298.9 |
| Various Locations | WSHP - Various Spaces | 11 | Water Source HP | 3.00 | 40.00 | 13.30 | 4.1 COP | FHP MANUFACTURING | GT036-2HZC | W | 6 | Yes | 11 | Water Source HP | 3.00 | 40.00 | 15.00 | 4.5 COP | 2.5 | 2,410 | 0 | \$296 | \$80,983 | \$2,244 | 266.1 |
| Various Locations | WSHP - Various Spaces | 3 | Water Source HP | 3.00 | 40.00 | 13.30 | 4.1 COP | FHP MANUFACTURING | GT036-2VTC | W | 6 | Yes | 3 | Water Source HP | 3.00 | 40.00 | 15.00 | 4.5 COP | 0.7 | 657 | 0 | \$81 | \$22,086 | \$612 | 266.1 |
| Various Locations | WSHP - Various Spaces | 12 | Water Source HP | 3.50 | 48.00 | 13.40 | 4.2 COP | FHP MANUFACTURING | GT042-4HZC | W | 6 | Yes | 12 | Water Source HP | 3.50 | 48.00 | 15.00 | 4.5 COP | 3.3 | 2,543 | 0 | \$312 | \$95,847 | \$2,856 | 297.8 |
| Various Locations | WSHP - Various Spaces | 17 | Water Source HP | 3.50 | 48.00 | 13.40 | 4.2 COP | FHP MANUFACTURING | GT042-4VTC | W | 6 | Yes | 17 | Water Source HP | 3.50 | 48.00 | 15.00 | 4.5 COP | 4.7 | 3,603 | 0 | \$442 | \$135,784 | \$4,046 | 297.8 |
| Various Locations | WSHP - Various Spaces | 2 | Water Source HP | 4.00 | 58.00 | 12.50 | 4.1 COP | FHP MANUFACTURING | GT048-4VTC | W | 6 | Yes | 2 | Water Source HP | 4.00 | 58.00 | 15.00 | 4.5 COP | 0.9 | 753 | 0 | \$92 | \$17,225 | \$544 | 180.6 |
| Various Locations | WSHP - Various Spaces | 4 | Water Source HP | 4.00 | 58.00 | 12.50 | 4.1 COP | FHP MANUFACTURING | GT048-4HZC | W | 6 | Yes | 4 | Water Source HP | 4.00 | 58.00 | 15.00 | 4.5 COP | 1.9 | 1,505 | 0 | \$185 | \$34,450 | \$1,088 | 180.6 |
| Various Locations | WSHP - Various Spaces | 3 | Water Source HP | 5.10 | 77.00 | 11.40 | 3.6 COP | FHP MANUFACTURING | GT062-4HZC | W | 6 | Yes | 3 | Water Source HP | 5.10 | 77.00 | 15.00 | 4.5 COP | 3.3 | 3,040 | 0 | \$373 | \$29,705 | \$1,040 | 76.8 |
| Various Locations | WSHP - Various Spaces | 8 | Water Source HP | 5.10 | 77.00 | 11.40 | 3.6 COP | FHP MANUFACTURING | GT062-4VTC | W | 6 | Yes | 8 | Water Source HP | 5.10 | 77.00 | 15.00 | 4.5 COP | 8.8 | 8,107 | 0 | \$995 | \$79,213 | \$2,774 | 76.8 |
| Various Locations | WSHP - Various Spaces | 1 | Water Source HP | 5.80 | 82.00 | 11.40 | 3.7 COP | FHP MANUFACTURING | GT070-4HZC | W | 6 | Yes | 1 | Water Source HP | 5.80 | 82.00 | 15.00 | 4.5 COP | 0.9 | 1,017 | 0 | \$125 | \$10,173 | \$522 | 77.3 |
| Various Locations | WSHP - Various Spaces | 5 | Water Source HP | 5.80 | 82.00 | 11.40 | 3.7 COP | FHP MANUFACTURING | GT070-4VTC | W | 6 | Yes | 5 | Water Source HP | 5.80 | 82.00 | 15.00 | 4.5 COP | 4.6 | 5,085 | 0 | \$624 | \$50,867 | \$2,610 | 77.3 |
| Various Locations | WSHP - Various Spaces | 2 | Water Source HP | 8.00 | 106.00 | 12.00 | 3.8 COP | GEO EXCEL | EM096-4HZC | W | 6 | Yes | 2 | Water Source HP | 8.00 | 106.00 | 15.00 | 4.5 COP | 1.8 | 2,232 | 0 | \$274 | \$22,917 | \$1,440 | 78.4 |
| Various Locations | WSHP - Various Spaces | 3 | Water Source HP | 10.00 | 142.00 | 12.20 | 4.1 COP | GEO EXCEL | EM120-4HZC | W | 6 | Yes | 3 | Water Source HP | 10.00 | 142.00 | 15.00 | 4.5 COP | 3.2 | 3,006 | 0 | \$369 | \$35,549 | \$2,700 | 89.0 |
| Various Locations | WSHP - Various Spaces | 5 | Water Source HP | 10.00 | 142.00 | 12.20 | 4.1 COP | GEO EXCEL | EM120-4VTC | W | 6 | Yes | 5 | Water Source HP | 10.00 | 142.00 | 15.00 | 4.5 COP | 5.4 | 5,010 | 0 | \$615 | \$59,248 | \$4,500 | 89.0 |



| | | Existing Conditions | | | | | | | | | Proposed Conditions | | | | | | | | Energy Impact & Financial Analysis | | | | | | |
|----------------------------|-----------------------------|---------------------|----------------------------|----------------------------------|---------------------------------|---|-------------------------|--------------|----------------|-----------------------|---------------------|---------------------------------|-----------------|----------------------------|----------------------------------|-------------------------------------|------------------------------------|-------------------------|------------------------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Area(s)/System(s) Served | System Quantity | System Type | Cooling Capacity per Unit (Tons) | Heating Capacity per Unit (MBh) | Cooling Mode Efficiency (SEER/IEER/EER) | Heating Mode Efficiency | Manufacturer | Model | Remaining Useful Life | ECM # | Install High Efficiency System? | System Quantity | System Type | Cooling Capacity per Unit (Tons) | Heating Capacity per Unit (kBtu/hr) | Cooling Mode Efficiency (SEER/EER) | Heating Mode Efficiency | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| Various Locations | WSHP - Various Spaces | 2 | Water Source HP | 11.60 | 174.00 | 10.50 | 3.4 COP | GEO EXCEL | EM140-4HZC | W | 6 | Yes | 2 | Water Source HP | 11.60 | 174.00 | 15.00 | 4.5 COP | 5.7 | 6,053 | 0 | \$743 | \$31,030 | \$2,088 | 39.0 |
| Various Locations | WSHP - Various Spaces | 3 | Water Source HP | 12.00 | 173.00 | 12.30 | 3.9 COP | GEO EXCEL | EM144-4VTC | W | 6 | Yes | 3 | Water Source HP | 12.00 | 173.00 | 15.00 | 4.5 COP | 5.1 | 4,497 | 0 | \$552 | \$49,294 | \$3,240 | 83.4 |
| Roof | RTU-606 - Room 606 | 1 | Package Unit | 5.00 | 80.00 | 12.00 | 0.8 AFUE | VALENT | PVG100 | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Roof | MUA-1 - Lab 601, 608, 609 | 1 | Package Unit | 10.00 | 320.00 | 12.00 | 0.8 AFUE | VALENT | PVG400 | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Roof | RTU-210 - Media Center | 1 | Package Unit | 10.00 | 120.00 | 12.00 | 0.8 AFUE | AAON | RN01030EA193KB | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Roof | DOAS-1 - Media Center | 1 | Package Unit | 4.00 | 49.00 | 12.00 | 0.816666666666667 AFUE | AAON | RQ004 | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Roof | RTU-1 - Woodshop | 1 | Package Unit | 10.00 | 120.00 | 12.00 | 0.8 AFUE | VALENT | PVG151 | | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Roof | RTU-420 - Girls Locker Room | 1 | Package Unit | 9.00 | 156.00 | 12.00 | 0.8 AFUE | AAON | RN00930EB093F9 | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Roof | 3rd Floor Elevator Room | 1 | Split-System Air-Source HP | 1.50 | 23.00 | 16.00 | 5.5 HSPF | MITSUBISHI | PUZA18NHA3 | B | 6 | Yes | 1 | Split-System Air-Source HP | 1.50 | 23.00 | 15.50 | 8.5 HSPF | 1.5 | 727 | 0 | \$89 | \$4,113 | \$150 | 44.4 |
| Ground Floor | IT Closet | 1 | Split-System | 1.50 | | 18.50 | | MITSUBISHI | PUYA18NKA7 | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Roof | Media Center | 1 | Ductless Mini-Split HP | 0.75 | 11.00 | 13.65 | 8.5 HSPF | LG | LUU097HV | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Roof | Media Center | 1 | Ductless Mini-Split HP | 2.00 | 26.00 | 13.50 | 8.5 HSPF | LG | LMU240HV | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Roof | Girl Locker Room Office | 1 | Ductless Mini-Split HP | 1.50 | 18.00 | 12.50 | 8.5 HSPF | LG | LUU189HV | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Roof | Media Center | 1 | Ductless Mini-Split HP | 12.00 | 162.00 | 12.50 | 8.5 HSPF | LG | ARUM144DTE5 | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| 2nd Floor senior storage | Senior Storage | 2 | Electric Resistance Heat | | 17.06 | | 1 COP | Qmark | MUH0571 | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| 400 Wing - All gender bath | All Gender Bath | 1 | Electric Resistance Heat | | 2.56 | | 1 COP | | | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| 400 Wing -Custodial Closet | Custodial Closet | 1 | Electric Resistance Heat | | 17.06 | | 1 COP | Qmark | MUH0571 | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| 600 Stair A | 600 Stair A | 1 | Electric Resistance Heat | | 17.06 | | 1 COP | | | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| 600 Stair B | 600 Stair B | 1 | Electric Resistance Heat | | 17.06 | | 1 COP | | | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| 6th Floor Supply Closet | Supply Closet | 2 | Electric Resistance Heat | | 17.06 | | 1 COP | Qmark | MUH0571 | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |



| | | Existing Conditions | | | | | | | | | Proposed Conditions | | | | | | | | Energy Impact & Financial Analysis | | | | | | |
|-------------------------------------|--------------------------|---------------------|--------------------------|----------------------------------|---------------------------------|---|-------------------------|--------------|---------|-----------------------|---------------------|---------------------------------|-----------------|-------------|----------------------------------|-------------------------------------|------------------------------------|-------------------------|------------------------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Area(s)/System(s) Served | System Quantity | System Type | Cooling Capacity per Unit (Tons) | Heating Capacity per Unit (MBh) | Cooling Mode Efficiency (SEER/IEER/EER) | Heating Mode Efficiency | Manufacturer | Model | Remaining Useful Life | ECM # | Install High Efficiency System? | System Quantity | System Type | Cooling Capacity per Unit (Tons) | Heating Capacity per Unit (kBtu/hr) | Cooling Mode Efficiency (SEER/EER) | Heating Mode Efficiency | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| Auditorium Attic | Auditorium Attic | 2 | Electric Resistance Heat | | 17.06 | | 1 COP | Qmark | MUH0571 | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Custodial Supply Room | Custodial Supply Room | 2 | Electric Resistance Heat | | 17.06 | | 1 COP | Qmark | MUH0571 | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| East Stair | East Stair | 1 | Electric Resistance Heat | | 17.06 | | 1 COP | | | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Electrical Room 111 | Electrical Room 111 | 1 | Electric Resistance Heat | | 17.06 | | 1 COP | Qmark | MUH0571 | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Main School Entrance | Main School Entrance | 2 | Electric Resistance Heat | | 17.06 | | 1 COP | | | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Middle Staircase | Middle Staircase | 1 | Electric Resistance Heat | | 17.06 | | 1 COP | | | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Pump Room 417 | Pump Room 417 | 1 | Electric Resistance Heat | | 17.06 | | 1 COP | Qmark | MUH0571 | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Room 104 / Auto Bay | Room 104 / Auto Bay | 1 | Electric Resistance Heat | | 17.06 | | 1 COP | Qmark | MUH0571 | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Room 508 | Room 508 | 1 | Electric Resistance Heat | | 17.06 | | 1 COP | | | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| West Staircase | West Staircase | 1 | Electric Resistance Heat | | 17.06 | | 1 COP | | | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Concession Stand - Men's Bathroom | Men's Bathroom | 1 | Electric Resistance Heat | | 5.12 | | 1 COP | | | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Concession Stand - Pantry | Pantry | 1 | Electric Resistance Heat | | 10.24 | | 1 COP | Qmark | MUH0321 | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Concession Stand - Utility Closet | Utility Closet | 1 | Electric Resistance Heat | | 10.24 | | 1 COP | Qmark | | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Concession Stand - Women's Bathroom | Women's Bathroom | 1 | Electric Resistance Heat | | 5.12 | | 1 COP | | | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Concession Stand - Utility Closet | Main Area | 1 | Electric Resistance Heat | | 10.24 | | 1 COP | | | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Pole Barn | Pole Barn | 2 | Electric Resistance Heat | | 17.06 | | 2 COP | | | W | | No | | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |

Pipe Insulation Recommendations

| | | Recommendation Inputs | | | Energy Impact & Financial Analysis | | | | | | |
|-----------------------|----------------------------|-----------------------|---------------------------------|--------------------|------------------------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Area(s)/System(s) Affected | ECM # | Length of Uninsulated Pipe (ft) | Pipe Diameter (in) | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| Custodial Supply Room | DHW | 7 | 12 | 1.50 | 0.0 | 0 | 8 | \$137 | \$160 | \$24 | 1.0 |
| Custodial Supply Room | DHW | 7 | 200 | 2.00 | 0.0 | 0 | 14 | \$252 | \$2,664 | \$400 | 9.0 |

DHW Inventory & Recommendations

| | | Existing Conditions | | | | | Proposed Conditions | | | | | | | Energy Impact & Financial Analysis | | | | | | |
|-----------------------------------|--------------------------|---------------------|--------------------------------------|----------------|----------------|-----------------------|---------------------|----------|-----------------|-------------|-----------|-------------------|------------------|------------------------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Area(s)/System(s) Served | System Quantity | System Type | Manufacturer | Model | Remaining Useful Life | ECM # | Replace? | System Quantity | System Type | Fuel Type | System Efficiency | Efficiency Units | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| Concession Stand - Utility Closet | Concession Stand | 1 | Storage Tank Water Heater (> 50 Gal) | Bradford White | EF60T125E3NA2 | W | | No | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Senior Storage Room | Senior Building | 1 | Storage Tank Water Heater (> 50 Gal) | Vaughn | S100A4184803-2 | W | | No | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Custodial Supply Room | High School | 2 | Storage Tank Water Heater (> 50 Gal) | AO SMITH | BTH-199 300 | W | | No | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Dishwasher Room | Booster Water Heater | 1 | Booster Water Heater | | | W | | No | | | | | | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |

Low-Flow Device Recommendations

| | | Recommendation Inputs | | | | Energy Impact & Financial Analysis | | | | | | |
|-----------------------|-------|-----------------------|---------------------------|--------------------------|--------------------------|------------------------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | ECM # | Device Quantity | Device Type | Existing Flow Rate (gpm) | Proposed Flow Rate (gpm) | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| Lower Library kitchen | 8 | 1 | Faucet Aerator (Kitchen) | 2.20 | 1.50 | 0.0 | 0 | 0 | \$7 | \$7 | \$2 | 0.7 |
| Room 402 Kitchen | 8 | 2 | Faucet Aerator (Kitchen) | 2.20 | 1.50 | 0.0 | 0 | 1 | \$14 | \$14 | \$4 | 0.7 |
| Science Classrooms | 8 | 65 | Faucet Aerator (Lavatory) | 2.20 | 0.50 | 0.0 | 9,036 | 0 | \$1,109 | \$466 | \$233 | 0.2 |
| Restrooms | 8 | 39 | Faucet Aerator (Lavatory) | 2.20 | 0.50 | 0.0 | 0 | 37 | \$660 | \$280 | \$140 | 0.2 |

Walk-In Cooler/Freezer Inventory & Recommendations

| | | Existing Conditions | | | Proposed Conditions | | | | Energy Impact & Financial Analysis | | | | | | |
|--------------|-------------------------|--------------------------------|--------------|----------------|---------------------|-----------------------------------|-----------------------------------|---------------------------------|------------------------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Cooler/Freezer Quantity | Case Type/Temperature | Manufacturer | Model | ECM # | Install EC Evaporator Fan Motors? | Install Electric Defrost Control? | Install Evaporator Fan Control? | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| HS - Kitchen | 1 | Low Temp Freezer (-35F to -5F) | BALLY | TEZA015H8HS2DB | 10, 11 | Yes | Yes | Yes | 0.2 | 3,148 | 0 | \$386 | \$2,799 | \$205 | 6.7 |

Commercial Refrigerator/Freezer Inventory & Recommendations

| Existing Conditions | | | | | | Proposed Conditions | | Energy Impact & Financial Analysis | | | | | | |
|---------------------|----------|---|--------------|---------------|------------------------|---------------------|--------------------------------|------------------------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Quantity | Refrigerator/ Freezer Type | Manufacturer | Model | ENERGY STAR Qualified? | ECM # | Install ENERGY STAR Equipment? | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| HS-Kitchen | 2 | Refrigerator Chest | Turbo Air | TOM-40SB-N | No | | No | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS-Kitchen | 2 | Refrigerator Chest | BEVERAGE-AIR | SM58HC-W | Yes | | No | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS-Kitchen | 2 | Refrigerator Chest | | | No | | No | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS-Kitchen | 1 | Stand-Up Freezer, Solid Door (>50 cu. ft.) | TRAULSEN | AHT232NUT-HHS | No | | No | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS-Kitchen | 2 | Stand-Up Refrigerator, Solid Door (≤15 cu. ft.) | IMBERA | VR06CBMAD | Yes | | No | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS-Kitchen | 1 | Stand-Up Refrigerator, Solid Door (>50 cu. ft.) | TRAULSEN | RDT332NUT-HHS | No | | No | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS-Kitchen | 2 | Stand-Up Refrigerator, Solid Door (>50 cu. ft.) | TRAULSEN | AHT232NUT-HHS | No | | No | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |

Commercial Ice Maker Inventory & Recommendations

| Existing Conditions | | | | | | Proposed Conditions | | Energy Impact & Financial Analysis | | | | | | |
|---------------------|----------|---|--------------|-----------|------------------------|---------------------|--------------------------------|------------------------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Quantity | Ice Maker Type | Manufacturer | Model | ENERGY STAR Qualified? | ECM # | Install ENERGY STAR Equipment? | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| HS - Ice Room | 1 | Self-Contained Unit (≥175 lbs/day), Batch | HOSHIKAKI | KM-520MAJ | No | | No | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| HS - Room 609 | 1 | Self-Contained Unit (≥175 lbs/day), Batch | HOSHIKAKI | | No | | No | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |

Cooking Equipment Inventory & Recommendations

| Existing Conditions | | | | | | Proposed Conditions | | Energy Impact & Financial Analysis | | | | | | |
|---------------------|----------|---|--------------|-------|----------------------------|---------------------|------------------------------------|------------------------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Quantity | Equipment Type | Manufacturer | Model | High Efficiency Equipment? | ECM # | Install High Efficiency Equipment? | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| Kitchen | 1 | Gas Combination Oven/Steam Cooker (<15 Pans) | Vulcan | | Yes | | No | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Kitchen | 1 | Electric Combination Oven/Steam Cooker (<15 Pans) | | | Yes | | No | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Kitchen | 1 | Gas Convection Oven (Full Size) | | | No | 9 | Yes | 0.0 | 0 | 19 | \$335 | \$9,290 | \$500 | 26.2 |
| Kitchen | 1 | Electric Fryer | Frymaster | | Yes | | No | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Kitchen | 2 | Gas Fryer | Vulcan | | Yes | | No | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Kitchen | 2 | Insulated Food Holding Cabinet (3/4 Size) | | | Yes | | No | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |



Dishwasher Inventory & Recommendations

| Existing Conditions | | | | | | | | Proposed Conditions | | Energy Impact & Financial Analysis | | | | | | |
|-----------------------|----------|---------------------------|--------------|--------------|------------------------|--------------------------|------------------------|---------------------|--------------------------------|------------------------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|--------------------------------|
| Location | Quantity | Dishwasher Type | Manufacturer | Model | Water Heater Fuel Type | Booster Heater Fuel Type | ENERGY STAR Qualified? | ECM # | Install ENERGY STAR Equipment? | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Payback w/ Incentives in Years |
| Lower Library Kitchen | 1 | Under Counter (High Temp) | GE | GDT2255SL0SS | Natural Gas | N/A | No | | No | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Room 402 Kitchen | 1 | Under Counter (High Temp) | BOSCH | | Natural Gas | N/A | No | | No | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Room 609 / Prep Room | 1 | Under Counter (High Temp) | MAYTAG | MDB4949SHZ | Electric | N/A | No | | No | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |
| Dishwasher Room | 1 | Door Type (High Temp) | Hubart | CRS66A | Electric | N/A | No | | No | 0.0 | 0 | 0 | \$0 | \$0 | \$0 | 0.0 |



Plug Load Inventory

| Existing Conditions | | | | | | |
|--------------------------------|----------|------------------------|-----------------|------------------------|--------------|-------|
| Location | Quantity | Equipment Description | Energy Rate (W) | ENERGY STAR Qualified? | Manufacturer | Model |
| Room 402 - Kitchen | 1 | Clothes Dryer | 5,000 | No | | |
| Custodial Supply Room | 1 | Clothes Washer | 900 | No | | |
| Room 402 - Kitchen | 1 | Clothes Washer | 900 | No | | |
| 3rd Fl Room 315 | 1 | Coffee Machine | 900 | No | | |
| Kitchen | 1 | Coffee Machine | 900 | No | | |
| Office - Boys Locker Room | 1 | Coffee Machine | 900 | No | | |
| Room 212 - Kitchen | 1 | Coffee Machine | 900 | No | | |
| Room 305 | 1 | Coffee Machine | 900 | No | | |
| Room 402 Kitchen | 1 | Coffee Machine | 900 | No | | |
| Room 414 | 1 | Coffee Machine | 900 | No | | |
| Room 507 | 1 | Coffee Machine | 900 | No | | |
| Room 602 | 1 | Coffee Machine | 900 | No | | |
| Room 603 / prep room | 1 | Coffee Machine | 900 | No | | |
| Room 607 / prep room | 1 | Coffee Machine | 900 | No | | |
| High School | 168 | Desktop | 105 | No | | |
| Room 605 | 1 | Fan Ceiling | 50 | No | | |
| High School | 15 | Microwave | 1,000 | No | | |
| Room 212 Hallway | 1 | Paper Shredder | 150 | No | | |
| Room 402 | 1 | Paper Shredder | 150 | No | | |
| Room 507 | 1 | Paper Shredder | 150 | No | | |
| Office - Boys Locker Room | 1 | Printer (Medium/Small) | 200 | No | | |
| Room 213 | 1 | Printer (Medium/Small) | 200 | No | | |
| Room 402 | 1 | Printer (Medium/Small) | 200 | No | | |
| Room 414 | 1 | Printer (Medium/Small) | 200 | No | | |
| Room 504 | 1 | Printer (Medium/Small) | 200 | No | | |
| Room 605 | 1 | Printer (Medium/Small) | 200 | No | | |
| 3rd Fl Room 315 | 1 | Printer/Copier (Large) | 600 | No | | |
| Office - Training | 1 | Printer/Copier (Large) | 600 | No | | |
| Room 209 | 1 | Printer/Copier (Large) | 600 | No | | |
| Room 212 Hallway | 1 | Printer/Copier (Large) | 600 | No | | |
| Room 215 Main area | 1 | Printer/Copier (Large) | 600 | No | | |
| Room 506 | 1 | Printer/Copier (Large) | 600 | No | | |
| Room 512 Superintendent office | 1 | Printer/Copier (Large) | 600 | No | | |
| Room 602 | 1 | Printer/Copier (Large) | 600 | No | | |
| High School | 52 | Projector | 200 | No | | |

| Existing Conditions | | | | | | |
|------------------------------|----------|----------------------------|-----------------|------------------------|--------------|-------|
| Location | Quantity | Equipment Description | Energy Rate (W) | ENERGY STAR Qualified? | Manufacturer | Model |
| Room 402 Kitchen | 1 | Refrigerator (Large) | 199 | No | | |
| Maintenance shop | 1 | Refrigerator (Mini) | 126 | No | | |
| Office Boys Locker Room | 1 | Refrigerator (Mini) | 126 | No | | |
| Room 112 | 1 | Refrigerator (Mini) | 126 | No | | |
| Room 114 | 1 | Refrigerator (Mini) | 126 | No | | |
| Room 207 | 1 | Refrigerator (Mini) | 126 | No | | |
| Room 215 Marianne office | 1 | Refrigerator (Mini) | 126 | No | | |
| Room 305 | 1 | Refrigerator (Mini) | 126 | No | | |
| Room 420D | 1 | Refrigerator (Mini) | 126 | No | | |
| Room 506 | 1 | Refrigerator (Mini) | 126 | No | | |
| 3rd Fl Room 315 | 1 | Refrigerator (Residential) | 172 | No | | |
| Custodial Suppy Room | 1 | Refrigerator (Residential) | 172 | No | | |
| Lower Library kitchen | 1 | Refrigerator (Residential) | 172 | No | | |
| Room 112 | 1 | Refrigerator (Residential) | 172 | No | | |
| Room 212 - Kitchen | 1 | Refrigerator (Residential) | 172 | No | | |
| Room 509A | 1 | Refrigerator (Residential) | 172 | No | | |
| Room 602 | 1 | Refrigerator (Residential) | 172 | No | | |
| Room 607 / prep room | 1 | Refrigerator (Residential) | 172 | No | | |
| Room 401 | 1 | Smart Board | 316 | No | | |
| Room 404 | 1 | Smart Board | 316 | No | | |
| High School | 30 | Television | 130 | No | | |
| 3rd Fl Room 315 | 1 | Toaster | 850 | No | | |
| 1 st Floor Hallway | 1 | Water Fountain | 92 | No | | |
| 2nd Floor Hallway | 1 | Water Fountain | 92 | No | | |
| 3 rd Floor Hallway | 1 | Water Fountain | 92 | No | | |
| 400 West Wing Hallway | 1 | Water Fountain | 92 | No | | |
| 500 Hallway | 1 | Water Fountain | 92 | No | | |
| 600 Hallway | 1 | Water Fountain | 92 | No | | |
| Auditorium Lobby | 1 | Water Fountain | 92 | No | | |
| Room 215 Main area | 1 | Water Fountain | 92 | No | | |
| Concession Stand - Main Area | 4 | Coffee Machine | 1,500 | No | | |
| Concession Stand - Pantry | 1 | Refrigerator (Residential) | 780 | No | | |
| Concession Stand - Pantry | 1 | Refrigerator (Residential) | 780 | No | | |
| Various Spaces | 33 | Misc Plug Load | 400 | No | | |
| Various Spaces | 3 | Server Closet | 2,000 | No | | |



| Existing Conditions | | | | | | |
|---------------------|----------|-----------------------|-----------------|------------------------|--------------|-------|
| Location | Quantity | Equipment Description | Energy Rate (W) | ENERGY STAR Qualified? | Manufacturer | Model |
| Maintenance Shop | 1 | Air Purifier | 400 | No | | |

Vending Machine Inventory & Recommendations

| | | Existing Conditions | Proposed Conditions | Energy Impact & Financial Analysis | | | | | | | |
|--------------------|----------|----------------------|---------------------|------------------------------------|-----------------------|--------------------------|----------------------------|----------------------------------|-------------------------|------------------|---------------------------------------|
| Location | Quantity | Vending Machine Type | ECM # | Install Controls? | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Total Incentives | Simple Payback w/ Incentives in Years |
| 3rd Floor Room 315 | 1 | Refrigerated | 12 | Yes | 0.2 | 1,612 | 0 | \$198 | \$230 | \$50 | 0.9 |

Custom (High Level) Measure Analysis


Electric Tank Water Heater to HPWH

NOTE: HPWH calculation should not be used for existing water heaters with a storage capacity greater than 120 gal.

| Existing Conditions | | | | | | Proposed Conditions | | | | Energy Impact & Financial Analysis | | | | | | | | | | | |
|-------------------------------------|--------------------------|-------------------|-----------|------------------------------|------------------------------|------------------------|-----|------------------------------|---------------------|------------------------------------|--------------------------|----------------------------|----------------------------------|-------------------------|-----------------|---------------------|------------------|----------------|---------------------------------|--------------------------------|--|
| Description | Area(s)/System(s) Served | SF of Area Served | Fuel Type | Input Capacity per Unit (kW) | Tank Capacity per Unit (Gal) | Description | COP | Tank Capacity per Unit (Gal) | Estimated Unit Cost | Total Peak kW Savings | Total Annual kWh Savings | Total Annual MMBtu Savings | Total Annual Energy Cost Savings | Estimated M&L Cost (\$) | Base Incentives | Enhanced Incentives | Total Incentives | Total Net Cost | Payback w/o Incentives in Years | Payback w/ Incentives in Years | |
| Storage Tank Water Heater (>50 Gal) | Senior Building | 20,000 | Electric | 18.0 | 100 | Heat Pump Water Heater | 2.5 | 100 | \$3,949.52 | 0.00 | 24,619 | 0 | \$3,022 | \$3,950 | \$0 | \$0 | \$0 | \$3,950 | 1.31 | 1.31 | |
| | | | Electric | | | | | | | | | | | | | | | | | | |
| | | | Electric | | | | | | | | | | | | | | | | | | |

APPENDIX B: ENERGY STAR STATEMENT OF ENERGY PERFORMANCE

Energy use intensity (EUI) is presented in terms of *site energy* and *source energy*. Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.



ENERGY STAR® Statement of Energy Performance

67

ENERGY STAR®
Score¹

Rumson-Fairhaven Regional High School (Campus)

Primary Property Type: K-12 School
Gross Floor Area (ft²): 188,875
Built: 1936

For Year Ending: September 30, 2022
Date Generated: March 09, 2023

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

| Property & Contact Information | | | |
|---|--|---|--|
| Property Address | Property Owner | Primary Contact | |
| Rumson-Fairhaven Regional High School (Campus) 74 Ridge Road Rumson, New Jersey 07760 | Rumson-Fairhaven Regional High School 74 Ridge Road Rumson, NJ 07760 (732) 639-2029 | Robert Romano 74 Ridge Road Rumson, NJ 07760 (732) 639-2029 rromano@rumsonfairhaven.org | |
| Property ID: 24399074 | | | |

| Energy Consumption and Energy Use Intensity (EUI) | | | |
|---|--|--|-------|
| Site EUI | Annual Energy by Fuel | National Median Comparison | |
| 43.2 kBtu/ft² | Natural Gas (kBtu) 642,087 (8%) | National Median Site EUI (kBtu/ft²) | 51.8 |
| | Electric - Grid (kBtu) 7,524,378 (92%) | National Median Source EUI (kBtu/ft²) | 137.8 |
| | | % Diff from National Median Source EUI | -16% |
| Source EUI | | Annual Emissions | |
| 115.1 kBtu/ft² | | Total (Location-Based) GHG Emissions (Metric Tons CO2e/year) | 690 |

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

LP Signature: _____ Date: _____

Licensed Professional

() - _____



Professional Engineer or Registered Architect Stamp (if applicable)

APPENDIX C: GLOSSARY

| TERM | DEFINITION |
|--------------------------|--|
| Blended Rate | Used to calculate fiscal savings associated with measures. The blended rate is calculated by dividing the amount of your bill by the total energy use. For example, if your bill is \$22,217.22, and you used 266,400 kilowatt-hours, your blended rate is 8.3 cents per kilowatt-hour. |
| Btu | <i>British thermal unit</i> : a unit of energy equal to the amount of heat required to increase the temperature of one pound of water by one-degree Fahrenheit. |
| CHP | <i>Combined heat and power</i> . Also referred to as cogeneration. |
| COP | <i>Coefficient of performance</i> : a measure of efficiency in terms of useful energy delivered divided by total energy input. |
| Demand Response | Demand response reduces or shifts electricity usage at or among participating buildings/sites during peak energy use periods in response to time-based rates or other forms of financial incentives. |
| DCV | <i>Demand control ventilation</i> : a control strategy to limit the amount of outside air introduced to the conditioned space based on actual occupancy need. |
| US DOE | <i>United States Department of Energy</i> |
| EC Motor | <i>Electronically commutated motor</i> |
| ECM | <i>Energy conservation measure</i> |
| EER | <i>Energy efficiency ratio</i> : a measure of efficiency in terms of cooling energy provided divided by electric input. |
| EUI | <i>Energy Use Intensity</i> : measures energy consumption per square foot and is a standard metric for comparing buildings' energy performance. |
| Energy Efficiency | Reducing the amount of energy necessary to provide comfort and service to a building/area. Achieved through the installation of new equipment and/or optimizing the operation of energy use systems. Unlike conservation, which involves some reduction of service, energy efficiency provides energy reductions without sacrifice of service. |
| ENERGY STAR | ENERGY STAR is the government-backed symbol for energy efficiency. The ENERGY STAR program is managed by the EPA. |
| EPA | <i>United States Environmental Protection Agency</i> |
| Generation | The process of generating electric power from sources of primary energy (e.g., natural gas, the sun, oil). |
| GHG | <i>Greenhouse gas</i> gases that are transparent to solar (short-wave) radiation but opaque to long-wave (infrared) radiation, thus preventing long-wave radiant energy from leaving Earth's atmosphere. The net effect is a trapping of absorbed radiation and a tendency to warm the planet's surface. |
| gpf | <i>Gallons per flush</i> |

| | |
|------------------|---|
| gpm | <i>Gallon per minute</i> |
| HID | <i>High intensity discharge</i> : high-output lighting lamps such as high-pressure sodium, metal halide, and mercury vapor. |
| hp | <i>Horsepower</i> |
| HPS | <i>High-pressure sodium</i> : a type of HID lamp. |
| HSPF | <i>Heating seasonal performance factor</i> : a measure of efficiency typically applied to heat pumps. Heating energy provided divided by seasonal energy input. |
| HVAC | <i>Heating, ventilating, and air conditioning</i> |
| IHP 2014 | US DOE Integral Horsepower rule. The current ruling regarding required electric motor efficiency. |
| IPLV | <i>Integrated part load value</i> : a measure of the part load efficiency usually applied to chillers. |
| kBtu | One thousand British thermal units |
| kW | <i>Kilowatt</i> : equal to 1,000 Watts. |
| kWh | <i>Kilowatt-hour</i> : 1,000 Watts of power expended over one hour. |
| LED | <i>Light emitting diode</i> : a high-efficiency source of light with a long lamp life. |
| LGEA | <i>Local Government Energy Audit</i> |
| Load | The total power a building or system is using at any given time. |
| Measure | A single activity, or installation of a single type of equipment, that is implemented in a building system to reduce total energy consumption. |
| MH | <i>Metal halide</i> : a type of HID lamp. |
| MBh | <i>Thousand Btu per hour</i> |
| MBtu | <i>One thousand British thermal units</i> |
| MMBtu | <i>One million British thermal units</i> |
| MV | <i>Mercury Vapor</i> : a type of HID lamp. |
| NJBPU | <i>New Jersey Board of Public Utilities</i> |
| NJCEP | <i>New Jersey's Clean Energy Program</i> : NJCEP is a statewide program that offers financial incentives, programs and services for New Jersey residents, business owners and local governments to help them save energy, money, and the environment. |
| psig | Pounds per square inch gauge |
| Plug Load | Refers to the amount of power used in a space by products that are powered by means of an ordinary AC plug. |
| PV | <i>Photovoltaic</i> : refers to an electronic device capable of converting incident light directly into electricity (direct current). |

| | |
|-----------------------------|---|
| SEER | <i>Seasonal energy efficiency ratio</i> : a measure of efficiency in terms of annual cooling energy provided divided by total electric input. |
| SEP | <i>Statement of energy performance</i> : a summary document from the ENERGY STAR Portfolio Manager. |
| Simple Payback | The amount of time needed to recoup the funds expended in an investment or to reach the break-even point between investment and savings. |
| SREC (II) | <i>Solar renewable energy credit</i> : a credit you can earn from the state for energy produced from a photovoltaic array. |
| T5, T8, T12 | A reference to a linear lamp diameter. The number represents increments of 1/8 th of an inch. |
| Temperature Setpoint | The temperature at which a temperature regulating device (thermostat, for example) has been set. |
| therm | 100,000 Btu. Typically used as a measure of natural gas consumption. |
| tons | A unit of cooling capacity equal to 12,000 Btu/hr. |
| Turnkey | Provision of a complete product or service that is ready for immediate use. |
| VAV | <i>Variable air volume</i> |
| VFD | <i>Variable frequency drive</i> : a controller used to vary the speed of an electric motor. |
| WaterSense® | The symbol for water efficiency. The WaterSense® program is managed by the EPA. |
| Watt (W) | Unit of power commonly used to measure electricity use. |
| | |

APPENDIX D: PV ANALYSIS



Rumson Fairhaven High School

Rumson Fairhaven High School

74 Ridge Rd
Rumson NJ 07760

(415) 271-8105
chuangxia@trccompanies.com

1 ABOUT US



ADAM GERZA
VP, Business Development



YULIA KRIVCHENKOVA
Manager, Utility Rates



MATTHEW CIMO
Western Regional Manager

OUR HISTORY

Energy Toolbase is an industry-leading software platform that specializes in modeling and proposing the economics of solar and energy storage projects. Our SaaS product is used by over 1,000 distributed energy organizations worldwide to accurately, objectively and transparently analyze their projects. In September of 2019, ETB merged with Pason Power, which specializes in designing, controlling and monitoring advanced energy storage systems. The newly combined company is backed by our parent, Pason Systems Inc. (TSX - PSI).

OUR MISSION

Our mission is to simplify complexity and to enable solar and energy storage developers to deploy projects more efficiently. We provide a cohesive suite of project modeling, energy storage control and asset monitoring products for solar + storage developers. We are a customer centric organization that takes great pride in the service we provide to our customers. Since our company's founding in 2014 our products have been guided by the same three core principles of: Accuracy, Objectivity, and Transparency.

PV SYSTEM DETAILS

GENERAL INFORMATION

Facility: Rumson-Fair Haven High school
Address: 74 Ridge Rd Rumson NJ 07760

SOLAR PV EQUIPMENT DESCRIPTION

Solar Panels: (2216) LG Electronics LG400Q1C-A6
Inverters: (48) Fronius USA Fronius Symo 15.0-3 (480V)

SOLAR PV EQUIPMENT TYPICAL LIFESPAN

Solar Panels: Greater than 30 Years
Inverters: 10 Years

Solar PV System Cost and Incentives

Solar PV System Cost \$4,697,061

Net Solar PV System Cost \$4,697,061

SOLAR PV SYSTEM RATING

Power Rating: 886,400 W-DC
Power Rating: 868,672 W-AC-CEC


ENERGY CONSUMPTION MIX

Annual Energy Use: 2,206,520 kWh



Utility 1,020,532 kWh (46.25%)
Solar PV 1,185,988 kWh (53.75%)

MONTHLY ENERGY USE VS SOLAR GENERATION



UTILITY RATES

The table below shows the rates associated with your current utility rate schedule (GS). Your estimated electric bills after solar are shown on the following page.

| Customer Charges | | | | Energy Charges | | | | Demand Charges | | | |
|------------------|-------------|--------------------|---------|----------------|--------------|-----------|-----------|----------------|-------------|-----------|--------|
| Season | Charge Type | Rate Type | GS | Season | Charge Type | Rate Type | GS | Season | Charge Type | Rate Type | GS |
| W | Flat Rate | per billing period | \$11.13 | W | T < 1,000 kw | Import | \$0.15486 | W | 10 kw < T | Import | \$6.17 |
| S | Flat Rate | per billing period | \$11.13 | W | 1,000 kw < T | Import | \$0.10474 | S | 10 kw < T | Import | \$6.63 |
| | | | | S | T < 1,000 kw | Import | \$0.15879 | | | | |
| | | | | S | 1,000 kw < T | Import | \$0.10424 | | | | |

CURRENT ELECTRIC BILL

The table below shows your annual electricity costs based on the most current utility rates and your previous 12 months of electrical usage.

RATE SCHEDULE: JCP&L - GS

| Time Periods | Energy Use (kWh) | Max Demand (kW) | Charges | | | |
|-------------------------|------------------|-----------------|---------|-----------|----------|-----------|
| Bill Ranges & Seasons | Total | NC / Max | Other | Energy | Demand | Total |
| 1/1/2022 - 2/1/2022 W | 209,520 | 470 | \$11 | \$21,994 | \$2,838 | \$24,844 |
| 2/1/2022 - 3/1/2022 W | 199,520 | 470 | \$11 | \$20,947 | \$2,838 | \$23,796 |
| 3/1/2022 - 4/1/2022 W | 204,400 | 405 | \$11 | \$21,458 | \$2,437 | \$23,906 |
| 4/1/2022 - 5/1/2022 W | 166,560 | 400 | \$11 | \$17,495 | \$2,406 | \$19,912 |
| 5/1/2022 - 6/1/2022 W | 185,520 | 450 | \$11 | \$19,481 | \$2,715 | \$22,207 |
| 6/1/2022 - 7/1/2022 S | 188,960 | 473 | \$11 | \$19,751 | \$3,070 | \$22,832 |
| 7/1/2022 - 8/1/2022 S | 174,080 | 473 | \$11 | \$18,200 | \$3,070 | \$21,281 |
| 8/1/2022 - 9/1/2022 S | 176,520 | 350 | \$11 | \$18,455 | \$2,254 | \$20,720 |
| 9/1/2022 - 10/1/2022 S | 188,320 | 451 | \$11 | \$19,685 | \$2,924 | \$22,620 |
| 10/1/2021 - 11/1/2021 W | 150,000 | 473 | \$11 | \$15,761 | \$2,857 | \$18,628 |
| 11/1/2021 - 12/1/2021 W | 152,000 | 473 | \$11 | \$15,970 | \$2,857 | \$18,838 |
| 12/1/2021 - 1/1/2022 W | 211,120 | 433 | \$11 | \$22,162 | \$2,610 | \$24,783 |
| Total | 2,206,520 | - | \$134 | \$231,359 | \$32,875 | \$264,368 |

4.1.5 NEW ELECTRIC BILL

RATE SCHEDULE: JCP&L - GS

| Time Periods | Energy Use (kWh) | Max Demand (kW) | Charges | | | |
|-------------------------|------------------|-----------------|---------|-----------|----------|-----------|
| Bill Ranges & Seasons | Total | NC / Max | Other | Energy | Demand | Total |
| 1/1/2022 - 2/1/2022 W | 154,434 | 452 | \$11 | \$16,225 | \$2,727 | \$18,963 |
| 2/1/2022 - 3/1/2022 W | 130,947 | 390 | \$11 | \$13,765 | \$2,345 | \$16,121 |
| 3/1/2022 - 4/1/2022 W | 103,732 | 334 | \$11 | \$10,915 | \$1,999 | \$12,925 |
| 4/1/2022 - 5/1/2022 W | 50,686 | 373 | \$11 | \$5,359 | \$2,240 | \$7,610 |
| 5/1/2022 - 6/1/2022 W | 46,895 | 419 | \$11 | \$4,962 | \$2,524 | \$7,496 |
| 6/1/2022 - 7/1/2022 S | 50,567 | 424 | \$11 | \$5,326 | \$2,745 | \$8,082 |
| 7/1/2022 - 8/1/2022 S | 33,043 | 427 | \$11 | \$3,499 | \$2,765 | \$6,275 |
| 8/1/2022 - 9/1/2022 S | 49,916 | 327 | \$11 | \$5,258 | \$2,102 | \$7,371 |
| 9/1/2022 - 10/1/2022 S | 79,879 | 401 | \$11 | \$8,381 | \$2,592 | \$10,984 |
| 10/1/2021 - 11/1/2021 W | 63,460 | 378 | \$11 | \$6,697 | \$2,271 | \$8,978 |
| 11/1/2021 - 12/1/2021 W | 95,087 | 346 | \$11 | \$10,009 | \$2,073 | \$12,093 |
| 12/1/2021 - 1/1/2022 W | 161,885 | 395 | \$11 | \$17,005 | \$2,375 | \$19,392 |
| Total | 1,020,531 | - | \$134 | \$107,399 | \$28,757 | \$136,290 |

ANNUAL ELECTRICITY SAVINGS: \$128,078

7 ENVIRONMENTAL BENEFITS



OVER THE NEXT 20 YEARS, YOUR SYSTEM WILL DO MORE THAN JUST SAVE YOU MONEY. ACCORDING TO THE EPA'S GREENHOUSE GAS EQUIVALENCIES CALCULATOR ([SOURCE](#)), YOUR SOLAR PV SYSTEM WILL HAVE THE IMPACT OF REDUCING:



18,580
tons of CO₂ Offset



42,246,869
Miles Driven By Cars



278,707
Trees Planted