



Local Government Energy Audit Report

Glen Meadow Middle School

February 14, 2025

Prepared for:

Vernon Township School District
7 Sammis Rd
Vernon, New Jersey 07462

Prepared by:

TRC
317 George Street
New Brunswick, New Jersey 08901



Disclaimer

The goal of this audit report is to identify potential energy efficiency opportunities and help prioritize specific measures for implementation. Most energy conservation measures have received preliminary analysis of feasibility that identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to establish a basis for further discussion and to help prioritize energy measures.

TRC reviewed the energy conservation measures and estimates of energy savings for technical accuracy. Actual, achieved energy savings depend on behavioral factors and other uncontrollable variables and, therefore, estimates of final energy savings are not guaranteed. TRC and the New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

TRC bases estimated material and labor costs primarily on RS Means cost manuals as well as on our experience at similar facilities. This approach is based on standard cost estimating manuals and is vendor neutral. Cost estimates include material and labor pricing associated with one for one equipment replacements. Cost estimates do not include demolition or removal of hazardous waste. The actual implementation costs for energy savings projects are anticipated to be significantly higher based on the specific conditions at your site(s). We strongly recommend that you work with your design engineer or contractor to develop actual project costs for your specific scope of work for the installation of high efficiency equipment. We encourage you to obtain multiple estimates when considering measure installations. Actual installation costs can vary widely based on selected products and installers. TRC and NJBPU do not guarantee cost estimates and shall in no event be held liable should actual installed costs vary from these material and labor estimates.

Incentive values provided in this report are estimated based on previously run state efficiency programs. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. Please review all available utility program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

The customer and their respective contractor(s) are responsible to implement energy conservation measures in complete conformance with all applicable local, state, and federal requirements.

Copyright ©2025 TRC. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product, or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks, or copyrights.

Table of Contents

1	Executive Summary	1
1.1	Planning Your Project	4
	Pick Your Installation Approach	4
	Options from Your Utility Company	4
	Options from New Jersey's Clean Energy Program	5
2	Existing Conditions	6
2.1	Site Overview	6
2.2	Building Occupancy	6
2.3	Building Envelope	6
2.4	Lighting Systems	8
2.5	Air Handling Systems	9
	Unit Ventilators	9
	Unitary Electric HVAC Equipment	10
	Air Handling Units (AHUs)	10
2.6	Heating Hot Water Systems	10
2.7	Chilled Water Systems	11
2.8	Building Automation System (BAS)	11
2.9	Domestic Hot Water	12
2.10	Food Service Equipment	12
2.11	Refrigeration	13
2.12	Plug Load and Vending Machines	13
2.13	Water-Using Systems	14
3	Energy Use and Costs	15
3.1	Electricity	17
3.2	No. 2 Fuel Oil	18
3.3	Benchmarking	19
	Tracking your Energy Performance	20
3.4	Understanding Your Utility Bills	20
4	Energy Conservation Measures	21
4.1	Lighting	24
	ECM 1: Retrofit Fixtures with LED Lamps	24

4.2	Lighting Controls	24
	ECM 2: Install Occupancy Sensor Lighting Controls.....	24
	ECM 3: Install High/Low Lighting Controls.....	25
4.3	Variable Frequency Drives (VFD)	25
	ECM 4: Install VFDs on Constant Volume (CV) Fans	26
	ECM 5: Install VFDs on Chilled Water Pumps	26
	ECM 6: Install VFDs on Heating Water Pumps.....	26
4.4	Unitary HVAC	27
	ECM 7: Install High Efficiency Air Conditioning Units	27
4.5	Domestic Water Heating.....	27
	ECM 8: Install Low-Flow DHW Devices	27
4.6	Food Service and Refrigeration Measures.....	28
	ECM 9: Refrigerator/Freezer Case Electrically Commutated Motors	28
	ECM 10: Refrigeration Controls	28
	ECM 11: Vending Machine Control.....	28
4.7	Measures for Future Consideration.....	29
	Upgrade to a Heat Pump System.....	29
	VRF Systems	30
	Replace Smooth V-Belts with Notched or Synchronous Belts	30
5	Energy Efficient Best Practices.....	32
	Energy Tracking with ENERGY STAR Portfolio Manager	32
	Lighting Maintenance	32
	Motor Maintenance.....	32
	Fans to Reduce Cooling Load	32
	AC System Evaporator/Condenser Coil Cleaning.....	33
	HVAC Filter Cleaning and Replacement.....	33
	Ductwork Maintenance	33
	Boiler Maintenance.....	33
	Water Heater Maintenance	33
	Procurement Strategies	34
6	Water Best Practices.....	35
	Getting Started.....	35
	Leak Detection and Repair	35
	Toilets and Urinals	35




Faucets and Showerheads	36
7 On-Site Generation	37
7.1 Solar Photovoltaic	38
7.2 Combined Heat and Power	43
8 Electric Vehicles.....	44
8.1 EV Charging	44
9 Project Funding and Incentives	46
9.1 New Jersey's Clean Energy Program	47
9.2 Utility Energy Efficiency Programs	54
10 Project Development	56
11 Energy Purchasing and Procurement Strategies	57
11.1 Retail Electric Supply Options	57
11.2 Retail Natural Gas Supply Options	57
Appendix A: Equipment Inventory & Recommendations	A-1
Appendix B: ENERGY STAR Statement of Energy Performance	B-1
Appendix C: Additional Study	C-1
Appendix D: Glossary	D-1


1 EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) report for Glen Meadow Middle School. This report provides you with information about your facility's energy use, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help make changes in your facility. TRC conducted this study as part of a comprehensive effort to assist New Jersey school districts and local governments in controlling their energy costs and to help protect our environment by reducing statewide energy consumption.

BUILDING PERFORMANCE REPORT



ENERGY STAR® Benchmarking Score	58 <i>(1-100 scale)</i>	<p>Congratulations, your building performs better than the national average. This report has suggestions about how to keep your building running efficiently, further improve performance, and lower your energy bills even more.</p>
---------------------------------	----------------------------	---



Energy Use by System


POTENTIAL IMPROVEMENTS



This energy audit considered a range of potential energy improvements in your building. Costs and savings will vary between improvements. Presented below are two potential scopes of work for your consideration.


Scenario 1: Full Package (All Evaluated Measures)

Installation Cost	\$174,810
Potential Rebates & Incentives ¹	\$28,000
Annual Cost Savings	\$34,484
Annual Energy Savings	Electricity: 251,071 kWh No. 2 Fuel Oil: -458 Gallons
Greenhouse Gas Emission Savings	121 Tons
Simple Payback	4.3 Years
Site Energy Savings (All Utilities)	13%



Scenario 2: Cost Effective Package²

Installation Cost	\$152,710
Potential Rebates & Incentives	\$25,700
Annual Cost Savings	\$32,850
Annual Energy Savings	Electricity: 239,575 kWh No. 2 Fuel Oil: -458 Gallons
Greenhouse Gas Emission Savings	115 Tons
Simple Payback	3.9 Years
Site Energy Savings (all utilities)	12%



On-site Generation Potential

Photovoltaic	Additional Scope
Combined Heat and Power	None

¹ Incentives are based on previously run state rebate programs. Contact your utility provider for current program incentives that may apply.

² A cost-effective measure is defined as one where the simple payback does not exceed two-thirds of the expected proposed equipment useful life. Simple payback is based on the net measure cost after potential incentives.

#	Energy Conservation Measure	Cost Effective?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades			149,338	28.3	-62	\$20,044	\$56,440	\$11,480	\$44,960	2.2	140,165
ECM 1	Retrofit Fixtures with LED Lamps	Yes	149,338	28.3	-62	\$20,044	\$56,440	\$11,480	\$44,960	2.2	140,165
Lighting Control Measures			17,180	2.6	-7	\$2,306	\$14,870	\$4,770	\$10,100	4.4	16,125
ECM 2	Install Occupancy Sensor Lighting Controls	Yes	12,920	2.0	-5	\$1,734	\$9,510	\$1,090	\$8,420	4.9	12,127
ECM 3	Install High/Low Lighting Controls	Yes	4,260	0.6	-2	\$572	\$5,360	\$3,680	\$1,680	2.9	3,998
Variable Frequency Drive (VFD) Measures			77,886	18.0	0	\$11,071	\$88,800	\$10,900	\$77,900	7.0	78,430
ECM 4	Install VFDs on Constant Volume (CV) Fans	Yes	56,435	14.7	0	\$8,022	\$60,600	\$6,400	\$54,200	6.8	56,830
ECM 5	Install VFDs on Chilled Water Pumps	Yes	8,580	1.9	0	\$1,220	\$11,300	\$1,800	\$9,500	7.8	8,640
ECM 6	Install VFDs on Heating Water Pumps	Yes	12,870	1.4	0	\$1,829	\$16,900	\$2,700	\$14,200	7.8	12,960
Unitary HVAC Measures			2,917	1.5	0	\$415	\$10,800	\$500	\$10,300	24.8	2,937
ECM 7	Install High Efficiency Air Conditioning Units	No	2,917	1.5	0	\$415	\$10,800	\$500	\$10,300	24.8	2,937
Domestic Water Heating Upgrade			0	0.0	6	\$116	\$180	\$90	\$90	0.8	1,005
ECM 8	Install Low-Flow DHW Devices	Yes	0	0.0	6	\$116	\$180	\$90	\$90	0.8	1,005
Food Service & Refrigeration Measures			3,751	0.3	0	\$533	\$3,720	\$260	\$3,460	6.5	3,777
ECM 9	Refrigerator/Freezer Case Electrically Commutated Motors	Yes	524	0.1	0	\$75	\$750	\$80	\$670	9.0	528
ECM 10	Refrigeration Controls	Yes	1,615	0.0	0	\$230	\$2,700	\$130	\$2,570	11.2	1,626
ECM 11	Vending Machine Control	Yes	1,612	0.2	0	\$229	\$270	\$50	\$220	1.0	1,623
TOTALS (COST EFFECTIVE MEASURES)			248,155	49.2	-63	\$34,070	\$164,010	\$27,500	\$136,510	4.0	239,502
TOTALS (ALL MEASURES)			251,071	50.6	-63	\$34,484	\$174,810	\$28,000	\$146,810	4.3	242,439

* - All incentives presented in this table are included as placeholders for planning purposes and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

All Evaluated Energy Improvements³

For more detail on each evaluated energy improvement and a break out of cost-effective improvements, see **Section 4: Energy Conservation Measures**.

³ TRC bases estimated material and labor costs primarily on RS Means cost manuals as well as on our experience at similar facilities. This approach is based on standard cost estimating manuals and is vendor neutral. Cost estimates include material and labor pricing associated with one for one equipment replacements. Cost estimates do not include demolition or removal of hazardous waste. The actual implementation costs for energy savings projects are anticipated to be significantly higher based on the specific conditions at your site(s). We strongly recommend that you work with your design engineer or contractor to develop actual project costs for your specific scope of work for the installation of high efficiency equipment. We encourage you to obtain multiple estimates when considering measure installations.

1.1 Planning Your Project

Careful planning makes for a successful energy project. When considering this scope of work, you will have some decision to make, such as:

- ◆ How will the project be funded/and or financed?
- ◆ Is it best to pursue individual ECMs, groups of ECMs, or use a comprehensive approach where all ECMs are installed together?
- ◆ Are there other facility improvements that should happen at the same time?

Pick Your Installation Approach

Utility-run energy efficiency programs and New Jersey's Clean Energy Programs, give you the flexibility to do a little or a lot. Rebates, incentives, and financing are available to help reduce both your installation costs and your energy bills. If you are planning to take advantage of these programs, make sure to review incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives *before* purchasing materials or starting installation.

Options from Your Utility Company

Prescriptive and Custom Rebates

For facilities wishing to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the Prescriptive and Custom Rebates program. To participate, you can use internal resources or an outside firm or contractor to perform the final design of the ECM(s) and install the equipment. Program pre-approval may be required for some incentives. Contact your utility company for more details prior to project installation.

Direct Install

The Direct Install program provides turnkey installation of multiple measures through an authorized contractor. This program can provide incentives up to 70% or 80% of the cost of selected measures. A Direct Install contractor will assess and verify individual measure eligibility and perform the installation work. The Direct Install program is available to sites with an average peak demand of less than 200 kW.

Engineered Solutions

The Engineered Solutions program provides tailored energy-efficiency assistance and turnkey engineering services to municipalities, universities, schools, hospitals, and healthcare facilities (MUSH), non-profit entities, and multifamily buildings. The program provides all professional services from audit, design, construction administration, to commissioning and measurement and verification for custom whole-building energy-efficiency projects. Engineered Solutions allows you to install as many measures as possible under a single project as well as address measures that may not qualify for other programs.

For more details on these programs please contact your utility provider.

Options from New Jersey's Clean Energy Program

Financing and Planning Support with the Energy Savings Improvement Program (ESIP)

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the ESIP. Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as attractive financing for implementing ECMs. You have already taken the first step as an LGEA customer, because this report is required to participate in ESIP.

Resiliency with Return on Investment through Combined Heat and Power (CHP)

The CHP program provides incentives for combined heat and power (i.e., cogeneration) and waste heat to power projects. Combined heat and power systems generate power on-site and recover heat from the generation system to meet on-site thermal loads. Waste heat to power systems use waste heat to generate power. You will work with a qualified developer who will design a system that meets your building's heating and cooling needs.

Successor Solar Incentive Program (SuSI)

New Jersey is committed to supporting solar energy. Solar projects help the state reach the renewable goals outlined in the state's Energy Master Plan. The SuSI program is used to register and certify solar projects in New Jersey. Rebates are not available, but certified solar projects are able to earn one SREC II (Solar Renewable Energy Certificates II) for each megawatt-hour of solar electricity produced from a qualifying solar facility.

Ongoing Electric Savings with Demand Response

The Demand Response Energy Aggregator program reduces electric loads at commercial facilities when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. By enabling commercial facilities to reduce electric demand during times of peak demand, the grid is made more reliable, and overall transmission costs are reduced for all ratepayers. Curtailment service providers provide regular payments to medium and large consumers of electric power for their participation in demand response (DR) programs. Program participation is voluntary, and facilities receive payments regardless of whether they are called upon to curtail their load during times of peak demand.

Large Energy User Program (LEUP)

LEUP is designed to promote self-investment in energy efficiency for the largest energy consumers in the state. Customers in this category spend about \$5 million a year on energy bills. This program incentivizes owners/users of buildings to upgrade or install energy conserving measures in existing buildings to help offset the capital costs associated with the project. The efficiency upgrades are customized to meet the requirements of the customers' existing facilities, while advancing the State's energy efficiency, conservation, and greenhouse gas reduction goals.

For more details on these programs please visit [New Jersey's Clean Energy Program website](#).



2 EXISTING CONDITIONS

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) report for Glen Meadow Middle School. This report provides information on how your facility uses energy, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help you implement the ECMs.

TRC conducted this study as part of a comprehensive effort to assist New Jersey educational and local government facilities in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

2.1 Site Overview

On August 9, 2024, TRC performed an energy audit at Glen Meadow Middle School located in Vernon, New Jersey. TRC met with facility staff to review the facility operations and help focus our investigation on specific energy-using systems.

Glen Meadow Middle School is a 2-story, 82,700 square foot building built in 1980. Spaces include classrooms, a gymnasium, corridors, stairwells, offices, a dining room, kitchen, and mechanical spaces.

2.2 Building Occupancy

The school is fully occupied from September through June. Typical weekday occupancy is 183 staff and 646 students. Summer occupancy includes continuing maintenance activities. There are no weekend activities.

Building Name	Weekday/Weekend	Operating Schedule
Glen Meadow Middle School - General Operating Hours	Weekday	6:00 AM - 11:00 PM
	Weekend	Varied
Glen Meadow Middle School - Class Hours	Weekday	7:00 AM - 3:00 PM

Building Occupancy Schedule

2.3 Building Envelope


Building walls are concrete block over structural steel with a brick façade. The roof is flat and covered with black membrane, which is in poor condition.





Building Façade

Most of the windows are double glazed and have aluminum frames with a thermal break. The glass-to-frame seals are in fair condition. The operable window weather seals are in fair condition, showing little evidence of wear. Exterior doors have aluminum frames and are in fair condition with undamaged door seals. Degraded window and door seals increase drafts and outside air infiltration.




Exterior Doors and Windows

2.4 Lighting Systems

The primary interior lighting system uses 32-Watt linear fluorescent T8 lamps. Fixture types include 1-, 2-, or 4-lamp, 4-foot-long recessed troffers and surface mounted fixtures. There are also 2-foot fixtures with linear tube lamps. Typically, T8 fluorescent lamps use electronic ballasts.

Some of the linear fixtures have been converted to LED tube lamps. Additionally, there are some compact fluorescent (CFL) plug-in and screw in lamps.

Gymnasium fixtures have manually controlled high bay, high output (HO) linear fluorescent lamps. All exit signs are LED. Most fixtures are in fair condition. Interior lighting levels were generally sufficient.



Linear Fluorescent and LED fixtures

Most lighting fixtures are controlled manually with a few controlled by occupancy sensors. Exterior fixtures include LED wall packs and flood light fixtures. Exterior fixtures are photocell controlled.



Canopy fixture and Wall Pack

The site has pole-mounted LED fixtures illuminating roadways and parking lots throughout the complex. Fixtures are controlled by photocells.



Pole Top Fixtures

2.5 Air Handling Systems

Unit Ventilators

Unit ventilators are equipped with supply fan motors, electronic controlled outside air dampers, and fan coil valves connected to the hydronics distribution system. They provide heating, cooling, and ventilation to classrooms. This system is original to the building and appears to be in fair operating condition.



Fan Coil Units

Unitary Electric HVAC Equipment

Classrooms and offices throughout the building use window air conditioning (AC) units. These vary in capacity between 1.5- and 2.66-tons. The units are in fair condition. They range in efficiency between 8.7 EER to 11.8 EER. They are not ENERGY STAR labeled. Select areas use ductless mini split air conditioning or heat pump systems. The systems range between 1- and 2-tons with heat pump heating capacities between 12 and 27.6 MBh. They vary in condition. The facility has one split system, 5-ton air conditioner with an EER of 9.



Condensing Units

Air Handling Units (AHUs)

The building is partially conditioned by air handling units. The units are equipped with supply fan motors, hot water heating coils, and chilled water coils for cooling. The units are controlled by the Building Automation System (BAS).




HV Unit and BMS Diagram

2.6 Heating Hot Water Systems

Two Weil-McLain 2,620 MBh oil fired hot water boilers serve the building heating load. The burners are fully- modulating with a nominal efficiency of 85 percent. The boilers are configured in an automated lead-lag control scheme. Multiple are required under high load conditions. Installed in 2011, they are in fair condition. There is no service contract in place.

The hydronic distribution system is a 4- pipe heating and cooling system.


The boilers are configured in a constant flow primary distribution with three 5 hp constant speed controlled hot water pumps, which are operating with an automated lead-lag control scheme. The boilers provide hot water to unit ventilators fin tube radiators, fan coil units, and AHUs throughout the building.



Boilers and Unit Label

2.7 Chilled Water Systems


The chiller plant consists of a 100-ton, Trane, R-410, air cooled scroll chiller. Two 5 hp chilled water pumps circulate water to end uses.



Chiller and Unit Label

2.8 Building Automation System (BAS)

An Automated Logic BAS controls the HVAC equipment, boilers, chiller, air handling units, and fan coil units. The BAS provides equipment scheduling control and monitors and controls space temperatures, supply air temperatures, humidity, heating water loop temperatures, and chilled water loop temperatures.



BAS Diagrams

2.9 Domestic Hot Water

Hot water is produced by a 75 gallon 76 MBh oil-fired storage water heater with an efficiency of 80 percent.

One fractional hp circulation pump circulates water to end uses. The circulation pump operates continuously.



Storage Tank Water Heater

2.10 Food Service Equipment

The kitchen has all-electric equipment that is used to prepare meals for students and staff. Most cooking is done using an electric oven. Bulk prepared foods are held in electric holding cabinets. Equipment is not high efficiency and is in fair condition.

The dishwasher is a non-ENERGY STAR high temperature, rack type unit. It has a 12-kW electric booster heater.

Visit https://www.energystar.gov/products/commercial_food_service_equipment for the latest information on high efficiency food service equipment.



Kitchen Equipment and Dishwasher

2.11 Refrigeration

The kitchen has a stand-up refrigerator with a solid door. There is also a refrigerator chest. All equipment is standard efficiency and in fair condition.

The walk-in refrigerator has an estimated 0.75-ton compressor located above it and a 2-fan evaporator.

Visit https://www.energystar.gov/products/commercial_food_service_equipment for the latest information on high efficiency food service equipment.



Walk in Cooler and Refrigerator Box


2.12 Plug Load and Vending Machines

You may wish to consider paying particular attention to minimizing your plug load usage. This report makes suggestions for ECMs in this area as well as energy efficient best practices.

There are approximately 67 computer workstations throughout the facility. Plug loads include general cafe and office equipment. There are classroom typical loads such as smart boards, projectors, and fans.

There are several residential style refrigerators throughout the building. These vary in condition and efficiency.

There is one refrigerated beverage vending machine. The vending machine is not equipped with occupancy-based controls.



Water Fountain and 3D Printer

2.13 Water-Using Systems

Water is provided by an on-site well.


Potable water is used for drinking, cleaning, cooking, sanitary fixtures, building conditioning, landscaping, and vehicle washing.

EPA WaterSense® has set maximum flow rates for sanitary fixtures. They are: 1.28 gallons per flush (gpf) for toilets, 0.5 gpf for urinals, 1.5 gallons per minute (gpm) for lavatory faucets, and 2.0 gpm for showerheads. There are 17 restrooms with toilets and sinks. Faucet flow rates are at 0.5 gallons per minute (gpm) or higher.

3 ENERGY USE AND COSTS


Twelve months of utility billing data are used to develop annual energy consumption and cost data. This information creates a profile of the annual energy consumption and energy costs.

Utility Summary		
Fuel	Usage	Cost
Electricity	735,984 kWh	\$104,615
No. 2 fuel oil	27,078 Gallons	\$71,138
Total		\$175,753



An energy balance identifies and quantifies energy use in your various building systems. This can highlight areas with the most potential for improvement. This energy balance was developed using calculated energy use for each of the end uses noted in the figure.


The energy auditor collects information regarding equipment operating hours, capacity, efficiency, and other operational parameters from facility staff, drawings, and on-site observations. This information is used as the inputs to calculate the existing conditions energy use for the site. The calculated energy use is then compared to the historical energy use and the initial inputs are revised, as necessary, to balance the calculated energy use to the historical energy use.



Energy Balance by System

3.1 Electricity

Sussex Rural Electric Cooperative delivers electricity under rate class 213 Commercial Sales.




Electric Billing Data					
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost
4/1/23	31	69,000	260	\$2,604	\$9,382
5/1/23	30	50,160	238	\$2,376	\$7,327
6/1/23	31	61,800	244	\$2,436	\$8,516
7/1/23	30	61,440	284	\$2,844	\$8,889
8/1/23	31	63,480	248	\$2,484	\$8,810
9/1/23	31	61,560	212	\$2,124	\$8,181
10/1/23	30	63,360	317	\$3,168	\$9,399
11/1/23	31	61,800	272	\$2,724	\$8,804
12/1/23	30	58,800	247	\$2,472	\$8,261
1/1/24	31	59,400	243	\$2,430	\$8,531
2/1/24	31	65,760	239	\$2,388	\$9,649
3/1/24	29	61,440	236	\$2,364	\$9,154
Totals	366	738,000	317	\$30,414	\$104,901
Annual	365	735,984	317	\$30,331	\$104,615

Notes:

- Peak demand of 317 kW occurred in September '23.
- Average demand over the past 12 months was 253 kW.
- The average electric cost over the past 12 months was \$0.142/kWh, which is the blended rate that includes energy supply, distribution, demand, and other charges. This report uses this blended rate to estimate energy cost savings.

3.2 No. 2 Fuel Oil

Bottini Fuel delivers No. 2 fuel oil to the project site.



No. 2 fuel oil Billing Data			
Period Ending	Days in Period	Oil Usage (Gallons)	Fuel Cost
3/1/23		5,001	\$5,001
4/1/23	31	0	\$0
5/1/23	30	0	\$0
6/1/23	31	0	\$0
7/1/23	30	0	\$0
8/1/23	31	0	\$0
9/1/23	31	0	\$0
10/1/23	30	5,000	\$16,131
11/1/23	31	5,000	\$15,647
12/1/23	30	5,000	\$14,241
1/1/24	31	5,000	\$14,662
2/1/24	31	0	\$0
Totals	337	25,001	\$65,681
Annual	365	27,078	\$71,138

Notes:

- The average No. 2 fuel oil cost for the past 12 months is \$2.627 per gallon, which is the blended rate used throughout the analysis.
- Fuel deliveries do not necessarily correspond to periods of use.


3.3 Benchmarking

Your building was benchmarked using the United States Environmental Protection Agency's (EPA) Portfolio Manager® software. Benchmarking compares your building's energy use to that of similar buildings across the country, while neutralizing variations due to location, occupancy, and operating hours. Some building types can be scored with a 1-100 ranking of a building's energy performance relative to the national building market. A score of 50 represents the national average and a score of 100 is best.

This ENERGY STAR benchmarking score provides a comprehensive snapshot of your building's energy performance. It assesses the building's physical assets, operations, and occupant behavior, which is compiled into a quick and easy-to-understand score.

Benchmarking Score	58
---------------------------	-----------

Congratulations, your building performs better than the national average. This report has suggestions about how to keep your building running efficiently, further improve performance, and lower your energy bills even more.



Energy Use Intensity Comparison⁴

Energy use intensity (EUI) measures energy consumption per square foot and is the standard metric for comparing buildings' energy performance. A lower EUI means better performance and less energy consumed. Several factors can cause a building to vary from typical energy usage. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and occupant behavior all contribute to a building's energy use and the benchmarking score.

⁴ Based on all evaluated ECMs

Tracking your Energy Performance

Keeping track of your energy and water use on a monthly basis is one of the best ways to keep utility costs in check and keep your facility operating efficiently. Update your utility information in Portfolio Manager regularly, so that you can keep track of your building's performance.

We have created a Portfolio Manager account for your facility and have already entered the monthly utility data shown above for you. Account login information for your account will be sent via email.

Free online training is available to help you use ENERGY STAR Portfolio Manager to track your building's performance at: <https://www.energystar.gov/buildings/training>.

For more information on ENERGY STAR and Portfolio Manager, visit their [website](#).

3.4 Understanding Your Utility Bills

The State of New Jersey Department of the Public Advocate provides detailed information on how to read natural gas and electric bills. Your bills contain important information including account numbers, meter numbers, rate schedules, meter readings, and the supply and delivery charges. Gas and electric bills both provide comparisons of current energy consumption with prior usage.

Sample bills, with annotation, may be viewed at:

https://www.nj.gov/rpa/docs/Understanding_Electric_Bill.pdf

https://www.nj.gov/rpa/docs/Understanding_Gas_Bill.pdf

Why Utility Bills Vary

Utility bills vary from one month to another for many reasons. For this reason, assessing the effects of your energy savings efforts can be difficult.

Billing periods vary, typically ranging between 28 and 33 days. Electric bills provide the kilowatt-hours (kWh) used per month while gas bills provide therms (or hundreds of cubic feet - CCF) per month consumption information. Monthly consumption information can be helpful as a tool to assess your efforts to reduce energy, particularly when compared to monthly usage from a similar calendar period in a prior year.

Bills typically vary seasonally, often with more gas consumed in the winter for heating, and more electricity used in the summer when air conditioning is used. Facilities with electric heating may experience higher electricity use in the winter. Seasonal variance will be impacted by the type of heating and cooling systems used. Normal seasonal fluctuations are further impacted by the weather. Extremely cold or hot weathers causes HVAC equipment to run longer, increasing usage. Other monthly fluctuations in usage can be caused by changes in building occupancy. Utility bills provide a comparison of usage between the current period and comparable billing month period of the prior year. Year-to-year monthly use comparisons can point to trends with energy savings for measures/projects that were implemented within the timeframe, but these comparisons do not account for changing weather or occupancy patterns.

The price of fuel and purchased power used to produce and delivery electricity and gas fluctuates. Any increase or decrease in these costs will be reflected in your monthly bill. Additionally, billing rates occasionally change after justification and approval of the NJBPU. For this reason, it is more useful to review energy use rather than cost when assessing energy use trends or the impact of energy conservation measures implemented.

4 ENERGY CONSERVATION MEASURES

The goal of this audit report is to identify and evaluate potential energy efficiency improvements and provide information about the cost effectiveness of those improvements. Most energy conservation measures have received preliminary analysis of feasibility, which identifies expected ranges of savings. This level of analysis is typically sufficient to demonstrate project cost-effectiveness and help prioritize energy measures.

Calculations of energy use and savings are based on the current version of the *New Jersey's Clean Energy Program Protocols to Measure Resource Savings*, which is approved by the NJBPU. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances.

Operation and maintenance costs for the proposed new equipment will generally be lower than the current costs for the existing equipment—especially if the existing equipment is at or past its normal useful life. We have conservatively assumed there to be no impact on overall maintenance costs over the life of the equipment.

Financial incentives in this report are based on the previously run state rebate program SmartStart, which has been retired. Now, all investor-owned gas and electric utility companies are offering complementary energy efficiency programs directly to their customers. Some measures and proposed upgrades may be eligible for higher incentives than those shown below. The incentives in the summary tables should be used for high-level planning purposes. To verify incentives, reach out to your utility provider or visit the [NJCEP website](#) for more information.

For a detailed list of the locations and recommended energy conservation measures for all inventoried equipment, see Appendix A: Equipment Inventory & Recommendations.

#	Energy Conservation Measure	Cost Effective?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades			149,338	28.3	-62	\$20,044	\$56,440	\$11,480	\$44,960	2.2	140,165
ECM 1	Retrofit Fixtures with LED Lamps	Yes	149,338	28.3	-62	\$20,044	\$56,440	\$11,480	\$44,960	2.2	140,165
Lighting Control Measures			17,180	2.6	-7	\$2,306	\$14,870	\$4,770	\$10,100	4.4	16,125
ECM 2	Install Occupancy Sensor Lighting Controls	Yes	12,920	2.0	-5	\$1,734	\$9,510	\$1,090	\$8,420	4.9	12,127
ECM 3	Install High/Low Lighting Controls	Yes	4,260	0.6	-2	\$572	\$5,360	\$3,680	\$1,680	2.9	3,998
Variable Frequency Drive (VFD) Measures			77,886	18.0	0	\$11,071	\$88,800	\$10,900	\$77,900	7.0	78,430
ECM 4	Install VFDs on Constant Volume (CV) Fans	Yes	56,435	14.7	0	\$8,022	\$60,600	\$6,400	\$54,200	6.8	56,830
ECM 5	Install VFDs on Chilled Water Pumps	Yes	8,580	1.9	0	\$1,220	\$11,300	\$1,800	\$9,500	7.8	8,640
ECM 6	Install VFDs on Heating Water Pumps	Yes	12,870	1.4	0	\$1,829	\$16,900	\$2,700	\$14,200	7.8	12,960
Unitary HVAC Measures			2,917	1.5	0	\$415	\$10,800	\$500	\$10,300	24.8	2,937
ECM 7	Install High Efficiency Air Conditioning Units	No	2,917	1.5	0	\$415	\$10,800	\$500	\$10,300	24.8	2,937
Domestic Water Heating Upgrade			0	0.0	6	\$116	\$180	\$90	\$90	0.8	1,005
ECM 8	Install Low-Flow DHW Devices	Yes	0	0.0	6	\$116	\$180	\$90	\$90	0.8	1,005
Food Service & Refrigeration Measures			3,751	0.3	0	\$533	\$3,720	\$260	\$3,460	6.5	3,777
ECM 9	Refrigerator/Freezer Case Electrically Commutated Motors	Yes	524	0.1	0	\$75	\$750	\$80	\$670	9.0	528
ECM 10	Refrigeration Controls	Yes	1,615	0.0	0	\$230	\$2,700	\$130	\$2,570	11.2	1,626
ECM 11	Vending Machine Control	Yes	1,612	0.2	0	\$229	\$270	\$50	\$220	1.0	1,623
TOTALS			251,071	50.6	-63	\$34,484	\$174,810	\$28,000	\$146,810	4.3	242,439

* - All incentives presented in this table are included as placeholders for planning purposes and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

All Evaluated ECMs

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		149,338	28.3	-62	\$20,044	\$56,440	\$11,480	\$44,960	2.2	140,165
ECM 1	Retrofit Fixtures with LED Lamps	149,338	28.3	-62	\$20,044	\$56,440	\$11,480	\$44,960	2.2	140,165
Lighting Control Measures		17,180	2.6	-7	\$2,306	\$14,870	\$4,770	\$10,100	4.4	16,125
ECM 2	Install Occupancy Sensor Lighting Controls	12,920	2.0	-5	\$1,734	\$9,510	\$1,090	\$8,420	4.9	12,127
ECM 3	Install High/Low Lighting Controls	4,260	0.6	-2	\$572	\$5,360	\$3,680	\$1,680	2.9	3,998
Variable Frequency Drive (VFD) Measures		77,886	18.0	0	\$11,071	\$88,800	\$10,900	\$77,900	7.0	78,430
ECM 4	Install VFDs on Constant Volume (CV) Fans	56,435	14.7	0	\$8,022	\$60,600	\$6,400	\$54,200	6.8	56,830
ECM 5	Install VFDs on Chilled Water Pumps	8,580	1.9	0	\$1,220	\$11,300	\$1,800	\$9,500	7.8	8,640
ECM 6	Install VFDs on Heating Water Pumps	12,870	1.4	0	\$1,829	\$16,900	\$2,700	\$14,200	7.8	12,960
Domestic Water Heating Upgrade		0	0.0	6	\$116	\$180	\$90	\$90	0.8	1,005
ECM 8	Install Low-Flow DHW Devices	0	0.0	6	\$116	\$180	\$90	\$90	0.8	1,005
Food Service & Refrigeration Measures		3,751	0.3	0	\$533	\$3,720	\$260	\$3,460	6.5	3,777
ECM 9	Refrigerator/Freezer Case Electrically Commutated Motors	524	0.1	0	\$75	\$750	\$80	\$670	9.0	528
ECM 10	Refrigeration Controls	1,615	0.0	0	\$230	\$2,700	\$130	\$2,570	11.2	1,626
ECM 11	Vending Machine Control	1,612	0.2	0	\$229	\$270	\$50	\$220	1.0	1,623
TOTALS		248,155	49.2	-63	\$34,070	\$164,010	\$27,500	\$136,510	4.0	239,502

* - All incentives presented in this table are included as placeholders for planning purposes and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Cost Effective ECMs

4.1 Lighting

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		149,338	28.3	-62	\$20,044	\$56,440	\$11,480	\$44,960	2.2	140,165
ECM 1	Retrofit Fixtures with LED Lamps	149,338	28.3	-62	\$20,044	\$56,440	\$11,480	\$44,960	2.2	140,165

When considering lighting upgrades, we suggest using a comprehensive design approach that simultaneously upgrades lighting fixtures and controls to maximize energy savings and improve occupant lighting. Comprehensive design will also consider appropriate lighting levels for different space types to make sure that the right amount of light is delivered where needed. If conversion to LED light sources is proposed, we suggest converting all of a specific lighting type (e.g., linear fluorescent) to LED lamps to minimize the number of lamp types in use at the facility, which should help reduce future maintenance costs.

ECM 1: Retrofit Fixtures with LED Lamps

Replace fluorescent and CFL lamps with LED lamps. Many LED tubes are direct replacements for existing fluorescent tubes and can be installed while leaving the fluorescent fixture ballast in place. LED lamps can be used in existing fixtures as a direct replacement for most other lighting technologies. Be sure to specify replacement lamps that are compatible with existing dimming controls, where applicable. In some circumstances, you may need to upgrade your dimming system for optimum performance.

This measure saves energy by installing LEDs, which use less power than other lighting technologies yet provide equivalent lighting output for the space. Maintenance savings may also be available, as longer-lasting LEDs lamps will not need to be replaced as often as the existing lamps.

Affected Building Areas: all areas with fluorescent fixtures with T8 tubes and CFL lamps

4.2 Lighting Controls

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures		17,180	2.6	-7	\$2,306	\$14,870	\$4,770	\$10,100	4.4	16,125
ECM 2	Install Occupancy Sensor Lighting Controls	12,920	2.0	-5	\$1,734	\$9,510	\$1,090	\$8,420	4.9	12,127
ECM 3	Install High/Low Lighting Controls	4,260	0.6	-2	\$572	\$5,360	\$3,680	\$1,680	2.9	3,998

Lighting controls reduce energy use by turning off or lowering lighting fixture power levels when not in use. A comprehensive approach to lighting design should upgrade the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

ECM 2: Install Occupancy Sensor Lighting Controls

Install occupancy sensors to control lighting fixtures in areas that are frequently unoccupied, even for short periods. For most spaces, we recommend that lighting controls use dual technology sensors, which reduce the possibility of lights turning off unexpectedly.

Occupancy sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Most occupancy sensor lighting controls allow users to manually turn fixtures on/off, as needed. Some controls can also provide dimming options.

Occupancy sensors can be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are best suited to single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in large spaces, locations without local switching, and where wall switches are not in the line-of-sight of the main work area.

This measure provides energy savings by reducing the lighting operating hours.

Affected Building Areas: offices, conference rooms, classrooms, and restrooms

ECM 3: Install High/Low Lighting Controls

Install occupancy sensors to provide dual level lighting control for lighting fixtures in spaces that are infrequently occupied but may require some level of continuous lighting for safety or security reasons.

Lighting fixtures with these controls operate at default low levels when the area is unoccupied to provide minimal lighting to meet security or safety code requirements for egress. Sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Fixtures automatically switch back to low level after a predefined period of vacancy. In parking lots and parking garages with significant ambient lighting, this control can sometimes be combined with photocell controls to turn the lights off when there is sufficient daylight.

The controller lowers the light level by dimming the fixture output. Therefore, the controlled fixtures need to have a dimmable ballast or driver. This will need to be considered when selecting retrofit lamps and bulbs for the areas proposed for high/low control.

For this type of measure the occupancy sensors will generally be ceiling or fixture mounted. Sufficient sensor coverage must be provided to ensure that lights turn on in each area as occupants approach the area.

This measure provides energy savings by reducing the light fixture power draw when reduced light output is appropriate.

Affected Building Areas: hallways and stairwells

4.3 Variable Frequency Drives (VFD)

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Variable Frequency Drive (VFD) Measures		77,886	18.0	0	\$11,071	\$88,800	\$10,900	\$77,900	7.0	78,430
ECM 4	Install VFDs on Constant Volume (CV) Fans	56,435	14.7	0	\$8,022	\$60,600	\$6,400	\$54,200	6.8	56,830
ECM 5	Install VFDs on Chilled Water Pumps	8,580	1.9	0	\$1,220	\$11,300	\$1,800	\$9,500	7.8	8,640
ECM 6	Install VFDs on Heating Water Pumps	12,870	1.4	0	\$1,829	\$16,900	\$2,700	\$14,200	7.8	12,960

Variable frequency drives control motors for fans, pumps, and process equipment based on the actual output required of the driven equipment. Energy savings result from more efficient control of motor energy usage when equipment operates at partial load. The magnitude of energy savings depends on the estimated amount of time that the motor would operate at partial load. For equipment with proposed

VFDs, we have included replacing the controlled motor with a new inverter duty rated motor to conservatively account for the cost of an inverter duty rated motor.

ECM 4: Install VFDs on Constant Volume (CV) Fans

Install VFDs to control constant volume fan motor speeds. This converts a constant-volume, single-zone air handling system into a variable-air-volume (VAV) system. A separate VFD is usually required to control the return fan motor or dedicated exhaust fan motor if the air handler has one.

Zone thermostats signal the VFD to adjust fan speed to maintain the appropriate temperature in the zone, while maintaining a constant supply air temperature.

VAV system controls should not raise the supply air temperature at the expense of the fan power. A common mistake is to reset the supply air temperature to achieve chiller energy savings, which can lead to additional air flow requirements. Supply air temperature should be kept low (e.g., 55°F) until the minimum fan speed (typically about 50%) is met. At this point, it is efficient to raise the supply air temperature as the load decreases, but not such that additional air flow and thus fan energy is required.

Energy savings result from reducing the fan speed (and power) when conditions allow for reduced air flow.

Affected Air Handlers: FCUs and AHUs

ECM 5: Install VFDs on Chilled Water Pumps

Install VFDs to control chilled water pumps. Two-way valves must serve the chilled water coils being served and the chilled water loop must have a differential pressure sensor installed. If three-way valves or a bypass leg are used in the chilled water distribution, they will need to be modified when this measure is implemented. As the chilled water valves close, the differential pressure increases, and the VFD modulates the pump speed to maintain a differential pressure setpoint.

For systems with variable chilled water flow through the chiller, the minimum flow to prevent the chiller from tripping off will need to be determined during the final project design. The control system should be programmed to maintain the minimum flow through the chiller and to prevent pump cavitation.

Energy savings result from reducing the pump motor speed (and power) as chilled water valves close. The magnitude of energy savings is based on the estimated amount of time that the system operates at reduced loads.

Affected Pumps: CHW pumps

ECM 6: Install VFDs on Heating Water Pumps

Install variable frequency drives (VFD) to control heating water pumps. Two-way valves must serve the hot water coils, and the hot water loop must have a differential pressure sensor installed. If three-way valves or a bypass leg are used in the hot water distribution, they will need to be modified when this measure is implemented. As the hot water valves close, the differential pressure increases and the VFD modulates the pump speed to maintain a differential pressure setpoint.

Energy savings result from reducing pump motor speed (and power) as hot water valves close. The magnitude of energy savings is based on the estimated amount of time that the system will operate at reduced load.

Affected Pumps: HHW pumps

4.4 Unitary HVAC

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Unitary HVAC Measures		2,917	1.5	0	\$415	\$10,800	\$500	\$10,300	24.8	2,937
ECM 7	Install High Efficiency Air Conditioning Units	2,917	1.5	0	\$415	\$10,800	\$500	\$10,300	24.8	2,937

Replacing the unitary HVAC units has a long payback period and may not be justifiable based simply on energy considerations. However, most of the units are nearing or have reached the end of their normal useful life. Typically, the marginal cost of purchasing a high efficiency unit can be justified by the marginal savings from the improved efficiency. When the split system is eventually replaced, consider purchasing equipment that exceeds the minimum efficiency required by building codes.

ECM 7: Install High Efficiency Air Conditioning Units

We evaluated replacing standard efficiency packaged air conditioning units with high efficiency packaged air conditioning units. The magnitude of energy savings for this measure depends on the relative efficiency of the older unit versus the new high efficiency unit, the average cooling and heating load, and the estimated annual operating hours.

Affected Units: Split System

4.5 Domestic Water Heating

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Domestic Water Heating Upgrade		0	0.0	6	\$116	\$180	\$90	\$90	0.8	1,005
ECM 8	Install Low-Flow DHW Devices	0	0.0	6	\$116	\$180	\$90	\$90	0.8	1,005

ECM 8: Install Low-Flow DHW Devices

Install low-flow devices to reduce overall hot water demand. The following low-flow devices are recommended to reduce hot water usage:

Device	Flow Rate
Faucet aerators (lavatory)	0.5 gpm
Faucet aerator (kitchen)	1.5 gpm
Showerhead	2.0 gpm
Pre-rinse spray valve (kitchen)	1.28 gpm

Low-flow devices reduce the overall water flow from the fixture, while still providing adequate pressure for washing.

4.6 Food Service and Refrigeration Measures

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Food Service & Refrigeration Measures		3,751	0.3	0	\$533	\$3,720	\$260	\$3,460	6.5	3,777
ECM 9	Refrigerator/Freezer Case Electrically Commutated Motors	524	0.1	0	\$75	\$750	\$80	\$670	9.0	528
ECM 10	Refrigeration Controls	1,615	0.0	0	\$230	\$2,700	\$130	\$2,570	11.2	1,626
ECM 11	Vending Machine Control	1,612	0.2	0	\$229	\$270	\$50	\$220	1.0	1,623

ECM 9: Refrigerator/Freezer Case Electrically Commutated Motors

Replace shaded pole or permanent split capacitor (PSC) motors with electronically commutated (EC) motors in the cooler. Fractional horsepower EC motors are significantly more efficient than mechanically commutated, brushed motors, particularly at low speeds or partial load. By using variable-speed technology, EC motors can optimize fan usage. Because these motors are brushless and use DC power, losses due to friction and phase shifting are eliminated.

Savings for this measure consider both the increased efficiency of the motor as well as the reduction in refrigeration load due to motor heat loss.

ECM 10: Refrigeration Controls

Install additional controls to optimize the operation of walk-in coolers and freezers.

Many walk-in coolers and freezers have continuously operating electric heaters on the doors to prevent condensation formation. This measure adds a control system feature to shut off the door heaters when the humidity level is low enough that condensation will not occur if the heaters are off. This is done by measuring the ambient humidity and temperature of the store, comparing that to the dewpoint, and using pulse width modulation to control the anti-sweat door heaters.

Defrost controllers can be used to override defrost of evaporator fans when the defrost operation is not necessary, which reduces annual energy consumption. This measure is applicable to existing evaporator fans with a traditional electric de-frost mechanism.

Many walk-in coolers and freezers have evaporator fans that run continuously. The measure adds a control system feature to automatically shut off evaporator fans when not needed.

Energy savings for each of the control measures account for reduction in compressor and fan operating hours as well as reduction in the refrigeration heat load as appropriate.

ECM 11: Vending Machine Control

Vending machines operate continuously, even during unoccupied hours. Install occupancy sensor controls to reduce energy use. These controls power down vending machines when the vending machine area has been vacant for some time, and power up the machines at necessary regular intervals or when the surrounding area is occupied. Energy savings are dependent on the vending machine and activity level in the area surrounding the machines.

4.7 Measures for Future Consideration

There are additional opportunities for improvement that Vernon Township BOE may wish to consider. These potential upgrades typically require further analysis, involve substantial capital investment, and/or include significant system reconfiguration. These measure(s) are therefore beyond the scope of this energy audit. These measure(s) are described here to support a whole building approach to energy efficiency and sustainability.

Vernon Township BOE may wish to consider the Energy Savings Improvement Program (ESIP) or other whole building approach. With interest in implementing comprehensive, largescale and/or complex system wide projects, these measures may be pursued during development of a future energy savings plan. We recommend that you work with your energy service company (ESCO) and/or design team to:

- Evaluate these measures further.
- Develop firm costs.
- Determine measure savings.
- Prepare detailed implementation plans.

Other modernization or capital improvement funds may be leveraged for these types of refurbishments. As you plan for capital upgrades, be sure to consider the energy impact of the building systems and controls being specified.

Upgrade to a Heat Pump System

Electric resistance heating units work by passing an electric current through wires to heat them. The system is 100% efficient since for every unit of electricity consumed, one unit of heat is produced.

But there is a way to convert electricity to create heat at better than a 1:1 ratio. Heat pumps operate on a more efficient principle, the refrigeration cycle. Instead of directly converting electricity to heat, electricity does the work, via a compressor, of moving refrigerant through a system that transfers heat from a cooler place to a warmer place. That system can move three to five as much energy as is available using electric resistance heating methods. Heat pumps work in a similar manner to an air conditioner, except they reverse the cooling process to circulate warm air instead of cold air. Also, heat pumps are generally capable of dispensing refrigerated air as they can typically be operated in air conditioning mode.

An electric furnace or boiler has no flue loss through a chimney. The AFUE rating for an all-electric furnace or boiler is between 95% and 100 percent. The lower values are for units installed outdoors because they have greater jacket heat loss. However, despite their high efficiency, the higher cost of electricity in most parts of the country makes all-electric furnaces or boilers an uneconomic choice. If you are interested in electric heating, consider installing a heat pump system.

Electric resistance heat, including electric furnaces and baseboard heaters, can be inexpensive to install but often expensive to run. Facilities with these systems can save substantial energy at a moderate cost by installing a heat pump when they replace a central air conditioner.

Even in buildings without central air-conditioning, there are opportunities to save energy when an existing electric furnace needs to be replaced, as well as opportunities to install ductless electric heat pumps in buildings with baseboard electric heaters and electric fan coils. Unit ventilators with built-in electric resistance heaters can be replaced with unit ventilators with integrated heat pumps.

Electric heat pumps have high coefficient of performance (COP) ratings and are substantially more efficient than traditional electric heating systems. Further investigation is required to determine whether installing a heat pump system is a cost-effective solution when replacing existing electrical heating systems.

VRF Systems

Consider variable refrigerant flow (VRF) systems as part of a comprehensive package unit upgrade project. (VRF systems use direct expansion (DX) heat pumps to transport heat between an outdoor condensing unit and a network of indoor evaporators, located near or within the conditioned space, through refrigerant piping installed in the building. Attributes that distinguish VRF from other DX system types are:

- Multiple indoor units connected to a common outdoor unit.
- Scalability
- Variable capacity
- Distributed control
- Simultaneous heating and cooling capability

VRF provides flexibility by allowing for many different indoor units (with different capacities and configurations), individual zone control, the unique ability to offer simultaneous heating and cooling in separate zones on a common refrigerant circuit, and heat recovery from one zone to another. VRF systems are equipped with at least one variable-speed and/or variable-capacity compressor.

To match the building’s load profiles, energy is transferred from one indoor space to another through the refrigerant line, and only one energy source is necessary to provide both heating and cooling. VRF systems also operate efficiently at part load because of the compressor’s variable capacity control. VRF systems are ideal for applications with varying loads or where zoning is required. Some other advantages of VRF systems include consistent comfort, quiet operation, energy efficiency, installation flexibility, zoned heating and cooling, state-of-the-art controls, and reliability.

VRF systems are more expensive than conventional heat pump systems; however, the higher initial cost can be offset by improved cooling efficiency during part load operation—a SEER (cooling) rating of 18.0 is not uncommon for small packaged VRF-equipped heat pumps.

When you are replacing packaged HVAC equipment, we recommend a comprehensive approach. Work with your contractor or design engineer to make sure your systems are sized and zoned according to current space configurations and occupancy. Select high efficiency equipment and controls that match your heating and cooling needs. Commission the system and controls to ensure proper operation, comfort, ventilation, and energy use.

Replace Smooth V-Belts with Notched or Synchronous Belts

This measure is for the replacement of smooth V-belts in non-residential package and split HVAC systems with notched V-belts or for the installation of new equipment with synchronous belts instead of smooth V-belts. Typically, there is a V-belt between the motor and the supply air fan and/or return air fan in larger package and split HVAC systems.

In general, there are two styles of grooved V-belts: notched and synchronous. The U.S. Department of Energy (DOE) compares these two types as follows:⁵

Characteristic	Notched V-Belts	Synchronous Belts
<u>Description</u>	A notched belt has grooves or notches that run perpendicular to the belt’s length, which reduces the bending resistance of the belt.	They are also called cogged, timing, positive-drive, or high-torque drive belts, and are “toothed”.
<u>Pulleys/Sprockets</u>	Can use the same pulleys as cross-section standard V-belts	Require the installation of mating grooved sprockets.

⁵ <https://www.nrel.gov/docs/fy13osti/56012.pdf> US DOE Motor Systems Tip Sheet #5

Characteristic	Notched V-Belts	Synchronous Belts
<u>Typical Efficiency</u>	Run cooler, last longer, and are about 2% more efficient than standard V-belts.	Operate with a consistent efficiency of 98% and maintain their efficiency over a wide load range.
<u>Constraints</u>	Have a sharp reduction in efficiency at high torque due to increased slippage.	Noisier than V-belts, less suited for use on shock-loaded applications, and transfer more vibration due to their stiffness.
<u>Other Benefits</u>	Lower cost than synchronous belts, overall.	Require minimal maintenance and re-tensioning. Operate in wet and oily environments, and run slip-free

The DOE offers the following suggested actions with respect to investigating the applicability of notched or synchronous V belts:

- Conducted a survey of belt-driven equipment. Gather application and operating-hour data. Then determine the cost effectiveness of replacing existing V-belts with notched belts or synchronous belts and sprockets.
- Consider synchronous belts for all new installations; the price premium is minimal due to the avoidance of conventional pulley costs.
- Consider having a power transmission specialist determine the energy and cost savings potential from retrofitting all V-belt drives with synchronous belts. Synchronous belts rely on tooth grip instead of friction to efficiently transfer power and provide a constant speed ratio.
- Install notched belts where the retrofit of a synchronous belt is not cost effective.

5 ENERGY EFFICIENT BEST PRACTICES

A whole building maintenance plan will extend equipment life; improve occupant comfort, health, and safety; and reduce energy and maintenance costs.

Operation and maintenance (O&M) plans enhance the operational efficiency of HVAC and other energy intensive systems and could save 5%–20% of the energy usage in your building without substantial capital investment. A successful plan includes your records of energy usage trends and costs, building equipment lists, current maintenance practices, and planned capital upgrades, and it incorporates your ideas for improved building operation. Your plan will address goals for energy-efficient operation, provide detail on how to reach the goals, and outline procedures for measuring and reporting whether goals have been achieved.

You may already be doing some of these things—see our list below for potential additions to your maintenance plan. Be sure to consult with qualified equipment specialists for details on proper maintenance and system operation.

Energy Tracking with ENERGY STAR Portfolio Manager



You've heard it before—you cannot manage what you do not measure. ENERGY STAR Portfolio Manager is an online tool that you can use to measure and track energy and water consumption, as well as greenhouse gas emissions⁶. Your account has already been established. Now you can continue to keep tabs on your energy performance every month.

Lighting Maintenance



Clean lamps, reflectors and lenses of dirt, dust, oil, and smoke buildup every six to twelve months. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust. Together, this can reduce total light output by up to 60% while still drawing full power.

In addition to routine cleaning, developing a maintenance schedule can ensure that maintenance is performed regularly, and it can reduce the overall cost of fixture re-lamping and re-ballasting. Group re-lamping and re-ballasting maintains lighting levels and minimizes the number of site visits by a lighting technician or contractor, decreasing the overall cost of maintenance.

Motor Maintenance

Motors have many moving parts. As these parts degrade over time, the efficiency of the motor is reduced. Routine maintenance prevents damage to motor components. Routine maintenance should include cleaning surfaces and ventilation openings on motors to prevent overheating, lubricating moving parts to reduce friction, inspecting belts and pulleys for wear and to ensure they are at proper alignment and tension, and cleaning and lubricating bearings. Consult a licensed technician to assess these and other motor maintenance strategies.

Fans to Reduce Cooling Load

Install ceiling fans to supplement your cooling system. Thermostat settings can typically be increased by 4°F with no change in overall occupant comfort due to the wind chill effect of moving air.

⁶ <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/use-portfolio-manager>

AC System Evaporator/Condenser Coil Cleaning

Dirty evaporator and condenser coils restrict air flow and restrict heat transfer. This increases the loads on the evaporator and condenser fan and decreases overall cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

HVAC Filter Cleaning and Replacement

Air filters should be checked regularly (often monthly) and cleaned or replaced when appropriate. Air filters reduce indoor air pollution, increase occupant comfort, and help keep equipment operating efficiently. If the building has a building management system, consider installing a differential pressure switch across filters to send an alarm about premature fouling or overdue filter replacement. Over time, filters become less and less effective as particulate buildup increases. Dirty filters also restrict air flow through the air conditioning or heat pump system, which increases the load on the distribution fans.

Ductwork Maintenance

Duct maintenance has two primary goals: keep the ducts clean to avoid air quality problems and seal leaks to save energy. Check for cleanliness, obstructions that block airflow, water damage, and leaks. Ducts should be inspected at least every two years.

The biggest symptoms of clogged air ducts are differing temperatures throughout the building and areas with limited airflow from supply registers. If a particular air duct is clogged, then air flow will only be cut off to some rooms in the building—not all of them. The reduced airflow will make it more difficult for those areas to reach the temperature setpoint, which will cause the HVAC system to run longer to cool or heat that area properly. If you suspect clogged air ducts, ensure that all areas in front of supply registers are clear of items that may block or restrict air flow, and you should check for fire dampers or balancing dampers that have failed closed.

Duct leakage in commercial buildings can account for 5%–25% of the supply airflow. In the case of rooftop air handlers, duct leakage can occur to the outside of the building wasting conditioned air. Check ductwork for leakage. Eliminating duct leaks can improve ventilation system performance and reduce heating and cooling system operation.

Distribution system losses are dependent on air system temperature, the size of the distribution system, and the level of insulation of the ductwork. Significant energy savings can be achieved when insulation has not been well maintained. When the insulation is missing or worn, the system efficiency can be significantly reduced. This measure saves energy by reducing heat transfer in the distribution system.

Boiler Maintenance

Many boiler problems develop slowly over time, so regular inspection and maintenance is essential to keeping the heating system running efficiently and preventing expensive repairs. Annual tune-ups should include a combustion analysis to analyze the exhaust from the boilers and to ensure the boiler is operating safely and efficiently. Boilers should be cleaned according to the manufacturer's instructions to remove soot and scale from the boiler sections to improve heat transfer.

Water Heater Maintenance

The lower the supply water temperature that is used for hand washing sinks, the less energy is needed to heat the water. Reducing the temperature results in energy savings and the change is often unnoticeable to users. Be sure to review the domestic water temperature requirements for sterilizers and dishwashers as you investigate reducing the supply water temperature.

Also, preventative maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. At least once a year, follow manufacturer instructions to drain a few gallons out of the

water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Annual checks should include checks for:

- Leaks or heavy corrosion on the pipes and valves.
- Corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot, or charred metal, this is a sign you may be having combustion issues, and you should have the unit serviced by a professional.
- For electric water heaters, look for signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank.
- For water heaters more than three years old, have a technician inspect the sacrificial anode annually.

Procurement Strategies

Purchasing efficient products reduces energy costs without compromising quality. Consider modifying your procurement policies and language to require ENERGY STAR products where available.

6 WATER BEST PRACTICES

Getting Started



The commercial and institutional sector is the second largest consumer of publicly supplied water in the United States, accounting for 17% of the withdrawals from public water supplies⁷. In New Jersey, excluding water used for power generation, approximately 80% of total water use was attributed to potable supply during the period of 2009 to 2018. Water withdrawals for potable supply have not changed noticeably during the period from 1990 to 2018⁸.

Water management planning serves as the foundation for any successful water reduction effort. It is the first step a commercial or institutional facility owner or manager should take to achieve and sustain long-term water savings. Understanding how water is used within a facility is critical for the water management planning process. A water assessment provides a comprehensive account of all known water uses at the facility. It allows the water management team to establish a baseline from which progress and program success can be measured. It also enables the water management team to set achievable goals and identify and prioritize specific projects based on the relative savings opportunities and project cost-effectiveness.

Water conservation devices may significantly reduce your water and sewer usage costs. Any reduction in water use reduces grid-level electricity use since a significant amount of electricity is used to treat and deliver water from reservoirs to end users.

For more information regarding water conservation or additional details regarding the practices shown below go to the EPA's WaterSense website⁹ or download a copy of EPA's "WaterSense at Work: Best Management Practices for Commercial and Institutional Facilities"¹⁰ to get ideas for creating a water management plan and best practices for a wide range of water using systems.

Leak Detection and Repair

Identifying and repairing leaks and other water use anomalies within a facility's water distribution system or from processes or equipment can keep a facility from wasting significant quantities of water. Examples of common leaks include leaking toilets and faucets, drip irrigation malfunctions, stuck float valves, and broken distribution lines. Reading meters, installing failure abatement technologies, and conducting visual and auditory inspections are important best practices to detect leaks. Train building occupants, employees, and visitors to report any leaks that they detect. To reduce unnecessary water loss, detected leaks should be repaired quickly. Repairing leaks in water distribution that is pressurized by on-site pumps or in heated or chilled water piping will also reduce energy use.

Toilets and Urinals

Toilets and urinals are considered sanitary fixtures and are found in most facilities. High efficiency fixtures are at least 20% more efficient than available standard products. Leaking or damaged equipment is a substantial source of water waste. Train users to report continuously flushing, leaking, or otherwise improperly operating equipment to the appropriate personnel. Depending on the age of the equipment

⁷ Estimated from analyzing data in: [Solley, Wayne B., et al, "Estimated Use of Water in the United States in 1995", U.S Geological Survey Circular 1200, \(1998\)](#)

⁸ <https://dep.nj.gov/wp-content/uploads/dsr/trends-water-supply.pdf>

⁹ <https://www.epa.gov/watersense>

¹⁰ <https://www.epa.gov/watersense/watersense-work-0>

and the frequency of use, it may be cost effective to replace older inefficient fixtures with current generation WaterSense labeled equipment.

Commercial facilities typically use tank toilets or wall-mount flushometers. Educate and inform users with restroom signage and other means to avoid flushing inappropriate objects. For tank toilets, periodically check to ensure fill valves are working properly and that water level is set correctly. Annually test toilets to ensure the flappers are not worn or allowing water to seep from the tank into the bowl and down the sewer. Control stops and piston valves on flushometer toilets should be checked at least annually.

Most urinals use water to flush liquid. These standard single-user fixtures are present in most facilities. Non-water urinals use a specially designed trap that allows liquid waste to drain out of the fixture through a trap seal, and into the drainage system. Flushing urinals should be inspected at least annually for proper valve and sensor operation. For non-water urinals, follow maintenance practices as directed by the manufacturer to ensure products perform as expected. Non-water urinals can be considered during urinal replacement, however, review the condition and design of the existing plumbing system and the expected usage patterns to ensure that these products will provide the anticipated performance.

Faucets and Showerheads

Faucets and showerheads are sanitary fixtures that generally dispense heated water. Reducing water use by these fixtures translates into a reduction of site fuel or electric use depending on how water is heated. High efficiency fixtures are at least 20% more efficient than available standard products. Leaking or damaged equipment is a substantial source of water waste. Train users to report continuously dripping, leaking, or otherwise improperly operating equipment to the appropriate personnel. Depending on the age of the equipment and the frequency of use, it may be cost effective to replace older fixtures with current generation WaterSense labeled equipment.

Faucets are used for a variety of purposes, and standard flow rates are dictated by the intended use. Public use lavatory faucets and kitchen faucets are subject to maximum flow rates while service sinks are not. Periodically inspect faucet aerators for scale buildup to ensure flow is not being restricted. Clean or replace the aerator or other spout end device as needed. Check and adjust automatic sensors (where installed) to ensure they are operating properly to avoid faucets running longer than necessary. Post materials in restrooms and kitchens to ensure user awareness of the facility's water-efficiency goals. Remind users to turn off the tap when they are done and to consider turning the tap off during sanitation activities when it is not being used. Consider installing lavatory and kitchen faucet fixtures with reduced flow. Federal standards limit kitchen and restroom faucet flows to 2.2 gpm. To qualify for a WaterSense label a faucet cannot exceed 1.5 gpm.

Effective in 1992, the maximum allowable flow rate for all showerheads sold in the United States is 2.5 gpm. Since this standard was enacted, many showerheads have been designed to use even less water. WaterSense labeled equipment is designed to use 2.0 gpm, or less. For optimum showerhead efficiency, the system pressure should be tested to make sure that it is between 20 and 80 pounds per square inch (psi). Verify that plumbing lines are routed through a shower valve to prevent water pressure fluctuations. Periodically inspect showerheads for scale buildup to ensure flow is not being restricted. In general, replace showerheads with 2.5 gpm flow rates or higher with WaterSense labeled models. Note: Use of poor performing replacement reduced flow showerheads may result in increased use if the duration of use is increased to compensate for reduced performance. WaterSense labeled showerheads are independently certified to meet or exceed minimum performance requirements for spray coverage and force.

7 ON-SITE GENERATION

You don't have to look far in New Jersey to see one of the thousands of solar electric systems providing clean power to homes, businesses, schools, and government buildings. On-site generation includes both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) technologies that generate power to meet all or a portion of the facility's electric energy needs. Also referred to as distributed generation, these systems contribute to greenhouse gas (GHG) emission reductions, demand reductions, and reduced customer electricity purchases, which results in improved electric grid reliability through better use of transmission and distribution systems.

Preliminary screenings were performed to determine if an on-site generation measure could be a cost-effective solution for your facility. Before deciding to install an on-site generation system, we recommend conducting a feasibility study to analyze existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.

7.1 Solar Photovoltaic

Photovoltaic (PV) panels convert sunlight into electricity. Individual panels are combined into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is then connected to the building's electrical distribution system.

An additional study for solar photovoltaic for the Glen Meadow Middle School is provided below.

Executive Summary

This section summarizes projected energy and cost impacts, as well as design considerations, for a proposed 345 kW-DC carport solar photovoltaic (PV) system for the Glen Meadow Middle School site located at 7 Sammis Road, Vernon, NJ 07462. Please note this is a feasibility stage memo, and all cost/savings values are solely estimates and not for design level application.

Here are the system details:

- ◆ 345 kW Carport Solar PV System: The carport solar panels are strategically positioned to make the most efficient use of the open parking spaces for maximizing coverage of the solar energy generation. The projected solar PV system is expected to generate a total energy output of 454,333 kWh, accounting for 62% of the site's total electricity consumption for the year 2023-2024.



Solar PV Layout Figure – HelioScope Design

Site Assessment for PV Installation

Based on the facility interview and site assessment, TRC has decided to focus solely on the carport solar option to determine project feasibility. The available open areas of the school are actively used for sports activities, limiting their suitability for ground mount solar installations. Additionally, the building's roof requires further review and assessment to evaluate its structural capacity to support the additional load associated with rooftop solar panels if that option were to be pursued. Therefore, only the carport solar option is considered in this feasibility review.

Equipment	Estimated Annual Energy Generation (kWh)	Estimated Annual GHG Reduction (MT-CO ₂ e)	Estimated Annual Cost Savings (\\$)	Estimated Gross Project Cost (\\$)	Total Incentives (\\$)	Net Project Cost (\\$)	Simple Payback Period ¹¹ (yr.)
345 kW Solar PV	454,333	90	\$53,512	\$2,165,000	\$1,190,750	\$974,250	18.2

Project Summary Table

Rebates and Incentives

Equipment	Estimated Gross Project Cost (\$)	ITC Rebate (1)	MACRS Rebate (2)	Net Project Cost
345 kW Solar PV	\$2,165,000	\$649,500	\$541,250	\$974,250

Incentive Summary Table

Multiple incentives are available to reduce the project cost.

1. Federal Income Tax Credit (ITC): As of the passage of the 2022 Inflation Reduction Act, the ITC refund can be claimed by non-taxable entities as a cash rebate. The ITC is equal to 30% of the system cost and is scheduled to persist until 2033.
2. Modified Accelerated Cost Recovery System (MACRS): As of the passage of the 2022 Inflation Reduction Act, the MACRS refund can be claimed by non-taxable entities as a cash rebate. This rebate allows 85% of the system cost to be claimed as equipment depreciation at Year 1, approximately equivalent to 25% of the system cost.

Ownership Models

This report explores two ownership models: Cash Purchase and Power Purchase Agreement (PPA).


¹¹ Simple payback is computed as the "Net Project Cost" divided by the "Estimated Annual Cost Savings".

- ◆ **Cash Purchase:** In this case, the entire system is purchased upfront by the customer.
- ◆ **Standard Power Purchase Agreement:** In this scenario, a third party installs and owns the system, and sells electricity to the customer at a reduced rate. Calculations assume the owner charges a 3% interest rate on the system. In the table below, the interest rate is factored in as an offset to the “Annual Savings (\$)”. Return on Investment (ROI) is null because there is no cost to the customer.

Ownership Plan	Upfront Gross Project Cost (\$)	Year 1 Cost After Rebates (\$)	Annual Savings (\$)	Lifetime 30-Year Cost Savings (\$)	30-Year ROI
Cash Purchase	\$2,165,000	\$974,250	\$53,512	\$1,605,369	165%
PPA	\$0	\$0	\$3,807	\$114,204	-

Ownership Model Table

Analysis clearly shows that opting for a cash purchase is more advantageous than choosing a Power Purchase Agreement (PPA). This conclusion is based on the consideration of existing available incentives (i.e., ITC & MACRS).



Ownership Model Life Cycle Comparison

PV System Sizing

TRC modeled the proposed solar PV system using HelioScope, a meteorologically and location-dependent solar resource, to estimate its available size and component quantities. The software accounts for building shading, tree shading, tilt angles, and appropriate spacing. The PV system is sized to utilize all available parking space.

Energy Generation and Management

A HelioScope model was developed to establish approximate PV system sizing. The output was entered into Energy Toolbase® (ETB), a utility cost analysis tool that compares the generation profile vs the building's monthly consumption data. ETB's estimate of baseline utility cost varied from available billing data by 32%, potentially due to rate schedule changes. ETB outputs were supplemented with worksheet calculations to true up the difference.

Cost savings were finalized by applying an 0.5% annual maintenance cost penalty to the solar PV system; the "Estimated Annual Cost Savings" in the Project Summary Table offsets the utility savings accordingly. The ETB analysis was used to simulate PV operation throughout the year and to calculate utility cost savings with hourly utility rate sensitivity.

Project Cost

Project cost estimates were calculated using RS Means 2022 Construction Cost Catalogue, along with vendor quotes and guidelines available from the modeling software. Construction costs have been escalated by 10% to account for inflation. Costs include contingencies and markups for all potential project tasks, including design, permitting, taxes, and a 30% contingency for infrastructure upgrades. A line-by-line breakdown of the costs considered is provided in Appendix C.

At a high level, average system costs are \$6.28/Watt solar PV, based on the gross project cost. Please note that while detailed, cost estimates are still at the feasibility stage. Costs may vary by 30% relative to engineering assessments of the electrical and structural infrastructure.

Successor Solar Incentive Program (SuSI)

The SuSI program replaces the SREC Registration Program (SRP) and the Transition Incentive (TI) program. The SuSI program is used to register and certify solar projects in New Jersey. Rebates are not available for solar projects. Solar projects may qualify to earn SREC- IIs (Solar Renewable Energy Certificates-II), however, the project owners must register their solar projects prior to the start of construction to establish the project's eligibility.

Get more information about solar power in New Jersey or find a qualified solar installer who can help you decide if solar is right for your building:

- ◆ **Successor Solar Incentive Program (SuSI):** <https://www.njcleanenergy.com/renewable-energy/programs/susi-program>
- ◆ **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- ◆ **NJ Solar Market FAQs:** www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs
- ◆ **Approved Solar Installers in the NJ Market:** http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1

7.2 Combined Heat and Power

Combined heat and power (CHP) generate electricity at the facility and puts waste heat energy to good use. Common types of CHP systems are reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines.


CHP systems typically produce a portion of the electric power used on-site, with the balance of electric power needs supplied by the local utility company. The heat is used to supplement (or replace) existing boilers and provide space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for space cooling.

The key criteria used for screening is the amount of time that the CHP system would operate at full load and the facility's ability to use the recovered heat. Facilities with a continuous need for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has no potential for installing a cost-effective CHP system.

Based on a preliminary analysis, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation. The lack of gas service, low or infrequent thermal load, and lack of space for siting the equipment are the most significant factors contributing to the lack of CHP potential.

The graphic below displays the results of the CHP potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.



Combined Heat and Power Screening

Find a qualified firm that specializes in commercial CHP cost assessment and installation: http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/

8 ELECTRIC VEHICLES

All electric vehicles (EVs) have an electric motor instead of an internal combustion engine. EVs function by plugging into a charge point, taking electricity from the grid, and then storing it in rechargeable batteries. Although electricity production may contribute to air pollution, the U.S. EPA categorizes all electric vehicles as zero-emission vehicles because they produce no direct exhaust or tailpipe emissions.

EVs are typically more expensive than similar conventional and hybrid vehicles, although some cost can be recovered through fuel savings, federal tax credit, or state incentives.

8.1 EV Charging

EV charging stations provide a means for electric vehicle operators to recharge their batteries at a facility. While many EV drivers charge at home, others do not have access to regular home charging, and the ability to charge at work or in public locations is critical to making EVs practical for more drivers. Charging can also be used for electric fleet vehicles, which can reduce fuel and maintenance costs for fleets that replace gas or diesel vehicles with EVs.

EV charging comes in three main types. For this assessment, the screening considers addition of Level 2 charging, which is most common at workplaces and other public locations. Depending on the site type and usage, other levels of charging power may be more appropriate.

The preliminary assessment of EV charging at the facility shows that there is medium potential for adding EV chargers to the facility's parking, based on potential costs of installation and other site factors.

The primary costs associated with installing EV charging are the charger hardware and the cost to extend power from the facility to parking spaces. This may include upgrades to electric panels to serve increased loads.


The type and size of the parking area impact the costs and feasibility of adding EV charging. Parking structure installations can be less costly than surface lot installations as power may be readily available, and equipment and wiring can be surface mounted. Parking lot installations often require trenching through concrete or asphalt surface. Large parking areas provide greater flexibility in charger siting than smaller lots.

The location and capacity of facility electric panels also impact charger installation costs. A Level 2 charger generally requires a dedicated 208-240V, 40 Amp circuit. The electric panel nearest the planned installation may not have available capacity and may need to be upgraded to serve new EV charging loads. Alternatively, chargers could be powered from a more distant panel. The distance from the panel to the location of charging stations ties directly to costs, as conduits, cables, and potential trenching costs all increase on a per-foot basis. The more charging stations planned, the more likely it is that additional electrical capacity will be needed.

Other factors to consider when planning for EV charging at a facility include who the intended users are, how long they park vehicles at the site, and whether they will need to pay for the electricity they use.



The graphic below displays the results of the EV charging assessment conducted as part of this audit. The position of each slider indicates the impact each factor has on the feasibility of installing EV charging at the site.



EV Charger Screening

Electric Vehicle Programs Available

New Jersey is leading the way on electric vehicle (EV) adoption on the East Coast. There are several programs designed to encourage EV adoption in New Jersey, which is crucial to reaching a 100% clean energy future.

NJCEP offers a variety of EV programs for vehicles, charging stations, and fleets. Certain EV charging stations that receive electric utility service from Atlantic City Electric Company (ACE), Public Service Electric and Gas Company (PSE&G) or Jersey Central Power and Light (JCP&L), may be eligible for additional electric vehicle charging incentives directly from the utility. Projects may be eligible for both the incentives offered by this BPU program and incentives offered by ACE, PSE&G or JCP&L, up to 90% of the combined charger purchase and installation costs. Please check ACE, PSE&G or JCP&L program eligibility requirements before purchasing EV charging equipment, as additional conditions on types of eligible chargers may apply for utility incentives.

EV Charging incentive information is available from Atlantic City Electric, PSE&G and JCP&L. For more information and to keep up to date on all EV programs please visit <https://www.njcleanenergy.com/commercial-industrial/programs/electric-vehicle-programs>

9 PROJECT FUNDING AND INCENTIVES

Ready to improve your building's performance? New Jersey's Clean Energy Programs and Utility Energy Efficiency Programs can help. Pick the program that works best for you. This section provides an overview of currently available incentive programs in New Jersey.

NJBPU and NJCEP Administered Programs



- New Construction (residential, commercial, industrial, government)
 - Large Energy Users
 - Energy Savings Improvement Program (financing)
 - State Facilities Initiative*
 - Local Government Energy Audits
 - Combined Heat & Power & Fuel Cells
- *State facilities are also eligible for utility programs

Utility Administered Programs



- Existing buildings (residential, commercial, industrial, government)
- Efficient Products
 - Lighting & Marketplace
 - HVAC
 - Appliance Rebates
 - Appliance Recycling

9.1 New Jersey's Clean Energy Program

Save money while saving the planet! New Jersey's Clean Energy Program is a statewide program that offers incentives, programs, and services that benefit New Jersey residents, businesses, educational, non-profit, and government entities to help them save energy, money, and the environment.

Large Energy Users

The Large Energy Users Program (LEUP) is designed to foster self-directed investment in energy projects. This program is offered to New Jersey's largest energy customers. To qualify entities must have incurred at least \$5 million in total energy costs in the prior fiscal year.

Incentives

Incentives are based on the specifications below. The maximum incentive per entity is the lesser of:

- \$4 million
- 75% of the total project(s) cost
- 90% of total NJCEP fund contribution in previous year
- \$0.33 per projected kWh saved; \$3.75 per projected Therm saved annually.

How to Participate

To participate in LEUP, you will first need submit an enrollment application. This program requires all qualified and approved applicants to submit an energy plan that outlines the proposed energy efficiency work for review and approval. Applicants may submit a Draft Energy Efficiency Plan (DEEP), or a Final Energy Efficiency Plan (FEED). Once the FEED is approved, the proposed work can begin.

Detailed program descriptions, instructions for applying, and applications can be found at <http://www.njcleanenergy.com/LEUP>.

Combined Heat and Power

The Combined Heat & Power (CHP) program provides incentives for eligible CHP or waste heat to power (WHP) projects. Eligible CHP or WHP projects must achieve an annual system efficiency of at least 65% (lower heating value, or LHV), based on total energy input and total utilized energy output. Mechanical energy may be included in the efficiency evaluation. ≤

Incentives¹²

Eligible Technology	Size (Installed Rated Capacity)	Incentive (\$/Watt) ⁵	% of Total Cost Cap per Project	\$ Cap per Project
CHPs powered by non-renewable or renewable fuel source, or a combination: ⁴ - Gas Internal Combustion Engine - Gas Combustion Turbine - Microturbine	≤500 kW ¹	\$2.00	30-40% ²	\$2 million
	>500 kW - 1 MW ¹	\$1.00		
	> 1 MW - 3 MW ¹	\$0.55	30%	\$3 million
	>3 MW ¹	\$0.35		
Fuel Cells ≥60%	Same as above ¹	Applicable amount above	30%	\$1 million
Waste Heat to Power (WHP) ³ Powered by non-renewable fuel source. Heat recovery or other mechanical recovery from existing equipment utilizing new electric generation equipment (e.g. steam turbine)	≤1MW ¹	\$1.00	30%	\$2 million
	> 1MW ¹	\$.50	30%	\$3 million

¹²

¹ Incentives are tiered, which means the incentive levels vary based upon the installed rated capacity, as listed in the chart above. For example, a 4 MW CHP system would receive \$2.00/watt for the first 500 kW, \$1.00/watt for the second 500 kW, \$0.55/watt for the next 2 MW and \$0.35/watt for the last 1 MW (up to the caps listed).

² The maximum incentive will be limited to 30% of total project. For CHP projects up to 1 MW, this cap will be increased to 40% where a cooling application is used or included with the CHP system (e.g. absorption chiller).

³ Projects will be eligible for incentives shown above, not to exceed the lesser of % of total project cost per project cap or maximum \$ per project cap. Projects installing CHP or FC with WHP will be eligible for incentive shown above, not to exceed the lesser caps of the CHP or FC incentive. Minimum efficiency will be calculated based on annual total electricity generated, utilized waste heat at the host site (i.e. not lost/rejected), and energy input.

⁴ Systems fueled by a Class 1 Renewable Fuel Source, as defined by N.J.A.C. 14:8-2.5, are eligible for a 30% incentive bonus. If the fuel is mixed, the bonus will be prorated accordingly. For example, if the mix is 60/40 (60% being a Class 1 renewable), the bonus will be 18%. This bonus will be included in the final performance incentive payment, based on system performance and fuel mix consumption data. Total incentive, inclusive of bonus, shall not exceed above stipulated caps.

⁵ CHP-FC systems located at Critical Facility and incorporating blackstart and islanding technology are eligible for a 25% incentive bonus. This bonus incentive will be paid with the second/Installation incentive payment. Total incentive, inclusive of bonus, shall not exceed above stipulated caps.



How to Participate

You will work with a qualified developer or consulting firm to complete the CHP application. Once the application is approved the project can be installed. Information about the CHP program can be found at <http://www.njcleanenergy.com/CHP>.

Successor Solar Incentive Program (SuSI)

The SuSI program replaces the SREC Registration Program (SRP) and the Transition Incentive (TI) program. The program is used to register and certify solar projects in New Jersey. Rebates are not available for solar projects, but owners of solar projects must register their projects prior to the start of construction to establish the project’s eligibility to earn SREC-IIs (Solar Renewable Energy Certificates-II). SuSI consists of two sub-programs. The Administratively Determined Incentive (ADI) Program and the Competitive Solar Incentive (CSI) Program.

Administratively Determined Incentive (ADI) Program

The ADI Program provides administratively set incentives for net metered residential projects, net metered non-residential projects 5 MW or less, and all community solar projects.

After the registration is accepted, construction is complete, and a complete final as-built packet has been submitted, the project is issued a New Jersey certification number, which enables it to generate New Jersey SREC- IIs.

Market Segments	Size MW dc	Incentive Value (\$/SREC II)	Public Entities Incentive Value - \$20 Adder (\$/SRECII)
Net Metered Residential	All types and sizes	\$90	N/A
Small Net Metered Non-Residential located on Rooftop, Carport, Canopy and Floating Solar	Projects smaller than 1 MW	\$100	\$120
Large Net Metered Non-Residential located on Rooftop, Carport, Canopy and Floating Solar	Projects 1 MW to 5 MW	\$90	\$110
Small Net Metered Non-Residential Ground Mount	Projects smaller than 1 MW	\$85	\$105
Large Net Metered Non-Residential Ground Mount	Projects 1 MW to 5 MW	\$80	\$100
LMI Community Solar	Up to 5 MW	\$90	N/A
Non-LMI Community Solar	Up to 5 MW	\$70	N/A
Interim Subsection (t)	All types and sizes	\$100	N/A

Eligible projects may generate SREC-IIs for 15 years following the commencement of commercial operations which is defined as permission to operate (PTO) from the Electric Distribution Company. After 15 years, projects may be eligible for a NJ Class I REC.

SREC-IIs will be purchased monthly by the SREC-II Program Administrator who will allocate the SREC-IIs to the Load Serving Entities (BGS Providers and Third-Party Suppliers) annually based on their market share of retail electricity sold during the relevant Energy Year.

The ADI Program online portal is now open to new registrations.

Competitive Solar Incentive (CSI) Program

The CSI Program opened on April 15, 2023, and will serve as the permanent program within the SuSI Program providing incentives to larger solar facilities. The CSI Program is open to qualifying grid supply solar facilities, non-residential net metered solar installations with a capacity greater than five (5) megawatts (“MW”), and to eligible grid supply solar facilities installed in combination with energy storage.

CSI eligible facilities will only be allowed to register in the CSI program upon award of a bid pursuant to N.J.A.C. 14:8-11.10.

The CSI program structure has separate categories, or tranches, to ensure that a range of solar project types, including those on preferred sites, are able to participate despite potentially different project cost profiles. The Board has approved four tranches for grid supply and large net metered solar and an additional fifth tranche for storage in combination with grid supply solar. The following table lists procurement targets for the first solicitation:

Tranche	Project Type	MW (dc) Targets
Tranche 1.	Basic Grid Supply	140
Tranche 2.	Grid Supply on the Built Environment	80
Tranche 3.	Grid Supply on Contaminated Sites and Landfills	40
Tranche 4.	Net Metered Non- Residential	40
Tranche 5.	*Storage Paired with Grid	160 MWh

*The storage tranche of 160 MWh corresponds to a 4-hour storage pairing of 40 MW of solar

Solar projects help the State of New Jersey reach renewable energy goals outlined in the state's Energy Master Plan.

If you are considering installing solar on your building, visit the following link for more information: <https://njcleanenergy.com/renewable-energy/programs/susi-program>

Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) serves New Jersey's government agencies by financing energy projects. An ESIP is a type of performance contract, whereby school districts, counties, municipalities, housing authorities, and other public and state entities enter contracts to help finance building energy upgrades. Annual payments are lower than the savings projected from the energy conservation measures (ECMs), ensuring that ESIP projects are cash flow positive for the life of the contract.

ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs described above can also be used to help further reduce the total project cost of eligible measures.

How to Participate

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an energy services company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is used for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the energy savings plan can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Carefully consider all alternatives to develop an approach that best meets your needs. A detailed program descriptions and application can be found at www.njcleanenergy.com/ESIP.

ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you can use NJCEP incentive programs to help further reduce costs when developing the energy savings plan. Refer to the ESIP guidelines at the link above for further information and guidance on next steps.

Demand Response (DR) Energy Aggregator

Demand Response Energy Aggregator is a program designed to reduce the electric load when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Grid operators call upon curtailment service providers and commercial facilities to reduce electric usage during times of peak demand, making the grid more reliable and reducing transmission costs for all ratepayers. Curtailment service providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants receive payments whether or not their facility is called upon to curtail its electric usage.

Typically, an electric customer must be capable of reducing their electric demand, within minutes, by at least 100 kW or more in order to participate in a DR program. Customers with greater capability to quickly curtail their demand during peak hours receive higher payments. Customers with back-up generators on site may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in DR programs often find it to be a valuable source of revenue for their facility, because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature setpoints on thermostats (so that air conditioning units run less frequently) or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a DR activity in most situations.

The first step toward participation in a DR program is to contact a curtailment service provider. A list of these providers is available on the website of the independent system operator, PJM, and it includes contact information for each company, as well as the states where they have active business¹³. PJM also posts training materials for program members interested in specific rules and requirements regarding DR activity along with a variety of other DR program information¹⁴.

Curtailment service providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities, and they may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

¹³ <http://www.pjm.com/markets-and-operations/demand-response.aspx>.

¹⁴ <http://www.pjm.com/training/training-events.aspx>.

9.2 Utility Energy Efficiency Programs

The Clean Energy Act, signed into law by Governor Murphy in 2018, requires New Jersey's investor-owned gas and electric utilities to reduce their customers' use by set percentages over time. To help reach these targets the New Jersey Board of Public Utilities approved a comprehensive suite of energy efficiency programs to be run by the utility companies.

Prescriptive and Custom

The Prescriptive and Custom rebate program through your utility provider offers incentives for installing prescriptive and custom energy efficiency measures at your facility. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades. This program serves most common equipment types and sizes.

Equipment Examples

Lighting

Lighting Controls

HVAC Equipment

Refrigeration

Gas Heating

Gas Cooling

Commercial Kitchen Equipment

Food Service Equipment

Variable Frequency Drives

Electronically Commutate Motors

Variable Frequency Drives

Plug Loads Controls

Washers and Dryers

Agricultural

Water Heating

The Prescriptive program provides fixed incentives for specific energy efficiency measures. Prescriptive incentives vary by equipment type. The Custom program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentives.

Direct Install

Direct Install is a turnkey program available to existing small to medium-sized facilities with an average peak electric demand that does not exceed 200 kW or less over the recent 12-month period. You work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives, and controls.

Incentives

The program pays up to 70% of the total installed cost of eligible measures.

How to Participate

To participate in Direct Install, you will work with a participating contractor. The contractor will be paid the measure incentives directly by the program, which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the Direct Install program, subject to program rules and eligibility, while the remaining percent of the cost is paid to the contractor by the customer.


Engineered Solutions

The Engineered Solutions Program provides tailored energy-efficiency assistance and services to municipalities, universities, schools, hospitals, and healthcare facilities (MUSH), non-profit entities, and multifamily buildings. Customers receive expert guided services, including investment-grade energy auditing, engineering design, installation assistance, construction administration, commissioning, and measurement and verification (M&V) services to support the implementation of cost-effective and comprehensive efficiency projects. Engineered Solutions is generally a good option for medium to large sized facilities with a peak demand over 200 kW looking to implement as many measures as possible under a single project to achieve deep energy savings. Engineered Solutions has an added benefit of addressing measures that may not qualify for other programs. Many facilities pursuing an Energy Savings Improvement Program loan also use this program. Incentives for this program are based on project scope and energy savings achieved.

For more information on any of these programs, contact your local utility provider or visit <https://www.njcleanenergy.com/transition>.

10 PROJECT DEVELOPMENT

Energy conservation measures (ECMs) have been identified for your site, and their energy and economic analyses are provided within this LGEA report. Note that some of the identified projects may be mutually exclusive, such as replacing equipment versus upgrading motors or controls. The next steps with project development are to set goals and create a comprehensive project plan. The graphic below provides an overview of the process flow for a typical energy efficiency or renewable energy project. We recommend implementing as many ECMs as possible prior to undertaking a feasibility study for a renewable project. The cyclical nature of this process flow demonstrates the ongoing work required to continually improve building energy efficiency over time. If your building(s) scope of work is relatively simple to implement or small in scope, the measurement and verification (M&V) step may not be required. It should be noted through a typical project cycle, there will be changes in costs based on specific scopes of work, contractor selections, design considerations, construction, etc. The estimated costs provided throughout this LGEA report demonstrate the unburdened turn-key material and labor cost only. There will be contingencies and additional costs at the time of implementation. We recommend comprehensive project planning that includes the review of multiple bids for project work, incorporates potential operations and maintenance (O&M) cost savings, and maximizes your incentive potential.



Project Development Cycle

11 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

11.1 Retail Electric Supply Options

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. Though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third-party supplier, consider shopping for a reduced rate from third-party electric suppliers. If your facility already buys electricity from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party electric suppliers is available at the NJBPU website¹⁵.

11.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey is also deregulated. Most customers that remain with the utility for natural gas service pay rates that are market based and fluctuate monthly. The utility provides basic gas supply service to customers who choose not to buy from a third-party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier typically depends on whether a customer prefers budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third-party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility does not already purchase natural gas from a third-party supplier, consider shopping for a reduced rate from third-party natural gas suppliers. If your facility already purchases natural gas from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party natural gas suppliers is available at the NJBPU website¹⁶.

¹⁵ www.state.nj.us/bpu/commercial/shopping.html

¹⁶ www.state.nj.us/bpu/commercial/shopping.html

APPENDIX A: EQUIPMENT INVENTORY & RECOMMENDATIONS

Lighting Inventory & Recommendations

Location	Existing Conditions						Proposed Conditions								Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Classroom 102	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	648	0	\$87	\$300	\$60	2.8
Classroom 104	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	648	0	\$87	\$300	\$60	2.8
Classroom 106	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	648	0	\$87	\$300	\$60	2.8
Classroom 108	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	648	0	\$87	\$300	\$60	2.8
Classroom 110	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	648	0	\$87	\$300	\$60	2.8
Classroom 112	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	648	0	\$87	\$300	\$60	2.8
Classroom 114	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	648	0	\$87	\$300	\$60	2.8
Classroom 118	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	648	0	\$87	\$300	\$60	2.8
Classroom 119	16	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	16	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.4	1,728	-1	\$232	\$810	\$160	2.8
Classroom 121	16	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	16	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.4	1,728	-1	\$232	\$810	\$160	2.8
Classroom 122	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	648	0	\$87	\$300	\$60	2.8
Classroom 124	9	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	2,975	1	Relamp	No	9	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	2,975	0.4	1,649	-1	\$221	\$800	\$180	2.8
Classroom 125	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	432	0	\$58	\$200	\$40	2.8
Classroom 126	6	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	2,975	1	Relamp	No	6	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	2,975	0.2	1,100	0	\$148	\$530	\$120	2.8
Classroom 127	9	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	9	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.2	972	0	\$130	\$460	\$90	2.8
Classroom 128	6	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	2,975	1	Relamp	No	6	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	2,975	0.2	1,100	0	\$148	\$530	\$120	2.8
Classroom 129	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	432	0	\$58	\$200	\$40	2.8
Classroom 130	6	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	2,975	1	Relamp	No	6	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	2,975	0.2	1,100	0	\$148	\$530	\$120	2.8
Classroom 132	6	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	2,975	1	Relamp	No	6	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	2,975	0.2	1,100	0	\$148	\$530	\$120	2.8
Classroom 133	5	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	5	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	540	0	\$72	\$250	\$50	2.8
Classroom 134/136	12	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Occupancy Sensor	S	114	2,975	1	Relamp	No	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	2,975	0.5	2,199	-1	\$295	\$1,060	\$240	2.8
Classroom 143	3	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	S	33	4,312	1	Relamp	No	3	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	4,312	0.0	228	0	\$31	\$110	\$20	2.9
Classroom 143	15	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1, 2	Relamp	Yes	15	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.5	2,988	-1	\$401	\$1,090	\$190	2.2
Classroom 150	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Classroom 150	4	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	S	32	4,312	1, 2	Relamp	Yes	4	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,975	0.1	417	0	\$56	\$430	\$60	6.6

Existing Conditions							Proposed Conditions							Energy Impact & Financial Analysis							
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Classroom 150	50	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	4,312	1, 2	Relamp	Yes	50	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	2,975	2.7	17,545	-7	\$2,355	\$5,740	\$1,140	2.0
Classroom 150A	9	LED - Fixtures: Ambient 1x4 Fixture	Wall Switch	S	20	4,312		None	No	9	LED - Fixtures: Ambient 1x4 Fixture	Wall Switch	20	4,312	0.0	0	0	\$0	\$0	\$0	0.0
Classroom 150B	2	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	S	30	2,975		None	No	2	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	30	2,975	0.0	0	0	\$0	\$0	\$0	0.0
Conference 100	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1, 2	Relamp	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.2	1,195	0	\$160	\$630	\$100	3.3
Corridor 2	3	Compact Fluorescent: (1) 13W Spiral Plug-In Lamp	Wall Switch	S	13	4,380	1	Relamp	No	3	LED Lamps: (1) 12W Plug-In Lamp	Wall Switch	10	4,380	0.0	43	0	\$6	\$80	\$0	13.7
Corridor 2	6	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	6	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Corridor 2	2	Incandescent: (1) 60W A19 Screw-In Lamp	Wall Switch	S	60	4,380	1	Relamp	No	2	LED Lamps: A19 Lamps	Wall Switch	9	4,380	0.1	491	0	\$66	\$50	\$0	0.8
Corridor 2	12	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	S	32	4,380	1, 3	Relamp	Yes	12	LED - Linear Tubes: (1) 4' Lamp	High/Low Control	15	3,022	0.2	1,272	-1	\$171	\$860	\$480	2.2
Corridor 2	16	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,380	1, 3	Relamp	Yes	16	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	3,022	0.5	3,237	-1	\$434	\$1,660	\$720	2.2
Corridor 2	35	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,380	1, 3	Relamp	Yes	35	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	3,022	1.1	7,081	-3	\$950	\$3,460	\$1,580	2.0
Dining Area 1 & 2	6	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	6	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Dining Area 1	48	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	S	32	4,312	1, 2	Relamp	Yes	48	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,975	0.8	5,008	-2	\$672	\$2,530	\$380	3.2
Dining Area 2	48	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	S	32	4,312	1, 2	Relamp	Yes	48	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,975	0.8	5,008	-2	\$672	\$2,530	\$380	3.2
Dining Area 1	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1, 2	Relamp	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.2	1,593	-1	\$214	\$730	\$120	2.9
Dining Area 2	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.2	864	0	\$116	\$400	\$80	2.8
Exterior 2	16	LED Lamps: (1) 30W ED37 Screw-In Lamp	Photocell		30	4,380		None	No	16	LED Lamps: (1) 30W ED37 Screw-In Lamp	Photocell	30	4,380	0.0	0	0	\$0	\$0	\$0	0.0
Exterior 2	1	LED - Fixtures: Flood Fixture	Photocell		75	4,380		None	No	1	LED - Fixtures: Flood Fixture	Photocell	75	4,380	0.0	0	0	\$0	\$0	\$0	0.0
Exterior 2	18	LED - Fixtures: Outdoor Pole/Arm-Mounted Area/Roadway Fixture	Photocell		120	4,380		None	No	18	LED - Fixtures: Outdoor Pole/Arm-Mounted Area/Roadway Fixture	Photocell	120	4,380	0.0	0	0	\$0	\$0	\$0	0.0
Exterior 2	10	LED - Fixtures: Wall Pack	Photocell		30	4,380		None	No	10	LED - Fixtures: Wall Pack	Photocell	30	4,380	0.0	0	0	\$0	\$0	\$0	0.0
Gymnasium 1	4	Exit Signs: LED - 2 W Lamp	None	S	6	8,760		None	No	4	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Gymnasium 1	24	Linear Fluorescent - T5HO: 4' T5HO (54W) - 6L	Occupancy Sensor	S	358	2,975	1	Relamp	No	24	LED - Linear Tubes: (6) 4' T5HO (25W) Lamps	Occupancy Sensor	153	2,975	3.5	16,102	-7	\$2,161	\$3,640	\$720	1.4
Janitorial 1	1	LED Lamps: (1) 10.5W Plug-In Lamp	Wall Switch	S	9	4,312		None	No	1	LED Lamps: (1) 10.5W Plug-In Lamp	Wall Switch	9	4,312	0.0	0	0	\$0	\$0	\$0	0.0
Janitorial 2	1	Compact Fluorescent: (1) 23W Spiral Plug-In Lamp	Wall Switch	S	23	4,312	1	Relamp	No	1	LED Lamps: (1) 12W Plug-In Lamp	Wall Switch	17	4,312	0.0	28	0	\$4	\$30	\$0	7.9
Kitchen 1	15	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1, 2	Relamp	Yes	15	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.5	2,988	-1	\$401	\$1,090	\$190	2.2
Library 1	36	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	4,312	1, 2	Relamp	Yes	36	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	2,975	1.9	12,632	-5	\$1,695	\$4,180	\$830	2.0

Location	Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis								
	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Locker Room 1	1	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	S	33	4,312	1	Relamp	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	4,312	0.0	76	0	\$10	\$40	\$10	2.9
Locker Room 1	9	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	S	32	4,312	1, 2	Relamp	Yes	9	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,975	0.1	939	0	\$126	\$560	\$90	3.7
Locker Room 1	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1, 2	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	398	0	\$53	\$250	\$40	3.9
Locker Room Boys	1	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	S	33	4,312	1	Relamp	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	4,312	0.0	76	0	\$10	\$40	\$10	2.9
Locker Room Boys	9	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	S	32	4,312	1, 2	Relamp	Yes	9	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,975	0.1	939	0	\$126	\$560	\$90	3.7
Locker Room Boys	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,312	0.0	157	0	\$21	\$50	\$10	1.9
Mechanical 2	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	4,312		None	No	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,312	0.0	0	0	\$0	\$0	\$0	0.0
Office - Enclosed 101A	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	432	0	\$58	\$200	\$40	2.8
Office - Enclosed 103	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	648	0	\$87	\$300	\$60	2.8
Office - Enclosed 107	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.0	216	0	\$29	\$100	\$20	2.8
Office - Enclosed 109	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.0	216	0	\$29	\$100	\$20	2.8
Office - Enclosed 111	1	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	S	25	2,975		None	No	1	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	25	2,975	0.0	0	0	\$0	\$0	\$0	0.0
Office - Enclosed 111	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.0	216	0	\$29	\$100	\$20	2.8
Office - Enclosed 113	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.0	216	0	\$29	\$100	\$20	2.8
Office - Enclosed 115	9	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	9	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.2	972	0	\$130	\$460	\$90	2.8
Office - Enclosed 117	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	648	0	\$87	\$300	\$60	2.8
Office - Enclosed 123	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1, 2	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	398	0	\$53	\$250	\$40	3.9
Office - Enclosed 131	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.0	216	0	\$29	\$100	\$20	2.8
Office - Enclosed 138	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1, 2	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	398	0	\$53	\$250	\$40	3.9
Office - Enclosed 138	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1, 2	Relamp	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	398	0	\$53	\$250	\$40	3.9
Office - Enclosed Boys Locker	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,312	0.0	157	0	\$21	\$50	\$10	1.9
Office - Enclosed Girls Locker	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,312	0.0	157	0	\$21	\$50	\$10	1.9
Office - Enclosed Main Office 101	8	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.2	864	0	\$116	\$400	\$80	2.8
Office - Enclosed Main Office 101	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.0	216	0	\$29	\$100	\$20	2.8
Restroom - Female 3	4	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Occupancy Sensor	S	32	2,975	1	Relamp	No	4	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,975	0.1	229	0	\$31	\$100	\$20	2.6

Existing Conditions							Proposed Conditions							Energy Impact & Financial Analysis							
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Restroom - Female 4	5	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Occupancy Sensor	S	32	2,975	1	Relamp	No	5	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,975	0.1	286	0	\$38	\$130	\$30	2.6
Restroom - Female Girls Locker	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,312	0.0	157	0	\$21	\$50	\$10	1.9
Restroom - Male 4	6	LED - Fixtures: Ambient - 4' - Direct Fixture	Occupancy Sensor	S	20	2,975		None	No	6	LED - Fixtures: Ambient - 4' - Direct Fixture	Occupancy Sensor	20	2,975	0.0	0	0	\$0	\$0	\$0	0.0
Restroom - Male 5	4	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Occupancy Sensor	S	32	2,975	1	Relamp	No	4	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,975	0.1	229	0	\$31	\$100	\$20	2.6
Restroom - Unisex 225	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,312	0.0	157	0	\$21	\$50	\$10	1.9
Restroom - Unisex 4	1	LED - Fixtures: Ambient - 4' - Direct Fixture	Wall Switch	S	20	4,312		None	No	1	LED - Fixtures: Ambient - 4' - Direct Fixture	Wall Switch	20	4,312	0.0	0	0	\$0	\$0	\$0	0.0
Restroom - Unisex 5	1	LED - Fixtures: Ambient - 4' - Direct Fixture	Wall Switch	S	20	4,312		None	No	1	LED - Fixtures: Ambient - 4' - Direct Fixture	Wall Switch	20	4,312	0.0	0	0	\$0	\$0	\$0	0.0
Restroom - Unisex 6	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,312	0.0	157	0	\$21	\$50	\$10	1.9
Storage 150C	1	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	S	32	4,312	1	Relamp	No	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	4,312	0.0	83	0	\$11	\$30	\$10	1.8
Storage 3	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312		None	No	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	4,312	0.0	0	0	\$0	\$0	\$0	0.0
Classroom 200	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.3	1,296	-1	\$174	\$610	\$120	2.8
Classroom 202	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.3	1,296	-1	\$174	\$610	\$120	2.8
Classroom 204	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.3	1,296	-1	\$174	\$610	\$120	2.8
Classroom 206	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.3	1,296	-1	\$174	\$610	\$120	2.8
Classroom 208	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.3	1,296	-1	\$174	\$610	\$120	2.8
Classroom 210	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.3	1,296	-1	\$174	\$610	\$120	2.8
Classroom 211	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Classroom 211	36	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	36	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.9	3,888	-2	\$522	\$1,820	\$360	2.8
Classroom 212	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.3	1,296	-1	\$174	\$610	\$120	2.8
Classroom 213	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	648	0	\$87	\$300	\$60	2.8
Classroom 214	19	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	19	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.5	2,052	-1	\$275	\$960	\$190	2.8
Classroom 215	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.3	1,296	-1	\$174	\$610	\$120	2.8
Classroom 217	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.3	1,296	-1	\$174	\$610	\$120	2.8
Classroom 218	3	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	324	0	\$43	\$150	\$30	2.8
Classroom 220	19	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	19	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.5	2,052	-1	\$275	\$960	\$190	2.8

Location	Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis								
	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Classroom 222	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.3	1,296	-1	\$174	\$610	\$120	2.8
Classroom 222 (9)	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.3	1,296	-1	\$174	\$610	\$120	2.8
Classroom 223	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Classroom 223	36	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	36	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.9	3,888	-2	\$522	\$1,820	\$360	2.8
Classroom 224	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.3	1,296	-1	\$174	\$610	\$120	2.8
Classroom 224	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.3	1,296	-1	\$174	\$610	\$120	2.8
Classroom 226	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.3	1,296	-1	\$174	\$610	\$120	2.8
Classroom 228	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	648	0	\$87	\$300	\$60	2.8
Classroom 230	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.3	1,296	-1	\$174	\$610	\$120	2.8
Classroom 240	1	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Occupancy Sensor	S	32	2,975	1	Relamp	No	1	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,975	0.0	57	0	\$8	\$30	\$10	2.6
Classroom 240	36	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	36	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.9	3,888	-2	\$522	\$1,820	\$360	2.8
Classroom 240	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.0	216	0	\$29	\$100	\$20	2.8
Corridor 1	1	Compact Fluorescent: (1) 13W Plug-In Lamp	Wall Switch	S	13	4,312		None	No	1	Compact Fluorescent: (1) 13W Plug-In Lamp	Wall Switch	13	4,312	0.0	0	0	\$0	\$0	\$0	0.0
Corridor 1	2	Compact Fluorescent: (1) 13W Biaxial Plug-In Lamp	Wall Switch	S	13	4,312	1	Relamp	No	2	LED Lamps: GX23 (Plug-In) Lamps	Wall Switch	10	4,312	0.0	28	0	\$4	\$30	\$0	7.9
Corridor 1	1	Compact Fluorescent: (1) 23W Spiral Plug-In Lamp	Wall Switch	S	23	4,312	1	Relamp	No	1	LED Lamps: (2) 23W Biax Lamps	Wall Switch	17	4,312	0.0	28	0	\$4	\$10	\$0	2.6
Corridor 1	8	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	8	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Corridor 1	1	Incandescent: (1) 60W A19 Screw-In Lamp	Wall Switch	S	60	4,312	1	Relamp	No	1	LED Lamps: A19 Lamps	Wall Switch	9	4,312	0.0	242	0	\$32	\$30	\$0	0.9
Corridor 1	26	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1, 3	Relamp	Yes	26	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	2,975	0.8	5,178	-2	\$695	\$2,720	\$1,170	2.2
Corridor 1	16	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1, 3	Relamp	Yes	16	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	2,975	0.5	3,187	-1	\$428	\$1,660	\$720	2.2
Mechanical 3	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,312	0.3	1,878	-1	\$252	\$610	\$120	1.9
Mechanical 4	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,312	0.3	1,878	-1	\$252	\$610	\$120	1.9
Office - Enclosed 207	7	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	7	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.2	756	0	\$101	\$350	\$70	2.8
Office - Enclosed 225	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.0	216	0	\$29	\$100	\$20	2.8
Office - Enclosed 225B	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.0	216	0	\$29	\$100	\$20	2.8
Office - Enclosed 225C	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.0	216	0	\$29	\$100	\$20	2.8

Location	Existing Conditions						Proposed Conditions								Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Office - Enclosed 227	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.3	1,296	-1	\$174	\$610	\$120	2.8
Office - Enclosed 229	6	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Occupancy Sensor	S	62	2,975	1	Relamp	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	648	0	\$87	\$300	\$60	2.8
Restroom - Female 2	1	LED Lamps: (1) 10.5W Plug-In Lamp	Wall Switch	S	11	4,312		None	No	1	LED Lamps: (1) 10.5W Plug-In Lamp	Wall Switch	11	4,312	0.0	0	0	\$0	\$0	\$0	0.0
Restroom - Female 2	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1, 2	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	797	0	\$107	\$530	\$80	4.2
Restroom - Male 1	1	LED Lamps: (1) 10.5W Plug-In Lamp	Wall Switch	S	11	4,312		None	No	1	LED Lamps: (1) 10.5W Plug-In Lamp	Wall Switch	11	4,312	0.0	0	0	\$0	\$0	\$0	0.0
Restroom - Male 1	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1, 2	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	797	0	\$107	\$530	\$80	4.2
Restroom - Male 2	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1, 2	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	797	0	\$107	\$530	\$80	4.2
Restroom - Male 3	1	LED Lamps: (1) 10.5W Plug-In Lamp	Wall Switch	S	11	4,312		None	No	1	LED Lamps: (1) 10.5W Plug-In Lamp	Wall Switch	11	4,312	0.0	0	0	\$0	\$0	\$0	0.0
Restroom - Male 3	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1, 2	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	797	0	\$107	\$530	\$80	4.2
Restroom - Male Boys Locker	1	LED Lamps: (1) 10.5W Plug-In Lamp	Wall Switch	S	11	4,312		None	No	1	LED Lamps: (1) 10.5W Plug-In Lamp	Wall Switch	11	4,312	0.0	0	0	\$0	\$0	\$0	0.0
Restroom - Male Boys Locker	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1, 2	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,975	0.1	797	0	\$107	\$530	\$80	4.2
Restroom - Unisex 1	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,312	0.0	157	0	\$21	\$50	\$10	1.9
Restroom - Unisex 2	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,312	0.0	157	0	\$21	\$50	\$10	1.9
Storage 240A	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,312	0.0	313	0	\$42	\$100	\$20	1.9
Storage 240B	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,312	1	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,312	0.0	157	0	\$21	\$50	\$10	1.9

Motor Inventory & Recommendations

		Existing Conditions									Proposed Conditions					Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Manufacturer	Model	Remaining Useful Life	Annual Operating Hours	ECM #	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Mechanical 2	Glen Meadow Middle School	1	Air Compressor	1.50	76.5%	No	Unknown	Unknown	W	1,000		No	76.5%	No		0.0	0	0	\$0	\$0	\$0	0.0
Mechanical 2	Glen Meadow Middle School	2	Chilled Water Pump	5.00	89.5%	No	Unknown	Unknown	W	2,745	5	No	89.5%	Yes	2	1.9	8,580	0	\$1,220	\$11,300	\$1,800	7.8
Mechanical 3	Glen Meadow Middle School	1	Exhaust Fan	0.50	70.0%	No	Unknown	Unknown	W	3,400		No	70.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Mechanical 3	Glen Meadow Middle School	1	Exhaust Fan	0.50	70.0%	No	Unknown	Unknown	W	3,200		No	70.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Mechanical 4	Glen Meadow Middle School	1	Exhaust Fan	0.50	70.0%	No	Unknown	Unknown	W	3,400		No	70.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Exterior 1	Glen Meadow Middle School	4	Exhaust Fan	0.10	65.0%	No	Unknown	Unknown	W	3,400		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Mechanical 2	Glen Meadow Middle School	3	Heating Hot Water Pump	5.00	89.5%	No	Century	Unknown	W	2,745	6	No	89.5%	Yes	3	1.4	12,870	0	\$1,829	\$16,900	\$2,700	7.8
Mechanical 2	Glen Meadow Middle School	1	DHW Circulation Pump	0.33	65.0%	No	Unknown	Unknown	W	8,760		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Mechanical 2	Glen Meadow Middle School	1	Other	0.13	70.0%	No	Unknown	Unknown	W	2,745		No	70.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Mechanical 2	Glen Meadow Middle School	1	Other	0.13	70.0%	No	Unknown	Unknown	W	2,745		No	70.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Mechanical 3	Glen Meadow Middle School	1	Return Fan	5.00	89.5%	No	Unknown	Unknown	W	3,400	4	No	89.5%	Yes	1	1.5	5,314	0	\$755	\$6,200	\$900	7.0
Glen Meadow Middle School	Glen Meadow Middle School	42	Supply Fan	0.17	65.0%	No	Unknown	Unknown	W	2,745		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Mechanical 3	Glen Meadow Middle School	1	Supply Fan	5.00	87.5%	No	Leeson	815000400	W	3,400	4	No	89.5%	Yes	1	1.5	5,654	0	\$804	\$5,600	\$900	5.8
Mechanical 4	Glen Meadow Middle School	1	Supply Fan	5.00	87.5%	No	Gould	6-322467-02	W	3,400	4	No	89.5%	Yes	1	1.5	5,654	0	\$804	\$5,600	\$900	5.8
Mechanical 3	Glen Meadow Middle School	1	Supply Fan	3.00	84.0%	No	Siemens	51-325-200	W	3,400	4	No	89.5%	Yes	1	0.9	3,773	0	\$536	\$5,100	\$200	9.1
Mechanical 3	Glen Meadow Middle School	1	Return Fan	1.50	77.0%	No	Baldor	M3154	W	3,400	4	No	86.5%	Yes	1	0.5	2,219	0	\$315	\$4,400	\$100	13.6
Mechanical 4	Glen Meadow Middle School	1	Supply Fan	10.00	86.5%	No	Marathon Electric	LVC 215TTDR7359BBW	W	3,400	4	No	91.7%	Yes	1	3.1	12,118	0	\$1,723	\$7,500	\$1,100	3.7
Mechanical 4	Glen Meadow Middle School	1	Supply Fan	7.50	91.0%	No	Marathon Electric	213TTDBD6026	W	3,400	4	No	91.0%	Yes	1	2.1	7,839	0	\$1,114	\$6,700	\$1,000	5.1
Mechanical 4	Glen Meadow Middle School	1	Return Fan	1.50	77.0%	No	Unknown	Unknown	W	3,400	4	No	86.5%	Yes	1	0.5	2,219	0	\$315	\$4,400	\$100	13.6
Mechanical 4	Glen Meadow Middle School	1	Return Fan	3.00	84.0%	No	Unknown	Unknown	W	3,400	4	No	89.5%	Yes	1	1.0	3,773	0	\$536	\$5,100	\$200	9.1

		Existing Conditions									Proposed Conditions					Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Manufacturer	Model	Remaining Useful Life	Annual Operating Hours	ECM #	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Mechanical 4	Glen Meadow Middle School	1	Return Fan	5.00	87.5%	No	Unknown	Unknown	W	3,400	4	No	89.5%	Yes	1	1.5	5,654	0	\$804	\$5,600	\$900	5.8
Mechanical 3	Glen Meadow Middle School	1	Return Fan	1.50	77.0%	No	Unknown	Unknown	W	3,400	4	No	86.5%	Yes	1	0.5	2,219	0	\$315	\$4,400	\$100	13.6

Packaged HVAC Inventory & Recommendations

		Existing Conditions									Proposed Conditions								Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (MBh)	Cooling Mode Efficiency (SEER/IEER/EER)	Heating Mode Efficiency	Manufacturer	Model	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (MBh)	Cooling Mode Efficiency (SEER/IEER/EER)	Heating Mode Efficiency	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Classroom 202	Glen Meadow Middle School	1	Window AC	1.50		11.80		LG	LW1821ERSM	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Classrooms	Glen Meadow Middle School	27	Window AC	1.50		9.70		Unknown	Unknown	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Classrooms	Glen Meadow Middle School	4	Window AC	1.50		9.70		Kenmore	580. 75180700	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Classroom 220	Glen Meadow Middle School	1	Window AC	2.66		8.50		Fedders	A6K32E7C-A	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Exterior	Glen Meadow Middle School	1	Ductless Mini-Split HP	2.00	27.60	12.50	11.6 COP	Fujitsu	AOU24RLXFW	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Exterior	Glen Meadow Middle School	1	Ductless Mini-Split HP	1.00	14.00	10.00	11.6 COP	Fujitsu	AOU12RL2	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Exterior	Glen Meadow Middle School	1	Ductless Mini-Split HP	1.00	12.00	10.00	6.8 HSPF	Sanyo	CH1222	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Exterior	Glen Meadow Middle School	1	Split-System	5.00		9.00		Trane	2TTB3060A	B	7	Yes	1	Split-System	5.00		16.00		1.5	2,917	0	\$415	\$10,800	\$500	24.8
Exterior	Glen Meadow Middle School	1	Ductless Mini-Split AC	1.00		14.00		Daikin	RX12RMVJUD	W		No							0.0	0	0	\$0	\$0	\$0	0.0

Electric Chiller Inventory & Recommendations

		Existing Conditions						Proposed Conditions							Energy Impact & Financial Analysis							
Location	Area(s)/System(s) Served	Chiller Quantity	System Type	Cooling Capacity per Unit (Tons)	Manufacturer	Model	Remaining Useful Life	ECM #	Install High Efficiency Chillers?	Chiller Quantity	System Type	Constant/Variable Speed	Cooling Capacity (Tons)	Full Load Efficiency (kW/Ton)	IPLV Efficiency (kW/Ton)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Exterior 2	Glen Meadow Middle School	1	Air-Cooled Scroll Chiller	100.00	Trane	CGAM 100A 2F02	W		No							0.0	0	0	\$0	\$0	\$0	0.0

Space Heating Boiler Inventory & Recommendations

		Existing Conditions						Proposed Conditions							Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	System Quantity	System Type	Output Capacity per Unit (MBh)	Manufacturer	Model	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Mechanical 2	Glen Meadow Middle School	2	Non-Condensing Hot Water Boiler	2,227	Weil-McLain	1088	W		No						0.0	0	0	\$0	\$0	\$0	0.0

DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis					
		System Quantity	System Type	Manufacturer	Model	Remaining Useful Life	ECM #	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives
Mechanical 2	Glen Meadow Middle School	1	Storage Tank Water Heater (> 50 Gal)	Bradford White	RG275H6X	W		No					0.0	0	0	\$0	\$0	\$0	0.0
Kitchen 1	Glen Meadow Middle School	1	Booster Water Heater	Hatco	C-12	W		No					0.0	0	0	\$0	\$0	\$0	0.0

Low-Flow Device Recommendations

Location	Recommendation Inputs					Energy Impact & Financial Analysis						
	ECM #	Device Quantity	Device Type	Existing Flow Rate (gpm)	Proposed Flow Rate (gpm)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Glen Meadow Middle School	8	22	Faucet Aerator (Lavatory)	1.50	0.50	0.0	0	6	\$116	\$180	\$90	0.8

Walk-In Cooler/Freezer Inventory & Recommendations

Location	Existing Conditions				Proposed Conditions				Energy Impact & Financial Analysis						
	Cooler/Freezer Quantity	Case Type/Temperature	Manufacturer	Model	ECM #	Install EC Evaporator Fan Motors?	Install Electric Defrost Control?	Install Evaporator Fan Control?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen 1	1	Cooler (35F to 55F)	Dunham-Bush	ECT9-85	9, 10	Yes	Yes	Yes	0.1	2,139	0	\$304	\$3,450	\$210	10.7

Commercial Refrigerator/Freezer Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions		Energy Impact & Financial Analysis						
	Quantity	Refrigerator/ Freezer Type	Manufacturer	Model	ENERGY STAR Qualified?	ECM #	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen 1	1	Stand-Up Refrigerator, Solid Door (31 - 50 cu. ft.)	Traulsen	Unknown	No		No	0.0	0	0	\$0	\$0	\$0	0.0
Dining Area 1	1	Refrigerator Chest	Unknown	Unknown	No		No	0.0	0	0	\$0	\$0	\$0	0.0

Commercial Ice Maker Inventory & Recommendations

Existing Conditions						Proposed Conditions		Energy Impact & Financial Analysis						
Location	Quantity	Ice Maker Type	Manufacturer	Model	ENERGY STAR Qualified?	ECM #	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen 1	1	Remote Condensing Unit (<1,000 lbs/day), Batch	Manitowoc	IYT0300A-161	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0

Cooking Equipment Inventory & Recommendations

Existing Conditions						Proposed Conditions		Energy Impact & Financial Analysis						
Location	Quantity	Equipment Type	Manufacturer	Model	High Efficiency Equipment?	ECM #	Install High Efficiency Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen 1	2	Insulated Food Holding Cabinet (3/4 Size)	Unknown	Unknown	No		No	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen 1	2	Gas Rack Oven (Double)	Unknown	Unknown	No		No	0.0	0	0	\$0	\$0	\$0	0.0

Dishwasher Inventory & Recommendations

Existing Conditions								Proposed Conditions		Energy Impact & Financial Analysis						
Location	Quantity	Dishwasher Type	Manufacturer	Model	Water Heater Fuel Type	Booster Heater Fuel Type	ENERGY STAR Qualified?	ECM #	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Payback w/ Incentives in Years
Kitchen 1	1	Single Tank Conveyor (High Temp)	Hobart	Unknown	Electric	None	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0

Plug Load Inventory

Existing Conditions						
Location	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified ?	Manufacturer	Model
Storage 3	1	Clothes Dryer	5,000	No	Unknown	Unknown
Storage 3	2	Clothes Washer	1,200	No	Unknown	Unknown
Classroom	5	Coffee Machine	1,500	No	Unknown	Unknown
Classroom	2	Dehumidifier	480	No	Unknown	Unknown
Classroom	67	Desktop	270	No	Unknown	Unknown
Classroom	5	Fan (Portable)	200	No	Unknown	Unknown
Classroom	1	Laptop	75	No	Unknown	Unknown
Classroom	19	Microwave	1,500	No	Unknown	Unknown
Classroom	55	Air Purifier	120	No	Unknown	Unknown
Office	3	Paper Shredder	75	No	Unknown	Unknown
Office	8	Printer (Medium/Small)	300	No	Unknown	Unknown
Office	8	Printer/Copier (Large)	600	No	Unknown	Unknown
Classroom	2	Projector	320	No	Unknown	Unknown
Classroom	21	Refrigerator (Mini)	126	No	Unknown	Unknown
Conference	3	Refrigerator (Residential)	463	No	Unknown	Unknown
Classroom	48	Smart Board	200	No	Unknown	Unknown
Office	15	Television	133	No	Unknown	Unknown
Corridor	5	Water Fountain	370	No	Elkay	LZS8WSSP
Restroom	16	Hand Dryer	1,320	No	Global Dryer	GX1
Classroom	3	3D Printer	500	No	Unknown	Unknown

Vending Machine Inventory & Recommendations

Location	Existing Conditions		Proposed Conditions		Energy Impact & Financial Analysis						
	Quantity	Vending Machine Type	ECM #	Install Controls?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Conference	1	Refrigerated	11	Yes	0.2	1,612	0	\$229	\$270	\$50	1.0

APPENDIX B: ENERGY STAR STATEMENT OF ENERGY PERFORMANCE

Energy use intensity (EUI) is presented in terms of site energy and source energy. Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

ENERGY STAR® Statement of Energy Performance

LEARN MORE AT energystar.gov

58

ENERGY STAR® Score¹

Glen Meadow Middle School

Primary Property Type: K-12 School
Gross Floor Area (ft²): 82,700
Built: 1980

For Year Ending: February 29, 2024
Date Generated: November 18, 2024

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information		
Property Address Glen Meadow Middle School 7 Sammis Road Vernon, New Jersey 07462	Property Owner Vernon Township School District 625 Route 517 PO Box 99 Vernon, NJ 07462 973-764-6494	Primary Contact Joe Van Kirk 625 Route 517 BO Box 99 Vernon, NJ 07462 973-764-6494 jvankirk@vtsd.com
Property ID: 35122010		

Energy Consumption and Energy Use Intensity (EUI)				
Site EUI 72.5 kBtu/ft ²	Annual Energy by Fuel		Annual Emissions	
	Electric - Grid (kBtu)	2,518,056 (42%)	Total (Location-Based) GHG Emissions (Metric Tons CO ₂ e/year)	476
	Fuel Oil (No. 1) (kBtu)	3,475,139 (58%)		
Source EUI 127.7 kBtu/ft ²	National Median Comparison		Green Power	
	National Median Site EUI (kBtu/ft ²)	79.3	Green Power – Onsite (kWh)	N/A
	National Median Source EUI (kBtu/ft ²)	139.7	Green Power – Offsite (kWh)	0
	% Diff from National Median Source EUI	-9%	Percent of RECs Retained	N/A

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

LP Signature: _____ Date: _____

Licensed Professional



Professional Engineer or Registered Architect Stamp (if applicable)

APPENDIX C: ADDITIONAL STUDY


Summary

DER	Gross Project Cost (\$)	Energy Generation (kWh)	Demand Reduction (kW)	GHG Reduction (MT CO2)	Total Annual Utility Cost Savings (\$/yr)	New Maintenance Penalty (\$/yr)	Net Annual Cost Savings (\$/yr)	Incentives (ITC) (\$)	Depreciation (MACRS) (\$)	Net Project Cost (\$)	Net Simple Payback (yr)
345 kW Solar PV	\$2,165,000	454,333	0	90	\$64,337	\$10,825	\$53,512	\$649,500	\$541,250	\$974,250	18.2
Total	\$2,165,000	454,333	0	90	\$64,337	\$10,825	\$53,512	\$649,500	\$541,250	\$974,250	18.2

PPA Alternative:	\$3,807
------------------	---------

Annual Utility Savings

Baseline kWh	738,000
Saved kWh	454,333
% NZE	62%
NZE Solar Size MW	560.40



Equipment	Estimated Max Demand Savings (kW)	Estimated Annual Energy Generation (kWh)	Estimated Annual GHG Reduction (MT-CO ₂ e)	Estimated Annual Cost Savings (\$)	Estimated Gross Project Cost (\$)	Total Incentives (\$)	Net Project Cost (\$)	Simple Payback Period (yr)
345 kW Solar PV	0	454,333	90	\$53,512	\$2,165,000	\$1,190,750	\$974,250	18.2
Total	0	454,333	90	\$53,512	\$2,165,000	\$1,190,750	\$974,250	18.2

Ownership Plan	Upfront Cost	Year 1 Cost After Rebates	Annual Savings	Lifetime 30-Year Cost Savings (\$)	30-Year ROI
Cash Purchase	\$2,165,000	\$974,250	\$53,512	\$1,605,369	165%
PPA	\$0	\$0	\$3,807	\$114,204	-

Equipment	Estimated Gross Project Cost (\$)	ITC Rebate	MACRS Rebate	Net Project Cost
345 kW Solar PV	\$2,165,000	\$649,500	\$541,250	\$974,250

System Description	Quantity	Unit	Equipment Cost per Unit (\$)	Labor Cost Per Unit (\$)	Material Cost Per Unit (\$)	Total Material Cost (\$)	Total Equipment Cost (\$)	Total Labor Cost (\$)	Total Cost (\$)	Source	Notes
Solar Array											
PV Modules (Trina Solar 320 W)	345,000	Watts DC			\$ 0.45	\$155,250	\$ -	\$ -	\$155,250	PV size from ETB, cost from NREL report	https://www.nrel.gov/docs/fy22osti/83586.pdf
Inverter, 30 kW	10	Ea.		\$ 400	\$ 4,500	\$ 45,000	\$ -	\$ 16,016	\$ 61,016	Inverter size from Helioscope - Cost from online quote Labor - 4 Hrs Electrician per unit	https://www.solaris-shop.com/sma-sunny-tripower-x-30-us-50-stp-30-us-50-480vac-afci-dc-disconnect-sunspec-certified-rapid-shutdown-transmitter/
Carport Racking Cost/Labor/Installation	345,000	Watts DC		\$ 1.21	\$ 1.00	\$345,000	\$ -	\$417,830	\$762,830	Energy ToolBase	Considered PV Mounting/Racking Cost
PV String Combiner Panels	8	Ea.		\$ 100.10	\$ 568	\$ 4,263	\$ -	\$ 1,502	\$ 5,765	Online Quote Labor - 1 Hrs Electrician per unit	https://www.solaris-shop.com/sma-cu1000-us-11-string-combiner-w-disconnect/ Each 1000V combiner box with disconnect switch can accommodate 8 strings total Project site has up to 60 strings
Electrical BOS Ground Carport	2,515	m^2	\$ -	\$ -	\$ 50.00	\$125,735	\$ -	\$ -	\$125,735	assumed the same cost as the ground mounted https://www.nrel.gov/docs/fy22osti/83586.pdf	U.S. Solar Photovoltaic System and Energy Storage Cost Benchmarks, With Minimum Sustainable Price Analysis: Q1 2022
Carport Linear LED Surface Mount Lighting Fixture	13	Ea.		\$ 100.10	\$ 61.83	\$ 777	\$ -	\$ 1,259	\$ 2,036	RS Means Line #: 26 51 13 44 2010 https://www.1000bulbs.com/product/217486/PLT-90093.html	(1) Electrician to install
Installation rental equipment Ground Mount	2,515	m^2	\$ 14.60	\$ -	\$ -	\$ -	\$ 36,715	\$ -	\$ 36,715	assumed the same cost as the ground mounted https://www.nrel.gov/docs/fy22osti/83586.pdf	U.S. Solar Photovoltaic System and Energy Storage Cost Benchmarks, With Minimum Sustainable Price Analysis: Q1 2022
Trenching/Site Prep and Wiring											
Schedule 80 PVC Piping 6" Diameter	500	LF	\$ -	\$ 45	\$ 53.00	\$26,500	\$ -	\$ 22,618	\$ 49,118	RS means - 221113742560	
Trenching and Backfill 12" wide, 36" Deep	5	Day.	\$ 425	\$1,836.40	\$ -	\$ -	\$ 2,125	\$ 9,182	\$ 11,307	Includes B-54 Crew - reference 312316142850	(2) Days of work (2) Laborers (1) 40 HP Chain Trencher (1) Light Equip Operator
Soil Excavation, Removal, loading, and hauling	5	L.C.Y	\$ 6.78	\$ 6.15	\$ -	\$ -	\$ 34	\$ 31	\$ 65	Includes B-34D Crew - reference 312323204304	Includes (1) Truck Driver (1) Truck Tractor (1) Dump Trailer

System Description	Quantity	Unit	Equipment Cost per Unit (\$)	Labor Cost Per Unit (\$)	Material Cost Per Unit (\$)	Total Material Cost (\$)	Total Equipment Cost (\$)	Total Labor Cost (\$)	Total Cost (\$)	Source	Notes
Backfill and Asphalt Paving 8" Thick	5	Day.	\$ 3,428	\$6,777.20	\$ 30.00	\$ 3,213	\$ 17,139	\$ 33,886	\$ 54,238	Includes B-25 Crew - reference 32 11 26 13 0560	1 Day of Filling Trench and Repaving Asphalt Includes (1) Labor Foreman (7) Laborers (3) Equipment Operators (1) Asphalt Paver, 130 H.P. (1) Tandem Roller, 10 Ton (1) Roller, Pneum. Wheel, 12 Ton
Other Costs											
Migrogrid Controller	345	kW	\$ -	\$ 7.63	\$ 155	\$ 53,475	\$ -	\$ 2,631	\$ 56,106	https://www.nrel.gov/docs/fy19osti/67821.pdf NREL data base (\$155,000/MW)	Inclusive of 1 Electrician @ 8 Hrs Per Unit
User Training	8	Hr.	\$ -	\$ 150	\$ -	\$ -	\$ -	\$ 1,200	\$ 1,200	-	
Total						\$759,200	\$ 56,000	506,200	\$1,321,380		

Markup	Cost
System Cost	\$1,321,380
NJ Sales Tax (6.625%)	\$50,297
O&P Cost (10%)	\$132,138
EPC Markup (10%)	\$132,138
Contingency (30%)	\$396,414
Escalation from 2022	\$132,138
Total Cost	\$2,165,000

Solar Cost	\$2,071,107	
Electrical Upgrades, Permitting and Misc...	\$93,893	
Solar Cost with Elec Upgrades	\$2,165,000	\$6.28



PPA Analysis



Year	Income			Net		
	Cash Purchase	Standard PPA	PPA with Year 10 Buyout	Cash Purchase	Standard PPA	PPA with Year 10 Buyout
0	-\$974,250	\$0	\$0	-\$974,250	\$0	\$0
1	\$53,512	\$3,807	\$3,807	-\$920,738	\$3,807	\$3,807
2	\$53,512	\$3,807	\$3,807	-\$867,225	\$7,614	\$7,614
3	\$53,512	\$3,807	\$3,807	-\$813,713	\$11,420	\$11,420
4	\$53,512	\$3,807	\$3,807	-\$760,201	\$15,227	\$15,227
5	\$53,512	\$3,807	\$3,807	-\$706,688	\$19,034	\$19,034
6	\$53,512	\$3,807	\$3,807	-\$653,176	\$22,841	\$22,841
7	\$53,512	\$3,807	\$3,807	-\$599,664	\$26,648	\$26,648
8	\$53,512	\$3,807	\$3,807	-\$546,151	\$30,454	\$30,454
9	\$53,512	\$3,807	\$3,807	-\$492,639	\$34,261	\$34,261
10	\$53,512	\$3,807	\$3,807	-\$439,127	\$38,068	\$38,068
11	\$53,512	\$3,807	-\$495,262	-\$385,615	\$41,875	-\$457,194
12	\$53,512	\$3,807	\$53,512	-\$332,102	\$45,682	-\$403,681
13	\$53,512	\$3,807	\$53,512	-\$278,590	\$49,488	-\$350,169
14	\$53,512	\$3,807	\$53,512	-\$225,078	\$53,295	-\$296,657
15	\$53,512	\$3,807	\$53,512	-\$171,565	\$57,102	-\$243,145
16	\$53,512	\$3,807	\$53,512	-\$118,053	\$60,909	-\$189,632
17	\$53,512	\$3,807	\$53,512	-\$64,541	\$64,716	-\$136,120
18	\$53,512	\$3,807	\$53,512	-\$11,028	\$68,522	-\$82,608
19	\$53,512	\$3,807	\$53,512	\$42,484	\$72,329	-\$29,095
20	\$53,512	\$3,807	\$53,512	\$95,996	\$76,136	\$24,417
21	\$53,512	\$3,807	\$53,512	\$149,509	\$79,943	\$77,929
22	\$53,512	\$3,807	\$53,512	\$203,021	\$83,750	\$131,442
23	\$53,512	\$3,807	\$53,512	\$256,533	\$87,556	\$184,954
24	\$53,512	\$3,807	\$53,512	\$310,046	\$91,363	\$238,466
25	\$53,512	\$3,807	\$53,512	\$363,558	\$95,170	\$291,979
26	\$53,512	\$3,807	\$53,512	\$417,070	\$98,977	\$345,491
27	\$53,512	\$3,807	\$53,512	\$470,582	\$102,784	\$399,003
28	\$53,512	\$3,807	\$53,512	\$524,095	\$106,590	\$452,516
29	\$53,512	\$3,807	\$53,512	\$577,607	\$110,397	\$506,028
30	\$53,512	\$3,807	\$53,512	\$631,119	\$114,204	\$559,540


Cash Purchase	
Gross Project Cost	\$2,165,000
Rebates	-\$649,500
85% Depreciation	-\$541,250
n/a	\$0
Final Cost	\$974,250
Utility Savings	\$53,512
Payback	18.2
Financial Life (yr)	30
ROI (Over EUL)	165%

Solar Cost: \$2,165,000

Standard PPA	
Gross Project Cost	\$2,165,000
Rebates	-\$649,500
85% Depreciation	-\$541,250
n/a	\$0
Final Cost	\$974,250
Financial Life (yr)	30
Interest Rate	3.0%
Annual Income from Loan	\$49,706
Utility Savings	\$53,512
Annual Savings	\$3,807

Solar Cost: \$2,165,000

PPA with Year 10 Buyout	
Gross Project Cost	\$2,165,000
Rebates	-\$649,500
85% Depreciation	-\$541,250
n/a	\$0
Final Cost	\$974,250
Financial Life (yr)	30
Interest Rate	3.0%
Years 1-10	
Contractor's Income	\$49,706
Utility Savings	\$53,512
Customer Savings	\$3,807
Years 11-30	
Contractor O&P	15%
Buyout Cost	\$548,774
Utility Savings	\$53,512
Year 11-25 Payback	10.3
Lifetime Savings	\$1,108,314
ROI (Over RUL)	202%





ETB Outputs

				Raw Utility Info			32.0% Cost Markup		
Bill Date Ranges		Energy Before PV/ESS (kWh)		Charges Before PV/ESS (\$)			Charges Before PV/ESS (\$)		
Start Date	End Date	Season	Total	Other	Energy	Total	Other	Energy	Total
1/1/2024	2/1/2024	S1	69000	25.59	7402.25	7427.84	\$ 33.78	\$ 9,770.97	\$ 9,804.75
2/1/2024	3/1/2024	S1	50160	25.59	5381.11	5406.7	\$ 33.78	\$ 7,103.07	\$ 7,136.84
3/1/2023	4/1/2023	S1	61800	25.59	6629.84	6655.43	\$ 33.78	\$ 8,751.39	\$ 8,785.17
4/1/2023	5/1/2023	S1	61440	25.59	6591.22	6616.81	\$ 33.78	\$ 8,700.41	\$ 8,734.19
5/1/2023	6/1/2023	S1	63480	25.59	6810.07	6835.66	\$ 33.78	\$ 8,989.29	\$ 9,023.07
6/1/2023	7/1/2023	S1	61560	25.59	6604.1	6629.69	\$ 33.78	\$ 8,717.41	\$ 8,751.19
7/1/2023	8/1/2023	S1	63360	25.59	6797.2	6822.79	\$ 33.78	\$ 8,972.30	\$ 9,006.08
8/1/2023	9/1/2023	S1	61800	25.59	6629.84	6655.43	\$ 33.78	\$ 8,751.39	\$ 8,785.17
9/1/2023	10/1/2023	S1	58800	25.59	6308.01	6333.6	\$ 33.78	\$ 8,326.57	\$ 8,360.35
10/1/2023	11/1/2023	S1	59400	25.59	6372.37	6397.96	\$ 33.78	\$ 8,411.53	\$ 8,445.31
11/1/2023	12/1/2023	S1	65760	25.59	7054.67	7080.26	\$ 33.78	\$ 9,312.16	\$ 9,345.94
12/1/2023	1/1/2024	S1	61440	25.59	6591.22	6616.81	\$ 33.78	\$ 8,700.41	\$ 8,734.19
Subtotal			738000	307.08	79171.9	0	\$ 405.35	\$ 104,506.91	\$ -
Adjustments			0	0	0	0	\$ -	\$ -	\$ -
Total			738000	307.08	79171.9	79478.98	\$ 405.35	\$ 104,506.91	\$ 104,912.25

				Charges After PV & Before ESS (\$)			Charges After PV & Before ESS (\$)		
Bill Date Ranges		Energy After PV & Before ESS (kWh)		Charges After PV & Before ESS (\$)			Charges After PV & Before ESS (\$)		
Start Date	End Date	Season	Total	Other	Energy	Total	Other	Energy	Total
1/1/2024	2/1/2024	S1	46938	25.59	5035.46	5061.05	\$ 33.78	\$ 6,646.81	\$ 6,680.59
2/1/2024	3/1/2024	S1	20472	25.59	2196.22	2221.81	\$ 33.78	\$ 2,899.01	\$ 2,932.79
3/1/2023	4/1/2023	S1	20643	25.59	2214.56	2240.15	\$ 33.78	\$ 2,923.22	\$ 2,957.00
4/1/2023	5/1/2023	S1	17086	25.59	1832.97	1858.56	\$ 33.78	\$ 2,419.52	\$ 2,453.30
5/1/2023	6/1/2023	S1	12798	25.59	1372.96	1398.55	\$ 33.78	\$ 1,812.31	\$ 1,846.09
6/1/2023	7/1/2023	S1	12617	25.59	1353.54	1379.13	\$ 33.78	\$ 1,786.67	\$ 1,820.45
7/1/2023	8/1/2023	S1	8989	25.59	964.33	989.92	\$ 33.78	\$ 1,272.92	\$ 1,306.69
8/1/2023	9/1/2023	S1	11385	25.59	1221.37	1246.96	\$ 33.78	\$ 1,612.21	\$ 1,645.99
9/1/2023	10/1/2023	S1	18279	25.59	1960.95	1986.54	\$ 33.78	\$ 2,588.45	\$ 2,622.23
10/1/2023	11/1/2023	S1	28774	25.59	3086.85	3112.44	\$ 33.78	\$ 4,074.64	\$ 4,108.42
11/1/2023	12/1/2023	S1	44450	25.59	4768.55	4794.14	\$ 33.78	\$ 6,294.49	\$ 6,328.26
12/1/2023	1/1/2024	S1	41236	25.59	4423.76	4449.35	\$ 33.78	\$ 5,839.36	\$ 5,873.14
Subtotal			283667	307.08	30431.51	0	\$ 405.35	\$ 40,169.59	\$ -
Adjustments			0	0	0	0	\$ -	\$ -	\$ -
Total			283667	307.08	30431.51	30738.59	\$ 405.35	\$ 40,169.59	\$ 40,574.94

				Charges After PV & Before ESS (\$)			Charges After PV/ESS (\$)		
Bill Date Ranges		Energy After PV & Before ESS (kWh)		Charges After PV & Before ESS (\$)			Charges After PV/ESS (\$)		
Start Date	End Date	Season	Total	Other	Energy	Total	Other	Energy	Total
1/1/2024	2/1/2024	S1	46938	25.59	5035.46	5061.05	\$ 33.78	\$ 6,646.81	\$ 6,680.59
2/1/2024	3/1/2024	S1	20472	25.59	2196.22	2221.81	\$ 33.78	\$ 2,899.01	\$ 2,932.79
3/1/2023	4/1/2023	S1	20643	25.59	2214.56	2240.15	\$ 33.78	\$ 2,923.22	\$ 2,957.00
4/1/2023	5/1/2023	S1	17086	25.59	1832.97	1858.56	\$ 33.78	\$ 2,419.52	\$ 2,453.30
5/1/2023	6/1/2023	S1	12798	25.59	1372.96	1398.55	\$ 33.78	\$ 1,812.31	\$ 1,846.09
6/1/2023	7/1/2023	S1	12617	25.59	1353.54	1379.13	\$ 33.78	\$ 1,786.67	\$ 1,820.45
7/1/2023	8/1/2023	S1	8989	25.59	964.33	989.92	\$ 33.78	\$ 1,272.92	\$ 1,306.69
8/1/2023	9/1/2023	S1	11385	25.59	1221.37	1246.96	\$ 33.78	\$ 1,612.21	\$ 1,645.99
9/1/2023	10/1/2023	S1	18279	25.59	1960.95	1986.54	\$ 33.78	\$ 2,588.45	\$ 2,622.23
10/1/2023	11/1/2023	S1	28774	25.59	3086.85	3112.44	\$ 33.78	\$ 4,074.64	\$ 4,108.42
11/1/2023	12/1/2023	S1	44450	25.59	4768.55	4794.14	\$ 33.78	\$ 6,294.49	\$ 6,328.26
12/1/2023	1/1/2024	S1	41236	25.59	4423.76	4449.35	\$ 33.78	\$ 5,839.36	\$ 5,873.14
Subtotal			283667	307.08	30431.51	0	\$ 405.35	\$ 40,169.59	\$ -
Adjustments			0	0	0	0	\$ -	\$ -	\$ -
Total			283667	307.08	30431.51	30738.59	\$ 405.35	\$ 40,169.59	\$ 40,574.94

Energy Toolbase

PV SYSTEM DETAILS

GENERAL INFORMATION

Facility: Glen Meadow Middle School
 Address: 7 Sammis Road, Vernon, NJ 07462

SOLAR PV EQUIPMENT DESCRIPTION

Solar Panels: (1078) Trina Solar TSM-PD14 320 (May16)
 Inverters: (10) SMA Sunny Tripower X 30-US

SOLAR PV EQUIPMENT TYPICAL LIFESPAN

Solar Panels: Greater than 30 Years
 Inverters: 15 Years

SOLAR PV SYSTEM RATING

Power Rating: 344,960 W-DC
 Power Rating: 303,579 W-AC-CEC

ENERGY CONSUMPTION MIX

Annual Energy Use: 738,000 kWh



Utility 283,667 kWh (38.44%)
 Solar PV 454,333 kWh (61.56%)

MONTHLY ENERGY USE VS SOLAR GENERATION



ENVIRONMENTAL BENEFITS



OVER THE NEXT 20 YEARS, YOUR SYSTEM WILL DO MORE THAN JUST SAVE YOU MONEY. ACCORDING TO THE EPA'S GREENHOUSE GAS EQUIVALENCIES CALCULATOR (SOURCE), YOUR SOLAR PV SYSTEM WILL HAVE THE IMPACT OF REDUCING:



7,118

tons of CO₂ Offset



16,184,099

Miles Driven By Cars



106,768

Trees Planted



APPENDIX D: GLOSSARY

TERM	DEFINITION
Blended Rate	Used to calculate fiscal savings associated with measures. The blended rate is calculated by dividing the amount of your bill by the total energy use. For example, if your bill is \$22,217.22, and you used 266,400 kilowatt-hours, your blended rate is 8.3 cents per kilowatt-hour.
Btu	<i>British thermal unit</i> : a unit of energy equal to the amount of heat required to increase the temperature of one pound of water by one-degree Fahrenheit.
CHP	<i>Combined heat and power</i> . Also referred to as cogeneration.
COP	<i>Coefficient of performance</i> : a measure of efficiency in terms of useful energy delivered divided by total energy input.
Demand Response	Demand response reduces or shifts electricity usage at or among participating buildings/sites during peak energy use periods in response to time-based rates or other forms of financial incentives.
DCV	<i>Demand control ventilation</i> : a control strategy to limit the amount of outside air introduced to the conditioned space based on actual occupancy need.
US DOE	<i>United States Department of Energy</i>
EC Motor	<i>Electronically commutated motor</i>
ECM	<i>Energy conservation measure</i>
EER	<i>Energy efficiency ratio</i> : a measure of efficiency in terms of cooling energy provided divided by electric input.
EUI	<i>Energy Use Intensity</i> : measures energy consumption per square foot and is a standard metric for comparing buildings' energy performance.
Energy Efficiency	Reducing the amount of energy necessary to provide comfort and service to a building/area. Achieved through the installation of new equipment and/or optimizing the operation of energy use systems. Unlike conservation, which involves some reduction of service, energy efficiency provides energy reductions without sacrifice of service.
ENERGY STAR	ENERGY STAR is the government-backed symbol for energy efficiency. The ENERGY STAR program is managed by the EPA.
EPA	<i>United States Environmental Protection Agency</i>
Generation	The process of generating electric power from sources of primary energy (e.g., natural gas, the sun, oil).
GHG	<i>Greenhouse gas</i> gases that are transparent to solar (short-wave) radiation but opaque to long-wave (infrared) radiation, thus preventing long-wave radiant energy from leaving Earth's atmosphere. The net effect is a trapping of absorbed radiation and a tendency to warm the planet's surface.
gpf	<i>Gallons per flush</i>

gpm	<i>Gallon per minute</i>
HID	<i>High intensity discharge</i> : high-output lighting lamps such as high-pressure sodium, metal halide, and mercury vapor.
hp	<i>Horsepower</i>
HPS	<i>High-pressure sodium</i> : a type of HID lamp.
HSPF	<i>Heating seasonal performance factor</i> : a measure of efficiency typically applied to heat pumps. Heating energy provided divided by seasonal energy input.
HVAC	<i>Heating, ventilating, and air conditioning</i>
IHP 2014	US DOE Integral Horsepower rule. The current ruling regarding required electric motor efficiency.
IPLV	<i>Integrated part load value</i> : a measure of the part load efficiency usually applied to chillers.
kBtu	One thousand British thermal units
kW	<i>Kilowatt</i> : equal to 1,000 Watts.
kWh	<i>Kilowatt-hour</i> : 1,000 Watts of power expended over one hour.
LED	<i>Light emitting diode</i> : a high-efficiency source of light with a long lamp life.
LGEA	<i>Local Government Energy Audit</i>
Load	The total power a building or system is using at any given time.
Measure	A single activity, or installation of a single type of equipment, which is implemented in a building system to reduce total energy consumption.
MH	<i>Metal halide</i> : a type of HID lamp.
MBh	<i>Thousand Btu per hour</i>
MBtu	<i>One thousand British thermal units</i>
MMBtu	<i>One million British thermal units</i>
MV	<i>Mercury Vapor</i> : a type of HID lamp.
NJBPU	<i>New Jersey Board of Public Utilities</i>
NJCEP	<i>New Jersey's Clean Energy Program</i> : NJCEP is a statewide program that offers financial incentives, programs and services for New Jersey residents, business owners and local governments to help them save energy, money, and the environment.
psig	Pounds per square inch gauge
Plug Load	Refers to the amount of power used in a space by products that are powered by means of an ordinary AC plug.
PV	<i>Photovoltaic</i> : refers to an electronic device capable of converting incident light directly into electricity (direct current).

SEER	<i>Seasonal energy efficiency ratio</i> : a measure of efficiency in terms of annual cooling energy provided divided by total electric input.
SEP	<i>Statement of energy performance</i> : a summary document from the ENERGY STAR Portfolio Manager.
Simple Payback	The amount of time needed to recoup the funds expended in an investment or to reach the break-even point between investment and savings.
SREC (II)	<i>Solar renewable energy credit</i> : a credit you can earn from the state for energy produced from a photovoltaic array.
T5, T8, T12	A reference to a linear lamp diameter. The number represents increments of 1/8 th of an inch.
Temperature Setpoint	The temperature at which a temperature regulating device (thermostat, for example) has been set.
therm	100,000 Btu. Typically used as a measure of natural gas consumption.
tons	A unit of cooling capacity equal to 12,000 Btu/hr.
Turnkey	Provision of a complete product or service that is ready for immediate use.
VAV	<i>Variable air volume</i>
VFD	<i>Variable frequency drive</i> : a controller used to vary the speed of an electric motor.
WaterSense®	The symbol for water efficiency. The WaterSense® program is managed by the EPA.
Watt (W)	Unit of power commonly used to measure electricity use.