



Local Government Energy Audit Report

Jefferson Elementary

October 25, 2024

Prepared for:

Westfield Board of Education
1210 Boulevard
Westfield, New Jersey 07090

Prepared by:

TRC
317 George Street
New Brunswick, New Jersey 08901

Disclaimer

The goal of this audit report is to identify potential energy efficiency opportunities and help prioritize specific measures for implementation. Most energy conservation measures have received preliminary analysis of feasibility that identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to establish a basis for further discussion and to help prioritize energy measures.

TRC reviewed the energy conservation measures and estimates of energy savings for technical accuracy. Actual, achieved energy savings depend on behavioral factors and other uncontrollable variables and, therefore, estimates of final energy savings are not guaranteed. TRC and the New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

TRC bases estimated material and labor costs primarily on RS Means cost manuals as well as on our experience at similar facilities. This approach is based on standard cost estimating manuals and is vendor neutral. Cost estimates include material and labor pricing associated with one for one equipment replacements. Cost estimates do not include demolition or removal of hazardous waste. The actual implementation costs for energy savings projects are anticipated to be significantly higher based on the specific conditions at your site(s). We strongly recommend that you work with your design en-er or contractor to develop actual project costs for your specific scope of work for the installation of high efficiency equipment. We encourage you to obtain multiple estimates when considering measure installations. Actual installation costs can vary widely based on selected products and installers. TRC and NJBPU do not guarantee cost estimates and shall in no event be held liable should actual installed costs vary from these material and labor estimates.

Incentive values provided in this report are estimated based of previously run state efficiency programs. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. Please review all available utility program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

The customer and their respective contractor(s) are responsible to implement energy conservation measures in complete conformance with all applicable local, state, and federal requirements.

Copyright ©2024 TRC. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Table of Contents


1	Executive Summary	1
1.1	Planning Your Project	4
	Pick Your Installation Approach	4
	Options from Your Utility Company	4
	Options from New Jersey's Clean Energy Program	5
2	Existing Conditions	6
2.1	Site Overview.....	6
	Recent improvements and Facility Concerns	6
2.2	Building Occupancy	6
2.3	Building Envelope	6
2.4	Lighting Systems	7
2.5	Air Handling Systems	9
	Unit Ventilators	9
	Unitary Electric HVAC Equipment	9
	Air Handling Units (AHUs)	10
2.6	Heating Steam Systems	11
2.7	Domestic Hot Water	11
2.8	Food Service Equipment.....	12
2.9	Plug Load and Vending Machines	13
2.10	Water-Using Systems	14
3	Energy Use and Costs	15
3.1	Electricity	17
3.2	Natural Gas	18
3.3	Benchmarking.....	19
	Tracking Your Energy Performance	20
3.4	Understanding Your Utility Bills	20
4	Energy Conservation Measures	21
4.1	Lighting	24
	ECM 1: Retrofit Fixtures with LED Lamps	24
4.2	Lighting Controls.....	24
	ECM 2: Install Occupancy Sensor Lighting Controls	24
	ECM 3: Install High/Low Lighting Controls	25
4.3	Variable Frequency Drives (VFD).....	25
	ECM 4: Install Boiler Draft Fan VFDs	26
4.4	Unitary HVAC.....	26
	ECM 5: Install High Efficiency Air Conditioning Units	26

4.5	Domestic Water Heating	26
	ECM 6: Install Low-Flow DHW Devices.....	26
5	Energy Efficient Best Practices	28
	Energy Tracking with ENERGY STAR Portfolio Manager	28
	Doors and Windows	28
	Lighting Maintenance.....	28
	Lighting Controls	29
	Motor Controls.....	29
	Motor Maintenance	29
	Fans to Reduce Cooling Load	29
	Thermostat Schedules and Temperature Resets	29
	AC System Evaporator/Condenser Coil Cleaning	29
	Boiler Maintenance	29
	Label HVAC Equipment	30
	Optimize HVAC Equipment Schedules	30
	Water Heater Maintenance	30
	Plug Load Controls.....	31
	Computer Monitor Replacement.....	31
	Computer Power Management Software	31
	Procurement Strategies	31
6	On-site Generation	32
6.1	Solar Photovoltaic	33
6.2	Combined Heat and Power	35
7	Electric Vehicles	36
7.1	EV Charging	36
8	Project Funding and Incentives.....	38
8.1	New Jersey’s Clean Energy Program	39
8.2	Utility Energy Efficiency Programs	46
9	Project Development	48
10	Energy Purchasing and Procurement Strategies	49
10.1	Retail Electric Supply Options.....	49
10.2	Retail Natural Gas Supply Options	49
	Appendix A: Equipment Inventory & Recommendations	A-1
	Appendix B: ENERGY STAR Statement of Energy Performance.....	B-1
	Appendix C: Glossary	C-1


1 EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) report for Jefferson Elementary. This report provides you with information about your facility's energy use, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help make changes in your facility. TRC conducted this study as part of a comprehensive effort to assist New Jersey school districts and local governments in controlling their energy costs and to help protect our environment by reducing statewide energy consumption.

BUILDING PERFORMANCE REPORT



ENERGY STAR® Benchmarking Score	66 <i>(1-100 scale)</i>	This building performs at or below the national average. This report contains suggestions about how to improve building performance and reduce energy costs.
------------------------------------	----------------------------	--



Energy Use by System


POTENTIAL IMPROVEMENTS



This energy audit considered a range of potential energy improvements in your building. Costs and savings will vary between improvements. Presented below are two potential scopes of work for your consideration.


Scenario 1: Full Package (All Evaluated Measures)

Installation Cost	\$31,630
Potential Rebates & Incentives ¹	\$4,857
Annual Cost Savings	\$2,749
Annual Energy Savings	Electricity: 14,661 kWh Natural Gas: 182 Therms
Greenhouse Gas Emission Savings	8 Tons
Simple Payback	9.7 Years
Site Energy Savings (All Utilities)	2%



Scenario 2: Cost Effective Package²

Installation Cost	\$18,937
Potential Rebates & Incentives	\$4,174
Annual Cost Savings	\$2,633
Annual Energy Savings	Electricity: 13,980 kWh Natural Gas: 182 Therms
Greenhouse Gas Emission Savings	8 Tons
Simple Payback	5.6 Years
Site Energy Savings (all utilities)	2%



On-site Generation Potential

Photovoltaic	High
Combined Heat and Power	None

¹ Incentives are based on previously run state rebate programs. Contact your utility provider for current program incentives that may apply.

² A cost-effective measure is defined as one where the simple payback does not exceed two-thirds of the expected proposed equipment useful life. Simple payback is based on the net measure cost after potential incentives.

#	Energy Conservation Measure	Cost Effective?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades			588	0.2	0	\$98	\$329	\$90	\$239	2.4	578
ECM 1	Retrofit Fixtures with LED Lamps	Yes	588	0.2	0	\$98	\$329	\$90	\$239	2.4	578
Lighting Control Measures			9,334	2.8	-2	\$1,551	\$11,565	\$3,710	\$7,855	5.1	9,171
ECM 2	Install Occupancy Sensor Lighting Controls	Yes	6,339	2.3	-1	\$1,053	\$8,640	\$1,120	\$7,520	7.1	6,228
ECM 3	Install High/Low Lighting Controls	Yes	2,995	0.4	-1	\$498	\$2,925	\$2,590	\$335	0.7	2,942
Variable Frequency Drive (VFD) Measures			4,058	1.3	0	\$687	\$6,692	\$200	\$6,492	9.5	4,086
ECM 4	Install Boiler Draft Fan VFDs	Yes	4,058	1.3	0	\$687	\$6,692	\$200	\$6,492	9.5	4,086
Unitary HVAC Measures			681	0.9	0	\$115	\$12,693	\$683	\$12,010	104.2	686
ECM 5	Install High Efficiency Air Conditioning Units	No	681	0.9	0	\$115	\$12,693	\$683	\$12,010	104.2	686
Domestic Water Heating Upgrade			0	0.0	20	\$298	\$351	\$174	\$177	0.6	2,369
ECM 6	Install Low-Flow DHW Devices	Yes	0	0.0	20	\$298	\$351	\$174	\$177	0.6	2,369
TOTALS (COST EFFECTIVE MEASURES)			13,980	4.3	18	\$2,633	\$18,937	\$4,174	\$14,763	5.6	16,204
TOTALS (ALL MEASURES)			14,661	5.1	18	\$2,749	\$31,630	\$4,857	\$26,773	9.7	16,890

* - All incentives presented in this table are included as placeholders for planning purposes and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

All Evaluated Energy Improvements³

For more detail on each evaluated energy improvement and a break out of cost-effective improvements, see **Section 4: Energy Conservation Measures**.

³ TRC bases estimated material and labor costs primarily on RS Means cost manuals as well as on our experience at similar facilities. This approach is based on standard cost estimating manuals and is vendor neutral. Cost estimates include material and labor pricing associated with one for one equipment replacements. Cost estimates do not include demolition or removal of hazardous waste. The actual implementation costs for energy savings projects are anticipated to be significantly higher based on the specific conditions at your site(s). We strongly recommend that you work with your design engineer or contractor to develop actual project costs for your specific scope of work for the installation of high efficiency equipment. We encourage you to obtain multiple estimates when considering measure installations.

1.1 Planning Your Project

Careful planning makes for a successful energy project. When considering this scope of work, you will have some decision to make, such as:

- ◆ How will the project be funded/and or financed?
- ◆ Is it best to pursue individual ECMs, groups of ECMs, or use a comprehensive approach where all ECMs are installed together?
- ◆ Are there other facility improvements that should happen at the same time?

Pick Your Installation Approach

Utility-run energy efficiency programs and New Jersey's Clean Energy Programs, give you the flexibility to do a little or a lot. Rebates, incentives, and financing are available to help reduce both your installation costs and your energy bills. If you are planning to take advantage of these programs, make sure to review incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives *before* purchasing materials or starting installation.

Options from Your Utility Company

Prescriptive and Custom Rebates

For facilities wishing to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the Prescriptive and Custom Rebates program. To participate, you can use internal resources or an outside firm or contractor to perform the final design of the ECM(s) and install the equipment. Program pre-approval may be required for some incentives. Contact your utility company for more details prior to project installation.

Direct Install

The Direct Install program provides turnkey installation of multiple measures through an authorized contractor. This program can provide incentives up to 70% or 80% of the cost of selected measures. A Direct Install contractor will assess and verify individual measure eligibility and perform the installation work. The Direct Install program is available to sites with an average peak demand of less than 200 kW.

Engineered Solutions

The Engineered Solutions program provides tailored energy-efficiency assistance and turnkey engineering services to municipalities, universities, schools, hospitals, and healthcare facilities (MUSH), non-profit entities, and multifamily buildings. The program provides all professional services from audit, design, construction administration, to commissioning and measurement and verification for custom whole-building energy-efficiency projects. Engineered Solutions allows you to install as many measures as possible under a single project as well as address measures that may not qualify for other programs.

For more details on these programs please contact your utility provider.

Options from New Jersey's Clean Energy Program

Financing and Planning Support with the Energy Savings Improvement Program (ESIP)

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the ESIP. Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as attractive financing for implementing ECMs. You have already taken the first step as an LGEA customer, because this report is required to participate in ESIP.

Resiliency with Return on Investment through Combined Heat and Power (CHP)

The CHP program provides incentives for combined heat and power (i.e., cogeneration) and waste heat to power projects. Combined heat and power systems generate power on-site and recover heat from the generation system to meet on-site thermal loads. Waste heat to power systems use waste heat to generate power. You will work with a qualified developer who will design a system that meets your building's heating and cooling needs.

Successor Solar Incentive Program (SuSI)

New Jersey is committed to supporting solar energy. Solar projects help the state reach the renewable goals outlined in the state's Energy Master Plan. The SuSI program is used to register and certify solar projects in New Jersey. Rebates are not available, but certified solar projects are able to earn one SREC II (Solar Renewable Energy Certificates II) for each megawatt-hour of solar electricity produced from a qualifying solar facility.

Ongoing Electric Savings with Demand Response

The Demand Response Energy Aggregator program reduces electric loads at commercial facilities when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. By enabling commercial facilities to reduce electric demand during times of peak demand, the grid is made more reliable, and overall transmission costs are reduced for all ratepayers. Curtailment service providers provide regular payments to medium and large consumers of electric power for their participation in demand response (DR) programs. Program participation is voluntary, and facilities receive payments regardless of whether they are called upon to curtail their load during times of peak demand.

Large Energy User Program (LEUP)

LEUP is designed to promote self-investment in energy efficiency for the largest energy consumers in the state. Customers in this category spend about \$5 million a year on energy bills. This program incentivizes owners/users of buildings to upgrade or install energy conserving measures in existing buildings to help offset the capital costs associated with the project. The efficiency upgrades are customized to meet the requirements of the customers' existing facilities, while advancing the State's energy efficiency, conservation, and greenhouse gas reduction goals.

For more details on these programs please visit [New Jersey's Clean Energy Program website](#).



2 EXISTING CONDITIONS

The New Jersey Board of Public Utilities (NJBPU) has sponsored this Local Government Energy Audit (LGEA) Report for Jefferson Elementary. This report provides information on how your facility uses energy, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help you implement the ECMs.

TRC conducted this study as part of a comprehensive effort to assist New Jersey educational and local government facilities in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

2.1 Site Overview

On March 12, 2024, TRC performed an energy audit at Jefferson Elementary located in Westfield, New Jersey. TRC met with Sean McArthur to review the facility operations and help focus our investigation on specific energy-using systems.

The Jefferson Elementary is a one-story, 47,965 square foot building built in 1954. Spaces include classrooms, gymnasium, media center, faculty room, corridors, stairwells, and mechanical spaces.

Recent improvements and Facility Concerns

Most of the lighting in the facility has been converted to LEDs.

Facility concerns include high electric bills.

2.2 Building Occupancy

The facility is occupied 10 months out of the year. Typical weekday occupancy is 58 staff and 473 students.

Building Name	Weekday/Weekend	Operating Schedule
Jefferson Elementary School	Weekday	9:00 AM to 5:00 PM
	Weekend	N/A

Building Occupancy Schedule

2.3 Building Envelope

Building walls are made of brick. The roof is flat and covered with white membrane, and it is in fair condition.

Most of the windows are double pane and have aluminum frames. The glass-to-frame seals are in fair condition. The operable window weather seals are in fair condition, showing little evidence of excessive wear. Exterior doors have aluminum frames and are in fair condition with undamaged door seals. Degraded window and door seals increase drafts and outside air infiltration.



Roof



Facade



Windows



Doors

2.4 Lighting Systems

The primary interior lighting system uses mainly LED fixtures and LED lamps. There are also several 32-Watt T8 fixtures.

Fixture types include 2-lamp or 4-lamp, 2-foot or 4-foot fixtures.

Most fixtures are in good condition. Gymnasium fixtures have manually controlled LED fixtures and LED lamps.

Interior lighting levels were generally sufficient. Exit signs are all LED. Most lighting fixtures are controlled manually and the remainder by occupancy sensors.



LED Lamp



LED Linear Fixture



LED Fixture



LED Exit Sign

Exterior fixtures include wall packs and floodlights with LED lamps with all exterior fixtures controlled by a time clock.



LED Flood Lamp



LED Wallpack



LED Lamp

2.5 Air Handling Systems

Unit Ventilators

Unit ventilators supply heating and ventilation to classrooms. The unit ventilators are equipped with supply fan motors connected to the hot water distribution system. They provide heating to the classrooms. This system is original to the building and appears to be in fair operating condition.

Unitary Electric HVAC Equipment

Several classrooms use window air conditioning (AC) units. These are about 0.5 tons in capacity. The units are in fair condition. They have a cooling efficiency of 15 EER and they are not ENERGY STAR labeled.

There are two variable refrigerant flow (VRF) units located in the exterior that serve the building. These units have 6 tons and 16 tons of cooling capacity and 54 MBh to 215 MBh in gas heating capacity respectively. The units are in fair operating condition.

There are split-system AC units throughout the building. These units range in cooling capacity between 3 tons and 5 tons, with cooling efficiencies between 11.5 SEER and 13 SEER. Most of the units are cooling only however, one unit has gas heating with a capacity of 96 MBh. All of these of these units each have a corresponding air handler unit attached to the system.

There is also one mini split heat pump with a cooling capacity of 2 tons and a cooling efficiency of 9.6 SEER serving part of the building. The heating capacity of the unit is 26 MBh with a heating efficiency of 3.34 COP.



Window AC



Split System AC



Variable Refrigerant Flow



Mini-split HP

Air Handling Units (AHUs)

Several parts of the building are conditioned by split system air handling units. These units are equipped with a supply fan motor, hot water heating coil, and a refrigerant coil for cooling. They are typically located in the plenum space above the ceiling and were inaccessible during the energy audit. The supply fan motors are assumed to be 0.5 hp, constant speed, and standard efficiency.

The air handling units are served by outdoor condensing units that have cooling capacities ranging from of 2 tons to 3.5 tons and cooling efficiencies between 11.50 EER to 13 EER. They vary between fair and poor condition. The heating coil is served by the hot water boiler, which is described in the next section of the report.

There is an energy recovery ventilator that heats and cools part of the building. The cooling capacity of the unit is 35 tons with a cooling efficiency of 14 SEER. The gas heating capacity is 480 Mbh with an efficiency of 80% AFUE. This unit has an economizer and is in good/fair condition.



Outdoor Air Unit



Condensing Unit

2.6 Heating Steam Systems

Two Easco 3,348 MBh steam boilers serve the building's heating load. The two, 2 hp burners are non-modulating and the boilers have a nominal efficiency of 82%. The boilers are configured in a lead-lag control scheme. Only one boiler is required under high load conditions. Installed in 2016, they are in fair condition. There is a service contract in place.

The boilers are configured in a constant flow primary distribution with three, 0.8 hp constant speed hot water pumps operating with a manual control scheme. The boilers provide hot water to unit ventilators and air handling units throughout the building. There are two heat exchangers converting steam to heating hot water.



Steam Boilers



Heating Hot Water Pumps

2.7 Domestic Hot Water

Hot water is produced by a 50-gallon, 50 MBh, gas-fired storage water heater with an efficiency of 80%. The domestic hot water pipes are insulated, and the insulation is in fair condition. One, 0.04 hp circulation pump distributes water to end uses. The circulation pump operates continuously.




Domestic Hot Water Heater



Insulated Pipes



Circulation Pump



DHW Nameplate

2.8 Food Service Equipment

The kitchen has a mix of gas and electric equipment that is used to prepare meals for students and staff. Most cooking is done using a convection gas-fired oven. Equipment is not high efficiency and is in fair condition.

Visit https://www.energystar.gov/products/commercial_food_service_equipment for the latest information on high efficiency food service equipment.



Convection Oven

2.9 Plug Load and Vending Machines

You may wish to consider paying particular attention to minimizing your plug load usage. This report makes suggestions for ECMs in this area as well as energy efficient best practices.

There are 27 computer workstations throughout the facility. Plug loads throughout the building include general cafe and office equipment. There are classroom typical loads such as televisions and projectors.

There are several residential-style refrigerators throughout the building that are used to store perishables. These vary in condition and efficiency.



Refrigerator



Projector



Coffee Maker



Desktop


2.10 Water-Using Systems

EPA WaterSense® has set maximum flow rates for sanitary fixtures. They are: 1.28 gallons per flush (gpf) for toilets, 0.5 gpf for urinals, 1.5 gallons per minute (gpm) for lavatory faucets, and 2.0 gpm for showerheads. There are 11 restrooms with toilets, urinals, and sinks. Faucet flow rates are at 2.0 gpm or higher.

3 ENERGY USE AND COSTS


Twelve months of utility billing data are used to develop annual energy consumption and cost data. This information creates a profile of the annual energy consumption and energy costs.

Utility Summary		
Fuel	Usage	Cost
Electricity	252,400 kWh	\$42,721
Natural Gas	19,651 Therms	\$28,921
Total		\$71,642



An energy balance identifies and quantifies energy use in your various building systems. This can highlight areas with the most potential for improvement. This energy balance was developed using calculated energy use for each of the end uses noted in the figure.


The energy auditor collects information regarding equipment operating hours, capacity, efficiency, and other operational parameters from facility staff, drawings, and on-site observations. This information is used as the inputs to calculate the existing conditions energy use for the site. The calculated energy use is then compared to the historical energy use and the initial inputs are revised, as necessary, to balance the calculated energy use to the historical energy use.



Energy Balance by System

3.1 Electricity

PSE&G delivers electricity under rate class General Lighting & Power (GLP), with electric production provided by Constellation, a third-party supplier.




Electric Billing Data					
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost
5/4/22	30	14,160	73	\$287	\$2,416
6/3/22	30	19,620	256	\$506	\$3,006
7/5/22	32	25,440	288	\$2,075	\$4,826
8/3/22	29	16,080	50	\$738	\$2,785
9/1/22	29	28,440	259	\$1,897	\$4,752
10/3/22	32	26,460	282	\$2,064	\$4,759
11/1/22	29	19,200	108	\$503	\$2,854
12/2/22	31	20,880	129	\$601	\$3,091
1/4/23	33	19,320	151	\$352	\$3,103
2/2/23	29	19,080	184	\$285	\$3,444
3/6/23	32	15,400	83	\$385	\$3,272
4/4/23	29	28,320	67	\$313	\$4,414
Totals	365	252,400	288	\$10,007	\$42,721
Annual	365	252,400	288	\$10,007	\$42,721

Notes:

- Peak demand of 288 kW occurred in June '22.
- Average demand over the past 12 months was 161 kW.
- The average electric cost over the past 12 months was \$0.169/kWh, which is the blended rate that includes energy supply, distribution, demand, and other charges. This report uses this blended rate to estimate energy cost savings.

3.2 Natural Gas

Elizabethtown Gas delivers natural gas under rate class General Delivery Service - Transportation, with natural gas supply provided by Direct Energy, a third-party supplier.



Gas Billing Data			
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost
5/5/22	29	1,853	\$2,418
6/7/22	33	375	\$854
7/7/22	30	200	\$635
8/8/22	32	24	\$415
9/7/22	30	98	\$540
10/6/22	29	268	\$851
11/4/22	29	2,692	\$3,707
12/6/22	32	4,117	\$5,119
1/6/23	31	7,156	\$9,696
2/6/23	31	2,708	\$3,560
3/7/23	29	158	\$652
4/6/23	30	2	\$474
Totals	365	19,651	\$28,921
Annual	365	19,651	\$28,921

Notes:

- The average gas cost for the past 12 months is \$1.472/therm, which is the blended rate used throughout the analysis.


3.3 Benchmarking

Your building was benchmarked using the United States Environmental Protection Agency’s (EPA) *Portfolio Manager*® software. Benchmarking compares your building’s energy use to that of similar buildings across the country, while neutralizing variations due to location, occupancy, and operating hours. Some building types can be scored with a 1-100 ranking of a building’s energy performance relative to the national building market. A score of 50 represents the national average and a score of 100 is best.

This ENERGY STAR benchmarking score provides a comprehensive snapshot of your building’s energy performance. It assesses the building’s physical assets, operations, and occupant behavior, which is compiled into a quick and easy-to-understand score.

Benchmarking Score	66
---------------------------	-----------

This building performs at, or below the national average. This report contains suggestions about how to improve building performance and reduce energy costs.



Energy Use Intensity Comparison⁴

Energy use intensity (EUI) measures energy consumption per square foot and is the standard metric for comparing buildings’ energy performance. A lower EUI means better performance and less energy consumed. Several factors can cause a building to vary from typical energy usage. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and occupant behavior all contribute to a building’s energy use and the benchmarking score.

⁴ Based on all evaluated ECMs

Tracking Your Energy Performance

Keeping track of your energy use on a monthly basis is one of the best ways to keep energy costs in check. Update your utility information in Portfolio Manager regularly, so that you can keep track of your building's performance.

We have created a Portfolio Manager account for your facility, and we have already entered the monthly utility data shown above for you. Account login information for your account will be sent via email.

Free online training is available to help you use ENERGY STAR Portfolio Manager to track your building's performance at: <https://www.energystar.gov/buildings/training>.

For more information on ENERGY STAR and Portfolio Manager, visit their [website](#).

3.4 Understanding Your Utility Bills

The State of New Jersey Department of the Public Advocate provides detailed information on how to read natural gas and electric bills. Your bills contain important information including account numbers, meter numbers, rate schedules, meter readings, and the supply and delivery charges. Gas and electric bills both provide comparisons of current energy consumption with prior usage.

Sample bills, with annotation, may be viewed at:

https://www.nj.gov/rpa/docs/Understanding_Electric_Bill.pdf

https://www.nj.gov/rpa/docs/Understanding_Gas_Bill.pdf

Why Utility Bills Vary

Utility bills vary from one month to another for many reasons. For this reason, assessing the effects of your energy savings efforts can be difficult.

Billing periods vary, typically ranging between 28 and 33 days. Electric bills provide the kilowatt-hours (kWh) used per month while gas bills provide therms (or hundreds of cubic feet - CCF) per month consumption information. Monthly consumption information can be helpful as a tool to assess your efforts to reduce energy, particularly when compared to monthly usage from a similar calendar period in a prior year.

Bills typically vary seasonally, often with more gas consumed in the winter for heating, and more electricity used in the summer when air conditioning is used. Facilities with electric heating may experience higher electricity use in the winter. Seasonal variance will be impacted by the type of heating and cooling systems used. Normal seasonal fluctuations are further impacted by the weather. Extremely cold or hot weathers causes HVAC equipment to run longer, increasing usage. Other monthly fluctuations in usage can be caused by changes in building occupancy. Utility bills provide a comparison of usage between the current period and comparable billing month period of the prior year. Year-to-year monthly use comparisons can point to trends with energy savings for measures/projects that were implemented within the timeframe, but these comparisons do not account for changing weather or occupancy patterns.

The price of fuel and purchased power used to produce and delivery electricity and gas fluctuates. Any increase or decrease in these costs will be reflected in your monthly bill. Additionally, billing rates occasionally change after justification and approval of the NJBPU. For this reason, it is more useful to review energy use rather than cost when assessing energy use trends or the impact of energy conservation measures implemented.

4 ENERGY CONSERVATION MEASURES

The goal of this audit report is to identify and evaluate potential energy efficiency improvements and provide information about the cost effectiveness of those improvements. Most energy conservation measures have received preliminary analysis of feasibility, which identifies expected ranges of savings. This level of analysis is typically sufficient to demonstrate project cost-effectiveness and help prioritize energy measures.

Calculations of energy use and savings are based on the current version of the *New Jersey's Clean Energy Program Protocols to Measure Resource Savings*, which is approved by the NJBPU. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances.

Operation and maintenance costs for the proposed new equipment will generally be lower than the current costs for the existing equipment—especially if the existing equipment is at or past its normal useful life. We have conservatively assumed there to be no impact on overall maintenance costs over the life of the equipment.

Financial incentives are based on previously run state rebate programs. New utility programs are expected to start rolling out in the spring and summer of 2021. Keep up to date with developments by visiting the [NJCEP website](#). Some measures and proposed upgrades may be eligible for higher incentives than those shown below.

For a detailed list of the locations and recommended energy conservation measures for all inventoried equipment, see Appendix A: Equipment Inventory & Recommendations.

#	Energy Conservation Measure	Cost Effective?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades			588	0.2	0	\$98	\$329	\$90	\$239	2.4	578
ECM 1	Retrofit Fixtures with LED Lamps	Yes	588	0.2	0	\$98	\$329	\$90	\$239	2.4	578
Lighting Control Measures			9,334	2.8	-2	\$1,551	\$11,565	\$3,710	\$7,855	5.1	9,171
ECM 2	Install Occupancy Sensor Lighting Controls	Yes	6,339	2.3	-1	\$1,053	\$8,640	\$1,120	\$7,520	7.1	6,228
ECM 3	Install High/Low Lighting Controls	Yes	2,995	0.4	-1	\$498	\$2,925	\$2,590	\$335	0.7	2,942
Variable Frequency Drive (VFD) Measures			4,058	1.3	0	\$687	\$6,692	\$200	\$6,492	9.5	4,086
ECM 4	Install Boiler Draft Fan VFDs	Yes	4,058	1.3	0	\$687	\$6,692	\$200	\$6,492	9.5	4,086
Unitary HVAC Measures			681	0.9	0	\$115	\$12,693	\$683	\$12,010	104.2	686
ECM 5	Install High Efficiency Air Conditioning Units	No	681	0.9	0	\$115	\$12,693	\$683	\$12,010	104.2	686
Domestic Water Heating Upgrade			0	0.0	20	\$298	\$351	\$174	\$177	0.6	2,369
ECM 6	Install Low-Flow DHW Devices	Yes	0	0.0	20	\$298	\$351	\$174	\$177	0.6	2,369
TOTALS			14,661	5.1	18	\$2,749	\$31,630	\$4,857	\$26,773	9.7	16,890

* - All incentives presented in this table are included as placeholders for planning purposes and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

All Evaluated ECMs

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		588	0.2	0	\$98	\$329	\$90	\$239	2.4	578
ECM 1	Retrofit Fixtures with LED Lamps	588	0.2	0	\$98	\$329	\$90	\$239	2.4	578
Lighting Control Measures		9,334	2.8	-2	\$1,551	\$11,565	\$3,710	\$7,855	5.1	9,171
ECM 2	Install Occupancy Sensor Lighting Controls	6,339	2.3	-1	\$1,053	\$8,640	\$1,120	\$7,520	7.1	6,228
ECM 3	Install High/Low Lighting Controls	2,995	0.4	-1	\$498	\$2,925	\$2,590	\$335	0.7	2,942
Variable Frequency Drive (VFD) Measures		4,058	1.3	0	\$687	\$6,692	\$200	\$6,492	9.5	4,086
ECM 4	Install Boiler Draft Fan VFDs	4,058	1.3	0	\$687	\$6,692	\$200	\$6,492	9.5	4,086
Domestic Water Heating Upgrade		0	0.0	20	\$298	\$351	\$174	\$177	0.6	2,369
ECM 6	Install Low-Flow DHW Devices	0	0.0	20	\$298	\$351	\$174	\$177	0.6	2,369
TOTALS		13,980	4.3	18	\$2,633	\$18,937	\$4,174	\$14,763	5.6	16,204

* - All incentives presented in this table are included as placeholders for planning purposes and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Cost Effective ECMs

4.1 Lighting

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		588	0.2	0	\$98	\$329	\$90	\$239	2.4	578
ECM 1	Retrofit Fixtures with LED Lamps	588	0.2	0	\$98	\$329	\$90	\$239	2.4	578

When considering lighting upgrades, we suggest using a comprehensive design approach that simultaneously upgrades lighting fixtures and controls to maximize energy savings and improve occupant lighting. Comprehensive design will also consider appropriate lighting levels for different space types to make sure that the right amount of light is delivered where needed. If conversion to LED light sources is proposed, we suggest converting all of a specific lighting type (e.g., linear fluorescent) to LED lamps to minimize the number of lamp types in use at the facility, which should help reduce future maintenance costs.

ECM 1: Retrofit Fixtures with LED Lamps

Replace fluorescent with LED lamps. Many LED tubes are direct replacements for existing fluorescent tubes and can be installed while leaving the fluorescent fixture ballast in place. LED lamps can be used in existing fixtures as a direct replacement for most other lighting technologies. Be sure to specify replacement lamps that are compatible with existing dimming controls, where applicable. In some circumstances, you may need to upgrade your dimming system for optimum performance.

This measure saves energy by installing LEDs, which use less power than other lighting technologies yet provide equivalent lighting output for the space. Maintenance savings may also be available, as longer-lasting LEDs lamps will not need to be replaced as often as the existing lamps.

Affected Building Areas: mechanical 1

4.2 Lighting Controls

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures		9,334	2.8	-2	\$1,551	\$11,565	\$3,710	\$7,855	5.1	9,171
ECM 2	Install Occupancy Sensor Lighting Controls	6,339	2.3	-1	\$1,053	\$8,640	\$1,120	\$7,520	7.1	6,228
ECM 3	Install High/Low Lighting Controls	2,995	0.4	-1	\$498	\$2,925	\$2,590	\$335	0.7	2,942

Lighting controls reduce energy use by turning off or lowering lighting fixture power levels when not in use. A comprehensive approach to lighting design should upgrade the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

ECM 2: Install Occupancy Sensor Lighting Controls

Install occupancy sensors to control lighting fixtures in areas that are frequently unoccupied, even for short periods. For most spaces, we recommend that lighting controls use dual technology sensors, which reduce the possibility of lights turning off unexpectedly.

Occupancy sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Most occupancy sensor lighting controls allow users to manually turn fixtures on/off, as needed. Some controls can also provide dimming options.

Occupancy sensors can be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are best suited to single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in large spaces, locations without local switching, and where wall switches are not in the line-of-sight of the main work area.

This measure provides energy savings by reducing the lighting operating hours.

Affected Building Areas: classrooms, faculty room, gymnasium, and media center

ECM 3: Install High/Low Lighting Controls

Install occupancy sensors to provide dual level lighting control for lighting fixtures in spaces that are infrequently occupied but may require some level of continuous lighting for safety or security reasons.

Lighting fixtures with these controls operate at default low levels when the area is unoccupied to provide minimal lighting to meet security or safety code requirements for egress. Sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Fixtures automatically switch back to low level after a predefined period of vacancy. In parking lots and parking garages with significant ambient lighting, this control can sometimes be combined with photocell controls to turn the lights off when there is sufficient daylight.

The controller lowers the light level by dimming the fixture output. Therefore, the controlled fixtures need to have a dimmable ballast or driver. This will need to be considered when selecting retrofit lamps and bulbs for the areas proposed for high/low control.

For this type of measure the occupancy sensors will generally be ceiling or fixture mounted. Sufficient sensor coverage must be provided to ensure that lights turn on in each area as occupants approach the area.

This measure provides energy savings by reducing the light fixture power draw when reduced light output is appropriate.

Affected Building Areas: corridors

4.3 Variable Frequency Drives (VFD)

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Variable Frequency Drive (VFD) Measures		4,058	1.3	0	\$687	\$6,692	\$200	\$6,492	9.5	4,086
ECM 4	Install Boiler Draft Fan VFDs	4,058	1.3	0	\$687	\$6,692	\$200	\$6,492	9.5	4,086

Variable frequency drives control motors for fans, pumps, and process equipment based on the actual output required of the driven equipment. Energy savings result from more efficient control of motor energy usage when equipment operates at partial load. The magnitude of energy savings depends on the estimated amount of time that the motor would operate at partial load. For equipment with proposed VFDs, we have included replacing the controlled motor with a new inverter duty rated motor to conservatively account for the cost of an inverter duty rated motor.

ECM 4: Install Boiler Draft Fan VFDs

Replace existing volume control devices on boiler draft fans, such as inlet vanes or dampers, with VFDs. Inlet vanes or dampers are an inefficient means of controlling the air volume compared to VFDs. The existing volume control device will be removed or permanently disabled, and the control signal will be redirected to the VFD to determine proper fan motor speed.

Energy savings result from reducing the draft fan speed (and power) when conditions allow for reduced combustion air flow.

Additional maintenance savings may result from this measure. VFDs are solid state electronic devices, which generally require less maintenance than mechanical air volume control devices.

4.4 Unitary HVAC

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Unitary HVAC Measures		681	0.9	0	\$115	\$12,693	\$683	\$12,010	104.2	686
ECM 5	Install High Efficiency Air Conditioning Units	681	0.9	0	\$115	\$12,693	\$683	\$12,010	104.2	686

Replacing the unitary HVAC units has a long payback period and may not be justifiable based simply on energy considerations. However, most of the units are nearing or have reached the end of their normal useful life. Typically, the marginal cost of purchasing a high efficiency unit can be justified by the marginal savings from the improved efficiency. When the split-system AC units are eventually replaced, consider purchasing equipment that exceeds the minimum efficiency required by building codes.

ECM 5: Install High Efficiency Air Conditioning Units

We evaluated replacing the standard efficiency packaged air conditioning units with high efficiency packaged air conditioning units. Some of the replacement units will incorporate efficient gas furnaces. The magnitude of energy savings for this measure depends on the relative efficiency of the older unit versus the new high efficiency unit, the average cooling and heating load, and the estimated annual operating hours.

Affected Units: 3.0-ton and 3.5-ton split-system AC units

4.5 Domestic Water Heating

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Domestic Water Heating Upgrade		0	0.0	20	\$298	\$351	\$174	\$177	0.6	2,369
ECM 6	Install Low-Flow DHW Devices	0	0.0	20	\$298	\$351	\$174	\$177	0.6	2,369

ECM 6: Install Low-Flow DHW Devices

Install low-flow devices to reduce overall hot water demand. The following low-flow devices are recommended to reduce hot water usage:

Device	Flow Rate
Faucet aerators (lavatory)	0.5 gpm
Faucet aerator (kitchen)	1.5 gpm
Showerhead	2.0 gpm
Pre-rinse spray valve (kitchen)	1.28 gpm

Low-flow devices reduce the overall water flow from the fixture, while still providing adequate pressure for washing. Additional cost savings may result from reduced water usage.

5 ENERGY EFFICIENT BEST PRACTICES

A whole building maintenance plan will extend equipment life; improve occupant comfort, health, and safety; and reduce energy and maintenance costs.

Operation and maintenance (O&M) plans enhance the operational efficiency of HVAC and other energy intensive systems and could save 5%–20% of the energy usage in your building without substantial capital investment. A successful plan includes your records of energy usage trends and costs, building equipment lists, current maintenance practices, and planned capital upgrades, and it incorporates your ideas for improved building operation. Your plan will address goals for energy-efficient operation, provide detail on how to reach the goals, and outline procedures for measuring and reporting whether goals have been achieved.

You may already be doing some of these things—see our list below for potential additions to your maintenance plan. Be sure to consult with qualified equipment specialists for details on proper maintenance and system operation.

Energy Tracking with ENERGY STAR Portfolio Manager



You've heard it before—you cannot manage what you do not measure. ENERGY STAR Portfolio Manager is an online tool that you can use to measure and track energy and water consumption, as well as greenhouse gas emissions⁵. Your account has already been established. Now you can continue to keep tabs on your energy performance every month.

Doors and Windows

Close exterior doors and windows in heated and cooled areas. Leaving doors and windows open leads to a loss of heat during the winter and chilled air during the summer. Reducing air changes per hour can lead to increased occupant comfort as well as heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

Lighting Maintenance



- Clean lamps, reflectors and lenses of dirt, dust, oil, and smoke buildup every six to twelve months. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust. Together, this can reduce total light output by up to 60% while still drawing full power.
- In addition to routine cleaning, developing a maintenance schedule can ensure that maintenance is performed regularly, and it can reduce the overall cost of fixture re-lamping and re-ballasting. Group re-lamping and re-ballasting maintains lighting levels and minimizes the number of site visits by a lighting technician or contractor, decreasing the overall cost of maintenance.

⁵ <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/use-portfolio-manager>.

Lighting Controls

As part of a lighting maintenance schedule, test lighting controls to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight and photocell sensors, maintenance involves cleaning sensor lenses and confirming that setpoints and sensitivity are configured properly. Adjust exterior lighting time clock controls seasonally as needed to match your lighting requirements.

Motor Controls

Electric motors often run unnecessarily, and this is an overlooked opportunity to save energy. These motors should be identified and turned off when appropriate. For example, exhaust fans often run unnecessarily when ventilation requirements are already met. Whenever possible, use automatic devices such as twist timers or occupancy sensors to turn off motors when they are not needed.

Motor Maintenance

Motors have many moving parts. As these parts degrade over time, the efficiency of the motor is reduced. Routine maintenance prevents damage to motor components. Routine maintenance should include cleaning surfaces and ventilation openings on motors to prevent overheating, lubricating moving parts to reduce friction, inspecting belts and pulleys for wear and to ensure they are at proper alignment and tension, and cleaning and lubricating bearings. Consult a licensed technician to assess these and other motor maintenance strategies.

Fans to Reduce Cooling Load

Install ceiling fans to supplement your cooling system. Thermostat settings can typically be increased by 4°F with no change in overall occupant comfort due to the wind chill effect of moving air.

Thermostat Schedules and Temperature Resets



Use thermostat setback temperatures and schedules to reduce heating and cooling energy use during periods of low or no occupancy. Thermostats should be programmed for a setback of 5°F-10°F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

AC System Evaporator/Condenser Coil Cleaning

Dirty evaporator and condenser coils restrict air flow and restrict heat transfer. This increases the loads on the evaporator and condenser fan and decreases overall cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

Boiler Maintenance

Many boiler problems develop slowly over time, so regular inspection and maintenance is essential to keeping the heating system running efficiently and preventing expensive repairs. Annual tune-ups should include a combustion analysis to analyze the exhaust from the boilers and to ensure the boiler is operating safely and efficiently. Boilers should be cleaned according to the manufacturer's instructions to remove soot and scale from the boiler tubes to improve heat transfer.

Label HVAC Equipment

For improved coordination in maintenance practices, we recommend labeling or re-labeling the site HVAC equipment. Maintain continuity in labeling by following labeling conventions as indicated in the facility drawings or EMS building equipment list. Use weatherproof or heatproof labeling or stickers for permanence, but do not cover over original equipment nameplates, which should be kept clean and readable whenever possible. Besides equipment, label piping for service and direction of flow when possible. Ideally, maintain a log of HVAC equipment, including nameplate information, asset tag designation, areas served, installation year, service dates, and other pertinent information.

This investment in your equipment will enhance collaboration and communication between your staff and your contracted service providers and may help you with regulatory compliance.

Optimize HVAC Equipment Schedules

Energy management systems (EMS) typically provide advanced controls for building HVAC systems, including chillers, boilers, air handling units, rooftop units and exhaust fans. The EMS monitors and reports operational status, schedules equipment start and stop times, locks out equipment operation based on outside air or space temperature, and often optimizes damper and valve operation based on complex algorithms. These EMS features, when in proper adjustment, can improve comfort for building occupants and save substantial energy.

Know your EMS scheduling capabilities. Regularly monitor HVAC equipment operating schedules and match them to building operating hours in order to eliminate unnecessary equipment operation and save energy. Monitoring should be performed often at sites with frequently changing usage patterns – daily in some cases. We recommend using the *optimal start* feature of the EMS (if available) to optimize the building warmup sequence. Most EMS scheduling programs provide for holiday schedules, which can be used during reduced use or shutdown periods. Finally, many systems are equipped with a one-time override function, which can be used to provide additional space conditioning due to a one-time, special event. When available this override feature should be used rather than changing the base operating schedule.


Water Heater Maintenance

The lower the supply water temperature that is used for hand washing sinks, the less energy is needed to heat the water. Reducing the temperature results in energy savings and the change is often unnoticeable to users. Be sure to review the domestic water temperature requirements for sterilizers and dishwashers as you investigate reducing the supply water temperature.

Also, preventative maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. At least once a year, follow manufacturer instructions to drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Annual checks should include checks for:

- Leaks or heavy corrosion on the pipes and valves.
- Corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot, or charred metal, this is a sign you may be having combustion issues, and you should have the unit serviced by a professional.
- For electric water heaters, look for signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank.
- For water heaters more than three years old, have a technician inspect the sacrificial anode annually.

Plug Load Controls



Reducing plug loads is a common way to decrease your electrical use. Limiting the energy use of plug loads can include increasing occupant awareness, removing under-used equipment, installing hardware controls, and using software controls. Consider enabling the most aggressive power settings on existing devices or install load sensing or occupancy sensing (advanced) power strips⁶. Your local utility may offer incentives or rebates for this equipment.

Computer Monitor Replacement

ENERGY STAR labeled computer monitors can be up to 25% more efficient than standard monitors. ENERGY STAR rated monitors have power consumption requirements for different operating modes such as on, idle, and sleep.

Computer Power Management Software

Many computers consume power during nights, weekends, and holidays. Screen savers are commonly confused as a power management strategy. This contributes to avoidable, excessive electrical energy consumption. There are innovative power management software packages available that are designed to deliver significant energy saving and provide ongoing tracking measurements. A central power management platform helps enforce energy savings policies as well as identify and eliminate underutilized devices.

Procurement Strategies

Purchasing efficient products reduces energy costs without compromising quality. Consider modifying your procurement policies and language to require ENERGY STAR or WaterSense products where available.

⁶ For additional information refer to “Assessing and Reducing Plug and Process Loads in Office Buildings” <http://www.nrel.gov/docs/fy13osti/54175.pdf>, or “Plug Load Best Practices Guide” <http://www.advancedbuildings.net/plug-load-best-practices-guide-offices>.

6 ON-SITE GENERATION

You don't have to look far in New Jersey to see one of the thousands of solar electric systems providing clean power to homes, businesses, schools, and government buildings. On-site generation includes both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) technologies that generate power to meet all or a portion of the facility's electric energy needs. Also referred to as distributed generation, these systems contribute to greenhouse gas (GHG) emission reductions, demand reductions, and reduced customer electricity purchases, which results in improved electric grid reliability through better use of transmission and distribution systems.


Preliminary screenings were performed to determine if an on-site generation measure could be a cost-effective solution for your facility. Before deciding to install an on-site generation system, we recommend conducting a feasibility study to analyze existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.

6.1 Solar Photovoltaic

Photovoltaic (PV) panels convert sunlight into electricity. Individual panels are combined into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is then connected to the building's electrical distribution system.

A preliminary screening based on the facility's electric demand, size and location of free area, and shading elements shows that the facility has high potential for installing a PV array.

The graphic below displays the results of the PV potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.



Potential	High	
System Potential	161	kW DC STC
Electric Generation	121,144	kWh/yr
Displaced Cost	\$20,500	/yr
Installed Cost	\$418,600	

Photovoltaic Screening

Successor Solar Incentive Program (SuSI)

The SuSI program replaces the SREC Registration Program (SRP) and the Transition Incentive (TI) program. The SuSI program is used to register and certify solar projects in New Jersey. Rebates are not available for solar projects. Solar projects may qualify to earn SREC- IIs (Solar Renewable Energy Certificates-II), however, the project owners *must* register their solar projects prior to the start of construction to establish the project's eligibility.

Get more information about solar power in New Jersey or find a qualified solar installer who can help you decide if solar is right for your building:

Successor Solar Incentive Program (SuSI): <https://www.njcleanenergy.com/renewable-energy/programs/susi-program>

- **Basic Info on Solar PV in NJ:** www.njcleanenergy.com/whysolar
- **NJ Solar Market FAQs:** www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs.
- **Approved Solar Installers in the NJ Market:** www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1

6.2 Combined Heat and Power

Combined heat and power (CHP) generates electricity at the facility and puts waste heat energy to good use. Common types of CHP systems are reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines.


CHP systems typically produce a portion of the electric power used on-site, with the balance of electric power needs supplied by the local utility company. The heat is used to supplement (or replace) existing boilers and provide space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for space cooling.

The key criteria used for screening is the amount of time that the CHP system would operate at full load and the facility's ability to use the recovered heat. Facilities with a continuous need for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has no potential for installing a cost-effective CHP system.

Based on a preliminary analysis, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation. The lack of gas service, low or infrequent thermal load, and lack of space for siting the equipment are the most significant factors contributing to the lack of CHP potential.

The graphic below displays the results of the CHP potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.



Combined Heat and Power Screening

Find a qualified firm that specializes in commercial CHP cost assessment and installation: http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/

7 ELECTRIC VEHICLES

All electric vehicles (EVs) have an electric motor instead of an internal combustion engine. EVs function by plugging into a charge point, taking electricity from the grid, and then storing it in rechargeable batteries. Although electricity production may contribute to air pollution, the U.S. EPA categorizes all electric vehicles as zero-emission vehicles because they produce no direct exhaust or tailpipe emissions.

EVs are typically more expensive than similar conventional and hybrid vehicles, although some cost can be recovered through fuel savings, federal tax credit, or state incentives.

7.1 EV Charging

EV charging stations provide a means for electric vehicle operators to recharge their batteries at a facility. While many EV drivers charge at home, others do not have access to regular home charging, and the ability to charge at work or in public locations is critical to making EVs practical for more drivers. Charging can also be used for electric fleet vehicles, which can reduce fuel and maintenance costs for fleets that replace gas or diesel vehicles with EVs.

EV charging comes in three main types. For this assessment, the screening considers addition of Level 2 charging, which is most common at workplaces and other public locations. Depending on the site type and usage, other levels of charging power may be more appropriate.


The preliminary assessment of EV charging at the facility shows that there is medium potential for adding EV chargers to the facility's parking, based on potential costs of installation and other site factors.

The primary costs associated with installing EV charging are the charger hardware and the cost to extend power from the facility to parking spaces. This may include upgrades to electric panels to serve increased loads.


The type and size of the parking area impact the costs and feasibility of adding EV charging. Parking structure installations can be less costly than surface lot installations as power may be readily available, and equipment and wiring can be surface mounted. Parking lot installations often require trenching through concrete or asphalt surface. Large parking areas provide greater flexibility in charger siting than smaller lots.

The location and capacity of facility electric panels also impact charger installation costs. A Level 2 charger generally requires a dedicated 208-240V, 40 Amp circuit. The electric panel nearest the planned installation may not have available capacity and may need to be upgraded to serve new EV charging loads. Alternatively, chargers could be powered from a more distant panel. The distance from the panel to the location of charging stations ties directly to costs, as conduits, cables, and potential trenching costs all increase on a per-foot basis. The more charging stations planned, the more likely it is that additional electrical capacity will be needed.

Other factors to consider when planning for EV charging at a facility include who the intended users are, how long they park vehicles at the site, and whether they will need to pay for the electricity they use.



The graphic below displays the results of the EV charging assessment conducted as part of this audit. The position of each slider indicates the impact each factor has on the feasibility of installing EV charging at the site.



EV Charger Screening

Electric Vehicle Programs Available

New Jersey is leading the way on electric vehicle (EV) adoption on the East Coast. There are several programs designed to encourage EV adoption in New Jersey, which is crucial to reaching a 100% clean energy future.

NJCEP offers a variety of EV programs for vehicles, charging stations, and fleets. Certain EV charging stations that receive electric utility service from Atlantic City Electric Company (ACE), Public Service Electric and Gas Company (PSE&G) or Jersey Central Power and Light (JCP&L), may be eligible for additional electric vehicle charging incentives directly from the utility. Projects may be eligible for both the incentives offered by this BPU program and incentives offered by ACE, PSE&G or JCP&L, up to 90% of the combined charger purchase and installation costs. Please check ACE, PSE&G or JCP&L program eligibility requirements before purchasing EV charging equipment, as additional conditions on types of eligible chargers may apply for utility incentives.

EV Charging incentive information is available from Atlantic City Electric, PSE&G and JCP&L. For more information and to keep up to date on all EV programs please visit <https://www.njcleanenergy.com/commercial-industrial/programs/electric-vehicle-programs>

8 PROJECT FUNDING AND INCENTIVES

Ready to improve your building's performance? New Jersey's Clean Energy Programs and Utility Energy Efficiency Programs can help. Pick the program that works best for you. This section provides an overview of currently available incentive programs in New Jersey.

NJBPU and NJCEP Administered Programs



- New Construction (residential, commercial, industrial, government)
 - Large Energy Users
 - Energy Savings Improvement Program (financing)
 - State Facilities Initiative*
 - Local Government Energy Audits
 - Combined Heat & Power & Fuel Cells
- *State facilities are also eligible for utility programs

Utility Administered Programs



- Existing buildings (residential, commercial, industrial, government)
- Efficient Products
 - Lighting & Marketplace
 - HVAC
 - Appliance Rebates
 - Appliance Recycling

8.1 New Jersey's Clean Energy Program

Save money while saving the planet! New Jersey's Clean Energy Program is a statewide program that offers incentives, programs, and services that benefit New Jersey residents, businesses, educational, non-profit, and government entities to help them save energy, money, and the environment.

Large Energy Users

The Large Energy Users Program (LEUP) is designed to foster self-directed investment in energy projects. This program is offered to New Jersey's largest energy customers. To qualify entities must have incurred at least \$5 million in total energy costs in the prior fiscal year.

Incentives

Incentives are based on the specifications below. The maximum incentive per entity is the lesser of:

- \$4 million
- 75% of the total project(s) cost
- 90% of total NJCEP fund contribution in previous year
- \$0.33 per projected kWh saved; \$3.75 per projected Therm saved annually

How to Participate

To participate in LEUP, you will first need submit an enrollment application. This program requires all qualified and approved applicants to submit an energy plan that outlines the proposed energy efficiency work for review and approval. Applicants may submit a Draft Energy Efficiency Plan (DEEP), or a Final Energy Efficiency Plan (FEED). Once the FEED is approved, the proposed work can begin.

Detailed program descriptions, instructions for applying, and applications can be found at <http://www.njcleanenergy.com/LEUP>.

Combined Heat and Power

The Combined Heat & Power (CHP) program provides incentives for eligible CHP or waste heat to power (WHP) projects. Eligible CHP or WHP projects must achieve an annual system efficiency of at least 65% (lower heating value, or LHV), based on total energy input and total utilized energy output. Mechanical energy may be included in the efficiency evaluation. ≤

Incentives⁷

Eligible Technology	Size (Installed Rated Capacity)	Incentive (\$/Watt) ⁵	% of Total Cost Cap per Project	\$ Cap per Project
CHPs powered by non-renewable or renewable fuel source, or a combination: ⁴ - Gas Internal Combustion Engine - Gas Combustion Turbine - Microturbine Fuel Cells ≥60%	≤500 kW ¹	\$2.00	30-40% ²	\$2 million
	>500 kW - 1 MW ¹	\$1.00		
	> 1 MW - 3 MW ¹	\$0.55	30%	\$3 million
	>3 MW ¹	\$0.35		
Fuel Cells ≥40%	Same as above ¹	Applicable amount above	30%	\$1 million
Waste Heat to Power (WHP) ³ Powered by non-renewable fuel source. Heat recovery or other mechanical recovery from existing equipment utilizing new electric generation equipment (e.g. steam turbine)	≤1MW ¹	\$1.00	30%	\$2 million
	> 1MW ¹	\$.50	30%	\$3 million

7

¹ Incentives are tiered, which means the incentive levels vary based upon the installed rated capacity, as listed in the chart above. For example, a 4 MW CHP system would receive \$2.00/watt for the first 500 kW, \$1.00/watt for the second 500 kW, \$0.55/watt for the next 2 MW and \$0.35/watt for the last 1 MW (up to the caps listed).

² The maximum incentive will be limited to 30% of total project. For CHP projects up to 1 MW, this cap will be increased to 40% where a cooling application is used or included with the CHP system (e.g. absorption chiller).

³ Projects will be eligible for incentives shown above, not to exceed the lesser of % of total project cost per project cap or maximum \$ per project cap. Projects installing CHP or FC with WHP will be eligible for incentive shown above, not to exceed the lesser caps of the CHP or FC incentive. Minimum efficiency will be calculated based on annual total electricity generated, utilized waste heat at the host site (i.e. not lost/rejected), and energy input.

⁴ Systems fueled by a Class 1 Renewable Fuel Source, as defined by N.J.A.C. 14:8-2.5, are eligible for a 30% incentive bonus. If the fuel is mixed, the bonus will be prorated accordingly. For example, if the mix is 60/40 (60% being a Class 1 renewable), the bonus will be 18%. This bonus will be included in the final performance incentive payment, based on system performance and fuel mix consumption data. Total incentive, inclusive of bonus, shall not exceed above stipulated caps.

⁵ CHP-FC systems located at Critical Facility and incorporating blackstart and islanding technology are eligible for a 25% incentive bonus. This bonus incentive will be paid with the second/Installation incentive payment. Total incentive, inclusive of bonus, shall not exceed above stipulated caps.



How to Participate

You will work with a qualified developer or consulting firm to complete the CHP application. Once the application is approved the project can be installed. Information about the CHP program can be found at <http://www.njcleanenergy.com/CHP>.

Successor Solar Incentive Program (SuSI)

The SuSI program replaces the SREC Registration Program (SRP) and the Transition Incentive (TI) program. The program is used to register and certify solar projects in New Jersey. Rebates are not available for solar projects, but owners of solar projects must register their projects prior to the start of construction to establish the project’s eligibility to earn SREC-IIs (Solar Renewable Energy Certificates-II). SuSI consists of two sub-programs. The Administratively Determined Incentive (ADI) Program and the Competitive Solar Incentive (CSI) Program.

Administratively Determined Incentive (ADI) Program

The ADI Program provides administratively set incentives for net metered residential projects, net metered non-residential projects 5 MW or less, and all community solar projects.

After the registration is accepted, construction is complete, and a complete final as-built packet has been submitted, the project is issued a New Jersey certification number, which enables it to generate New Jersey SREC- IIs.

Market Segments	Size MW dc	Incentive Value (\$/SREC II)	Public Entities Incentive Value - \$20 Adder (\$/SRECII)
Net Metered Residential	All types and sizes	\$90	N/A
Small Net Metered Non-Residential located on Rooftop, Carport, Canopy and Floating Solar	Projects smaller than 1 MW	\$100	\$120
Large Net Metered Non-Residential located on Rooftop, Carport, Canopy and Floating Solar	Projects 1 MW to 5 MW	\$90	\$110
Small Net Metered Non-Residential Ground Mount	Projects smaller than 1 MW	\$85	\$105
Large Net Metered Non-Residential Ground Mount	Projects 1 MW to 5 MW	\$80	\$100
LMI Community Solar	Up to 5 MW	\$90	N/A
Non-LMI Community Solar	Up to 5 MW	\$70	N/A
Interim Subsection (t)	All types and sizes	\$100	N/A

Eligible projects may generate SREC-IIs for 15 years following the commencement of commercial operations which is defined as permission to operate (PTO) from the Electric Distribution Company. After 15 years, projects may be eligible for a NJ Class I REC.

SREC-IIs will be purchased monthly by the SREC-II Program Administrator who will allocate the SREC-IIs to the Load Serving Entities (BGS Providers and Third-Party Suppliers) annually based on their market share of retail electricity sold during the relevant Energy Year.

The ADI Program online portal is now open to new registrations.

Competitive Solar Incentive (CSI) Program

The CSI Program opened on April 15, 2023, and will serve as the permanent program within the SuSI Program providing incentives to larger solar facilities. The CSI Program is open to qualifying grid supply solar facilities, non-residential net metered solar installations with a capacity greater than five (5) megawatts (“MW”), and to eligible grid supply solar facilities installed in combination with energy storage.

CSI eligible facilities will only be allowed to register in the CSI program upon award of a bid pursuant to N.J.A.C. 14:8-11.10.

The CSI program structure has separate categories, or tranches, to ensure that a range of solar project types, including those on preferred sites, are able to participate despite potentially different project cost profiles. The Board has approved four tranches for grid supply and large net metered solar and an additional fifth tranche for storage in combination with grid supply solar. The following table lists procurement targets for the first solicitation:

Tranche	Project Type	MW (dc) Targets
Tranche 1.	Basic Grid Supply	140
Tranche 2.	Grid Supply on the Built Environment	80
Tranche 3.	Grid Supply on Contaminated Sites and Landfills	40
Tranche 4.	Net Metered Non- Residential	40
Tranche 5.	*Storage Paired with Grid	160 MWh

*The storage tranche of 160 MWh corresponds to a 4-hour storage pairing of 40 MW of solar

Solar projects help the State of New Jersey reach renewable energy goals outlined in the state's Energy Master Plan.

If you are considering installing solar on your building, visit the following link for more information: <https://njcleanenergy.com/renewable-energy/programs/susi-program>

Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) serves New Jersey's government agencies by financing energy projects. An ESIP is a type of performance contract, whereby school districts, counties, municipalities, housing authorities, and other public and state entities enter contracts to help finance building energy upgrades. Annual payments are lower than the savings projected from the energy conservation measures (ECMs), ensuring that ESIP projects are cash flow positive for the life of the contract.

ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs described above can also be used to help further reduce the total project cost of eligible measures.

How to Participate

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an energy services company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is used for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the energy savings plan can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Carefully consider all alternatives to develop an approach that best meets your needs. A detailed program descriptions and application can be found at www.njcleanenergy.com/ESIP.

ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you can use NJCEP incentive programs to help further reduce costs when developing the energy savings plan. Refer to the ESIP guidelines at the link above for further information and guidance on next steps.

Demand Response (DR) Energy Aggregator

Demand Response Energy Aggregator is a program designed to reduce the electric load when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Grid operators call upon curtailment service providers and commercial facilities to reduce electric usage during times of peak demand, making the grid more reliable and reducing transmission costs for all ratepayers. Curtailment service providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary, and participants receive payments whether or not their facility is called upon to curtail its electric usage.

Typically, an electric customer must be capable of reducing their electric demand, within minutes, by at least 100 kW or more in order to participate in a DR program. Customers with greater capability to quickly curtail their demand during peak hours receive higher payments. Customers with back-up generators on site may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in DR programs often find it to be a valuable source of revenue for their facility, because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature setpoints on thermostats (so that air conditioning units run less frequently) or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a DR activity in most situations.

The first step toward participation in a DR program is to contact a curtailment service provider. A list of these providers is available on the website of the independent system operator, PJM, and it includes contact information for each company, as well as the states where they have active business⁸. PJM also posts training materials for program members interested in specific rules and requirements regarding DR activity along with a variety of other DR program information⁹.

Curtailment service providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities, and they may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

⁸ <http://www.pjm.com/markets-and-operations/demand-response.aspx>.

⁹ <http://www.pjm.com/training/training-events.aspx>.

8.2 Utility Energy Efficiency Programs

The Clean Energy Act, signed into law by Governor Murphy in 2018, requires New Jersey's investor-owned gas and electric utilities to reduce their customers' use by set percentages over time. To help reach these targets the New Jersey Board of Public Utilities approved a comprehensive suite of energy efficiency programs to be run by the utility companies.

Prescriptive and Custom

The Prescriptive and Custom rebate program through your utility provider offers incentives for installing prescriptive and custom energy efficiency measures at your facility. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades. This program serves most common equipment types and sizes.

Equipment Examples

Lighting

Lighting Controls

HVAC Equipment

Refrigeration

Gas Heating

Gas Cooling

Commercial Kitchen Equipment

Food Service Equipment

Variable Frequency Drives

Electronically Commutate Motors

Variable Frequency Drives

Plug Loads Controls

Washers and Dryers

Agricultural

Water Heating

The Prescriptive program provides fixed incentives for specific energy efficiency measures. Prescriptive incentives vary by equipment type. The Custom program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentives.

Direct Install

Direct Install is a turnkey program available to existing small to medium-sized facilities with an average peak electric demand that does not exceed 200 kW or less over the recent 12-month period. You work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives, and controls.

Incentives

The program pays up to 70% of the total installed cost of eligible measures.

How to Participate

To participate in Direct Install, you will work with a participating contractor. The contractor will be paid the measure incentives directly by the program, which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the Direct Install program, subject to program rules and eligibility, while the remaining percent of the cost is paid to the contractor by the customer.


Engineered Solutions

The Engineered Solutions Program provides tailored energy-efficiency assistance and services to municipalities, universities, schools, hospitals, and healthcare facilities (MUSH), non-profit entities, and multifamily buildings. Customers receive expert guided services, including investment-grade energy auditing, engineering design, installation assistance, construction administration, commissioning, and measurement and verification (M&V) services to support the implementation of cost-effective and comprehensive efficiency projects. Engineered Solutions is generally a good option for medium to large sized facilities with a peak demand over 200 kW looking to implement as many measures as possible under a single project to achieve deep energy savings. Engineered Solutions has an added benefit of addressing measures that may not qualify for other programs. Many facilities pursuing an Energy Savings Improvement Program loan also use this program. Incentives for this program are based on project scope and energy savings achieved.

For more information on any of these programs, contact your local utility provider or visit <https://www.njcleanenergy.com/transition>.

9 PROJECT DEVELOPMENT

Energy conservation measures (ECMs) have been identified for your site, and their energy and economic analyses are provided within this LGEA report. Note that some of the identified projects may be mutually exclusive, such as replacing equipment versus upgrading motors or controls. The next steps with project development are to set goals and create a comprehensive project plan. The graphic below provides an overview of the process flow for a typical energy efficiency or renewable energy project. We recommend implementing as many ECMs as possible prior to undertaking a feasibility study for a renewable project. The cyclical nature of this process flow demonstrates the ongoing work required to continually improve building energy efficiency over time. If your building(s) scope of work is relatively simple to implement or small in scope, the measurement and verification (M&V) step may not be required. It should be noted through a typical project cycle, there will be changes in costs based on specific scopes of work, contractor selections, design considerations, construction, etc. The estimated costs provided throughout this LGEA report demonstrate the unburdened turn-key material and labor cost only. There will be contingencies and additional costs at the time of implementation. We recommend comprehensive project planning that includes the review of multiple bids for project work, incorporates potential operations and maintenance (O&M) cost savings, and maximizes your incentive potential.



Project Development Cycle

10 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

10.1 Retail Electric Supply Options

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. Though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third-party supplier, consider shopping for a reduced rate from third-party electric suppliers. If your facility already buys electricity from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party electric suppliers is available at the NJBPU website¹⁰.

10.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey is also deregulated. Most customers that remain with the utility for natural gas service pay rates that are market based and fluctuate monthly. The utility provides basic gas supply service to customers who choose not to buy from a third-party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier typically depends on whether a customer prefers budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third-party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility does not already purchase natural gas from a third-party supplier, consider shopping for a reduced rate from third-party natural gas suppliers. If your facility already purchases natural gas from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party natural gas suppliers is available at the NJBPU website¹¹.

¹⁰ www.state.nj.us/bpu/commercial/shopping.html

¹¹ www.state.nj.us/bpu/commercial/shopping.html

APPENDIX A: EQUIPMENT INVENTORY & RECOMMENDATIONS

Lighting Inventory & Recommendations

Location	Existing Conditions						Proposed Conditions							Energy Impact & Financial Analysis							
	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
1	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,800	2	None	Yes	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Occupancy Sensor	10	1,242	0.0	6	0	\$1	\$0	\$0	0.0
1	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
2	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,800	2	None	Yes	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Occupancy Sensor	10	1,242	0.0	6	0	\$1	\$0	\$0	0.0
2	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
3	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,800	2	None	Yes	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Occupancy Sensor	10	1,242	0.0	6	0	\$1	\$0	\$0	0.0
3	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
4	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,800	2	None	Yes	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Occupancy Sensor	10	1,242	0.0	6	0	\$1	\$0	\$0	0.0
4	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
5	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,800	2	None	Yes	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Occupancy Sensor	10	1,242	0.0	6	0	\$1	\$0	\$0	0.0
5	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
6	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,800	2	None	Yes	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Occupancy Sensor	10	1,242	0.0	6	0	\$1	\$0	\$0	0.0
6	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
7	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,800	2	None	Yes	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Occupancy Sensor	10	1,242	0.0	6	0	\$1	\$0	\$0	0.0
7	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
8	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,800	2	None	Yes	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Occupancy Sensor	10	1,242	0.0	6	0	\$1	\$0	\$0	0.0
8	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
10	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,800	2	None	Yes	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Occupancy Sensor	10	1,242	0.0	6	0	\$1	\$0	\$0	0.0
10	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
12	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,800	2	None	Yes	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Occupancy Sensor	10	1,242	0.0	6	0	\$1	\$0	\$0	0.0
12	6	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.0	107	0	\$18	\$270	\$35	13.2
13	2	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,800	2	None	Yes	2	LED Lamps: (1) 10W A19 Screw-In Lamp	Occupancy Sensor	10	1,242	0.0	12	0	\$2	\$0	\$0	0.0
13	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
14	2	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,800	2	None	Yes	2	LED Lamps: (1) 10W A19 Screw-In Lamp	Occupancy Sensor	10	1,242	0.0	12	0	\$2	\$0	\$0	0.0
14	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
15	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6

Location	Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis								
	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
16	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
17	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
18	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
19	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
20	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
21	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
22	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
23	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
24	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
8A	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.0	71	0	\$12	\$270	\$35	19.9
8B	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.0	53	0	\$9	\$270	\$35	26.5
8C	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,800	0.0	0	0	\$0	\$0	\$0	0.0
9	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,800		None	No	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	1,800	0.0	0	0	\$0	\$0	\$0	0.0
9	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	214	0	\$35	\$270	\$35	6.6
A	6	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	S	35	1,380		None	No	6	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	35	1,380	0.0	0	0	\$0	\$0	\$0	0.0
A	3	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	S	45	1,380		None	No	3	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	45	1,380	0.0	0	0	\$0	\$0	\$0	0.0
A1	2	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	S	35	1,380		None	No	2	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	35	1,380	0.0	0	0	\$0	\$0	\$0	0.0
A1	11	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	S	45	1,380		None	No	11	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	45	1,380	0.0	0	0	\$0	\$0	\$0	0.0
B	2	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	S	35	1,380		None	No	2	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	35	1,380	0.0	0	0	\$0	\$0	\$0	0.0
B	12	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	S	45	1,380		None	No	12	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	45	1,380	0.0	0	0	\$0	\$0	\$0	0.0
B1	3	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	S	35	1,380		None	No	3	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	35	1,380	0.0	0	0	\$0	\$0	\$0	0.0
B1	7	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	S	45	1,380		None	No	7	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	45	1,380	0.0	0	0	\$0	\$0	\$0	0.0
Corridor 1	12	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	12	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Corridor 1	9	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	4,380	3	None	Yes	9	LED Lamps: (1) 10W A19 Screw-In Lamp	High/Low Control	10	3,022	0.0	134	0	\$22	\$450	\$315	6.0
Corridor 1	5	LED - Fixtures: Ambient 2x2 Fixture	Wall Switch	S	35	4,380	3	None	Yes	5	LED - Fixtures: Ambient 2x2 Fixture	High/Low Control	35	3,022	0.0	261	0	\$43	\$225	\$175	1.2

Existing Conditions							Proposed Conditions							Energy Impact & Financial Analysis							
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Corridor 1	60	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	4,380	3	None	Yes	60	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	3,022	0.4	2,599	-1	\$432	\$2,250	\$2,100	0.3
Exterior 1	9	LED Lamps: (1) 10W A19 Screw-In Lamp	Timeclock		10	2,500		None	No	9	LED Lamps: (1) 10W A19 Screw-In Lamp	Timeclock	10	2,500	0.0	0	0	\$0	\$0	\$0	0.0
Exterior 1	10	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Timeclock		15	2,500		None	No	10	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Timeclock	15	2,500	0.0	0	0	\$0	\$0	\$0	0.0
Exterior 1	3	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Timeclock		75	2,500		None	No	3	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Timeclock	75	2,500	0.0	0	0	\$0	\$0	\$0	0.0
Faculty room	1	LED - Fixtures: Ambient 2x4 Fixture	Wall Switch	S	45	1,800	2	None	Yes	1	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	45	1,242	0.0	28	0	\$5	\$0	\$0	0.0
Faculty room	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.0	71	0	\$12	\$270	\$35	19.9
Gymnasium	6	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	6	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Gymnasium	2	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,800	2	None	Yes	2	LED Lamps: (1) 10W A19 Screw-In Lamp	Occupancy Sensor	10	1,242	0.0	12	0	\$2	\$0	\$0	0.0
Gymnasium	27	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	27	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.2	481	0	\$80	\$540	\$70	5.9
Main office	5	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,800	2	None	Yes	5	LED Lamps: (1) 10W A19 Screw-In Lamp	Occupancy Sensor	10	1,242	0.0	31	0	\$5	\$270	\$35	46.1
Main office	15	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	15	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.1	267	0	\$44	\$270	\$35	5.3
Mechanical 1	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Mechanical 1	9	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	1,800	1	Relamp	No	9	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,800	0.2	588	0	\$98	\$329	\$90	2.4
Media center	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,800	2	None	Yes	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Occupancy Sensor	10	1,242	0.0	6	0	\$1	\$0	\$0	0.0
Media center	24	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,800	2	None	Yes	24	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,242	0.2	427	0	\$71	\$540	\$70	6.6
Restroom - Female 1	1	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	S	35	1,380		None	No	1	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	35	1,380	0.0	0	0	\$0	\$0	\$0	0.0
Restroom - Female 1	3	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	S	45	1,380		None	No	3	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	45	1,380	0.0	0	0	\$0	\$0	\$0	0.0
Restroom - Female 2	2	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	S	45	1,380		None	No	2	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	45	1,380	0.0	0	0	\$0	\$0	\$0	0.0
Restroom - Female 3	2	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	S	45	1,380		None	No	2	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	45	1,380	0.0	0	0	\$0	\$0	\$0	0.0
Restroom - Male 1	1	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	S	35	1,380		None	No	1	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	35	1,380	0.0	0	0	\$0	\$0	\$0	0.0
Restroom - Male 1	3	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	S	45	1,380		None	No	3	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	45	1,380	0.0	0	0	\$0	\$0	\$0	0.0
Restroom - Male 1	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	S	29	1,380		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,380	0.0	0	0	\$0	\$0	\$0	0.0
Restroom - Male 2	2	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	S	45	1,380		None	No	2	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	45	1,380	0.0	0	0	\$0	\$0	\$0	0.0
Restroom - Male 3	2	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	S	45	1,380		None	No	2	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	45	1,380	0.0	0	0	\$0	\$0	\$0	0.0
Restroom - Unisex 1	1	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	S	45	1,380		None	No	1	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	45	1,380	0.0	0	0	\$0	\$0	\$0	0.0

Existing Conditions							Proposed Conditions							Energy Impact & Financial Analysis							
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Restroom - Unisex 2	1	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	S	45	1,380		None	No	1	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	45	1,380	0.0	0	0	\$0	\$0	\$0	0.0
Storage 1	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	S	17	1,000		None	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	1,000	0.0	0	0	\$0	\$0	\$0	0.0
Storage 2	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,000		None	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,000	0.0	0	0	\$0	\$0	\$0	0.0
Storage 3	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,000		None	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,000	0.0	0	0	\$0	\$0	\$0	0.0
Storage 4	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,000		None	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,000	0.0	0	0	\$0	\$0	\$0	0.0
Storage 5	2	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,000		None	No	2	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	1,000	0.0	0	0	\$0	\$0	\$0	0.0

Motor Inventory & Recommendations

		Existing Conditions									Proposed Conditions					Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Manufacturer	Model	Remaining Useful Life	Annual Operating Hours	ECM #	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Mechanical 1	Whole building	2	Air Compressor	3.0	82.5%	No	Baldor	M32111-8	W	500		No	82.5%	No		0.0	0	0	\$0	\$0	\$0	0.0
Mechanical 1	Whole building	2	Combustion Air Fan	2.0	80.0%	No	Marathon	5k49NN2180	W	2,600	4	No	85.5%	Yes	2	1.3	4,058	0	\$687	\$6,692	\$200	9.5
Mechanical 1	Whole building	2	Condensate Pump	0.8	76.8%	No	Marathon	P48K2EB7	W	1,800		No	76.8%	No		0.0	0	0	\$0	\$0	\$0	0.0
Exterior 1	Whole building	14	Exhaust Fan	0.5	72.4%	No	Greenheck	G-097-4-VG	W	1,800		No	72.4%	No		0.0	0	0	\$0	\$0	\$0	0.0
Mechanical 1	Whole building	3	Heating Hot Water Pump	0.8	80.4%	No	Marathon	5kc39qn3219gx	W	1,800		No	80.4%	No		0.0	0	0	\$0	\$0	\$0	0.0
Mechanical 1	Whole building	2	Other	0.5	78.2%	No	Unknown	Unknown	W	1,800		No	78.2%	No		0.0	0	0	\$0	\$0	\$0	0.0
Mechanical 1	Whole building	2	Other	0.3	73.4%	No	Unknown	Unknown	W	1,800		No	73.4%	No		0.0	0	0	\$0	\$0	\$0	0.0
Mechanical 1	Whole building	1	Process Blower	4.6	93.6%	No	APCOM	YDK-34W-2	W	1,800		No	93.6%	No		0.0	0	0	\$0	\$0	\$0	0.0
Mechanical 1	Whole building	1	DHW Circulation Pump	0.0	69.5%	No	Taco	007-SF5	W	8,760		No	69.5%	No		0.0	0	0	\$0	\$0	\$0	0.0
Classrooms	Classrooms	46	Supply Fan	0.5	76.2%	No	Various	Various	W	1,800		No	76.2%	No		0.0	0	0	\$0	\$0	\$0	0.0
Exterior 1	Exterior	2	Supply Fan	15.0	80.0%	No	Trane	OAND420D3-D1B400L	W	2,500		No	80.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Interior	Interior	4	Supply Fan	0.5	76.0%	No	Unknown	Unknown	W	2,745		No	76.0%	No		0.0	0	0	\$0	\$0	\$0	0.0

Packaged HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions									Proposed Conditions								Energy Impact & Financial Analysis						
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (MBh)	Cooling Mode Efficiency (SEER/IEER/EER)	Heating Mode Efficiency	Manufacturer	Model	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (MBh)	Cooling Mode Efficiency (SEER/IEER/EER)	Heating Mode Efficiency	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Interior	Storage 3	1	Fan Coil		40.00		1 COP	Mitsubishi	TPEFY0360A140A	W		No						0.0	0	0	\$0	\$0	\$0	0.0	
Exterior	Unknown	1	Split-System	2.00		13.00		York	TCGD24S21S2XA	W		No						0.0	0	0	\$0	\$0	\$0	0.0	
Exterior	Unknown	1	Split-System Air-Source HP	6.00	54.00	16.00	3.7 COP	Trane	TUHYE0723AN40AN	W		No						0.0	0	0	\$0	\$0	\$0	0.0	
Exterior	Unknown	1	Split-System	5.00		13.00		Trane	4TTR6024J1000BA	W		No						0.0	0	0	\$0	\$0	\$0	0.0	
Exterior	Unknown	1	Split-System	3.00	96.00	12.20	0.96 AFUE	Goodman	CXL1911D	B	5	Yes	1	Split-System	3.00	96.00	16.00	0.96 AFUE	0.4	276	0	\$47	\$6,286	\$315	127.8
Exterior	Unknown	1	Split-System	3.00		13.00		Thermal zone	TZAB-336-2N	W		No						0.0	0	0	\$0	\$0	\$0	0.0	
Exterior	Unknown	1	Split-System	3.50		11.50		Goodman	CKL42-12	B	5	Yes	1	Split-System	3.50		16.00		0.5	405	0	\$69	\$6,407	\$368	88.2
Exterior	Unknown	1	Ductless Mini-Split HP	2.00	26.00	9.60	1 COP	Mitsubishi	PUY-A24NHA4	W		No						0.0	0	0	\$0	\$0	\$0	0.0	
Exterior	Media Center	1	Split-System Air-Source HP	16.00	215.00	10.20	3.34 COP	Trane	TUHYE1923AN40AN	W		No						0.0	0	0	\$0	\$0	\$0	0.0	
Exterior	Unknown	1	Package Unit	35.00	480.00	14.00	0.8 AFUE	Trane	OAND420D3-D1B400L	W		No						0.0	0	0	\$0	\$0	\$0	0.0	
Classrooms	Classrooms	24	Window AC	0.50		15.00		Various	Unknown	W		No						0.0	0	0	\$0	\$0	\$0	0.0	

Space Heating Boiler Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis						
		System Quantity	System Type	Output Capacity per Unit (MBh)	Manufacturer	Model	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives
Mechanical 1	Whole building	2	Forced Draft Steam Boiler	3,348	Easco	NB1967	W		No					0.0	0	0	\$0	\$0	\$0	0.0

DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis					
		System Quantity	System Type	Manufacturer	Model	Remaining Useful Life	ECM #	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives
Mechanical 1	Whole building	1	Storage Tank Water Heater (≤ 50 Gal)	AO SMITH	GPVT-50 200	W		No					0.0	0	0	\$0	\$0	\$0	0.0

Low-Flow Device Recommendations

Location	Recommendation Inputs					Energy Impact & Financial Analysis						
	ECM #	Device Quantity	Device Type	Existing Flow Rate (gpm)	Proposed Flow Rate (gpm)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Restrooms	6	46	Faucet Aerator (Lavatory)	2.00	0.50	0.0	0	19	\$283	\$330	\$165	0.6
Kitchen	6	1	Faucet Aerator (Kitchen)	2.00	1.50	0.0	0	0	\$2	\$7	\$2	2.5
Storage	6	2	Faucet Aerator (Lavatory)	2.00	0.50	0.0	0	1	\$12	\$14	\$7	0.6

Cooking Equipment Inventory & Recommendations

Existing Conditions						Proposed Conditions		Energy Impact & Financial Analysis						
Location	Quantity	Equipment Type	Manufacturer	Model	High Efficiency Equipment?	ECM #	Install High Efficiency Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Gymnasium	1	Gas Convection Oven (Half Size)	Unknown	Unknown	No		No	0.0	0	0	\$0	\$0	\$0	0.0

Plug Load Inventory

Existing Conditions						
Location	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?	Manufacturer	Model
Various	2	Coffee Machine	800	No	Various	Various
Various	27	Desktop	1,000	No	Various	Various
Various	4	Microwave	1,500	No	Various	Various
Various	1	Paper Shredder	100	No	Various	Various
Various	2	Printer (Medium/Small)	200	No	Various	Various
Various	5	Printer/Copier (Large)	400	No	Various	Various
Various	31	Projector	150	No	Various	Various
Various	6	Refrigerator (Residential)	800	No	Various	Various
Various	1	Television	150	No	Various	Various
Various	3	Water Cooler	200	No	Various	Various

APPENDIX B: ENERGY STAR STATEMENT OF ENERGY PERFORMANCE

Energy use intensity (EUI) is presented in terms of *site energy* and *source energy*. Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

ENERGY STAR® Statement of Energy Performance

LEARN MORE AT energystar.gov

66

**ENERGY STAR®
Score¹**

Jefferson Elementary School

Primary Property Type: K-12 School
Gross Floor Area (ft²): 47,965
Built: 1954

For Year Ending: March 31, 2023
Date Generated: May 19, 2024

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information		
Property Address Jefferson Elementary School 1210 Boulevard Westfield, New Jersey 07090	Property Owner Westfield Board of Education 302 Elm Street Westfield, NJ 07090 (908) 789-4400	Primary Contact Sean McArthur 302 Elm Street Westfield, NJ 07090 (908) 789-4460 smcarthur@westfieldnj12.org
Property ID: 4163456		

Energy Consumption and Energy Use Intensity (EUI)			
Site EUI 60.6 kBtu/ft ²	Annual Energy by Fuel		National Median Comparison
	Electric - Grid (kBtu)	857,473 (30%)	National Median Site EUI (kBtu/ft ²)
	Natural Gas (kBtu)	2,047,051 (70%)	National Median Source EUI (kBtu/ft ²)
			% Diff from National Median Source EUI
			-16%
Source EUI 94.9 kBtu/ft ²			Annual Emissions
			Total (Location-Based) GHG Emissions (Metric Tons CO ₂ e/year)
			186

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

LP Signature: _____ Date: _____

Licensed Professional

() _____



Professional Engineer or Registered Architect Stamp (if applicable)

APPENDIX C: GLOSSARY

TERM	DEFINITION
Blended Rate	Used to calculate fiscal savings associated with measures. The blended rate is calculated by dividing the amount of your bill by the total energy use. For example, if your bill is \$22,217.22, and you used 266,400 kilowatt-hours, your blended rate is 8.3 cents per kilowatt-hour.
Btu	<i>British thermal unit</i> : a unit of energy equal to the amount of heat required to increase the temperature of one pound of water by one-degree Fahrenheit.
CHP	<i>Combined heat and power</i> . Also referred to as cogeneration.
COP	<i>Coefficient of performance</i> : a measure of efficiency in terms of useful energy delivered divided by total energy input.
Demand Response	Demand response reduces or shifts electricity usage at or among participating buildings/sites during peak energy use periods in response to time-based rates or other forms of financial incentives.
DCV	<i>Demand control ventilation</i> : a control strategy to limit the amount of outside air introduced to the conditioned space based on actual occupancy need.
US DOE	<i>United States Department of Energy</i>
EC Motor	<i>Electronically commutated motor</i>
ECM	<i>Energy conservation measure</i>
EER	<i>Energy efficiency ratio</i> : a measure of efficiency in terms of cooling energy provided divided by electric input.
EUI	<i>Energy Use Intensity</i> : measures energy consumption per square foot and is a standard metric for comparing buildings' energy performance.
Energy Efficiency	Reducing the amount of energy necessary to provide comfort and service to a building/area. Achieved through the installation of new equipment and/or optimizing the operation of energy use systems. Unlike conservation, which involves some reduction of service, energy efficiency provides energy reductions without sacrifice of service.
ENERGY STAR	ENERGY STAR is the government-backed symbol for energy efficiency. The ENERGY STAR program is managed by the EPA.
EPA	<i>United States Environmental Protection Agency</i>
Generation	The process of generating electric power from sources of primary energy (e.g., natural gas, the sun, oil).
GHG	<i>Greenhouse gas</i> gases that are transparent to solar (short-wave) radiation but opaque to long-wave (infrared) radiation, thus preventing long-wave radiant energy from leaving Earth's atmosphere. The net effect is a trapping of absorbed radiation and a tendency to warm the planet's surface.
gpf	<i>Gallons per flush</i>

gpm	<i>Gallon per minute</i>
HID	<i>High intensity discharge</i> : high-output lighting lamps such as high-pressure sodium, metal halide, and mercury vapor.
hp	<i>Horsepower</i>
HPS	<i>High-pressure sodium</i> : a type of HID lamp.
HSPF	<i>Heating seasonal performance factor</i> : a measure of efficiency typically applied to heat pumps. Heating energy provided divided by seasonal energy input.
HVAC	<i>Heating, ventilating, and air conditioning</i>
IHP 2014	US DOE Integral Horsepower rule. The current ruling regarding required electric motor efficiency.
IPLV	<i>Integrated part load value</i> : a measure of the part load efficiency usually applied to chillers.
kBtu	One thousand British thermal units
kW	<i>Kilowatt</i> : equal to 1,000 Watts.
kWh	<i>Kilowatt-hour</i> : 1,000 Watts of power expended over one hour.
LED	<i>Light emitting diode</i> : a high-efficiency source of light with a long lamp life.
LGEA	<i>Local Government Energy Audit</i>
Load	The total power a building or system is using at any given time.
Measure	A single activity, or installation of a single type of equipment, which is implemented in a building system to reduce total energy consumption.
MH	<i>Metal halide</i> : a type of HID lamp.
MBh	<i>Thousand Btu per hour</i>
MBtu	<i>One thousand British thermal units</i>
MMBtu	<i>One million British thermal units</i>
MV	<i>Mercury Vapor</i> : a type of HID lamp.
NJBPU	<i>New Jersey Board of Public Utilities</i>
NJCEP	<i>New Jersey's Clean Energy Program</i> : NJCEP is a statewide program that offers financial incentives, programs and services for New Jersey residents, business owners and local governments to help them save energy, money, and the environment.
psig	Pounds per square inch gauge
Plug Load	Refers to the amount of power used in a space by products that are powered by means of an ordinary AC plug.
PV	<i>Photovoltaic</i> : refers to an electronic device capable of converting incident light directly into electricity (direct current).

SEER	<i>Seasonal energy efficiency ratio</i> : a measure of efficiency in terms of annual cooling energy provided divided by total electric input.
SEP	<i>Statement of energy performance</i> : a summary document from the ENERGY STAR Portfolio Manager.
Simple Payback	The amount of time needed to recoup the funds expended in an investment or to reach the break-even point between investment and savings.
SREC (II)	<i>Solar renewable energy credit</i> : a credit you can earn from the state for energy produced from a photovoltaic array.
T5, T8, T12	A reference to a linear lamp diameter. The number represents increments of 1/8 th of an inch.
Temperature Setpoint	The temperature at which a temperature regulating device (thermostat, for example) has been set.
therm	100,000 Btu. Typically used as a measure of natural gas consumption.
tons	A unit of cooling capacity equal to 12,000 Btu/hr.
Turnkey	Provision of a complete product or service that is ready for immediate use.
VAV	<i>Variable air volume</i>
VFD	<i>Variable frequency drive</i> : a controller used to vary the speed of an electric motor.
WaterSense	The symbol for water efficiency. The WaterSense program is managed by the EPA.
Watt (W)	Unit of power commonly used to measure electricity use.
