



Local Government Energy Audit Report

Clifton Fire Station No. 4

May 15, 2020

Prepared for:

City of Clifton
144 Main Avenue
Clifton, NJ 07014

Prepared by:

TRC
900 Route 9 North
Woodbridge, NJ 07095

Disclaimer

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information about financial incentives that may be available. Most energy conservation measures have received preliminary analysis of feasibility that identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to establish a basis for further discussion and to help prioritize energy measures.

TRC reviewed the energy conservation measures and estimates of energy savings were reviewed for technical accuracy. Actual, achieved energy savings depend on behavioral factors and other uncontrollable variables and, therefore, estimates of final energy savings are not guaranteed. TRC and the New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

TRC bases estimated installation costs on our experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from RS Means. Cost estimates include material and labor pricing associated with installation of primary recommended equipment only. Cost estimates do not include demolition or removal of hazardous waste. We encourage the owner of the facility to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Actual installation costs can vary widely based on individual measures and conditions. TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. Please review all available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

The customer and their respective contractor(s) are responsible to implement energy conservation measures in complete conformance with all applicable local, state and federal requirements.

Copyright ©2020 TRC. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Table of Contents


1	Executive Summary	1
1.1	Planning Your Project	4
	Pick Your Installation Approach	4
	More Options from Around the State	6
2	Existing Conditions	7
2.1	Site Overview.....	7
2.2	Building Occupancy	7
2.3	Building Envelope	8
2.4	Lighting Systems	9
2.5	Police firing range HVAC Systems & Equipment	10
	Make Up Air Unit (MUA)	10
	Air Handling Units (AHUs)	11
2.6	Fire Department HVAC Systems & Equipment.....	11
	Electric HVAC.....	11
	Gas-Fired HVAC	12
2.7	Heating Hot Water System.....	12
2.8	Domestic Hot Water	13
2.9	Food Service Equipment.....	13
2.10	Plug Load & Vending Machines	14
2.11	Water-Using Systems	14
3	Energy Use and Costs	15
3.1	Electricity	17
3.2	Natural Gas.....	18
3.3	Benchmarking.....	19
	Tracking Your Energy Performance.....	20
4	Energy Conservation Measures	21
4.1	Lighting	24
	ECM 1: Retrofit Fixtures with LED Lamps.....	24
4.2	Lighting Controls.....	25
	ECM 2: Install Occupancy Sensor Lighting Controls	25
	ECM 3: Install High/Low Lighting Controls	25
4.3	Variable Frequency Drives (VFD).....	26
	ECM 4: Install VFDs on Constant Volume (CV) Fans	26
4.4	Gas-Fired Heating	27
	ECM 5: Install High Efficiency Hot Water Boilers	27
	ECM 6: Install Infrared Heaters	27
4.5	Domestic Water Heating	28

ECM 7: Install Low-Flow DHW Devices.....	28
4.6 Food Service & Refrigeration Measures.....	28
ECM 8: Vending Machine Control	28
4.7 Measures for Future Consideration	29
High Speed Insulated Overhead Doors	29
Controls for MUA	29
5 Energy Efficient Best Practices	30
Energy Tracking with ENERGY STAR® Portfolio Manager®.....	30
Weatherization.....	30
Doors and Windows	30
Window Treatments/Coverings	30
Lighting Maintenance.....	31
Motor Maintenance	31
Fans to Reduce Cooling Load	31
Thermostat Schedules and Temperature Resets	31
Economizer Maintenance	31
AC System Evaporator/Condenser Coil Cleaning	31
HVAC Filter Cleaning and Replacement	32
Boiler Maintenance	32
Furnace Maintenance	32
Water Heater Maintenance	32
Plug Load Controls.....	33
Water Conservation	33
Procurement Strategies	33
6 On-site Generation	34
6.1 Solar Photovoltaic	35
6.2 Combined Heat and Power	36
7 Project Funding and Incentives.....	37
7.1 SmartStart	38
7.2 Direct Install	39
7.3 Pay for Performance - Existing Buildings.....	40
7.4 Combined Heat and Power	41
7.5 Energy Savings Improvement Program	42
7.6 SREC Registration Program.....	43
8 Energy Purchasing and Procurement Strategies	44
8.1 Retail Electric Supply Options.....	44
8.2 Retail Natural Gas Supply Options	44
Appendix A: Equipment Inventory & Recommendations	A-1
Appendix B: ENERGY STAR® Statement of Energy Performance.....	B-1
Appendix C: Glossary	C-1

1 EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) report for Clifton Fire Station No. 4. This report provides you with information about your facility's energy use, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help make changes in your facility. TRC conducted this study as part of a comprehensive effort to assist New Jersey school districts and local governments in controlling their energy costs and to help protect our environment by reducing statewide energy consumption.

BUILDING PERFORMANCE REPORT



ENERGY STAR® Benchmarking Score	N/A <i>(1-100 scale)</i>	A standard energy use benchmark is not available for this facility type. This report contains suggestions about how to improve building performance and reduce energy costs.
---------------------------------	-----------------------------	--




Figure 1 - Energy Use by System


POTENTIAL IMPROVEMENTS



This energy audit considered a range of potential energy improvements in your building. Costs and savings will vary between improvements. Presented below are two potential scopes of work for your consideration.


Scenario 1: Full Package (all evaluated measures)

Installation Cost	\$33,232	200.0
Potential Rebates & Incentives ¹	\$8,790	
Annual Cost Savings	\$2,368	
Annual Energy Savings	Electricity: 11,608 kWh Natural Gas: 624 Therms	
Greenhouse Gas Emission Savings	9 Tons	
Simple Payback	10.3 Years	
Site Energy Savings (all utilities)	7%	



Scenario 2: Cost Effective Package²

Installation Cost	\$13,985	200.0
Potential Rebates & Incentives	\$5,170	
Annual Cost Savings	\$1,837	
Annual Energy Savings	Electricity: 11,558 kWh Natural Gas: 8 Therms	
Greenhouse Gas Emission Savings	6 Tons	
Simple Payback	4.8 Years	
Site Energy Savings (all utilities)	3%	



On-site Generation Potential

Photovoltaic	None
Combined Heat and Power	None

¹ Incentives are based on current SmartStart Prescriptive incentives. Other Program incentives may apply.

² A cost-effective measure is defined as one where the simple payback does not exceed two-thirds of the expected proposed equipment useful life. Simple payback is based on the net measure cost after potential incentives.

#	Energy Conservation Measure	Cost Effective?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades			305	0.0	0	\$48	\$52	\$18	\$34	0.7	300
ECM 1	Retrofit Fixtures with LED Lamps	Yes	305	0.0	0	\$48	\$52	\$18	\$34	0.7	300
Lighting Control Measures			2,795	0.3	-1	\$438	\$3,157	\$630	\$2,527	5.8	2,745
ECM 2	Install Occupancy Sensor Lighting Controls	Yes	2,745	0.3	-1	\$430	\$2,932	\$630	\$2,302	5.4	2,696
ECM 3	Install High/Low Lighting Controls	No	50	0.0	0	\$8	\$225	\$0	\$225	28.9	49
Variable Frequency Drive (VFD) Measures			6,897	5.7	0	\$1,092	\$10,750	\$4,400	\$6,350	5.8	6,945
ECM 4	Install VFDs on Constant Volume (CV) Fans	Yes	6,897	5.7	0	\$1,092	\$10,750	\$4,400	\$6,350	5.8	6,945
Gas Heating (HVAC/Process) Replacement			0	0.0	62	\$523	\$19,021	\$3,620	\$15,401	29.4	7,218
ECM 5	Install High Efficiency Hot Water Boilers	No	0	0.0	38	\$319	\$13,202	\$2,420	\$10,782	33.8	4,407
ECM 6	Install Infrared Heaters	No	0	0.0	24	\$204	\$5,820	\$1,200	\$4,620	22.7	2,810
Domestic Water Heating Upgrade			0	0.0	1	\$12	\$22	\$22	\$0	0.0	167
ECM 7	Install Low-Flow DHW Devices	Yes	0	0.0	1	\$12	\$22	\$22	\$0	0.0	167
Food Service & Refrigeration Measures			1,612	0.2	0	\$255	\$230	\$100	\$130	0.5	1,623
ECM 8	Vending Machine Control	Yes	1,612	0.2	0	\$255	\$230	\$100	\$130	0.5	1,623
TOTALS (COST EFFECTIVE MEASURES)			11,558	6.3	1	\$1,837	\$13,985	\$5,170	\$8,816	4.8	11,730
TOTALS (ALL MEASURES)			11,608	6.3	62	\$2,368	\$33,232	\$8,790	\$24,442	10.3	18,996

* - All incentives presented in this table are based on NJ SmartStart equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 2 – Evaluated Energy Improvements

For more detail on each evaluated energy improvement and a break out of cost-effective improvements, see **Section 4: Energy Conservation Measures**.

1.1 Planning Your Project

Careful planning makes for a successful energy project. When considering this scope of work, you will have some decisions to make, such as:

- ◆ How will the project be funded and/or financed?
- ◆ Is it best to pursue individual ECMs, groups of ECMs, or use a comprehensive approach where all ECMs are installed together?
- ◆ Are there other facility improvements that should happen at the same time?

Pick Your Installation Approach

New Jersey’s Clean Energy Programs give you the flexibility to do a little or a lot. Rebates, incentives, and financing are available to help reduce both your installation costs and your energy bills. If you are planning to take advantage of these programs, make sure to review incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives before purchasing materials or starting installation.

The potential ECMs identified for this building likely qualify for multiple incentive and funding programs. Based on current program rules and requirements, your measures are likely to qualify for the following programs:

Energy Conservation Measure		SmartStart	Direct Install	Pay For Performance
ECM 1	Retrofit Fixtures with LED Lamps	X	X	
ECM 2	Install Occupancy Sensor Lighting Controls	X	X	
ECM 3	Install High/Low Lighting Controls		X	
ECM 4	Install VFDs on Constant Volume (CV) Fans	X		
ECM 5	Install High Efficiency Hot Water Boilers	X	X	
ECM 6	Install Infrared Heaters	X	X	
ECM 7	Install Low-Flow DHW Devices	X	X	
ECM 8	Vending Machine Control	X	X	

Figure 3 – Funding Options



New Jersey's Clean Energy Programs At-A-Glance

	SmartStart Flexibility to install at your own pace	Direct Install Turnkey installation	Pay for Performance Whole building upgrades
Who should use it?	Buildings installing individual measures or small group of measures.	Small to mid-size facilities that can bundle multiple measures together. Average peak demand should be below 200 kW. Not suitable for significant building shell issues.	Mid to large size facilities looking to implement as many measures as possible at one time. Peak demand should be over 200 kW.
How does it work?	Use in-house staff or your preferred contractor.	Pre-approved contractors pass savings along to you via reduced material and labor costs.	Whole-building approach to energy upgrades designed to reduce energy use by at least 15%. The more you save, the higher the incentives.
What are the Incentives?	Fixed incentives for specific energy efficiency measures.	Incentives pay up to 70% of eligible costs, up to \$125,000 per project. You pay the remaining 30% directly to the contractor.	Up to 25% of installation cost, calculated based on level of energy savings per square foot.
How do I participate?	Submit an application for the specific equipment to be installed.	Contact a participating contractor in your region.	Contact a pre-qualified Partner to develop your Energy Reduction Plan and set your energy savings targets.

Take the next step by visiting www.njcleanenergy.com for program details, applications, and to contact a qualified contractor.

Individual Measures with SmartStart

For facilities wishing to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate, you can use internal resources or an outside firm or contractor to perform the final design of the ECM(s) and install the equipment. Program pre-approval is required for some SmartStart incentives, so only after receiving pre-approval should you proceed with ECM installation.

Turnkey Installation with Direct Install

The Direct Install program provides turnkey installation of multiple measures through an authorized network of participating contractors. This program can provide substantially higher incentives than SmartStart, up to 70% of the cost of selected measures. Direct Install contractors will assess and verify individual measure eligibility and, in most cases, they perform the installation work. The Direct Install program is available to sites with an average peak demand of less than 200 kW.

Whole Building Approach with Pay for Performance

Pay for Performance can be a good option for medium to large sized facilities to achieve deep energy savings. Pay for Performance allows you to install as many measures as possible under a single project as well as address measures that may not qualify for other programs. Many facilities pursuing an Energy Savings Improvement Program (ESIP) loan also use this program. Pay for Performance works for larger customers with a peak demand over 200 kW. The minimum installed scope of work must include at least two unique measures resulting in at least 15% energy savings, where lighting cannot make up the majority of the savings.

More Options from Around the State

Financing and Planning Support with the Energy Savings Improvement Program (ESIP)

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the ESIP. Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. You have already taken the first step as an LGEA customer, because this report is required to participate in ESIP.

Resiliency with Return on Investment through Combined Heat & Power (CHP)

The CHP program provides incentives for combined heat and power (aka cogeneration) and waste heat to power projects. Combined heat and power systems generate power on-site and recover heat from the generation system to meet on-site thermal loads. Waste heat to power systems use waste heat to generate power. You will work with a qualified developer who will design a system that meets your building's heating and cooling needs.

Ongoing Electric Savings with Demand Response

The Demand Response Energy Aggregator program reduces electric loads at commercial facilities when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. By enabling commercial facilities to reduce electric demand during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment service providers provide regular payments to medium and large consumers of electric power for their participation in demand response (DR) programs. Program participation is voluntary, and facilities receive payments regardless of whether they are called upon to curtail their load during times of peak demand.

2 EXISTING CONDITIONS

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) Report for Clifton Fire Station No. 4. This report provides information on how your facility uses energy, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help you implement the ECMs. This report also contains valuable information on financial incentives from New Jersey’s Clean Energy Program (NJCEP) for implementing ECMs.

TRC conducted this study as part of a comprehensive effort to assist New Jersey educational and local government facilities in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

2.1 Site Overview

On January 14, 2020, TRC performed an energy audit at Clifton Fire Station No. 4 located in Clifton, New Jersey. TRC met with Mike Pressler to review the facility operations and help focus our investigation on specific energy-using systems.

Clifton Fire Station No. 4 is a two-story, 9,060 square foot building built in 1968. Spaces in the Fire Station include a garage, kitchen/lounge, office, pantry, restrooms, dorm rooms, work out room, storage rooms, restrooms, corridors, stairwells and mechanical space. The Police firing range is located below grade. Spaces in the Police firing range include a stairwell, hallway, restroom, the firing range and office space. The facility is 100% heated and cooled, except the Fire Station garage.

General note: The facility includes a Police firing range which contributes to the very high electric intensity of the facility. Per discussions with the facility personnel, the Fire Station is planning to install an exhaust system for the garage, and bid walkthroughs are currently underway. It should be noted that the addition of an exhaust system will tend to increase energy use at the facility.

2.2 Building Occupancy

The Fire Station is occupied year-round. Typical weekday occupancy includes 3 personnel in the Fire Station. The Police firing range is occupied for 8 months out of the year. During this time, training is conducted Monday through Friday for 8 hours a day.

Building Name	Weekday/Weekend	Operating Schedule
Fire Station No. 4	Weekday	24/7
	Weekend	24/7
Police Firing Range (8 Months of the Year)	Weekday	9:00 AM - 5:00 PM
	Weekend	No Use

Figure 4 - Building Occupancy Schedule

2.3 Building Envelope

Building walls are concrete block with a brick facade. The roof is pitched with a black membrane and appears to be in fair condition. Most of the windows are operable, double pane with metal frames. The glass-to-frame seals are in fair condition. The operable window weather seals and the windows are in fair condition. Exterior doors are metal or glass with metal frames and are in fair condition with worn or missing door weather-stripping. Overhead doors are minimally insulated sectional steel doors with worn sealing materials. They are operated by fractional horsepower motors. Degraded window and door seals increase drafts and outside air infiltration.



Overhead Doors



Building Façade



Exterior door with no Weather-stripping



Police firing range Entrance

2.4 Lighting Systems

The primary interior lighting system uses 15-Watt linear 4-foot LED lamps or 8-Watt linear 2' LED lamps. Fixture types include 1-lamp or 2-lamp, 4-foot long recessed troffer fixtures and wrap fixtures. Additionally, there are some LED recessed can fixtures and LED general purpose lamps in a few areas. These LED upgrades were completed 5 to 10 years ago under the Direct Install program. There is a compact fluorescent lamp fixture in the pantry and there are linear T8 lamps in the undercounter fixtures in the kitchen. Interior light fixtures are manually controlled via wall switches. Most fixtures are in good condition. Interior lighting levels were generally sufficient. Exterior fixtures include wall pack fixtures and screw in lamp fixtures, all LED, and in good condition. They are controlled by photocell controls.



Linear LED Lamp Recessed Troffer Fixtures



Linear LED Lamp Wrap Fixtures




LED Screw in Lamps



Wall Switches

The police firing range hallway, restroom, and office areas are lit by LED lamp fixtures. The firing range is lit by approximately 70 PAR38 LED flood lamps. Additionally, there are some LED lay in 2x2 panels and LED recessed can fixtures. These LED upgrades were also completed 5 to 10 years ago under the Direct Install program. Interior light fixtures are manually controlled via wall switches. Most fixtures are in good condition. Interior lighting levels were generally sufficient.



Police firing range



LED Lamp Wrap Fixture

2.5 Police firing range HVAC Systems & Equipment

Make Up Air Unit (MUA)

The police firing range is conditioned by a Make Up Air Unit (MUA-1). This system is served by a 60-ton Trane, air-cooled condenser. The MUA has a gas-fired furnace with a 1250 Mbh capacity and a nominal heating efficiency of 80%. The MUA includes four 20 hp variable speed supply fan motors, a fractional hp combustion air fan, and two 25 hp exhaust fan motors. The purpose of this system is to maintain high ventilation levels to remove smoke and particulates when the space is in use. This system is new, in good condition, and has a cooling efficiency of 11.25 EER (energy efficiency ratio). This system is controlled through a touchscreen interface with direct digital controls (DDC) within the police office, providing both temperature and humidity control.



Police firing range HVAC System



Police firing range HVAC System

Air Handling Units (AHUs)

The police office is conditioned by a heat pump system that is served by a 5-ton York, outdoor condensing unit. The system has a ½ hp supply fan motor. The system is in good condition and has a cooling efficiency of 13 EER. This system is controlled by a thermostat and was set to 70°F at the time of the audit. The police firing range is also served by AHU-1 which has two 10 hp supply fan motors that are constant speed and high efficiency.



Police firing range Fan Coil Unit



Thermostat

2.6 Fire Department HVAC Systems & Equipment

Electric HVAC

The fire station main area is conditioned by a split-system air-source heat pump (HP) system that is served by a 5-ton Trane outdoor condensing unit. The cooling efficiency is 14 EER and the system is in good condition. The heating capacity is 30 Mbh with a coefficient of performance (COP) of 3.6. This is considered a high efficiency system. The system is controlled by a thermostat which was set to 75°F and heating at the time of the audit. There is also a window air-conditioning unit that is of low efficiency and .67 tons in capacity. This cools the kitchen lounge pantry and manually turned on and off as needed.



Split HP System – Outdoor Condensing Unit



Thermostat

Gas-Fired HVAC

The fire station garage is conditioned by two gas-fired, warm air unit heaters. Each has a heating capacity of 125 Mbh and an efficiency of 83%. These were installed in 2017 and are in good condition. These are located at the ceiling of the garage and controlled to maintain 70°F in the space.



Gas Fired Unit Heaters in Garage

2.7 Heating Hot Water System

The fire station is heated by a hydronic system. A Weil McLain 550 Mbh hot water boiler serves the building heating load. The burners are non-modulating with a nominal efficiency of 80%. Installed in 2012, it is in fair condition. The hydronic distribution system is a two-pipe, heating only system. There are two fractional hp hot water pump motors that distribute hot water through the facility. These motors are constant speed and in good condition. The boiler provides hot water to perimeter radiators throughout the building, except the garage. Pipes are insulated and the insulation is in fair condition. Hot water is supplied at 180°F when the outside air temperature is low. The outdoor air reset schedule is unknown.



Hot Water Boiler



Hot Water Pump Motors



Hot Water Baseboard

2.8 Domestic Hot Water

Hot water is produced by an 80% efficient, 40 gallon 38 MBh Rheem gas-fired storage tank water heater. The equipment is in fair condition. A fractional hp circulation pump distributes water to end uses. The domestic hot water pipes are insulated, and the insulation is in fair condition.



High Flow Sink Aerator

2.9 Food Service Equipment

The kitchen has gas residential stove and an undercounter dishwasher. Both pieces of equipment have relatively low use and are high efficiency.

Visit https://www.energystar.gov/products/commercial_food_service_equipment for the latest information on high efficiency food service equipment.



Kitchen Equipment

2.10 Plug Load & Vending Machines

The location is doing a great job managing their electrical plug loads. This report makes additional suggestions for ECMs in this area as well as Energy Efficient Best Practices.

There are a five computer workstations throughout the facility. Plug loads throughout the building include general café and office equipment. There are residential style refrigerators which vary in condition and efficiency. There are also several fans and a space heater. There is one refrigerated beverage vending machine which is not currently equipped with occupancy-based controls. There is specialty equipment for the moving target system in the police firing range.



Moving Target System in Police firing range



Café Equipment in Police firing range



Clothes Washer & Dryer in Fire Station



Vending Machine in Fire Station


2.11 Water-Using Systems

There are restrooms with showers and sinks. Faucet flow rates are at 2.2 gallons per minute (gpm) and considered high flow devices. Showerheads vary in flow rate.

3 ENERGY USE AND COSTS

Twelve months of utility billing data are used to develop annual energy consumption and cost data. This information creates a profile of the annual energy consumption and energy costs.

Utility Summary		
Fuel	Usage	Cost
Electricity	113,470 kWh	\$17,974
Natural Gas	11,275 Therms	\$9,568
Total		\$27,542



An energy balance identifies and quantifies energy use in your various building systems. This can highlight areas with the most potential for improvement. This energy balance was developed using calculated energy use for each of the end uses noted in the figure.

The energy auditor collects information regarding equipment operating hours, capacity, efficiency, and other operational parameters from facility staff, drawings, and on-site observations. This information is used as the inputs to calculate the existing conditions energy use for the site. The calculated energy use is then compared to the historical energy use and the initial inputs are revised, as necessary, to balance the calculated energy use to the historical energy use.





Figure 5 - Energy Balance

3.1 Electricity

PSE&G supplies and delivers electricity under rate class GLP.




Electric Billing Data						
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost	TRC Estimated Usage?
6/15/18	31	7,980	35	\$151	\$1,400	Yes
7/15/18	30	9,560	47	\$199	\$1,650	Yes
8/13/18	31	9,400	56	\$232	\$1,602	Yes
9/14/18	30	9,910	96	\$332	\$1,651	Yes
10/13/18	31	8,960	97	\$385	\$1,438	Yes
11/15/18	30	9,010	58	\$180	\$1,508	Yes
12/14/18	31	10,830	45	\$178	\$1,451	Yes
1/14/19	31	9,490	84	\$329	\$1,450	Yes
2/16/19	30	9,250	48	\$159	\$1,255	Yes
3/16/19	29	11,100	85	\$333	\$1,646	Yes
4/14/19	31	8,090	97	\$425	\$1,331	Yes
5/16/19	30	9,890	96	\$379	\$1,591	Yes
Totals	365	113,470	97	\$3,282	\$17,974	
Annual	365	113,470	97	\$3,282	\$17,974	

Notes:

- Peak demand of 97 kW occurred in April '19.
- Average demand over the past 12 months was 70 kW.
- The average electric cost over the past 12 months was \$0.158/kWh, which is the blended rate that includes energy supply, distribution, demand, and other charges. This report uses this blended rate to estimate energy cost savings.
- There are two electric meters at this facility. The annual kWh consumption for the meters is approximately a 50% split between the Fire Station and the Police firing range. The square footage breakdown is approximately 80% for the Fire Station and 20% for the Police firing range.
 - The Fire Station has an electric intensity of approximately 8 kWh/sq. ft.
 - The Police firing range has an electric intensity of approximately 30 kWh/sq. ft.

3.2 Natural Gas

PSE&G delivers natural gas under rate class GSG (HTG), with natural gas supply provided by East Coast Power and Gas, a third-party supplier.



Gas Billing Data				
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost	TRC Estimated Usage?
6/15/18	31	128	\$111	Yes
7/15/18	30	100	\$85	Yes
8/13/18	31	129	\$118	Yes
9/14/18	30	129	\$118	Yes
10/13/18	31	129	\$118	Yes
11/15/18	30	129	\$118	Yes
12/14/18	31	2,995	\$2,518	Yes
1/14/19	31	3,051	\$2,607	Yes
2/16/19	30	917	\$803	Yes
3/16/19	29	2,165	\$1,885	Yes
4/14/19	31	1,131	\$869	Yes
5/16/19	30	271	\$220	Yes
Totals	365	11,275	\$9,568	
Annual	365	11,275	\$9,568	

Notes:

- The average gas cost for the past 12 months is \$0.849/therm, which is the blended rate used throughout the analysis.

3.3 Benchmarking

Your building was benchmarked using the United States Environmental Protection Agency's (EPA) *Portfolio Manager*® software. Benchmarking compares your building's energy use to that of similar buildings across the country, while neutralizing variations due to location, occupancy and operating hours. Some building types can be scored with a 1-100 ranking of a building's energy performance relative to the national building market. A score of 50 represents the national average and a score of 100 is best.

This ENERGY STAR® benchmarking score provides a comprehensive snapshot of your building's energy performance. It assesses the building's physical assets, operations, and occupant behavior, which is compiled into a quick and easy-to-understand score.

Benchmarking Score	N/A
---------------------------	------------

Due to its unique characteristics, this building type is not able to receive a benchmarking score. This report contains suggestions about how to improve building performance and reduce energy costs.




Figure 6 - Energy Use Intensity Comparison³

Energy use intensity (EUI) measures energy consumption per square foot and is the standard metric for comparing buildings' energy performance. A lower EUI means better performance and less energy consumed. A number of factors can cause a building to vary from the "typical" energy usage. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and occupant behavior all contribute to a building's energy use and the benchmarking score.

³ Based on all evaluated ECMs



Tracking Your Energy Performance

Keeping track of your energy use on a monthly basis is one of the best ways to keep energy costs in check. Update your utility information in Portfolio Manager® regularly, so that you can keep track of your building's performance.

We have created a Portfolio Manager® account for your facility and we have already entered the monthly utility data shown above for you. Account login information for your account will be sent via email.

Free online training is available to help you use ENERGY STAR® Portfolio Manager® to track your building's performance at: <https://www.energystar.gov/buildings/training>.

For more information on ENERGY STAR® and Portfolio Manager®, visit their website⁴.

⁴ <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.

4 ENERGY CONSERVATION MEASURES

The goal of this audit report is to identify and evaluate potential energy efficiency improvements, provide information about the cost effectiveness of those improvements, and recognize potential financial incentives from NJBPU. Most energy conservation measures have received preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is typically sufficient to demonstrate project cost-effectiveness and help prioritize energy measures.

Calculations of energy use and savings are based on the current version of the *New Jersey's Clean Energy Program Protocols to Measure Resource Savings*, which is approved by the NJBPU. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances.

Operation and maintenance costs for the proposed new equipment will generally be lower than the current costs for the existing equipment—especially if the existing equipment is at or past its normal useful life. We have conservatively assumed there to be no impact on overall maintenance costs over the life of the equipment.

Financial incentives are based on the current NJCEP prescriptive SmartStart program. A higher level of investigation may be necessary to support any SmartStart Custom, Pay for Performance, or Direct Install incentive applications. Some measures and proposed upgrades may be eligible for higher incentives than those shown below through other NJCEP programs described in a following section of this report.

For a detailed list of the locations and recommended energy conservation measures for all inventoried equipment, see **Appendix A: Equipment Inventory & Recommendations**.

#	Energy Conservation Measure	Cost Effective?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades			305	0.0	0	\$48	\$52	\$18	\$34	0.7	300
ECM 1	Retrofit Fixtures with LED Lamps	Yes	305	0.0	0	\$48	\$52	\$18	\$34	0.7	300
Lighting Control Measures			2,795	0.3	-1	\$438	\$3,157	\$630	\$2,527	5.8	2,745
ECM 2	Install Occupancy Sensor Lighting Controls	Yes	2,745	0.3	-1	\$430	\$2,932	\$630	\$2,302	5.4	2,696
ECM 3	Install High/Low Lighting Controls	No	50	0.0	0	\$8	\$225	\$0	\$225	28.9	49
Variable Frequency Drive (VFD) Measures			6,897	5.7	0	\$1,092	\$10,750	\$4,400	\$6,350	5.8	6,945
ECM 4	Install VFDs on Constant Volume (CV) Fans	Yes	6,897	5.7	0	\$1,092	\$10,750	\$4,400	\$6,350	5.8	6,945
Gas Heating (HVAC/Process) Replacement			0	0.0	62	\$523	\$19,021	\$3,620	\$15,401	29.4	7,218
ECM 5	Install High Efficiency Hot Water Boilers	No	0	0.0	38	\$319	\$13,202	\$2,420	\$10,782	33.8	4,407
ECM 6	Install Infrared Heaters	No	0	0.0	24	\$204	\$5,820	\$1,200	\$4,620	22.7	2,810
Domestic Water Heating Upgrade			0	0.0	1	\$12	\$22	\$22	\$0	0.0	167
ECM 7	Install Low-Flow DHW Devices	Yes	0	0.0	1	\$12	\$22	\$22	\$0	0.0	167
Food Service & Refrigeration Measures			1,612	0.2	0	\$255	\$230	\$100	\$130	0.5	1,623
ECM 8	Vending Machine Control	Yes	1,612	0.2	0	\$255	\$230	\$100	\$130	0.5	1,623
TOTALS			11,608	6.3	62	\$2,368	\$33,232	\$8,790	\$24,442	10.3	18,996

* - All incentives presented in this table are based on NJ SmartStart equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 7 – All Evaluated ECMs

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		305	0.0	0	\$48	\$52	\$18	\$34	0.7	300
ECM 1	Retrofit Fixtures with LED Lamps	305	0.0	0	\$48	\$52	\$18	\$34	0.7	300
Lighting Control Measures		2,745	0.3	-1	\$430	\$2,932	\$630	\$2,302	5.4	2,696
ECM 2	Install Occupancy Sensor Lighting Controls	2,745	0.3	-1	\$430	\$2,932	\$630	\$2,302	5.4	2,696
Variable Frequency Drive (VFD) Measures		6,897	5.7	0	\$1,092	\$10,750	\$4,400	\$6,350	5.8	6,945
ECM 4	Install VFDs on Constant Volume (CV) Fans	6,897	5.7	0	\$1,092	\$10,750	\$4,400	\$6,350	5.8	6,945
Domestic Water Heating Upgrade		0	0.0	1	\$12	\$22	\$22	\$0	0.0	167
ECM 7	Install Low-Flow DHW Devices	0	0.0	1	\$12	\$22	\$22	\$0	0.0	167
Food Service & Refrigeration Measures		1,612	0.2	0	\$255	\$230	\$100	\$130	0.5	1,623
ECM 8	Vending Machine Control	1,612	0.2	0	\$255	\$230	\$100	\$130	0.5	1,623
TOTALS		11,558	6.3	1	\$1,837	\$13,985	\$5,170	\$8,816	4.8	11,730

* - All incentives presented in this table are based on NJ SmartStart equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 8 – Cost Effective ECMs

4.1 Lighting

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		305	0.0	0	\$48	\$52	\$18	\$34	0.7	300
ECM 1	Retrofit Fixtures with LED Lamps	305	0.0	0	\$48	\$52	\$18	\$34	0.7	300

When considering lighting upgrades, we suggest using a comprehensive design approach that simultaneously upgrades lighting fixtures and controls to maximize energy savings and improve occupant lighting. Comprehensive design will also consider appropriate lighting levels for different space types to make sure that the right amount of light is delivered where needed. If conversion to LED light sources are proposed, we suggest converting all of a specific lighting type (e.g., linear fluorescent) to LED lamps to minimize the number of lamp types in use at the facility, which should help reduce future maintenance costs.

ECM 1: Retrofit Fixtures with LED Lamps

Replace fluorescent and compact fluorescent lamps with LED lamps. Many LED tubes are direct replacements for existing fluorescent tubes and can be installed while leaving the fluorescent fixture ballast in place. LED lamps can be used in existing fixtures as a direct replacement for most other lighting technologies.

This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space. Maintenance savings may also be available, as longer-lasting LEDs lamps will not need to be replaced as often as the existing lamps.

Affected building areas: pantry and under counter fixtures in the kitchen.

4.2 Lighting Controls

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures		2,795	0.3	-1	\$438	\$3,157	\$630	\$2,527	5.8	2,745
ECM 2	Install Occupancy Sensor Lighting Controls	2,745	0.3	-1	\$430	\$2,932	\$630	\$2,302	5.4	2,696
ECM 3	Install High/Low Lighting Controls	50	0.0	0	\$8	\$225	\$0	\$225	28.9	49

Lighting controls reduce energy use by turning off or lowering lighting fixture power levels when not in use. A comprehensive approach to lighting design should upgrade the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

ECM 2: Install Occupancy Sensor Lighting Controls

Install occupancy sensors to control lighting fixtures in areas that are frequently unoccupied, even for short periods. For most spaces, we recommend that lighting controls use dual technology sensors, which reduce the possibility of lights turning off unexpectedly.

Occupancy sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Most occupancy sensor lighting controls allow users to manually turn fixtures on/off, as needed. Some controls can also provide dimming options.

Occupancy sensors can be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are best suited to single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in large spaces, locations without local switching, and where wall switches are not in the line-of-sight of the main work area.

This measure provides energy savings by reducing the lighting operating hours.

Affected building areas: offices, garage, kitchen/lounge, workout room and restrooms.

ECM 3: Install High/Low Lighting Controls

We evaluated the installation of an occupancy sensor to provide dual level lighting control for lighting fixtures in spaces that are infrequently occupied but may require some level of continuous lighting for safety or security reasons.

Lighting fixtures with these controls operate at default low levels when the area is unoccupied to provide minimal lighting to meet security or safety code requirements for egress. Sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Fixtures automatically switch back to low level after a predefined period of vacancy. In parking lots and parking garages with significant ambient lighting, this control can sometimes be combined with photocell controls to turn the lights off when there is sufficient daylight.

The controller lowers the light level by dimming the fixture output. Therefore, the controlled fixtures need to have a dimmable ballast or driver. This will need to be considered when selecting retrofit lamps and bulbs for the areas proposed for high/low control.

This measure provides energy savings by reducing the light fixture power draw when reduced light output is appropriate.

Affected building areas: vestibule.

For this type of measure the occupancy sensors will generally be ceiling or fixture mounted. Sufficient sensor coverage must be provided to ensure that lights turn on in each area as an occupant approaches.

4.3 Variable Frequency Drives (VFD)

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Variable Frequency Drive (VFD) Measures		6,897	5.7	0	\$1,092	\$10,750	\$4,400	\$6,350	5.8	6,945
ECM 4	Install VFDs on Constant Volume (CV) Fans	6,897	5.7	0	\$1,092	\$10,750	\$4,400	\$6,350	5.8	6,945

Variable frequency drives control motors for fans, pumps, and process equipment based on the actual output required of the driven equipment. Energy savings result from more efficient control of motor energy usage when equipment operates at partial load. The magnitude of energy savings depends on the estimated amount of time that the motor would operate at partial load. For equipment with proposed VFDs, we have included replacing the controlled motor with a new inverter duty rated motor to conservatively account for the cost of an inverter duty rated motor.

ECM 4: Install VFDs on Constant Volume (CV) Fans

Install VFDs to control constant volume fan motor speed. This converts a constant-volume, single-zone air handling system into a variable-air-volume (VAV) system. A separate VFD is usually required to control the return fan motor or dedicated exhaust fan motor, if the air handler has one.

Zone thermostats signal the VFD to adjust fan speed to maintain the appropriate temperature in the zone, while maintaining a constant supply air temperature. Energy savings result from reducing the fan speed (and power) when conditions allow for reduced air flow.

Affected air handlers: AHU-1.

4.4 Gas-Fired Heating

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Gas Heating (HVAC/Process) Replacement		0	0.0	62	\$523	\$19,021	\$3,620	\$15,401	29.4	7,218
ECM 5	Install High Efficiency Hot Water Boilers	0	0.0	38	\$319	\$13,202	\$2,420	\$10,782	33.8	4,407
ECM 6	Install Infrared Heaters	0	0.0	24	\$204	\$5,820	\$1,200	\$4,620	22.7	2,810

ECM 5: Install High Efficiency Hot Water Boilers

We evaluated the replacement of the inefficient hot water boiler with high efficiency hot water boiler. Energy savings results from improved combustion efficiency and reduced standby losses at low loads.

The most notable efficiency improvement is condensing hydronic boilers which can achieve over 90% efficiency under the proper conditions. Condensing hydronic boilers typically operate at efficiencies between 85% and 87% (comparable to other high efficiency boilers) when the return water temperature is above 130°F. The boiler efficiency increases as the return water temperature drops below 130°F. Therefore, condensing hydronic boilers are evaluated when the return water temperature is less than 130°F during most of the operating hours.

For the purposes of this analysis, we evaluated the replacement of boilers on a one-for-one basis with equipment of the same capacity. We recommend that you work with your mechanical design team to select boilers that are sized appropriately for the heating load at this facility. In many cases installing multiple modular boilers rather than one or two large boilers will result in higher overall plant efficiency while providing additional system redundancy.

Replacing the boilers has a long payback and may not be justifiable based simply on energy considerations. However, the boilers [are nearing, have reached] the end of their normal useful life. Typically, the marginal cost of purchasing high efficiency boilers can be justified by the marginal savings from the improved efficiency. When the boiler is eventually replaced, consider purchasing boilers that exceed the minimum efficiency required by building codes. We also recommend working with your mechanical design team to determine whether the heating system can operate with return water temperatures below 130°F, which would allow the use of condensing boilers.

ECM 6: Install Infrared Heaters

We evaluated the replacement of forced air heating equipment with low-intensity infrared heating units with an enclosed flame, rather than an open flame on a ceramic or metal surface.

Forced air furnaces heat all of the air in the space served, which is inefficient for large volume spaces with relatively few occupants, areas with high ceilings, or areas with high outside air infiltration. Infrared heaters heat objects and surfaces directly, including the occupants of the space, rather than heating large volumes of air. Infrared heaters also heat the floor which then re-radiates the heat. As a result, infrared heaters are more effective and efficient at maintaining occupant comfort at significantly lower cost for certain space types.

Affected building areas: garage

4.5 Domestic Water Heating

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Domestic Water Heating Upgrade		0	0.0	1	\$12	\$22	\$22	\$0	0.0	167
ECM 7	Install Low-Flow DHW Devices	0	0.0	1	\$12	\$22	\$22	\$0	0.0	167

ECM 7: Install Low-Flow DHW Devices

Install low-flow devices to reduce overall hot water demand. The following low flow devices are recommended to reduce hot water usage:

Device	Flow Rate
Faucet aerators (lavatory)	0.5 gpm
Faucet aerator (kitchen)	1.5 gpm
Showerhead	2.0 gpm
Pre-rinse spray valve (kitchen)	1.28 gpm

Low-flow devices reduce the overall water flow from the fixture, while still providing adequate pressure for washing. Additional cost savings may result from reduced water usage.

4.6 Food Service & Refrigeration Measures

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Food Service & Refrigeration Measures		1,612	0.2	0	\$255	\$230	\$100	\$130	0.5	1,623
ECM 8	Vending Machine Control	1,612	0.2	0	\$255	\$230	\$100	\$130	0.5	1,623

ECM 8: Vending Machine Control

Vending machines operate continuously, even during unoccupied hours. Install occupancy sensor controls to reduce energy use. These controls power down vending machines when the vending machine area has been vacant for some time, and they power up the machines at necessary regular intervals or when the surrounding area is occupied. Energy savings are dependent on the vending machine and activity level in the area surrounding the machines.

4.7 Measures for Future Consideration

There are additional opportunities for improvement that the City of Clifton may wish to consider. These potential upgrades typically require further analysis, involve substantial capital investment and/or include significant system reconfiguration. These measures are therefore beyond the scope of this energy audit. These measure(s) are described here to support a whole building approach to energy efficiency and sustainability.

The City of Clifton may wish to consider the Energy Savings Improvement Program (ESIP) and take a whole building/entity wide energy project approach. With interest in implementing comprehensive, largescale and/or complex system wide projects, these measures may be pursued during development of a future energy savings plan. We recommend that you work with your energy service company (ESCO) and/or design team to evaluate these measures further, develop firm costs, savings estimates and detailed implementation plans. Other modernization or capital improvement funds may be leveraged for these types of refurbishments. As you plan for capital upgrades, be sure to consider the energy impact of the building systems and controls being specified.

High Speed Insulated Overhead Doors

Energy efficient overhead doors are an important consideration when improving the building envelope of the main garage area. The heat transfer through the closed overhead doors through by conduction and space convection heat loss when overhead doors are opened are responsible for a significant portion of the facility's heating energy consumption. We recommend replacing overhead doors with high speed insulated overhead doors. This measure will permit overhead doors to open and close more than twice as quickly as the existing case, significantly reducing heat loss in the garage area. The insulation will further mitigate heat loss when the doors are closed. For this measure to be effective the overhead doors would need to remain closed whenever the garage is being conditioned except when vehicles need to leave or enter.

As part of the installation, the overhead door frames should be properly sealed with weather stripping and sealing materials to ensure the mitigation of air infiltration. Building envelopes that limit air infiltration play a key role in optimizing heating and cooling efficiency, controlling moisture, and providing occupant comfort. Overhead door replacement may be an expensive upgrade, especially as it may involve structural or architectural elements.

Overall savings will also vary depending on the type of heating system present. Since infrared heaters tend to radiate heat directly to occupants or objects, they contribute less to overall heat loss than forced air systems do. Areas with forced air heat are the better candidates for this measure.

We recommend this as a measure for further study.

Controls for MUA

The make-up air unit may be controlled to a higher degree to provide energy savings. This may be possible by installing a contaminant sensor as an input to control the MUA fans so they provide ventilation to match the activity level in the range. Not enough information is known about the current operation and control capabilities of this system to confirm the savings potential. We recommend working with a HVAC controls specialist or contractor to determine feasibility. For the AHU and MUA which serve the same area in the Police firing range, the installation of VFDs would need to be completed for all the supply and exhaust fans in order to maintain pressure balances. This measure should also investigate integrating the controls with the existing MUA fan motor VFDs. This measure should be considered in conjunction with ECM 4, the installation of variable speed drives.

We recommend this as a measure for further study.

5 ENERGY EFFICIENT BEST PRACTICES

A whole building maintenance plan will extend equipment life; improve occupant comfort, health, and safety; and reduce energy and maintenance costs. You may already be doing some of these things— see our list below for potential additions to your maintenance plan. Be sure to consult with qualified equipment specialists for details on proper maintenance and system operation.

Energy Tracking with ENERGY STAR® Portfolio Manager®



You've heard it before - you can't manage what you don't measure. ENERGY STAR® Portfolio Manager® is an online tool that you can use to measure and track energy and water consumption, as well as greenhouse gas emissions⁵. Your account has already been established. Now you can continue to keep tabs on your energy performance every month.

Weatherization

Caulk or weather strip leaky doors and windows to reduce drafts and loss of heated or cooled air. Sealing cracks and openings can reduce heating and cooling costs, improve building durability, and create a healthier indoor environment. Materials used may include caulk, polyurethane foam, and other weather-stripping materials. There is an energy savings opportunity by reducing the uncontrolled air exchange between the outside and inside of the building. Blower door assisted comprehensive building air sealing will reduce the amount of air exchange which will in turn reduce the load on the buildings heating and cooling equipment and thus providing energy savings and increased occupant comfort.

Doors and Windows

Close exterior doors and windows in heated and cooled areas. Leaving doors and windows open leads to a loss of heat during the winter and chilled air during the summer. Reducing air changes per hour (ACH) can lead to increased occupant comfort as well as heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

Window Treatments/Coverings

Use high-reflectivity films or cover windows with shades or shutters to reduce solar heat gain and reduce the load on cooling and heating systems. Older, single pane windows and east or west-facing windows are especially prone to solar heat gain. In addition, use shades or shutters at night during cold weather to reduce heat loss.

⁵ <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/use-portfolio-manager>.

Lighting Maintenance



- Clean lamps, reflectors and lenses of dirt, dust, oil, and smoke buildup every six to twelve months. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust. Together, this can reduce total light output by up to 60% while still drawing full power.
- In addition to routine cleaning, developing a maintenance schedule can ensure that maintenance is performed regularly, and it can reduce the overall cost of fixture re-lamping and re-ballasting. Group re-lamping and re-ballasting maintains lighting levels and minimizes the number of site visits by a lighting technician or contractor, decreasing the overall cost of maintenance.


Motor Maintenance

Motors have many moving parts. As these parts degrade over time, the efficiency of the motor is reduced. Routine maintenance prevents damage to motor components. Routine maintenance should include cleaning surfaces and ventilation openings on motors to prevent overheating, lubricating moving parts to reduce friction, inspecting belts and pulleys for wear and to ensure they are at proper alignment and tension, and cleaning and lubricating bearings. Consult a licensed technician to assess these and other motor maintenance strategies.

Fans to Reduce Cooling Load

Install ceiling fans to supplement your cooling system. Thermostat settings can typically be increased by 4°F with no change in overall occupant comfort due to the wind chill effect of moving air.

Thermostat Schedules and Temperature Resets



Use thermostat setback temperatures and schedules to reduce heating and cooling energy use during periods of low or no occupancy. Thermostats should be programmed for a setback of 5°F-10°F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

Economizer Maintenance

Economizers can significantly reduce cooling system load. A malfunctioning economizer can increase the amount of heating and mechanical cooling required by introducing excess amounts of cold or hot outside air. Common economizer malfunctions include broken outdoor thermostat or enthalpy control, or dampers that are stuck or improperly adjusted.

Periodic inspection and maintenance will keep economizers working in sync with the heating and cooling system. This maintenance should be part of annual system maintenance, and it should include proper setting of the outdoor thermostat/enthalpy control, inspection of control and damper operation, lubrication of damper connections, and adjustment of minimum damper position.

AC System Evaporator/Condenser Coil Cleaning

Dirty evaporator and condenser coils restrict air flow and restrict heat transfer. This increases the loads on the evaporator and condenser fan and decreases overall cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

HVAC Filter Cleaning and Replacement

Air filters should be checked regularly (often monthly) and cleaned or replaced when appropriate. Air filters reduce indoor air pollution, increase occupant comfort, and help keep equipment operating efficiently. If the building has a building management system, consider installing a differential pressure switch across filters to send an alarm about premature fouling or overdue filter replacement. Over time, filters become less and less effective as particulate buildup increases. Dirty filters also restrict air flow through the air conditioning or heat pump system, which increases the load on the distribution fans.

Boiler Maintenance

Many boiler problems develop slowly over time, so regular inspection and maintenance is essential to keeping the heating system running efficiently and preventing expensive repairs. Annual tune-ups should include a combustion analysis to analyze the exhaust from the boilers and to ensure the boiler is operating safely and efficiently. Boilers should be cleaned according to the manufacturer's instructions to remove soot and scale from the boiler tubes to improve heat transfer.

Furnace Maintenance

Preventative maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. Following the manufacturer's instructions, a yearly tune-up should: check for gas / carbon monoxide leaks; change the air and fuel filters; check components for cracks, corrosion, dirt, or debris build-up; ensure the ignition system is working properly; test and adjust operation and safety controls; inspect electrical connections; and lubricate motors and bearings.


Water Heater Maintenance

The lower the supply water temperature that is used for hand washing sinks, the less energy is needed to heat the water. Reducing the temperature results in energy savings and the change is often unnoticeable to users. Be sure to review the domestic water temperature requirements for sterilizers and dishwashers as you investigate reducing the supply water temperature.

Also, preventative maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. At least once a year, follow manufacturer instructions to drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Annual checks should include checks for:

- Leaks or heavy corrosion on the pipes and valves.
- Corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot, or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional.
- For electric water heaters, look for signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank.
- For water heaters more than three years old, have a technician inspect the sacrificial anode annually.

Plug Load Controls



Reducing plug loads is a common way to decrease your electrical use. Limiting the energy use of plug loads can include increasing occupant awareness, removing under-used equipment, installing hardware controls, and using software controls. Consider enabling the most aggressive power settings on existing devices or install load sensing or occupancy sensing (advanced) power strips⁶. Your local utility may offer incentives or rebates for this equipment.

Water Conservation



Installing dual flush or low-flow toilets and low-flow/waterless urinals are ways to reduce water use. The EPA WaterSense[®] ratings for urinals is 0.5 gallons per flush (gpf) and for flush valve toilets is 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

For more information regarding water conservation go to the EPA's WaterSense[®] website⁷ or download a copy of EPA's "WaterSense[®] at Work: Best Management Practices for Commercial and Institutional Facilities"⁸ to get ideas for creating a water management plan and best practices for a wide range of water using systems.

Water conservation devices that do not reduce hot water consumption will not provide energy savings at the site level, but they may significantly affect your water and sewer usage costs. Any reduction in water use does however ultimately reduce grid-level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users.

If the facility has detached buildings with a master water meter for the entire campus, check for unnatural wet areas in the lawn or water seeping in the foundation at water pipe penetrations through the foundation. Periodically check overnight meter readings when the facility is unoccupied, and there is no other scheduled water usage.

Manage irrigation systems to use water more effectively outside the building. Adjust spray patterns so that water lands on intended lawns and plantings and not on pavement and walls. Consider installing an evapotranspiration irrigation controller that will prevent over-watering.

Procurement Strategies

Purchasing efficient products reduces energy costs without compromising quality. Consider modifying your procurement policies and language to require ENERGY STAR[®] or WaterSense[®] products where available.

⁶ For additional information refer to "Assessing and Reducing Plug and Process Loads in Office Buildings" <http://www.nrel.gov/docs/fy13osti/54175.pdf>, or "Plug Load Best Practices Guide" <http://www.advancedbuildings.net/plug-load-best-practices-guide-offices>.

⁷ <https://www.epa.gov/watersense>.

⁸ <https://www.epa.gov/watersense/watersense-work-0>.

6 ON-SITE GENERATION

You don't have to look far in New Jersey to see one of the thousands of solar electric systems providing clean power to homes, businesses, schools, and government buildings. On-site generation includes both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) technologies that generate power to meet all or a portion of the facility's electric energy needs. Also referred to as distributed generation, these systems contribute to greenhouse gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, which results in improved electric grid reliability through better use of transmission and distribution systems.

Preliminary screenings were performed to determine if an on-site generation measure could be a cost-effective solution for your facility. Before deciding to install an on-site generation system, we recommend conducting a feasibility study to analyze existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.

6.1 Solar Photovoltaic

Photovoltaic (PV) panels convert sunlight into electricity. Individual panels are combined into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is then connected to the building's electrical distribution system.

A preliminary screening based on the facility's electric demand, size and location of free area, and shading elements shows that the facility has no potential for installing a PV array.

This facility does not appear to meet the minimum criteria for a cost-effective solar PV installation. To be cost-effective, a solar PV array needs certain minimum criteria, such as sufficient and sustained electric demand and sufficient flat or south-facing rooftop or other unshaded space on which to place the PV panels.

The graphic below displays the results of the PV potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.




Figure 9 - Photovoltaic Screening

6.2 Combined Heat and Power

Combined heat and power (CHP) generates electricity at the facility and puts waste heat energy to good use. Common types of CHP systems are reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines.

CHP systems typically produce a portion of the electric power used on-site, with the balance of electric power needs supplied by the local utility company. The heat is used to supplement (or replace) existing boilers and provide space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for space cooling.

The key criteria used for screening is the amount of time that the CHP system would operate at full load and the facility's ability to use the recovered heat. Facilities with a continuous need for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has no potential for installing a cost-effective CHP system.

Based on a preliminary analysis, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation. The low or infrequent thermal load is the most significant factor contributing to the lack of CHP potential.

The graphic below displays the results of the CHP potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.




Figure 10 - Combined Heat and Power Screening

7 PROJECT FUNDING AND INCENTIVES

Ready to improve your building’s performance? New Jersey’s Clean Energy Programs can help. Pick the program that works best for you. Incentive programs that may apply to this facility are identified in the Executive Summary. This section provides an overview of currently available New Jersey Clean Energy Programs.

	SmartStart <i>Flexibility to install at your own pace</i>	Direct Install <i>Turnkey installation</i>	Pay for Performance <i>Whole building upgrades</i>
Who should use it?	Buildings installing individual measures or small group of measures.	Small to mid-size facilities that can bundle multiple measures together. Average peak demand should be below 200 kW. Not suitable for significant building shell issues.	Mid to large size facilities looking to implement as many measures as possible at one time. Peak demand should be over 200 kW.
How does it work?	Use in-house staff or your preferred contractor.	Pre-approved contractors pass savings along to you via reduced material and labor costs.	Whole-building approach to energy upgrades designed to reduce energy use by at least 15%. The more you save, the higher the incentives.
What are the Incentives?	Fixed incentives for specific energy efficiency measures.	Incentives pay up to 70% of eligible costs, up to \$125,000 per project. You pay the remaining 30% directly to the contractor.	Up to 25% of installation cost, calculated based on level of energy savings per square foot.
How do I participate?	Submit an application for the specific equipment to be installed.	Contact a participating contractor in your region.	Contact a pre-qualified Partner to develop your Energy Reduction Plan and set your energy savings targets.
Take the next step by visiting www.njcleanenergy.com for program details, applications, and to contact a qualified contractor.			

7.1 SmartStart



SmartStart offers incentives for installing prescriptive and custom energy efficiency measures at your facility. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades. This program serves most common equipment types and sizes.

SmartStart routinely adds, removes, or modifies incentives from year-to-year for various energy-efficient equipment based on market trends and new technologies.

Equipment with Prescriptive Incentives Currently Available:

Electric Chillers
Electric Unitary HVAC
Gas Cooling
Gas Heating
Gas Water Heating
Ground Source Heat Pumps
Lighting

Lighting Controls
Refrigeration Doors
Refrigeration Controls
Refrigerator/Freezer Motors
Food Service Equipment
Variable Frequency Drives

Incentives

The SmartStart Prescriptive program provides fixed incentives for specific energy efficiency measures. Prescriptive incentives vary by equipment type.

SmartStart Custom provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentives. Custom incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings. Incentives are capped at 50% of the total installed incremental project cost, or a project cost buy down to a one-year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

How to Participate

Submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. You can work with your preferred contractor or use internal staff to install measures.

Visit www.njcleanenergy.com/SSB for a detailed program description, instructions for applying, and applications.

7.2 Direct Install



Direct Install is a turnkey program available to existing small to medium-sized facilities with an average peak electric demand that does not exceed 200 kW over the recent 12-month period. You work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for

installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives, and controls.

Incentives

The program pays up to 70% of the total installed cost of eligible measures, up to \$125,000 per project. Each entity is limited to incentives up to \$250,000 per fiscal year.

How to Participate

To participate in Direct Install, you will need to contact the participating contractor assigned to the region of the state where your facility is located. A complete list of Direct Install program partners is provided on the Direct Install website linked below. The contractor will be paid the measure incentives directly by the program, which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the program, subject to program caps and eligibility, while the remaining 30% of the cost is paid to the contractor by the customer.

Detailed program descriptions and applications can be found at: www.njcleanenergy.com/DI.

7.3 Pay for Performance - Existing Buildings



Pay for Performance works for larger customers with a peak demand over 200 kW. The minimum installed scope of work must include at least two unique measures that results in at least 15% source energy savings, and lighting cannot make up the majority of the savings. P4P is a generally a good option for medium-to-large sized facilities looking to implement as many

measures as possible under a single project to achieve deep energy savings. This program has an added benefit of addressing measures that may not qualify for other programs. Many facilities pursuing an Energy Savings Improvement Program loan also use this program.

Based on the site building and utility data provided, the facility does not meet the requirements of the current P4P program.

Incentives

Incentives are based on estimated and achieved energy savings ranging from \$0.18-\$0.22/kWh and \$1.80-\$2.50/therm, capped at the lesser of 50% total project cost, or \$1 million per electric account and \$1 million per natural gas account, per fiscal year, not to exceed \$2 million per project. An incentive of \$0.15/square foot is also available to offset the cost of developing the Energy Reduction Plan (see below) contingent on the project moving forward with measure installation.

How to Participate

Contact one of the pre-approved consultants and contractors (“Partners”). Under direct contract to you, they will help further evaluate the measures identified in this report through development of the energy reduction plan), assist you in implementing selected measures, and verify actual savings one year after the installation. Your Partner will also help you apply for incentives.

Approval of the final scope of work is required by the program prior to installation. Installation can be done by the contractor of your choice (some P4P Partners are also contractors) or by internal staff, but the Partner remains involved throughout construction to ensure compliance with the program requirements.

Detailed program descriptions, instructions for applying, applications and list of Partners can be found at: www.njcleanenergy.com/P4P.

7.4 Combined Heat and Power

The Combined Heat & Power (CHP) program provides incentives for eligible CHP or waste heat to power (WHP) projects. Eligible CHP or WHP projects must achieve an annual system efficiency of at least 65% (lower heating value, or LHV), based on total energy input and total utilized energy output. Mechanical energy may be included in the efficiency evaluation.

Incentives

Eligible Technologies	Size (Installed Rated Capacity) ¹	Incentive (\$/kW)	% of Total Cost Cap per Project ³	\$ Cap per Project ³
Powered by non-renewable or renewable fuel source ⁴	≤500 kW	\$2,000	30-40% ²	\$2 million
	Gas Internal Combustion Engine	>500 kW - 1 MW		
Gas Combustion Turbine	> 1 MW - 3 MW	\$550	30%	\$3 million
Microturbine	>3 MW	\$350		
Fuel Cells with Heat Recovery				
Waste Heat to Power*	<1 MW	\$1,000	30%	\$2 million
	> 1MW	\$500		\$3 million

*Waste Heat to Power: Powered by non-renewable fuel source, heat recovery or other mechanical recovery from existing equipment utilizing new electric generation equipment (e.g. steam turbine).

Check the NJCEP website for details on program availability, current incentive levels, and requirements.

How to Participate

You work with a qualified developer or consulting firm to complete the CHP application. Once the application is approved the project can be installed. Information about the CHP program can be found at: www.njcleanenergy.com/CHP.

7.5 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) serves New Jersey's government agencies by financing energy projects. An ESIP is a type of performance contract, whereby school districts, counties, municipalities, housing authorities and other public and state entities enter into contracts to help finance building energy upgrades. Annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive for the life of the contract.

ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs described above can also be used to help further reduce the total project cost of eligible measures.

How to Participate

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an energy services company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is used for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the energy savings plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Carefully consider all alternatives to develop an approach that best meets your needs. A detailed program description and application can be found at: www.njcleanenergy.com/ESIP.

ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you can use NJCEP incentive programs to help further reduce costs when developing the energy savings plan. Refer to the ESIP guidelines at the link above for further information and guidance on next steps.

7.6 SREC Registration Program

The SREC (Solar Renewable Energy Certificate) Registration Program (SRP) is used to register the intent to install solar projects in New Jersey. Rebates are not available for solar projects, but owners of solar projects *must* register their projects prior to the start of construction to establish the project's eligibility to earn SRECs. Registration of the intent to participate in New Jersey's solar marketplace provides market participants with information about the pipeline of anticipated new solar capacity and insight into future SREC pricing.

After the registration is accepted, construction is complete, and final paperwork has been submitted and is deemed complete, the project is issued a New Jersey certification number, which enables it to generate New Jersey SRECs. SRECs are generated once the solar project has been authorized to be energized by the Electric Distribution Company (EDC).

Each time a solar installation generates 1,000 kilowatt-hours (kWh) of electricity, an SREC is earned. Solar project owners report the energy production to the SREC Tracking System. This reporting allows SRECs to be placed in the customer's electronic account. SRECs can then be sold on the SREC Tracking System, providing revenue for the first 15 years of the project's life.

Electricity suppliers, the primary purchasers of SRECs, are required to pay a Solar Alternative Compliance Payment (SACP) if they do not meet the requirements of New Jersey's Solar Renewable Portfolio Standard. Purchasing SRECs can help them meet those requirements. As SRECs are traded in a competitive market, the price may vary significantly. The actual price of an SREC during a trading period fluctuates depending on supply and demand.

Information about the SRP can be found at: www.njcleanenergy.com/srec.

8 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

8.1 Retail Electric Supply Options

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third-party supplier, consider shopping for a reduced rate from third-party electric suppliers. If your facility already buys electricity from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party electric suppliers is available at the NJBPU website⁹.

8.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey is also deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate monthly. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third-party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier typically depends on whether a customer prefers budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third-party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility does not already purchase natural gas from a third-party supplier, consider shopping for a reduced rate from third-party natural gas suppliers. If your facility already purchases natural gas from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party natural gas suppliers is available at the NJBPU website¹⁰.

⁹ www.state.nj.us/bpu/commercial/shopping.html.

¹⁰ www.state.nj.us/bpu/commercial/shopping.html.

APPENDIX A: EQUIPMENT INVENTORY & RECOMMENDATIONS

Lighting Inventory & Recommendations

Location	Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis								
	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Police Firing Range Stairs	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch		29	8,736		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	8,736	0.0	0	0	\$0	\$0	\$0	0.0
Hallway	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	8,736		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	8,736	0.0	0	0	\$0	\$0	\$0	0.0
Restroom	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	4,368		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,368	0.0	0	0	\$0	\$0	\$0	0.0
Firing Range Office	3	LED - Fixtures: Ambient 2x2 Fixture	Wall Switch	S	20	4,368	2	None	Yes	3	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	20	3,014	0.0	88	0	\$14	\$270	\$70	14.6
Firing Range Office	7	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	S	17	4,368	2	None	Yes	7	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	3,014	0.0	174	0	\$27	\$270	\$70	7.3
Closet	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	S	17	1,456		None	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	1,456	0.0	0	0	\$0	\$0	\$0	0.0
Firing Range	70	LED Lamps: 15W PAR38 Screw in Lamps	Wall Switch	S	15	4,368		None	No	70	LED Lamps: 15W PAR38 Screw in Lamps	Wall Switch	15	4,368	0.0	0	0	\$0	\$0	\$0	0.0
Office	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	4,368	2	None	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,014	0.0	170	0	\$27	\$270	\$70	7.5
Office	4	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	S	17	4,368	2	None	Yes	4	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	3,014	0.0	99	0	\$16	\$270	\$70	12.8
Office	2	LED - Fixtures: Downlight Recessed	Wall Switch	S	10	4,368	2	None	Yes	2	LED - Fixtures: Downlight Recessed	Occupancy Sensor	10	3,014	0.0	29	0	\$5	\$0	\$0	0.0
Office	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	4,368	2	None	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,014	0.0	127	0	\$20	\$270	\$70	10.0
Exterior	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Photocell		23	4,380		None	No	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Photocell	23	4,380	0.0	0	0	\$0	\$0	\$0	0.0
Exterior	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Photocell		23	4,380		None	No	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Photocell	23	4,380	0.0	0	0	\$0	\$0	\$0	0.0
Exterior	2	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Photocell		9	4,380		None	No	2	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Photocell	9	4,380	0.0	0	0	\$0	\$0	\$0	0.0
Exterior	2	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Photocell		30	4,380		None	No	2	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Photocell	30	4,380	0.0	0	0	\$0	\$0	\$0	0.0
Exterior	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Photocell		14	4,380		None	No	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Photocell	14	4,380	0.0	0	0	\$0	\$0	\$0	0.0
Exterior	3	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Photocell		14	4,380		None	No	3	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Photocell	14	4,380	0.0	0	0	\$0	\$0	\$0	0.0
Exterior	2	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Photocell		9	4,380		None	No	2	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Photocell	9	4,380	0.0	0	0	\$0	\$0	\$0	0.0
Garage	15	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	8,736	2	None	Yes	15	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	6,028	0.1	1,272	0	\$199	\$540	\$140	2.0
Garage	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	S	15	8,736		None	No	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	8,736	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen/Lounge	4	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	S	17	8,736	2	None	Yes	4	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	6,028	0.0	199	0	\$31	\$270	\$70	6.4
Kitchen/Lounge	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	8,736	2	None	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	6,028	0.0	170	0	\$27	\$0	\$0	0.0
Pantry	1	Compact Fluorescent: 32W PAR38 Screw in Lamp	Wall Switch	S	32	1,456	1,2	Relamp	Yes	1	LED Lamps: Screw in Lamp	Occupancy Sensor	18	1,005	0.0	31	0	\$5	\$133	\$2	27.2
Office	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	8,736	2	None	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	6,028	0.0	170	0	\$27	\$116	\$0	4.4
Vestibule	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	S	17	8,736	3	None	Yes	1	LED - Linear Tubes: (2) 2' Lamps	High/Low Control	17	6,028	0.0	50	0	\$8	\$225	\$0	28.9

Location	Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis								
	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Under Counter	1	Linear Fluorescent - T8: 2' T8 (17W) - 1L	Wall Switch	S	22	8,736	1	Relamp	No	1	LED - Linear Tubes: (1) 2' Lamp	Wall Switch	9	8,736	0.0	127	0	\$20	\$16	\$6	0.5
Under Counter	1	Linear Fluorescent - T8: 3' T8 (25W) - 1L	Wall Switch	S	27	8,736	1	Relamp	No	1	LED - Linear Tubes: (1) 3' Lamp	Wall Switch	11	8,736	0.0	156	0	\$24	\$18	\$10	0.3
Restroom	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	8,736		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	8,736	0.0	0	0	\$0	\$0	\$0	0.0
Restroom	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	8,736	2	None	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	6,028	0.0	85	0	\$13	\$270	\$70	15.1
Restroom	1	LED Lamps: 9W Screw in Lamp	Wall Switch	S	9	8,736	2	None	Yes	1	LED Lamps: 9W Screw in Lamp	Occupancy Sensor	9	6,028	0.0	26	0	\$4	\$0	\$0	0.0
Dorm Room	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	4,368		None	No	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,368	0.0	0	0	\$0	\$0	\$0	0.0
Dorm Room	2	LED - Fixtures: Downlight Recessed	Wall Switch	S	10	4,368		None	No	2	LED - Fixtures: Downlight Recessed	Wall Switch	10	4,368	0.0	0	0	\$0	\$0	\$0	0.0
Hallway	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	S	17	8,736		None	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	8,736	0.0	0	0	\$0	\$0	\$0	0.0
Work Out Room	3	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	S	15	8,736	2	None	Yes	3	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	6,028	0.0	127	0	\$20	\$270	\$0	13.6
Closet	1	LED Lamps: 7W Screw in Lamp	Wall Switch	S	7	1,456		None	No	1	LED Lamps: 7W Screw in Lamp	Wall Switch	7	1,456	0.0	0	0	\$0	\$0	\$0	0.0
Closet	1	LED Lamps: 7W Screw in Lamp	Wall Switch	S	7	1,456		None	No	1	LED Lamps: 7W Screw in Lamp	Wall Switch	7	1,456	0.0	0	0	\$0	\$0	\$0	0.0
Closet	1	LED Lamps: 7W Screw in Lamp	Wall Switch	S	7	1,456		None	No	1	LED Lamps: 7W Screw in Lamp	Wall Switch	7	1,456	0.0	0	0	\$0	\$0	\$0	0.0
Hallway	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	S	17	8,736		None	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	8,736	0.0	0	0	\$0	\$0	\$0	0.0
Dorm Room	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	4,368		None	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,368	0.0	0	0	\$0	\$0	\$0	0.0
Dorm Room	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	4,368		None	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,368	0.0	0	0	\$0	\$0	\$0	0.0
Restroom	1	LED Lamps: 9W Screw in Lamp	Wall Switch	S	9	8,736		None	No	1	LED Lamps: 9W Screw in Lamp	Wall Switch	9	8,736	0.0	0	0	\$0	\$0	\$0	0.0
Stairs	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch		29	8,736		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	8,736	0.0	0	0	\$0	\$0	\$0	0.0
Transition Spaces	4	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	4	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0

Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions							Proposed Conditions					Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Remaining Useful Life	Annual Operating Hours	ECM #	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Police Firing Range	MUA-1	4	Supply Fan	20.0	93.0%	Yes	N	640		No	93.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Police Firing Range	AHU-1	2	Supply Fan	10.0	91.7%	No	W	1,130	4	No	91.7%	Yes	2	5.7	6,897	0	\$1,092	\$10,750	\$4,400	5.8
Police Firing Range	HVAC-1	1	Supply Fan	0.5	65.0%	No	W	640		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Fire Station No. 4	Hot Water Pumps	2	Heating Hot Water Pump	0.2	65.0%	No	W	915		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Fire Station No. 4	Overhead Doors	2	Other	0.2	65.0%	No	W	365		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Police Firing Range	MUA-1	1	Combustion Air Fan	0.8	65.0%	No	N	640		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Police Firing Range	MUA-1	2	Exhaust Fan	25.0	93.6%	Yes	N	640		No	93.6%	No		0.0	0	0	\$0	\$0	\$0	0.0

Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions							Energy Impact & Financial Analysis					
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (MBh)	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (MBh)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives
Outside Police	MUA-1	1	Split-System AC	60.00		W		No						0.0	0	0	\$0	\$0	\$0	0.0
Outside Police	Outdoor Condensing Unit	1	Split-System AC	5.00		W		No						0.0	0	0	\$0	\$0	\$0	0.0
Fire Station No. 4	Outdoor Condensing Unit	1	Split-System Air-Source HP	5.00	30.00	W		No						0.0	0	0	\$0	\$0	\$0	0.0
Fire Station No. 4	Kitchen/Lounge	1	Window AC	0.67		W		No						0.0	0	0	\$0	\$0	\$0	0.0

Fuel Heating Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis					
		System Quantity	System Type	Output Capacity per Unit (MBh)	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Outside Police	Police Firing Range (MUA-1)	1	Furnace	1,250	N		No						0.0	0	0	\$0	\$0	\$0	0.0
Garage	Space Heating	2	Warm Air Unit Heater	125	W	6	Yes	2	Infrared Unit Heater	125	93.00%	Et	0.0	0	24	\$204	\$5,820	\$1,200	22.7
Fire Station No. 4	Space Heating	1	Non-Condensing Hot Water Boiler	550	W	5	Yes	1	Condensing Hot Water Boiler	550	91.00%	Et	0.0	0	38	\$319	\$13,202	\$2,420	33.8

DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions			Proposed Conditions							Energy Impact & Financial Analysis						
		System Quantity	System Type	Remaining Useful Life	ECM #	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Mechanical Room	Domestic Hot Water	1	Storage Tank Water Heater (≤ 50 Gal)	W		No						0.0	0	0	\$0	\$0	\$0	0.0

Low-Flow Device Recommendations

Location	Recommendation Inputs					Energy Impact & Financial Analysis						
	ECM #	Device Quantity	Device Type	Existing Flow Rate (gpm)	Proposed Flow Rate (gpm)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Restrooms	7	3	Faucet Aerator (Lavatory)	2.20	0.50	0.0	0	1	\$12	\$22	\$22	0.0

Cooking Equipment Inventory & Recommendations

Location	Existing Conditions				Proposed Conditions		Energy Impact & Financial Analysis						
	Quantity	Equipment Type		High Efficiency Equipment?	ECM #	Install High Efficiency Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen	1	Gas Convection Oven (Full Size)		Yes		No	0.0	0	0	\$0	\$0	\$0	0.0

Dishwasher Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions		Energy Impact & Financial Analysis								
	Quantity	Dishwasher Type			Water Heater Fuel Type	Booster Heater Fuel Type	ENERGY STAR Qualified?	ECM #	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Payback w/ Incentives in Years
Kitchen	1	Under Counter (High Temp)			Electric	None	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0

Plug Load Inventory

Existing Conditions				
Location	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
Police Firing Range	3	Computer	125	
Police Firing Range	1	Speaker	250	
Police Firing Range	1	Coffee Machine	800	
Police Firing Range	1	Mini Fridge	260	
Police Firing Range	2	Microwave	700	
Police Firing Range	1	TV	55	
Police Firing Range	7	Moving Target System	373	
Fire Station No.4	2	Computer	125	
Fire Station No.4	1	Medium Printer	100	
Fire Station No.4	3	Fan	100	
Fire Station No.4	3	TV	55	
Fire Station No.4	1	Radio	25	
Fire Station No.4	2	Coffee Machine	800	
Fire Station No.4	1	Large Coffee Machine	1,600	
Fire Station No.4	1	Microwave	700	
Fire Station No.4	1	Ceiling Fan	125	
Fire Station No.4	1	Large Refrigerator	1,100	
Fire Station No.4	1	Electric Space Heater	1,500	
Fire Station No.4	1	Clothes Washer/Dryer	3,000	
Fire Station No.4	1	Misc Server Load	1,200	

Vending Machine Inventory & Recommendations

Existing Conditions		Proposed Conditions			Energy Impact & Financial Analysis						
Location	Quantity	Vending Machine Type	ECM #	Install Controls?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Fire Station No. 4	1	Refrigerated	8	Yes	0.2	1,612	0	\$255	\$230	\$100	0.5

APPENDIX B: ENERGY STAR® STATEMENT OF ENERGY PERFORMANCE

EUI is presented in terms of *site energy* and *source energy*. Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

ENERGY STAR® Statement of Energy Performance

LEARN MORE AT energystar.gov

N/A

Clifton Fire Station No. 4

Primary Property Type: Fire Station
Gross Floor Area (ft²): 9,060
Built: 1968

For Year Ending: April 30, 2019
Date Generated: March 01, 2020

ENERGY STAR®
Score¹

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information			
Property Address Clifton Fire Station No. 4 144 Main Avenue Clifton, New Jersey 07014	Property Owner City of Clifton 900 Clifton Avenue Clifton, NJ 07013 (973) 470-5854	Primary Contact Dominick Villano 900 Clifton Avenue Clifton, NJ 07013 (973) 470-5854 dvillano@cliftonnj.org	
Property ID: 9002088			

Energy Consumption and Energy Use Intensity (EUI)			
Site EUI 166.3 kBtu/ft ²	Annual Energy by Fuel Electric - Grid (kBtu) 382,655 (25%) Natural Gas (kBtu) 1,124,095 (75%)	National Median Comparison National Median Site EUI (kBtu/ft ²) 83.6 National Median Source EUI (kBtu/ft ²) 124.9 % Diff from National Median Source EUI 99%	
Source EUI 248.5 kBtu/ft ²	Annual Emissions Greenhouse Gas Emissions (Metric Tons CO ₂ /year) 98		

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

LP Signature: _____ Date: _____

Licensed Professional

() _____



Professional Engineer or Registered Architect Stamp (if applicable)

APPENDIX C: GLOSSARY

TERM	DEFINITION
Blended Rate	Used to calculate fiscal savings associated with measures. The blended rate is calculated by dividing the amount of your bill by the total energy use. For example, if your bill is \$22,217.22, and you used 266,400 kilowatt-hours, your blended rate is 8.3 cents per kilowatt-hour.
Btu	<i>British thermal unit</i> : a unit of energy equal to the amount of heat required to increase the temperature of one pound of water by one-degree Fahrenheit.
CHP	<i>Combined heat and power</i> . Also referred to as cogeneration.
COP	<i>Coefficient of performance</i> : a measure of efficiency in terms of useful energy delivered divided by total energy input.
Demand Response	Demand response reduces or shifts electricity usage at or among participating buildings/sites during peak energy use periods in response to time-based rates or other forms of financial incentives.
DCV	<i>Demand control ventilation</i> : a control strategy to limit the amount of outside air introduced to the conditioned space based on actual occupancy need.
US DOE	<i>United States Department of Energy</i>
EC Motor	<i>Electronically commutated motor</i>
ECM	<i>Energy conservation measure</i>
EER	<i>Energy efficiency ratio</i> : a measure of efficiency in terms of cooling energy provided divided by electric input.
EUI	<i>Energy Use Intensity</i> : measures energy consumption per square foot and is a standard metric for comparing buildings' energy performance.
Energy Efficiency	Reducing the amount of energy necessary to provide comfort and service to a building/area. Achieved through the installation of new equipment and/or optimizing the operation of energy use systems. Unlike conservation, which involves some reduction of service, energy efficiency provides energy reductions without sacrifice of service.
ENERGY STAR®	ENERGY STAR® is the government-backed symbol for energy efficiency. The ENERGY STAR® program is managed by the EPA.
EPA	<i>United States Environmental Protection Agency</i>
Generation	The process of generating electric power from sources of primary energy (e.g., natural gas, the sun, oil).
GHG	<i>Greenhouse gas</i> gases that are transparent to solar (short-wave) radiation but opaque to long-wave (infrared) radiation, thus preventing long-wave radiant energy from leaving Earth's atmosphere. The net effect is a trapping of absorbed radiation and a tendency to warm the planet's surface.
gpf	<i>Gallons per flush</i>

gpm	<i>Gallon per minute</i>
HID	<i>High intensity discharge: high-output lighting lamps such as high-pressure sodium, metal halide, and mercury vapor.</i>
hp	<i>Horsepower</i>
HPS	<i>High-pressure sodium: a type of HID lamp</i>
HSPF	<i>Heating seasonal performance factor: a measure of efficiency typically applied to heat pumps. Heating energy provided divided by seasonal energy input.</i>
HVAC	<i>Heating, ventilating, and air conditioning</i>
IHP 2014	<i>US DOE Integral Horsepower rule. The current ruling regarding required electric motor efficiency.</i>
IPLV	<i>Integrated part load value: a measure of the part load efficiency usually applied to chillers.</i>
kBtu	<i>One thousand British thermal units</i>
kW	<i>Kilowatt: equal to 1,000 Watts.</i>
kWh	<i>Kilowatt-hour: 1,000 Watts of power expended over one hour.</i>
LED	<i>Light emitting diode: a high-efficiency source of light with a long lamp life.</i>
LGEA	<i>Local Government Energy Audit</i>
Load	<i>The total power a building or system is using at any given time.</i>
Measure	<i>A single activity, or installation of a single type of equipment, that is implemented in a building system to reduce total energy consumption.</i>
MH	<i>Metal halide: a type of HID lamp</i>
MBh	<i>Thousand Btu per hour</i>
MBtu	<i>One thousand British thermal units</i>
MMBtu	<i>One million British thermal units</i>
MV	<i>Mercury Vapor: a type of HID lamp</i>
NJBPU	<i>New Jersey Board of Public Utilities</i>
NJCEP	<i>New Jersey's Clean Energy Program: NJCEP is a statewide program that offers financial incentives, programs and services for New Jersey residents, business owners and local governments to help them save energy, money and the environment.</i>
psig	<i>Pounds per square inch gauge</i>
Plug Load	<i>Refers to the amount of power used in a space by products that are powered by means of an ordinary AC plug.</i>
PV	<i>Photovoltaic: refers to an electronic device capable of converting incident light directly into electricity (direct current).</i>

SEER	<i>Seasonal energy efficiency ratio</i> : a measure of efficiency in terms of annual cooling energy provided divided by total electric input.
SEP	<i>Statement of energy performance</i> : a summary document from the ENERGY STAR® Portfolio Manager®.
Simple Payback	The amount of time needed to recoup the funds expended in an investment or to reach the break-even point between investment and savings.
SREC	<i>Solar renewable energy credit</i> : a credit you can earn from the state for energy produced from a photovoltaic array.
T5, T8, T12	A reference to a linear lamp diameter. The number represents increments of 1/8 th of an inch.
Temperature Setpoint	The temperature at which a temperature regulating device (thermostat, for example) has been set.
therm	100,000 Btu. Typically used as a measure of natural gas consumption.
tons	A unit of cooling capacity equal to 12,000 Btu/hr.
Turnkey	Provision of a complete product or service that is ready for immediate use
VAV	<i>Variable air volume</i>
VFD	<i>Variable frequency drive</i> : a controller used to vary the speed of an electric motor.
WaterSense®	The symbol for water efficiency. The WaterSense® program is managed by the EPA.
Watt (W)	Unit of power commonly used to measure electricity use.