



Local Government Energy Audit: Energy Audit Report



Copyright ©2017 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Field House

1 Normal Ave

Montclair, New Jersey 07043

Montclair State University

July 11, 2018

Final Report by:

TRC Energy Services

Disclaimer

The intent of this energy analysis report is to identify energy savings opportunities and recommend upgrades to the facility's energy using equipment and systems. Approximate savings are included in this report to help make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. Further design and analysis may be necessary in order to implement some of the measures recommended in this report.

The energy conservation measures and estimates of energy savings have been reviewed for technical accuracy. However, estimates of final energy savings are not guaranteed, because final savings may depend on behavioral factors and other uncontrollable variables. TRC Energy Services (TRC) and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

Estimated installation costs are based on TRC's experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from *RS Means*. The owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for certain measures and conditions, TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. The owner of the facility should review available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

Table of Contents

1	Executive Summary.....	1
1.1	Facility Summary	1
1.2	Your Cost Reduction Opportunities.....	1
	Energy Conservation Measures.....	1
	Energy Efficient Practices	3
	On-Site Generation Measures.....	3
1.3	Implementation Planning.....	4
2	Facility Information and Existing Conditions	6
2.1	Project Contacts	6
2.2	General Site Information.....	6
2.3	Building Occupancy	6
2.4	Building Envelope	7
2.5	On-Site Generation.....	7
2.6	Energy-Using Systems	8
	Lighting System	8
	Heating Ventilation and Air Conditioning System	8
	Building Plug Load	9
3	Site Energy Use and Costs.....	10
3.1	Total Cost of Energy	10
3.2	Electricity Usage	11
3.3	Benchmarking.....	12
3.4	Energy End-Use Breakdown	13
4	Energy Conservation Measures	14
4.1	High Priority ECMs.....	14
4.2	Lighting Upgrades.....	15
	ECM 1: Install LED Fixtures	15
	ECM 2: Retrofit Fluorescent Fixtures with LED Lamps and Drivers.....	16
	ECM 3: Retrofit Fixtures with LED Lamps.....	16
4.3	Lighting Control Measures	17
	ECM 4: Install Occupancy Sensor Lighting Controls	17
4.4	Variable Frequency Drive Measures	18
	ECM 5: Install VFDs on Constant Volume (CV) HVAC	18
4.5	Domestic Hot Water Heating System Upgrades	19
	ECM 6: Install Low-Flow DHW Devices.....	19
5	Energy Efficient Practices	20
	Perform Proper Lighting Maintenance.....	20
	Develop a Lighting Maintenance Schedule	20
	Clean Evaporator/Condenser Coils on AC Systems	20

Clean and/or Replace HVAC Filters	20
Perform Proper Water Heater Maintenance	21
Plug Load Controls.....	21
6 On-Site Generation Measures	22
6.1 Photovoltaic.....	22
6.2 Combined Heat and Power	23
7 Demand Response	24
8 Project Funding / Incentives	25
8.1 SmartStart	26
8.2 Pay for Performance - Existing Buildings.....	27
8.3 Energy Savings Improvement Program	28
9 Energy Purchasing and Procurement Strategies	29
9.1 Retail Electric Supply Options.....	29
9.2 Retail Natural Gas Supply Options	29

Appendix A: Equipment Inventory & Recommendations

Appendix B: ENERGY STAR® Statement of Energy Performance

Table of Figures

Figure 1 – Previous 12 Month Utility Costs..... 2

Figure 2 – Potential Post-Implementation Costs 2

Figure 3 – Summary of Energy Reduction Opportunities 2

Figure 4 – Project Contacts 6

Figure 5 - Building Schedule..... 6

Figure 6 – Building Façade 7

Figure 7 - Building Lighting Systems 8

Figure 8 – DX Split System..... 8

Figure 9 - Utility Summary 10

Figure 10 - Energy Cost Breakdown 10

Figure 11 - Electric Usage & Demand..... 11

Figure 12 - Electric Usage & Demand..... 11

Figure 13 - Energy Use Intensity Comparison – Existing Conditions..... 12

Figure 14 - Energy Use Intensity Comparison – Following Installation of Recommended Measures 12

Figure 15 - Energy Balance (% and kBtu/SF) 13

Figure 16 – Summary of High Priority ECMs 14

Figure 17 – Summary of Lighting Upgrade ECMs..... 15

Figure 18 – Summary of Lighting Control ECMs 17

Figure 19 – Summary of Variable Frequency Drive ECMs 18

Figure 20 - Summary of Domestic Water Heating ECMs 19

Figure 21 - ECM Incentive Program Eligibility 25

I EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBPU) has sponsored this Local Government Energy Audit (LGEA) Report for Field House.

The goal of an LGEA report is to provide you with information on how your facility uses energy, identify energy conservation measures (ECMs) that can reduce your energy use, and provide information and assistance to help facilities implement ECMs. The LGEA report also contains valuable information on financial incentives from New Jersey's Clean Energy Program (NJCEP) for implementing ECMs.

This study was conducted by TRC Energy Services (TRC), as part of a comprehensive effort to assist New Jersey higher education facilities in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

I.1 Facility Summary

Field House is a 7,376-square foot facility constructed in 1982. The building is two stories and includes an office, soccer rooms, fitness rooms, locker rooms, mechanical spaces, and electrical rooms.

Lighting at the field house consists of a combination of 32-Watt T8 fluorescent fixtures, 40-Watt T12 fluorescent fixtures, and 75-Watt incandescent fixtures; all of which are inefficient in performance when compared to the latest lighting technology available in the market. Exterior lighting is provided by a combination of 400-Watt Metal Halide fixtures and 23-Watt compact fluorescent fixtures. Lighting control is provided by manual switches for interior fixtures and photocells for exterior fixtures.

Cooling is provided by split system DX and package terminal air conditioning systems.

A thorough description of the facility and our observations are located in Section 2.

I.2 Your Cost Reduction Opportunities

Energy Conservation Measures

TRC evaluated and recommends six (6) measures which together represent an opportunity for Field House to reduce annual energy costs by \$4,233 and annual greenhouse gas emissions by 25,374 lbs CO₂e. We estimate that if all high priority measures are implemented as recommended, the project will pay for itself in 2.9 years. TRC has defined high priority measures as the evaluated measures that have a simple payback less than the typical equipment life of the proposed equipment. The breakdown of existing and potential utility costs after project implementation are illustrated in Figure 1 and Figure 2, respectively. Together these measures represent an opportunity to reduce Field House's annual energy use by 26%.

Figure 1 – Previous 12 Month Utility Costs





Figure 2 – Potential Post-Implementation Costs



A detailed description of Field House’s existing energy use can be found in Section 3.

Estimates of the total cost, energy savings, and financial incentives for the evaluated energy efficient upgrades are summarized below in Figure 3. A brief description of each category can be found below and a description of savings opportunities can be found in Section 4.

Figure 3 – Summary of Energy Reduction Opportunities

Energy Conservation Measure		High Priority?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades			15,712	2.3	0.0	\$2,639.64	\$6,544.10	\$715.00	\$5,829.10	2.2	15,822
ECM 1	Install LED Fixtures	Yes	2,801	0.4	0.0	\$470.53	\$781.35	\$200.00	\$581.35	1.2	2,820
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	Yes	8,076	1.2	0.0	\$1,356.84	\$4,022.00	\$310.00	\$3,712.00	2.7	8,133
ECM 3	Retrofit Fixtures with LED Lamps	Yes	4,835	0.7	0.0	\$812.27	\$1,740.74	\$205.00	\$1,535.74	1.9	4,869
Lighting Control Measures			1,254	0.2	0.0	\$210.68	\$3,240.00	\$420.00	\$2,820.00	13.4	1,263
ECM 4	Install Occupancy Sensor Lighting Controls	Yes	1,254	0.2	0.0	\$210.68	\$3,240.00	\$420.00	\$2,820.00	13.4	1,263
Variable Frequency Drive (VFD) Measures			4,266	1.5	0.0	\$716.72	\$3,275.85	\$400.00	\$2,875.85	4.0	4,296
ECM 5	Install VFDs on Constant Volume (CV) HVAC	Yes	4,266	1.5	0.0	\$716.72	\$3,275.85	\$400.00	\$2,875.85	4.0	4,296
Domestic Water Heating Upgrade			3,965	0.0	0.0	\$666.13	\$936.02	\$0.00	\$936.02	1.4	3,993
ECM 6	Install Low-Flow Domestic Hot Water Devices	Yes	3,965	0.0	0.0	\$666.13	\$936.02	\$0.00	\$936.02	1.4	3,993
TOTALS FOR HIGH PRIORITY MEASURES			25,197	4.0	0.0	\$4,233.17	\$13,995.97	\$1,535.00	\$12,460.97	2.9	25,374
TOTALS FOR ALL EVALUATED MEASURES			25,197	4.0	0.0	\$4,233.17	\$13,995.97	\$1,535.00	\$12,460.97	2.9	25,374

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Lighting Upgrades generally involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measure save energy by reducing the power used by the lighting components due to improved electrical efficiency.

Lighting Controls measures generally involve the installation of automated controls to turn off lights or reduce light output when not needed. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

Variable Frequency Drives (VFDs) are motor control devices. These measures control the speed of a motor so that the motor spins at peak efficiency during partial load conditions. Sensors adapt the speed

to flow, temperature, or pressure settings which is much more efficient than using a valve or damper to control flow rates, or running the motor at full speed when only partial power is needed. These measures save energy by controlling motor usage more efficiently.

Domestic Hot Water upgrade measures generally involve replacing older inefficient domestic water heating systems with modern energy efficient systems. New domestic hot water heating systems can provide equivalent, or greater, water heating capacity compared to older systems at a reduced energy cost. These measures save energy by reducing the fuel used for domestic hot water heating due to improved heating efficiency or reducing standby losses.

Energy Efficient Practices

TRC also identified six (6) low cost or no cost energy efficient practices. A facility's energy performance can be significantly improved by employing certain behavioral or operational adjustments and by performing better routine maintenance on building systems. These practices can extend equipment lifetime, improve occupant comfort, provide better health and safety, as well as reduce annual energy and O&M costs. Potential opportunities identified at Field House include:

- Perform Proper Lighting Maintenance
- Develop a Lighting Maintenance Schedule
- Clean Evaporator/Condenser Coils on AC Systems
- Clean and/or Replace HVAC Filters
- Perform Proper Water Heater Maintenance
- Install Plug Load Controls

For details on these Energy Efficient Practices, please refer to Section 5.

On-Site Generation Measures

TRC evaluated the potential for installing on-site generation for Field House. Based on the configuration of the site and its loads there is a low potential for installing any PV and combined heat and power self-generation measures.

For details on our evaluation and on-site generation potential, please refer to Section 6.

1.3 Implementation Planning

To realize the energy savings from the ECMs listed in this report, a project implementation plan must be developed. Available capital must be considered and decisions need to be made whether it is best to pursue individual ECMs separately, groups of ECMs, or a comprehensive approach where all ECMs are implemented together, possibly in conjunction with other facility upgrades or improvements.

Rebates, incentives, and financing are available from NJCEP, as well as other sources, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any measure, please review the relevant incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives prior to purchasing materials or commencing with installation. The ECMs outlined in this report may qualify under the following program(s):

- SmartStart
- Pay for Performance - Existing Building (P4P)
- Energy Savings Improvement Program (ESIP)

For facilities wanting to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate in this program, you may utilize internal resources, or an outside firm or contractor, to do the final design of the ECM(s) and do the installation. Program pre-approval is required for some SmartStart incentives, so only after receiving pre-approval should you proceed with ECM installation. The incentive estimates listed above in Figure 3 are based on the SmartStart program. More details on this program and others are available in Section 8.

Larger facilities with an interest in a more comprehensive whole building approach to energy conservation should consider participating in the Pay for Performance (P4P) program. Projects eligible for this project program must meet minimum savings requirements. Final incentives are calculated based on actual measured performance achieved at the end of the project. The application process is more involved, and it requires working with a qualified P4P contractor, but the process may result in greater energy savings overall and more lucrative incentives, up to 50% of project's total cost.

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the Energy Savings Improvement Program (ESIP). Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. An LGEA report (or other approved energy audit) is required for participation in ESIP. Please refer to Section 8.3 for additional information on the ESIP Program.

The Demand Response Energy Aggregator is a (non-NJCEP) program designed to reduce electric loads at commercial facilities, when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. Demand Response (DR) service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability. By enabling grid operators to call upon commercial facilities to reduce their electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and facilities receive payments whether or not they are called upon to curtail their load during times of peak demand. Refer to Section 7 for additional information on this program.

Additional information on relevant incentive programs is located in Section 8. You may also check the following website for more details: www.njcleanenergy.com/ci.

2 FACILITY INFORMATION AND EXISTING CONDITIONS

2.1 Project Contacts

Figure 4 – Project Contacts

Name	Role	E-Mail	Phone #
Customer			
Ana Pinto	Director of Energy Management	pintoa@mail.montclair.edu	973-655-3244
TRC Energy Services			
Smruti Srinivasan	Auditor	SSrinivasan@trcsolutions.com	(732) 855-0033

2.2 General Site Information

On April 27, 2017, TRC performed an energy audit at Field House located in Montclair, New Jersey. TRC met with Ana Pinto to review the facility operations and help focus our investigation on specific energy-using systems.

Field House is a 7,376-square foot facility constructed in 1982. Field House is a two-story building that has an office, soccer rooms, fitness rooms, locker rooms, mechanical spaces, and electrical rooms.

Field House’s lighting consists of a combination of 32-Watt T8 fluorescent fixtures, 40-Watt T12 fluorescent fixtures, and 75-Watt incandescent fixtures; all of which are inefficient in performance when compared to the latest lighting technology available in the market. Exterior lighting is provided by a combination of 400-Watt metal halide fixtures and 23-Watt compact fluorescent fixtures. Lighting control is provided by manual switches for interior fixtures and photocells for exterior fixtures.

Cooling is provided by split system DX and package terminal air conditioning systems.

2.3 Building Occupancy

The typical schedule is presented in the table below.

Figure 5 - Building Schedule

Building Name	Weekday/Weekend	Operating Schedule
Field House	Weekday	8:00 AM - 8:00 PM
Field House	Weekend	8:00 AM - 8:00 PM

2.4 Building Envelope

The field house is a two-story building. The construction is of concrete masonry block with finished painted exterior and double pane clear windows with fixed frames and interior panes. The flat roof is constructed of built-up roofing material.

Figure 6 – Building Façade



2.5 On-Site Generation

The campus has a central cogeneration plant. The cogeneration plant uses natural gas fired turbines to produce electricity. Waste heat from the turbines is used to produce steam. The steam is delivered to some of the buildings on campus and used to produce chilled water which is delivered to some of the buildings on campus. See the campus summary report for additional information regarding the campus cogeneration plant.

Field House does not have any on-site electric generation capacity.

2.6 Energy-Using Systems


Please see **Appendix A: Equipment Inventory & Recommendations** for an inventory of the facility's equipment.

Lighting System

Field house's lighting consists of a combination of 32-Watt T8 fluorescent fixtures, 40-Watt T12 fluorescent fixtures, and 75-Watt incandescent fixtures, which are inefficient in performance when compared to the latest lighting technology available in the market. All the linear fluorescent fixtures are 4-foot long troffers with diffusers having 1, 2, and 3-lamp configurations. The facility also has LED-based exit signs.

Interior lighting control in the building is provided by manual switches.

Figure 7 - Building Lighting Systems



The building's exterior lighting consists primarily of 400-Watt metal halide fixtures and 23-Watt compact fluorescent fixtures. The exterior lamps are controlled by photocells.

Heating Ventilation and Air Conditioning System

Ventilation for the facility is provided by constant air volume system air handling units equipped with electric duct reheat.

Cooling for the facility is provided by split systems with capacities ranging between 1.25 ton and 3 tons. The facility is also served by a 0.78-ton terminal AC system. The units each utilize a scroll compressor and a direct-expansion (DX) coil.

Figure 8 – DX Split System



Building Plug Load

The facility has three (3) televisions and a microwave, which serve as plug loads. None of the plug loads have any automation control.

3 SITE ENERGY USE AND COSTS

This building receives electricity and natural gas through master meters. It also receives electricity, steam and chilled water from the campus central cogeneration plant. These utilities were prorated for individual buildings based on building size and function.

Prorated and direct purchase utility data were evaluated to determine the annual energy performance metrics for the building in energy cost per square foot and energy usage per square foot. These metrics are an estimate of the relative energy efficiency of this building. There are a number of factors that could cause the energy use of this building to vary from the “typical” energy usage profile for facilities with similar characteristics. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and energy efficient behavior of occupants all contribute to benchmarking scores. Please refer to the Benchmarking section within Section 3.3 for additional information.

3.1 Total Cost of Energy


The following energy consumption and cost data is based on the last 12-month period of utility billing data that was provided for each utility. A profile of the annual energy consumption and energy cost of the facility was developed from this information.

Figure 9 - Utility Summary

Utility Summary for Field House		
Fuel	Usage	Cost
Electricity	95,546 kWh	\$6,539
Total		\$6,539

The current annual energy cost for this facility is \$6,539 as shown in the chart below.

Figure 10 - Energy Cost Breakdown



3.2 Electricity Usage

Electricity is provided by PSE&G. The average electric cost over the past 12 months was \$0.168/kWh, which is the blended rate that includes energy supply, distribution, and other charges. This rate is used throughout the analyses in this report to assess energy costs and savings. The monthly electricity consumption and peak demand are shown in the chart below.

Figure 11 - Electric Usage & Demand




Figure 12 - Electric Usage & Demand

Electric Billing Data for Field House				
Period Ending	Days in Period	Electric Usage (kWh)	Total Electric Cost	TRC Estimated Usage?
11/30/15	30	7,915	\$467	Yes
12/31/15	31	7,866	\$591	Yes
1/31/16	31	8,167	\$486	Yes
2/28/16	28	7,858	\$1,129	Yes
3/31/16	31	8,051	\$452	Yes
4/30/16	30	7,965	\$451	Yes
5/31/16	31	7,735	\$442	Yes
6/30/16	30	7,304	\$475	Yes
7/31/16	31	7,906	\$503	Yes
8/31/16	31	8,107	\$533	Yes
9/30/16	30	8,442	\$520	Yes
10/31/16	31	8,228	\$490	Yes
Totals	365	95,546	\$6,539	12
Annual	365	95,546	\$6,539	

3.3 Benchmarking

This facility was benchmarked using *Portfolio Manager*, an online tool created and managed by the United States Environmental Protection Agency (EPA) through the ENERGY STAR® program. Portfolio Manager analyzes your building’s consumption data, cost information, and operational use details and then compares its performance against a national median for similar buildings of its type. Metrics provided by this analysis are Energy Use Intensity (EUI) and an ENERGY STAR® score for select building types.

The EUI is a measure of a facility’s energy consumption per square foot, and it is the standard metric for comparing buildings’ energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more or less energy than similar buildings of its type on a square foot basis. EUI is presented in terms of “site energy” and “source energy.” Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

Figure 13 - Energy Use Intensity Comparison – Existing Conditions

Energy Use Intensity Comparison - Existing Conditions		
	Field House	National Median Building Type: Higher Education - Public
Source Energy Use Intensity (kBtu/ft ²)	138.8	262.6
Site Energy Use Intensity (kBtu/ft ²)	44.2	130.7

Implementation of all recommended measures in this report would improve the building’s estimated EUI significantly, as shown in the table below:

Figure 14 - Energy Use Intensity Comparison – Following Installation of Recommended Measures

Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	Field House	National Median Building Type: Higher Education - Public
Source Energy Use Intensity (kBtu/ft ²)	102.2	262.6
Site Energy Use Intensity (kBtu/ft ²)	32.5	130.7

Many types of commercial buildings are also eligible to receive an ENERGY STAR® score. This score is a percentile ranking from 1 to 100. It compares your building’s energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75 percent of all similar buildings nationwide and may be eligible for ENERGY STAR® certification.

As the electric and gas accounts were shared between various buildings, it was not possible to benchmark these buildings and provide a score individually. A campus wide Portfolio Manager Statement of Energy Performance (SEP) was generated.


For more information on ENERGY STAR® certification go to: <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.

A Portfolio Manager account has been created online for your facility and you will be provided with the login information for the account. We encourage you to update your utility information in Portfolio Manager regularly, so that you can keep track of your building’s performance. Free online training is available to help you use ENERGY STAR® Portfolio Manager to track your building’s performance at: <https://www.energystar.gov/buildings/training>.

3.4 Energy End-Use Breakdown

In order to provide a complete overview of energy consumption across building systems, an energy balance was performed. An energy balance utilizes standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building to determine their proportional contribution to overall building energy usage. This chart of energy end uses highlights the relative contribution of each equipment category to total energy usage. This can help determine where the greatest benefits might be found from energy efficiency measures.

Figure 15 - Energy Balance (% and kBtu/SF)



4 ENERGY CONSERVATION MEASURES

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information to the campus regarding financial incentives for which they may qualify to implement the recommended measures. For this audit report, most measures have received only a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to demonstrate project cost-effectiveness and help prioritize energy measures. Savings are based on the New Jersey Clean Energy Program Protocols to Measure Resource Savings dated June 29, 2016, approved by the New Jersey Board of Public Utilities. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances. A higher level of investigation may be necessary to support any custom SmartStart or Pay for Performance, or Direct Install incentive applications. Financial incentives for the ECMs identified in this report have been calculated based the NJCEP prescriptive SmartStart program. Some measures and proposed upgrade projects may be eligible for higher incentives than those shown below through other NJCEP programs as described in Section 8.

The following sections describe the evaluated measures.

4.1 High Priority ECMs

The measures below have been evaluated by the auditor and are recommended for implementation at the facility.

Figure 16 – Summary of High Priority ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		15,712	2.3	0.0	\$2,639.64	\$6,544.10	\$715.00	\$5,829.10	2.2	15,822
ECM 1	Install LED Fixtures	2,801	0.4	0.0	\$470.53	\$781.35	\$200.00	\$581.35	1.2	2,820
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	8,076	1.2	0.0	\$1,356.84	\$4,022.00	\$310.00	\$3,712.00	2.7	8,133
ECM 3	Retrofit Fixtures with LED Lamps	4,835	0.7	0.0	\$812.27	\$1,740.74	\$205.00	\$1,535.74	1.9	4,869
Lighting Control Measures		1,254	0.2	0.0	\$210.68	\$3,240.00	\$420.00	\$2,820.00	13.4	1,263
ECM 4	Install Occupancy Sensor Lighting Controls	1,254	0.2	0.0	\$210.68	\$3,240.00	\$420.00	\$2,820.00	13.4	1,263
Variable Frequency Drive (VFD) Measures		4,266	1.5	0.0	\$716.72	\$3,275.85	\$400.00	\$2,875.85	4.0	4,296
ECM 5	Install VFDs on Constant Volume (CV) HVAC	4,266	1.5	0.0	\$716.72	\$3,275.85	\$400.00	\$2,875.85	4.0	4,296
Domestic Water Heating Upgrade		3,965	0.0	0.0	\$666.13	\$936.02	\$0.00	\$936.02	1.4	3,993
ECM 6	Install Low-Flow Domestic Hot Water Devices	3,965	0.0	0.0	\$666.13	\$936.02	\$0.00	\$936.02	1.4	3,993
TOTALS		25,197	4.0	0.0	\$4,233.17	\$13,995.97	\$1,535.00	\$12,460.97	2.9	25,374

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

4.2 Lighting Upgrades

Our recommendations for upgrades to existing lighting fixtures are summarized in Figure 17 below.

Figure 17 – Summary of Lighting Upgrade ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		15,712	2.3	0.0	\$2,639.64	\$6,544.10	\$715.00	\$5,829.10	2.2	15,822
ECM 1	Install LED Fixtures	2,801	0.4	0.0	\$470.53	\$781.35	\$200.00	\$581.35	1.2	2,820
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	8,076	1.2	0.0	\$1,356.84	\$4,022.00	\$310.00	\$3,712.00	2.7	8,133
ECM 3	Retrofit Fixtures with LED Lamps	4,835	0.7	0.0	\$812.27	\$1,740.74	\$205.00	\$1,535.74	1.9	4,869

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 1: Install LED Fixtures

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0
Exterior	2,801	0.4	0.0	\$470.53	\$781.35	\$200.00	\$581.35	1.2	2,820

Measure Description

We recommend replacing existing fixtures containing HID lamps with new high performance LED light fixtures. This measure saves energy by installing LEDs which use less power than other technologies with a comparable light output.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a HID fixture.

ECM 2: Retrofit Fluorescent Fixtures with LED Lamps and Drivers

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	8,076	1.2	0.0	\$1,356.84	\$4,022.00	\$310.00	\$3,712.00	2.7	8,133
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

Measure Description

We recommend retrofitting existing T12 fluorescent fixtures by removing fluorescent tubes and ballasts and replacing them with LEDs and LED drivers (if necessary), which are designed to be used retrofitted fluorescent fixtures. The measure uses the existing fixture housing but replaces the rest of the components with more efficient lighting technology. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of fluorescent tubes and more than 10 times longer than many incandescent lamps.

ECM 3: Retrofit Fixtures with LED Lamps

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	4,654	0.7	0.0	\$781.89	\$1,418.22	\$205.00	\$1,213.22	1.6	4,687
Exterior	181	0.0	0.0	\$30.38	\$322.52	\$0.00	\$322.52	10.6	182

Measure Description

We recommend retrofitting existing T8 linear fluorescent, compact fluorescent, and incandescent lighting technologies with LED lamps. Many LED tube lamps are direct replacements for existing fluorescent lamps and can be installed while leaving the fluorescent fixture ballast in place. LED bulbs can be used in existing fixtures as a direct replacement for most other lighting technologies. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of fluorescent tubes and more than 10 times longer than many incandescent lamps.

4.3 Lighting Control Measures

Our recommendations for lighting control measures are summarized in Figure 18 below.

Figure 18 – Summary of Lighting Control ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures		1,254	0.2	0.0	\$210.68	\$3,240.00	\$420.00	\$2,820.00	13.4	1,263
ECM 4	Install Occupancy Sensor Lighting Controls	1,254	0.2	0.0	\$210.68	\$3,240.00	\$420.00	\$2,820.00	13.4	1,263

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 4: Install Occupancy Sensor Lighting Controls

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
1,254	0.2	0.0	\$210.68	\$3,240.00	\$420.00	\$2,820.00	13.4	1,263

Measure Description

We recommend installing occupancy sensors to control lighting fixtures that are currently controlled by manual switches in all restrooms, soccer rooms, locker rooms, offices areas, etc. Lighting sensors detect occupancy using ultrasonic and/or infrared sensors. For most spaces, we recommend lighting controls use dual technology sensors, which can eliminate the possibility of any lights turning off unexpectedly. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Some controls also provide dimming options and all modern occupancy controls can be easily over-ridden by room occupants to allow them to manually turn fixtures on or off, as desired. Energy savings results from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are recommended for single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in locations without local switching or where wall switches are not in the line-of-sight of the main work area and in large spaces. We recommend a comprehensive approach to lighting design that upgrades both the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

4.4 Variable Frequency Drive Measures

Our recommendations for variable frequency drive (VFD) measures are summarized in Figure 19 below.

Figure 19 – Summary of Variable Frequency Drive ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Variable Frequency Drive (VFD) Measures		4,266	1.5	0.0	\$716.72	\$3,275.85	\$400.00	\$2,875.85	4.0	4,296
ECM 5	Install VFDs on Constant Volume (CV) HVAC	4,266	1.5	0.0	\$716.72	\$3,275.85	\$400.00	\$2,875.85	4.0	4,296

ECM 5: Install VFDs on Constant Volume (CV) HVAC

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
4,266	1.5	0.0	\$716.72	\$3,275.85	\$400.00	\$2,875.85	4.0	4,296

Measure Description

We recommend installing variable frequency drives (VFDs) to control supply fan motor speeds to convert a constant-volume, single-zone air handling system into a variable-air-volume (VAV) system. A separate VFD is usually required to control the return fan motor or dedicated exhaust fan motor, if the air handler has one. Zone thermostats will cause the VFD to modulate fan speed to maintain the appropriate temperature in the zone, while maintaining a constant supply air temperature. Energy savings results from reducing fan speed (and power) when there is a reduced load required for the zone. The magnitude of energy savings is based on the estimated amount of time that fan motors operate at partial load.

For air handlers with direct expansion (DX) cooling systems, the minimum air flow across the cooling coil required to prevent the coil from freezing will have to be determined during the final project design. The control system should be programmed to maintain the minimum air flow whenever the compressor is operating.

4.5 Domestic Hot Water Heating System Upgrades

Our recommendations for domestic water heating system improvements are summarized in Figure 20 below.

Figure 20 - Summary of Domestic Water Heating ECMs

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Domestic Water Heating Upgrade	3,965	0.0	0.0	\$666.13	\$936.02	\$0.00	\$936.02	1.4	3,993
ECM 6 Install Low-Flow Domestic Hot Water Devices	3,965	0.0	0.0	\$666.13	\$936.02	\$0.00	\$936.02	1.4	3,993

ECM 6: Install Low-Flow DHW Devices

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
3,965	0.0	0.0	\$666.13	\$936.02	\$0.00	\$936.02	1.4	3,993

Measure Description

We recommend installing low-flow domestic hot water devices to reduce overall hot water demand. Energy demand from domestic hot water heating systems can be reduced by reducing water usage in general. Faucet aerators and low-flow showerheads can reduce hot water usage, relative to standard showerheads and aerators, which saves energy.

Low-flow devices reduce the overall water flow from the fixture, while still providing adequate pressure for washing. This reduces the amount of water used per day resulting in energy and water savings.

5 ENERGY EFFICIENT PRACTICES

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of many low cost or no-cost energy efficiency strategies. By employing certain behavioral and operational changes and performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and energy and O&M costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

Perform Proper Lighting Maintenance

In order to sustain optimal lighting levels, lighting fixtures should undergo routine maintenance. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust on lamps, fixtures and reflective surfaces. Together, these factors can reduce total illumination by 20% - 60% or more, while operating fixtures continue drawing full power. To limit this reduction, lamps, reflectors and diffusers should be thoroughly cleaned of dirt, dust, oil, and smoke film buildup approximately every 6 – 12 months.

Develop a Lighting Maintenance Schedule

In addition to routine fixture cleaning, development of a maintenance schedule can both ensure maintenance is performed regularly and can reduce the overall cost of fixture re-lamping and re-ballasting. By re-lamping and re-ballasting fixtures in groups, lighting levels are better maintained and the number of site visits by a lighting technician or contractor can be minimized, decreasing the overall cost of maintenance.

Clean Evaporator/Condenser Coils on AC Systems

Dirty evaporators and condensers coils cause a restriction to air flow and restrict heat transfer. This results in increased evaporator and condenser fan load and a decrease in cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

Clean and/or Replace HVAC Filters

Air filters work to reduce the amount of indoor air pollution and increase occupant comfort. Over time, filters become less and less effective as particulate buildup increases. In addition to health concerns related to clogged filters, filters that have reached saturation also restrict air flow through the facility's air conditioning or heat pump system, increasing the load on the distribution fans and decreasing occupant comfort levels. Filters should be checked monthly and cleaned or replaced when appropriate.

Perform Proper Water Heater Maintenance

At least once a year, drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Once a year check for any leaks or heavy corrosion on the pipes and valves. For gas water heaters, check the draft hood and make sure it is placed properly, with a few inches of air space between the tank and where it connects to the vent. Look for any corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional. For electric water heaters, look for any signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank. For water heaters over three to four years old have a technician inspect the sacrificial anode annually.

Plug Load Controls

There are a variety of ways to limit the energy use of plug loads including increasing occupant awareness, removing under-utilized equipment, installing hardware controls, and using software controls. Some control steps to take are to enable the most aggressive power settings on existing devices or install load sensing or occupancy sensing (advanced) power strips. For additional information refer to “Plug Load Best Practices Guide” <http://www.advancedbuildings.net/plug-load-best-practices-guide-offices>.

6 ON-SITE GENERATION MEASURES

On-site generation measure options include both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey's Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State's electrical needs to be met by renewable sources by 2050.

Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before making a decision to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.

6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility's electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.

A preliminary screening based on the campus' electric demand and the size and location of free areas on campus was performed and is addressed in the campus level summary report.

For more information on solar PV technology and commercial solar markets in New Jersey, or to find a qualified solar installer, who can provide a more detailed assessment of the specific costs and benefits of solar develop of the site, please visit the following links below:

- **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- **NJ Solar Market FAQs:** <http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs>
- **Approved Solar Installers in the NJ Market:** http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1

6.2 Combined Heat and Power

Combined heat and power (CHP) is the on-site generation of electricity along with the recovery of heat energy, which is put to beneficial use. Common technologies for CHP include reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines. Electric generation from a CHP system is typically interconnected to local power distribution systems. Heat is recovered from exhaust and ancillary cooling systems and interconnected to the existing hot water (or steam) distribution systems.

The campus has a CHP plant that uses natural gas fired turbines to generate electricity. Waste heat from the turbines is used to produce steam which is either delivered to buildings on campus or used to produce chilled water which is delivered to buildings on campus. Since the campus has a CHP that serves a significant portion of the campus further evaluation of individual building CHP applications were not done.

7 DEMAND RESPONSE

Demand Response (DR) is a program designed to reduce the electric load of commercial facilities when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability.

By enabling grid operators to call upon Curtailment Service Providers and commercial facilities to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants receive payments whether or not their facility is called upon to curtail their electric usage.

Typically an electric customer needs to be capable of reducing their electric demand, within minutes, by at least 100 kW or more in order to participate in a DR program. Customers with a greater capability to quickly curtail their demand during peak hours will receive higher payments. Customers with back-up generators onsite may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in a DR programs often find it to be a valuable source of revenue for their facility because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature set points on thermostats, so that air conditioning units run less frequently, or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, in order to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a demand response activity in most situations.

The first step toward participation in a DR program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business (<http://www.pjm.com/markets-and-operations/demand-response/csps.aspx>). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity (<http://www.pjm.com/training/training%20material.aspx>), along with a variety of other DR program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

In our opinion this building is not is a good candidate for DR.

8 PROJECT FUNDING / INCENTIVES

The NJCEP is able to provide the incentive programs described below, and other benefits to ratepayers, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey’s Electricity Restructuring Law (1999), which requires all customers of investor-owned electric and gas utilities to pay a surcharge on their monthly energy bills. As a customer of a state-regulated electric or gas utility and therefore a contributor to the fund your organization is eligible to participate in the LGEA program and also eligible to receive incentive payment for qualifying energy efficiency measures. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 21 for a list of the eligible programs identified for each recommended ECM.

Figure 21 - ECM Incentive Program Eligibility

Energy Conservation Measure		SmartStart Prescriptive	Pay For Performance Existing Buildings
ECM 1	Install LED Fixtures	X	X
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	X	X
ECM 3	Retrofit Fixtures with LED Lamps	X	X
ECM 4	Install Occupancy Sensor Lighting Controls	X	X
ECM 5	Install VFDs on Constant Volume (CV) HVAC	X	X
ECM 6	Install Low-Flow Domestic Hot Water Devices		X

SmartStart is generally well-suited for implementation of individual measures or small group of measures. It provides flexibility to install measures at your own pace using in-house staff or a preferred contractor. Direct Install caters to small to mid-size facilities that can bundle multiple ECMs together. This can greatly simplify participation and may lead to higher incentive amounts, but requires the use of pre-approved contractors. The Pay for Performance (P4P) program is a “whole-building” energy improvement program designed for larger facilities. It requires implementation of multiple measures meeting minimum savings thresholds, as well as use of pre-approved consultants. This facility does not meet all of the criteria for participating in the P4P program based on the measures identified in this study. However, since additional measures may be identified during the P4P evaluation and the facility is close to meeting the P4P program criteria it is worth considering the P4P program for this site. The Large Energy Users Program (LEUP) is available to New Jersey’s largest energy users giving them flexibility to install as little or as many measures, in a single facility or several facilities, with incentives capped based on the entity’s annual energy consumption. LEUP applicants can use in-house staff or a preferred contractor.

Generally, the incentive values provided throughout the report assume the SmartStart program is utilized because it provides a consistent basis for comparison of available incentives for various measures, though in many cases incentive amounts may be higher through participation in other programs.

Brief descriptions of all relevant financing and incentive programs are located in the sections below. Further information, including most current program availability, requirements, and incentive levels can be found at: www.njcleanenergy.com/ci.

8.1 SmartStart

Overview

The SmartStart program offers incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives from year to year for various energy efficiency equipment based on market trends and new technologies.

Equipment with Prescriptive Incentives Currently Available:

Electric Chillers

Electric Unitary HVAC

Gas Cooling

Gas Heating

Gas Water Heating

Ground Source Heat Pumps

Lighting

Lighting Controls

Refrigeration Doors

Refrigeration Controls

Refrigerator/Freezer Motors

Food Service Equipment

Variable Frequency Drives

Most equipment sizes and types are served by this program. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades.

Incentives

The SmartStart prescriptive incentive program provides fixed incentives for specific energy efficiency measures, whereas the custom SmartStart program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentive offerings for specific devices.

Since your facility is an existing building, only the retrofit incentives have been applied in this report. Custom measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at 50% of the total installed incremental project cost, or a project cost buy down to a one year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

How to Participate

To participate in the SmartStart program you will need to submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: www.njcleanenergy.com/SSB.

8.2 Pay for Performance - Existing Buildings

Overview

The Pay for Performance – Existing Buildings (P4P EB) program is designed for larger customers with a peak demand over 200 kW in any of the preceding 12 months. Under this program the minimum installed scope of work must include at least two unique measures resulting in at least 15% energy savings, where lighting cannot make up the majority of the savings. P4P is a generally a good option for medium to large sized facilities looking to implement as many measures as possible under a single project in order to achieve deep energy savings. This program has an added benefit of evaluating a broad spectrum of measures that may not otherwise qualify under other programs. Many facilities pursuing an Energy Savings Improvement Program (ESIP) loan also utilize the P4P program.

Incentives

Incentives are calculated based on estimated and achieved energy savings ranging from \$0.18-\$0.22/kWh and \$1.80-\$2.50/therm, capped at the lesser of 50% total project cost, or \$1 million per electric account and \$1 million per natural gas account, per fiscal year, not to exceed \$2 million per project. An incentive of \$0.15/square foot is also available to offset the cost of developing the Energy Reduction Plan (see below) contingent on the project moving forward with measure installation.

How to Participate

To participate in the P4B EB program you will need to contact one of the pre-approved consultants and contractors (“Partners”). Under direct contract to you, the Partner will help further evaluate the measures identified in this report through development of the Energy Reduction Plan (ERP), assist you in implementing selected measures, and verify actual savings one year after the installation. At each of these three milestones your Partner will also facilitate securing program incentives.

Approval of the final scope of work is required by the program prior to installation completion. Although installation can be accomplished by a contractor of your choice (some P4P Partners are also contractors) or by internal personnel, the Partner must remain involved to ensure compliance with the program guidelines and requirements.

Detailed program descriptions, instructions for applying, applications and list of Partners can be found at: www.njcleanenergy.com/P4P.

8.3 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) is an alternate method for New Jersey's government agencies to finance the implementation of energy conservation measures. An ESIP is a type of "performance contract," whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. This is done in a manner that ensures that annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive in year one, and every year thereafter. ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs can be leveraged to help further reduce the total project cost of eligible measures.

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an Energy Services Company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is utilized for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the Energy Savings Plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Entities should carefully consider all alternatives to develop an approach that best meets their needs. A detailed program descriptions and application can be found at: www.njcleanenergy.com/ESIP

Please note that ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you may utilize NJCEP incentive programs to help further reduce costs when developing the ESP. You should refer to the ESIP guidelines at the link above for further information and guidance on next steps.

9 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

9.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third party (i.e. non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third party supplier, consider shopping for a reduced rate from third party electric suppliers. If your facility is purchasing electricity from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

9.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate on a monthly basis. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third party supplier, consider shopping for a reduced rate from third party natural gas suppliers. If your facility is purchasing natural gas from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party natural gas suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

APPENDIX A: EQUIPMENT INVENTORY & RECOMMENDATIONS

Lighting Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Entrance	1	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	4,368	Relamp	No	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	4,368	0.01	76	0.0	\$12.84	\$35.90	\$5.00	2.41
Fitness Room	4	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	4,368	Relamp	Yes	4	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	3,058	0.06	439	0.0	\$73.76	\$683.60	\$90.00	8.05
Fitness Room	7	Linear Fluorescent - T12: 4' T12 (40W) - 1L	Wall Switch	46	4,368	Relamp & Reballast	No	7	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	4,368	0.16	1,108	0.0	\$186.08	\$686.00	\$35.00	3.50
Fitness Room	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Electrical Room	4	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	4,368	Relamp	No	4	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	4,368	0.05	352	0.0	\$59.07	\$143.60	\$20.00	2.09
2nd Floor Entrance	1	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	4,368	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,368	0.04	296	0.0	\$49.79	\$117.00	\$10.00	2.15
Electrical Room	2	Linear Fluorescent - T12: 4' T12 (40W) - 1L	Wall Switch	46	4,368	Relamp & Reballast	No	2	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	4,368	0.05	316	0.0	\$53.17	\$196.00	\$10.00	3.50
2nd Floor Reception	4	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	4,368	Relamp & Reballast	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,058	0.20	1,360	0.0	\$228.53	\$738.00	\$75.00	2.90
2nd Floor Reception	1	Linear Fluorescent - T12: 4' T12 (40W) - 1L	Wall Switch	46	4,368	Relamp & Reballast	No	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	4,368	0.02	158	0.0	\$26.58	\$98.00	\$5.00	3.50
Storage	1	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	4,368	Relamp	No	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	4,368	0.01	88	0.0	\$14.77	\$35.90	\$5.00	2.09
MSU Soccer Room	6	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	4,368	Relamp & Reballast	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,058	0.30	2,040	0.0	\$342.79	\$972.00	\$95.00	2.56
MRR	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	4,368	Relamp & Reballast	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,058	0.10	680	0.0	\$114.26	\$774.00	\$90.00	5.99
MRR	8	Halogen Incandescent INC - 75W	Wall Switch	75	4,368	Relamp	No	8	LED Screw-In Lamps: LED - 11W	Wall Switch	11	4,368	0.38	2,562	0.0	\$430.39	\$430.02	\$40.00	0.91
MRR	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Locker Room Men	4	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	4,368	Relamp & Reballast	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,058	0.20	1,360	0.0	\$228.53	\$738.00	\$75.00	2.90
Locker Room Men	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Locker Room Women	5	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	4,368	Relamp	Yes	5	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,058	0.15	1,047	0.0	\$175.95	\$832.50	\$120.00	4.05
Locker Room Women	1	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	4,368	Relamp	No	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	4,368	0.01	88	0.0	\$14.77	\$35.90	\$5.00	2.09
Locker Room Women	1	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	4,368	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,368	0.04	296	0.0	\$49.79	\$117.00	\$10.00	2.15
Locker Room Women	1	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	4,368	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,368	0.04	296	0.0	\$49.79	\$117.00	\$10.00	2.15
Locker Room Women	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Room	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	4,368	Relamp & Reballast	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,058	0.10	680	0.0	\$114.26	\$504.00	\$55.00	3.93
Ground Floor Room	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	4,368	Relamp & Reballast	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	3,058	0.10	680	0.0	\$114.26	\$504.00	\$55.00	3.93
WRR	1	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	4,368	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,368	0.04	296	0.0	\$49.79	\$117.00	\$10.00	2.15
Coach's Office	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	93	4,368	Relamp	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	3,058	0.18	1,257	0.0	\$211.14	\$570.80	\$95.00	2.25

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Locker Room	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	4,368	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,368	0.09	593	0.0	\$99.58	\$234.00	\$20.00	2.15
Locker Room	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Exterior	2	Compact Fluorescent CFL - 23W	Wall Switch	23	4,368	Relamp	No	2	LED Screw-In Lamps: LED - 16W	Wall Switch	16	4,368	0.01	69	0.0	\$11.65	\$107.51	\$0.00	9.23
Exterior	4	Compact Fluorescent CFL - 23W	Wall Switch	23	4,368	Relamp	No	4	LED Screw-In Lamps: LED - 16W	Wall Switch	16	4,368	0.02	139	0.0	\$23.29	\$215.01	\$0.00	9.23
Exterior	2	Metal Halide: (1) 400W Lamp	Wall Switch	458	4,368	Fixture Replacement	No	2	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Wall Switch	137	4,368	0.47	3,221	0.0	\$541.11	\$781.35	\$200.00	1.07
Entrance	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Field House	Field House	1	Supply Fan	7.0	91.7%	No	3,391	No	91.7%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mechanical Room	Field House	2	Water Supply Pump	0.3	85.5%	No	2,745	No	85.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Field House	Field House	1	Supply Fan	0.3	85.5%	No	2,745	No	85.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Field House	Field House	1	Supply Fan	0.3	85.5%	No	2,745	No	85.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Field House	Field House	1	Supply Fan	0.3	85.5%	No	2,745	No	85.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Field House	Field House	1	Supply Fan	0.3	85.5%	No	2,745	No	85.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Field House	Field House	1	Supply Fan	0.3	85.5%	No	2,745	No	85.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Field House	Field House	1	Supply Fan	0.3	85.5%	No	2,745	No	85.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Field House	Field House	1	Supply Fan	0.3	85.5%	No	2,745	No	85.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Field House	Field House	1	Supply Fan	0.3	85.5%	No	2,745	No	85.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Field House	Field House	1	Supply Fan	0.3	85.5%	No	2,745	No	85.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Field House	Field House	1	Supply Fan	0.3	85.5%	No	2,745	No	85.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Field House	Field House	1	Supply Fan	0.3	85.5%	No	2,745	No	85.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Field House	Field House	1	Supply Fan	0.3	85.5%	No	2,745	No	85.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rooftop	Field House	1	Exhaust Fan	0.3	85.5%	No	2,745	No	85.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Exterior	Field House	1	Supply Fan	5.0	85.5%	No	2,745	No	85.5%	Yes	1	1.47	4,266	0.0	\$716.72	\$3,275.85	\$400.00	4.01

Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions									Energy Impact & Financial Analysis							
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Rooftop	Field House	1	Split-System AC	2.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rooftop	Field House	1	Split-System AC	3.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rooftop	Field House	1	Split-System AC	3.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rooftop	Field House	1	Split-System AC	2.50		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rooftop	Field House	1	Split-System AC	2.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rooftop	Field House	1	Split-System AC	2.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rooftop	Field House	1	Split-System AC	2.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rooftop	Field House	1	Split-System AC	1.25		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rooftop	Field House	1	Split-System AC	2.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rooftop	Field House	1	Split-System AC	2.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rooftop	Field House	1	Split-System AC	2.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rooftop	Field House	1	Split-System AC	2.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Field House	Field House	1	Packaged Terminal AC	0.78		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions						Energy Impact & Financial Analysis						
		System Quantity	System Type	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Mechanical Room	Field House	2	Storage Tank Water Heater (> 50 Gal)	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Low-Flow Device Recommendations

Location	Recommendation Inputs				Energy Impact & Financial Analysis						
	Device Quantity	Device Type	Existing Flow Rate (gpm)	Proposed Flow Rate (gpm)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
MRR	1	Faucet Aerator (Lavatory)	2.20	1.00	0.00	505	0.0	\$84.84	\$7.17	\$0.00	0.08
MRR	2	Faucet Aerator (Lavatory)	2.20	1.00	0.00	1,010	0.0	\$169.68	\$14.34	\$0.00	0.08
WRR	1	Faucet Aerator (Lavatory)	2.20	1.00	0.00	505	0.0	\$84.84	\$7.17	\$0.00	0.08
WRR	2	Faucet Aerator (Lavatory)	2.20	1.00	0.00	1,010	0.0	\$169.68	\$14.34	\$0.00	0.08
WRR	10	Showerhead	2.20	2.00	0.00	935	0.0	\$157.11	\$893.00	\$0.00	5.68

Plug Load Inventory

Location	Existing Conditions			
	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
Field House	3	Television	150.0	Yes
Field House	1	Microwave	1,000.0	Yes

APPENDIX B: ENERGY STAR® STATEMENT OF ENERGY PERFORMANCE

ENERGY STAR® Statement of Energy Performance

LEARN MORE AT energystar.gov

N/A **Montclair State University Campus (Buildings 1-41)**

ENERGY STAR® Score¹

Primary Property Type: College/University
Gross Floor Area (ft²): 2,925,896
Built: 1908

For Year Ending: October 31, 2016
Date Generated: October 10, 2017

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information

Property Address	Property Owner	Primary Contact
Montclair State University Campus (Buildings 1-41) 1 Normal Avenue Montclair, New Jersey 07043	Montclair State University 1 Normal Avenue Montclair, NJ 07043 973-655-3244	Ana Pinto 1 Normal Avenue Montclair, NJ 07043 973-655-3244 pintoa@montclair.edu
Property ID: 6069294		

Energy Consumption and Energy Use Intensity (EUI)

Site EUI	Annual Energy by Fuel	National Median Comparison
172.3 kBtu/ft ²	District Chilled Water - 81,507,530 (16%) Other (kBtu)	National Median Site EUI (kBtu/ft ²) 147.6 National Median Source EUI (kBtu/ft ²) 262.6 % Diff from National Median Source EUI 17%
	District Steam (kBtu) 223,798,259 (44%) Electric - Grid (kBtu) 161,334,839 (32%) Natural Gas (kBtu) 37,406,141 (7%)	
Source EUI 306.4 kBtu/ft ²		Annual Emissions Greenhouse Gas Emissions (Metric Tons CO ₂ e/year) N/A

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: _____ Date: _____

Licensed Professional

 () _____



Professional Engineer Stamp (if applicable)