



Local Government Energy Audit: Energy Audit Report



Copyright ©2018 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Community Pool

Township of Maplewood

187 Boyden Avenue
Maplewood, NJ 07040

November 16, 2018

Final Report by:

TRC Energy Services

Disclaimer

The intent of this energy analysis report is to identify energy savings opportunities and recommend upgrades to the facility's energy using equipment and systems. Approximate savings are included in this report to help make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. Further design and analysis may be necessary to implement some of the measures recommended in this report.

The energy conservation measures and estimates of energy savings have been reviewed for technical accuracy. However, estimates of final energy savings are not guaranteed, because final savings may depend on behavioral factors and other uncontrollable variables. TRC Energy Services (TRC) and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

Estimated installation costs are based on TRC's experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from *RS Means*. The owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for certain measures and conditions, TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. The owner of the facility should review available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

Table of Contents

1	Executive Summary.....	1
1.1	Facility Summary	1
1.2	Your Cost Reduction Opportunities.....	2
	Energy Conservation Measures.....	2
	Energy Efficient Practices	3
	On-Site Generation Measures.....	3
1.3	Implementation Planning.....	3
2	Facility Information and Existing Conditions	5
2.1	Project Contacts	5
2.2	General Site Information.....	5
2.3	Building Occupancy	5
2.4	Building Envelope	6
2.5	On-Site Generation.....	6
2.6	Energy-Using Systems	6
	Lighting System	6
	Motors 7	
	Domestic Water Heating System	8
	Food Service & Refrigeration	8
2.7	Water-Using Systems	8
3	Site Energy Use and Costs.....	10
3.1	Total Cost of Energy	10
3.2	Electricity Usage	11
3.3	Natural Gas Usage	12
3.4	Benchmarking.....	13
3.5	Energy End-Use Breakdown	14
4	Energy Conservation Measures	15
4.1	Recommended ECMs	15
4.1.1	Lighting Upgrades.....	16
	ECM 1: Install LED Fixtures	16
	ECM 2: Retrofit Fluorescent Fixtures with LED Lamps and Drivers.....	17
	ECM 3: Retrofit Fixtures with LED Lamps.....	17
	ECM 4: Install LED Exit Signs.....	18
4.1.2	Lighting Control Measures	19
	ECM 5: Install Occupancy Sensor Lighting Controls	19
4.1.3	Motor Upgrades	20
	ECM 6: Premium Efficiency Motors.....	20
5	Energy Efficient Practices	21
	Perform Regular Lighting Maintenance	21
	Develop a Lighting Maintenance Schedule	21

Ensure Lighting Controls Are Operating Properly	21
Reduce Motor Short Cycling.....	21
Perform Routine Motor Maintenance	21
Perform Regular Water Heater Maintenance	22
Plug Load Controls.....	22
Water Conservation	22
6 On-Site Generation Measures	23
6.1 Photovoltaic.....	23
6.2 Combined Heat and Power	24
7 Demand Response	25
8 Project Funding / Incentives	26
8.1 SmartStart	27
8.2 Direct Install	28
8.3 Energy Savings Improvement Program	28
9 Energy Purchasing and Procurement Strategies	30
9.1 Retail Electric Supply Options.....	30
9.2 Retail Natural Gas Supply Options	30

Appendix A: Equipment Inventory & Recommendations

Appendix B: ENERGY STAR® Statement of Energy Performance

Table of Figures

Figure 1 – Previous 12 Month Utility Costs..... 2

Figure 2 – Potential Post-Implementation Costs 2

Figure 3 – Summary of Energy Reduction Opportunities 2

Figure 4 – Project Contacts 5

Figure 5 - Building Schedule..... 5

Figure 6 - Utility Summary 10

Figure 7 - Energy Cost Breakdown 10

Figure 8 - Electric Usage & Demand..... 11

Figure 9 - Electric Usage & Demand..... 11

Figure 10 - Natural Gas Usage..... 12

Figure 11 - Natural Gas Usage..... 12

Figure 12 - Energy Use Intensity Comparison – Existing Conditions..... 13

Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures 13

Figure 14 - Energy Balance (% and kBtu/SF) 14

Figure 15 – Summary of Recommended ECMs..... 15

Figure 16 – Summary of Lighting Upgrade ECMs..... 16

Figure 17 – Summary of Lighting Control ECMs 19

Figure 18 – Summary of Motor ECMs..... 20

Figure 18 - Photovoltaic Screening 23

Figure 19 - Combined Heat and Power Screening 24

Figure 20 - ECM Incentive Program Eligibility 26

I EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBPU) has sponsored this Local Government Energy Audit (LGEA) Report for the Maplewood Township Community Pool.

The goal of an LGEA report is to provide you with information on how your facility uses energy, identify energy conservation measures (ECMs) that can reduce your energy use, and provide information and assistance to help facilities implement ECMs. The LGEA report also contains valuable information on financial incentives from New Jersey's Clean Energy Program (NJCEP) for implementing ECMs.

This study was conducted by TRC Energy Services (TRC), as part of a comprehensive effort to assist New Jersey local governments in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

I.1 Facility Summary

The Maplewood Township Community Pool is a 28,691 square foot recreation facility comprised of four outdoor swimming pools, a snack bar, restrooms and locker rooms, a utility room, and a maintenance room. The facility was constructed in 1946. The facility is open to the public every day from Memorial Day to Labor Day. Swim lessons and diving lessons are offered to the children of members of the pool.

The main pool is Olympic-sized ranging from 4 feet to 8 feet deep. The main pool also features the twists and turns of two exhilarating water slides. One 20 hp and two 15 hp pumps are used respectively to supply water to the main pool and the two water slides.

The training pool is designed for the kids that are transitioning from tentative exploration to eager submersion. Depth ranges from 2 feet to 4 feet deep with one dedicated lifeguard. One 5 hp pump supplies water to the pool.

The baby pool is designed exclusively for the babies. They can ease in from the edge as the pool gradually deepens to a maximum depth of 2 feet and also has features including rain curtains, showering mushroom, and pool toys. Two 5 hp pumps are used to supply water to the pool.

The dive tank can mount three diving boards, an 11-foot dive platform, a 22-foot dive platform, or the 33-foot high dive platform. One 15 hp pump is used to circulate water to this pool.

The main facility building houses the office, restroom and locker rooms, snack bar, pump room, and maintenance room and is constructed of brick masonry. It has an asphalt shingled pitched roof. There are two small buildings that house other facility equipment such as chlorine and pumps.

Interior lighting includes a combination of linear fluorescent T8 and T12 fixtures as well as a small number of incandescent and compact fluorescent lamps (CFL). Exterior lighting consists of metal halide and LED fixtures that are controlled with photocells. Ten small portable electric heaters are used in various spaces of the facility to prevent freezing of certain equipment. There is cooling or other heating equipment present in the facility.

A thorough description of the facility and our observations are in Section 2.

1.2 Your Cost Reduction Opportunities

Energy Conservation Measures

TRC evaluated six measures which together represent an opportunity for Community Pool to reduce annual energy costs by \$2,974 and annual greenhouse gas emissions by 14,605 lbs. CO₂e. We estimate that if all measures were implemented as recommended, the project would pay for itself in 3.8 years. The breakdown of existing and potential utility costs after project implementation are illustrated in Figure 1 and Figure 2, respectively. Together these measures represent an opportunity to reduce Community Pool's annual energy use by 7%.

Figure 1 – Previous 12 Month Utility Costs





Figure 2 – Potential Post-Implementation Costs



A detailed description of Community Pool's existing energy use can be found in Section 3.

Estimates of the total cost, energy savings, and financial incentives for the proposed energy efficient upgrades are summarized below in Figure 3. A brief description of each category can be found below and a description of savings opportunities can be found in Section 4.

Figure 3 – Summary of Energy Reduction Opportunities

Energy Conservation Measure	Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		13,601	4.3	0.0	\$2,788.64	\$11,271.22	\$1,815.00	\$9,456.22	3.4	13,696
ECM 1	Install LED Fixtures	5,127	1.0	0.0	\$1,051.20	\$4,424.75	\$1,110.00	\$3,314.75	3.2	5,163
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	1,522	0.8	0.0	\$312.08	\$2,161.00	\$95.00	\$2,066.00	6.6	1,533
ECM 3	Retrofit Fixtures with LED Lamps	6,637	2.5	0.0	\$1,360.70	\$4,040.14	\$610.00	\$3,430.14	2.5	6,683
ECM 4	Install LED Exit Signs	315	0.0	0.0	\$64.66	\$645.33	\$0.00	\$645.33	10.0	318
Lighting Control Measures		709	0.4	0.0	\$145.33	\$1,428.00	\$200.00	\$1,228.00	8.4	714
ECM 5	Install Occupancy Sensor Lighting Controls	709	0.4	0.0	\$145.33	\$1,428.00	\$200.00	\$1,228.00	8.4	714
Motor Upgrades		194	0.1	0.0	\$39.79	\$710.97	\$0.00	\$710.97	17.9	195
ECM 6	Premium Efficiency Motors	194	0.1	0.0	\$39.79	\$710.97	\$0.00	\$710.97	17.9	195
TOTALS FOR HIGH PRIORITY MEASURES		14,504	4.8	0.0	\$2,973.76	\$13,410.19	\$2,015.00	\$11,395.19	3.8	14,605
TOTALS FOR ALL EVALUATED MEASURES		14,504	4.8	0.0	\$2,973.76	\$13,410.19	\$2,015.00	\$11,395.19	3.8	14,605

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Lighting Upgrades involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measures save energy by reducing the power used by the lighting components due to improved electrical efficiency.

Lighting Controls measures include the installation of automated controls to turn off lights or reduce light output when not needed. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

Motor Upgrades generally involve replacing older standard efficiency motors with high efficiency standard (NEMA Premium). Motors replacements generally assume the same size motors, just higher efficiency. Although occasionally additional savings can be achieved by downsizing motors to better meet current load requirements. This measure saves energy by reducing the power used by the motors, due to improved electrical efficiency.

Energy Efficient Practices

TRC also identified eight low cost (or no cost) energy efficient practices. A facility's energy performance can be significantly improved by employing certain behavioral or operational adjustments and by performing better routine maintenance on building systems. These practices can extend equipment lifetime, improve occupant comfort, provide better health and safety, as well as reduce annual energy and O&M costs. Potential opportunities identified at Community Pool include:

- Perform Regular Lighting Maintenance
- Develop a Lighting Maintenance Schedule
- Ensure Lighting Controls Are Operating Properly
- Reduce Motor Short Cycling
- Perform Routine Motor Maintenance
- Perform Regular Water Heater Maintenance
- Install Plug Load Controls
- Water Conservation

For details on these energy efficient practices, please refer to Section 5.

On-Site Generation Measures

TRC evaluated the potential for installing on-site generation for Community Pool. Based on the configuration of the site and its loads there is a low potential for installing any PV and combined heat and power self-generation measures.

For details on our evaluation and on-site generation potential, please refer to Section 6.

1.3 Implementation Planning

To realize the energy savings from the ECMs listed in this report, a project implementation plan must be developed. Available capital must be considered and decisions need to be made whether it is best to pursue individual ECMs separately, groups of ECMs, or a comprehensive approach where all ECMs are implemented together, possibly in conjunction with other facility upgrades or improvements.

Rebates, incentives, and financing are available from NJCEP, as well as other sources, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any measure, please review the relevant incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives prior to purchasing materials or commencing with installation.

The ECMs outlined in this report may qualify under the following program(s):

- SmartStart
- Direct Install
- Energy Savings Improvement Program (ESIP)

For facilities wanting to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate in this program, you may utilize internal resources, or an outside firm or contractor, to do the final design of the ECM(s) and do the installation. Program pre-approval is required for some SmartStart incentives, so only after receiving pre-approval should you proceed with ECM installation. The incentive estimates listed above in Figure 3 are based on the SmartStart program. More details on this program and others are available in Section 8.

This facility may also qualify for the Direct Install program which can provide turnkey installation of multiple measures, through an authorized network of participating contractors. This program can provide substantially higher incentives than SmartStart, up to 70% of the cost of selected measures, although measure eligibility will have to be assessed and be verified by the designated Direct Install contractor and, in most cases, they will perform the installation work.

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the Energy Savings Improvement Program (ESIP). Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. An LGEA report (or other approved energy audit) is required for participation in ESIP. Please refer to Section 8.3 for additional information on the ESIP Program.

The Demand Response Energy Aggregator is a (non-NJCEP) program designed to reduce electric loads at commercial facilities, when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. Demand Response (DR) service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability. By enabling grid operators to call upon commercial facilities to reduce their electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and facilities receive payments whether or not they are called upon to curtail their load during times of peak demand. Refer to Section 7 for additional information on this program.

Additional information on relevant incentive programs is in Section 8. You may also check the following website for more details: www.njcleanenergy.com/ci.

2 FACILITY INFORMATION AND EXISTING CONDITIONS

2.1 Project Contacts

Figure 4 – Project Contacts

Name	Role	E-Mail	Phone #
Customer			
Joseph Manning	Business Administrator	Joseph F. Manning <twpadmin@twp.maplewood.nj.us	973-762-8120 ex. 2000
Designated Representative			
Joe Pukatch	Maintenance Personnel		973-762-8120 ex. 2000
TRC Energy Services			
Moussa Traore	Auditor	mtraore@trcsolutions.com	(732) 855-0033

2.2 General Site Information

On May 08, 2018, TRC performed an energy audit at Community Pool located in Maplewood, New Jersey. TRC’s auditor met with Joe Pukatch, Maintenance Personnel to review the facility operations and help focus our investigation on specific energy-using systems.

The Maplewood Township Community Pool is a 28,691 square foot recreation facility comprised of four outdoor swimming pools, a snack bar, restrooms and locker rooms, a utility room, and a maintenance room. The facility was constructed in 1946. The facility is open to the public every day from Memorial Day to Labor Day. Swim lessons and diving lessons are offered to the children of members of the pool.



Image 1: Baby Pool

2.3 Building Occupancy

The facility is open to the public every day from Memorial Day to Labor Day. The typical schedule is presented in the table below. During a typical day, the facility is occupied by five staff and 400 people.

Figure 5 - Building Schedule

Building Name	Weekday/Weekend	Operating Schedule
Community Pool	Weekday	12:00 PM - 8:00 PM
Community Pool	Weekend	12:00 PM - 6:00 PM

2.4 Building Envelope

The building's exterior walls are constructed of brick masonry with an asphalt shingled pitched roof. The windows throughout the building are single-pane glass with wood frames in fair condition. The exterior doors are constructed of wood. Overall, the building envelope appears to be in good condition for its age.



Image 2: Building Envelope

2.5 On-Site Generation

The Community Pool does not have any on-site electric generation capacity.

2.6 Energy-Using Systems

Please see Appendix A: Equipment Inventory & Recommendations for an inventory of the facility's equipment.

Lighting System

Lighting at the facility is provided by a combination of linear fluorescent T8 and T12 fixtures as well as some incandescent and compact fluorescent lamps (CFL). Most of the T8 fixtures are 2-lamp, 4-foot long troffers with diffusers while the T12 fixtures are mainly 2-lamp, 8-foot long industrial reflector fixture. The T12 fixtures are found in the maintenance room, water treatment room, workshop and utility room. The 100-Watt incandescent lamps are also used in the maintenance room, main lobby, mens locker room and storage room while CFL are used to illuminate the front entrance and the facility manager office. The remaining areas use the T8 lamps. Exit signs in the building have fluorescent lamps. The facility has minimal exterior lighting which consist of 50-Watt and 175-Watt metal halide, 100-Watt incandescent lamps and three pole-mounted fixtures containing LED lamps. The exterior lights are controlled with photocells while the interior lighting system is controlled with manual switches.




Image 3: Interior's T8 & T12 Fixtures



Image 4: Incandescent Lamp & Exterior Metal Halide Lamp

Motors

They are various types of motors installed throughout the facility. Each of the four outdoor pools has one or two dedicated water circulator pumps. Sump pumps and some small fractional chlorine pumps are also found in the facility. Most of the water supply pumps are newly installed except one of 5 hp pump serving the baby pool that is in fair condition. The pumps run at constant speed. Some pumps may run continuously. Refer to the table below for the description and condition of the major water supply pumps.

Areas Served	Quantity	Capacity (HP)	Description	Manufacturer	Existing Condition
Baby Pool	1	5	Water Supply Pump	A O Smith	New (Good)
Baby Pool	1	5	Water Supply Pump	Century Motors	Fair
Training Pool	1	5	Water Supply Pump	Pentair	New (Good)
Main Pool	1	20	Water Supply Pump	Marathon	New (Good)
Diving Pool	1	15	Water Supply Pump	Century Motors	New (Good)
Water Slides	2	15	Water Supply Pump	US Motors	Good



Image 5: Old 5 hp Baby Pool Water Supply Pump



Image 6: 15 hp Water Slides Water Supply Pumps

Domestic Water Heating System

The domestic hot water heating system for the facility consists of two Rheem gas-fired, non-condensing water heaters. An 86 gallon, 400 kBtuh storage hot water heater with an 80% nominal efficiency serves the locker room showers and restrooms. A fractional horsepower recirculation pump is used to distribute 120°F water. The snack bar has a dedicated 40-gallon, 40 kBtuh water heater with a nominal efficiency of 80%. The water heaters are in the utility room. They appear to be in good condition.



Image 7: Domestic Water Heaters

Food Service & Refrigeration

The main building houses a private snack bar that is used to prepare hot snacks for the swimmers. Most of the cooking is done using the gas fired convection ovens. The snack bar also contains refrigerated beverage services provided by standup solid doors refrigerators and one ice making machine.

2.7 Water-Using Systems

The facility restrooms and shower rooms are equipped with low flow fixtures.



Image 8: Typical Restroom & Shower Room Faucets

3 SITE ENERGY USE AND COSTS

Utility data for electricity and natural gas was analyzed to identify opportunities for savings. In addition, data for electricity and natural gas was evaluated to determine the annual energy performance metrics for the building in energy cost per square foot and energy usage per square foot. These metrics are an estimate of the relative energy efficiency of this building. There are several factors that could cause the energy use of this building to vary from the “typical” energy usage profile for facilities with similar characteristics. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and energy efficient behavior of occupants all contribute to benchmarking scores. Please refer to the Benchmarking section within Section 0 for additional information.

3.1 Total Cost of Energy


The following energy consumption and cost data is based on the last 12-month period of utility billing data that was provided for each utility. A profile of the annual energy consumption and energy cost of the facility was developed from this information.

Figure 6 - Utility Summary

Utility Summary for Community Pool		
Fuel	Usage	Cost
Electricity	157,153 kWh	\$32,221
Natural Gas	1,701 Therms	\$1,504
Total		\$33,725

The current annual energy cost for this facility is \$33,725 as shown in the chart below.

Figure 7 - Energy Cost Breakdown



3.2 Electricity Usage

Electricity is provided by PSE&G. The average electric cost over the past 12 months was \$0.205/kWh, which is the blended rate that includes energy supply, distribution, and other charges. This rate is used throughout the analyses in this report to assess energy costs and savings. The monthly electricity consumption and peak demand are shown in the chart below.

Figure 8 - Electric Usage & Demand




Figure 9 - Electric Usage & Demand

Electric Billing Data for Community Pool					
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost
2/19/16	28	3,820	27	\$119	\$1,050
3/18/16	31	3,250	14	\$61	\$968
4/18/16	30	5,440	18	\$78	\$1,248
5/18/16	31	6,020	28	\$124	\$1,401
6/17/16	30	35,120	25	\$108	\$5,238
7/20/16	31	22,930	28	\$127	\$5,690
8/18/16	31	29,250	28	\$124	\$5,222
9/16/16	30	21,643	27	\$115	\$3,356
10/17/16	31	19,020	26	\$117	\$4,397
11/19/16	30	3,270	13	\$59	\$1,152
12/16/16	31	3,450	26	\$114	\$1,338
1/18/17	31	3,940	27	\$122	\$1,160
Totals	365	157,153	28.2	\$1,268	\$32,221
Annual	365	157,153	28.2	\$1,268	\$32,221

3.3 Natural Gas Usage

Natural gas is provided by PSE&G. The average gas cost for the past 12 months is \$0.884/therm, which is the blended rate used throughout the analyses in this report. The monthly gas consumption is shown in the chart below.

Figure 10 - Natural Gas Usage




Figure 11 - Natural Gas Usage

Gas Billing Data for Community Pool			
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost
2/19/16	28	125	\$106
3/18/16	31	134	\$107
4/18/16	30	161	\$126
5/18/16	31	60	\$55
6/17/16	30	111	\$93
7/20/16	31	236	\$199
8/18/16	31	196	\$171
9/16/16	30	163	\$145
10/17/16	31	192	\$182
11/19/16	30	64	\$66
12/16/16	31	145	\$135
1/18/17	31	114	\$118
Totals	365	1,701	\$1,504
Annual	365	1,701	\$1,504

3.4 Benchmarking

This facility was benchmarked using *Portfolio Manager*[®], an online tool created and managed by the United States Environmental Protection Agency (EPA) through the ENERGY STAR[®] program. Portfolio Manager[®] analyzes your building’s consumption data, cost information, and operational use details and then compares its performance against a national median for similar buildings of its type. Metrics provided by this analysis are Energy Use Intensity (EUI) and an ENERGY STAR[®] score for select building types.

The EUI is a measure of a facility’s energy consumption per square foot, and it is the standard metric for comparing buildings’ energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more or less energy than similar buildings of its type on a square foot basis. EUI is presented in terms of “site energy” and “source energy.” Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

Figure 12 - Energy Use Intensity Comparison – Existing Conditions

Energy Use Intensity Comparison - Existing Conditions		
	Community Pool	National Median Building Type: Rec./Entertainment/Parks
Source Energy Use Intensity (kBtu/ft ²)	64.9	96.8
Site Energy Use Intensity (kBtu/ft ²)	24.6	41.2

Implementation of all recommended measures in this report would improve the building’s estimated EUI significantly, as shown in the table below:

Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures

Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	Community Pool	National Median Building Type: Rec./Entertainment/Parks
Source Energy Use Intensity (kBtu/ft ²)	59.5	96.8
Site Energy Use Intensity (kBtu/ft ²)	22.9	41.2

Many types of commercial buildings are also eligible to receive an ENERGY STAR[®] score. This score is a percentile ranking from 1 to 100. It compares your building’s energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75% of all similar buildings nationwide and may be eligible for ENERGY STAR[®] certification. This building is not eligible to receive a score because the property type falls under Other-Recreation property type, which is currently not being rated by ENERGY STAR[®] score.

A Portfolio Manager[®] Statement of Energy Performance (SEP) was generated for this facility, see Appendix B: ENERGY STAR[®] Statement of Energy Performance.


For more information on ENERGY STAR[®] certification go to: <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.

A Portfolio Manager[®] account has been created online for your facility and you will be provided with the login information for the account. We encourage you to update your utility information in Portfolio Manager[®] regularly, so that you can keep track of your building’s performance. Free online training is available to help you use ENERGY STAR[®] Portfolio Manager[®] to track your building’s performance at: <https://www.energystar.gov/buildings/training>.

3.5 Energy End-Use Breakdown

To provide a complete overview of energy consumption across building systems, an energy balance was performed at this facility. An energy balance utilizes standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building to determine their proportional contribution to overall building energy usage. This chart of energy end uses highlights the relative contribution of each equipment category to total energy usage. This can help determine where the greatest benefits might be found from energy efficiency measures.

Figure 14 - Energy Balance (% and kBtu/SF)



4 ENERGY CONSERVATION MEASURES

Level of Analysis

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information to the Community Pool regarding financial incentives for which they may qualify to implement the recommended measures. For this audit report, most measures have received only a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to demonstrate project cost-effectiveness and help prioritize energy measures. Savings are based on the New Jersey Clean Energy Program Protocols to Measure Resource Savings dated June 29, 2016, approved by the New Jersey Board of Public Utilities. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances. A higher level of investigation may be necessary to support any custom SmartStart or Pay for Performance, or Direct Install incentive applications. Financial incentives for the ECMs identified in this report have been calculated based the NJCEP prescriptive SmartStart program. Some measures and proposed upgrade projects may be eligible for higher incentives than those shown below through other NJCEP programs as described in Section 8.

The following sections describe the evaluated measures.

4.1 Recommended ECMs

The measures below have been evaluated by the auditor and are recommended for implementation at the facility.

Figure 15 – Summary of Recommended ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		13,601	4.3	0.0	\$2,788.64	\$11,271.22	\$1,815.00	\$9,456.22	3.4	13,696
ECM 1	Install LED Fixtures	5,127	1.0	0.0	\$1,051.20	\$4,424.75	\$1,110.00	\$3,314.75	3.2	5,163
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	1,522	0.8	0.0	\$312.08	\$2,161.00	\$95.00	\$2,066.00	6.6	1,533
ECM 3	Retrofit Fixtures with LED Lamps	6,637	2.5	0.0	\$1,360.70	\$4,040.14	\$610.00	\$3,430.14	2.5	6,683
ECM 4	Install LED Exit Signs	315	0.0	0.0	\$64.66	\$645.33	\$0.00	\$645.33	10.0	318
Lighting Control Measures		709	0.4	0.0	\$145.33	\$1,428.00	\$200.00	\$1,228.00	8.4	714
ECM 5	Install Occupancy Sensor Lighting Controls	709	0.4	0.0	\$145.33	\$1,428.00	\$200.00	\$1,228.00	8.4	714
Motor Upgrades		194	0.1	0.0	\$39.79	\$710.97	\$0.00	\$710.97	17.9	195
ECM 6	Premium Efficiency Motors	194	0.1	0.0	\$39.79	\$710.97	\$0.00	\$710.97	17.9	195
TOTALS		14,504	4.8	0.0	\$2,973.76	\$13,410.19	\$2,015.00	\$11,395.19	3.8	14,605

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

4.1.1 Lighting Upgrades

Our recommendations for existing lighting fixture upgrades are summarized in Figure 16 below.

Figure 16 – Summary of Lighting Upgrade ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		13,601	4.3	0.0	\$2,788.64	\$11,271.22	\$1,815.00	\$9,456.22	3.4	13,696
ECM 1	Install LED Fixtures	5,127	1.0	0.0	\$1,051.20	\$4,424.75	\$1,110.00	\$3,314.75	3.2	5,163
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	1,522	0.8	0.0	\$312.08	\$2,161.00	\$95.00	\$2,066.00	6.6	1,533
ECM 3	Retrofit Fixtures with LED Lamps	6,637	2.5	0.0	\$1,360.70	\$4,040.14	\$610.00	\$3,430.14	2.5	6,683
ECM 4	Install LED Exit Signs	315	0.0	0.0	\$64.66	\$645.33	\$0.00	\$645.33	10.0	318

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM I: Install LED Fixtures

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	344	0.2	0.0	\$70.54	\$1,299.33	\$310.00	\$989.33	14.0	346
Exterior	4,783	0.8	0.0	\$980.66	\$3,125.42	\$800.00	\$2,325.42	2.4	4,816

Measure Description

We recommend replacing existing fixtures containing metal halide and 2-pin circle CFL lamps with new high performance LED light fixtures. This measure saves energy by installing LEDs which use less power than other technologies with a comparable light output.

ECM 2: Retrofit Fluorescent Fixtures with LED Lamps and Drivers

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	1,522	0.8	0.0	\$312.08	\$2,161.00	\$95.00	\$2,066.00	6.6	1,533
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

Measure Description

We recommend retrofitting existing T12 fluorescent fixtures by removing fluorescent tubes and ballasts and replacing them with LEDs and LED drivers (if necessary), which are designed to be used retrofitted fluorescent fixtures. The measure uses the existing fixture housing but replaces the rest of the components with more efficient lighting technology. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of fluorescent lamps.

ECM 3: Retrofit Fixtures with LED Lamps

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	3,864	2.1	0.0	\$792.24	\$3,556.36	\$575.00	\$2,981.36	3.8	3,891
Exterior	2,773	0.5	0.0	\$568.46	\$483.78	\$35.00	\$448.78	0.8	2,792

Measure Description

We recommend retrofitting existing T8 fluorescent, incandescent, and compact fluorescent lamps with LED lamps. Many LED tube lamps are direct replacements for existing fluorescent lamps and can be installed while leaving the fluorescent fixture ballast in place. LED bulbs can be used in existing fixtures as a direct replacement for most other lighting technologies. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of fluorescent lamps and more than ten times longer than many incandescent lamps.

ECM 4: Install LED Exit Signs

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	315	0.0	0.0	\$64.66	\$645.33	\$0.00	\$645.33	10.0	318
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

Measure Description

We recommend replacing all incandescent or compact fluorescent Exit signs with LED Exit signs. LED Exit signs require virtually no maintenance and have a life expectancy of at least 20 years. This measure saves energy by installing LED fixtures, which use less power than other technologies with an equivalent lighting output.

4.1.2 Lighting Control Measures

Our recommendation for existing lighting control upgrades is summarized in Figure 17 below.

Figure 17 – Summary of Lighting Control ECMs

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures	709	0.4	0.0	\$145.33	\$1,428.00	\$200.00	\$1,228.00	8.4	714
ECM 5 Install Occupancy Sensor Lighting Controls	709	0.4	0.0	\$145.33	\$1,428.00	\$200.00	\$1,228.00	8.4	714

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 5: Install Occupancy Sensor Lighting Controls

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
709	0.4	0.0	\$145.33	\$1,428.00	\$200.00	\$1,228.00	8.4	714

Measure Description

We recommend installing occupancy sensors to control lighting fixtures that are currently controlled by manual switches in maintenance room, workshop, restrooms and locker rooms, and snack bar. Lighting sensors detect occupancy using ultrasonic and/or infrared sensors. For most spaces, we recommend lighting controls use dual technology sensors, which can eliminate the possibility of any lights turning off unexpectedly. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Some controls also provide dimming options and all modern occupancy controls can be easily over-ridden by room occupants to allow them to manually turn fixtures on or off, as desired. Energy savings results from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are recommended for single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in locations without local switching or where wall switches are not in the line-of-sight of the main work area and in large spaces. We recommend a comprehensive approach to lighting design that upgrades both the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

4.1.3 Motor Upgrades

Our recommendation for motor upgrades is summarized in Figure 18 below.

Figure 18 – Summary of Motor ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Motor Upgrades		194	0.1	0.0	\$39.79	\$710.97	\$0.00	\$710.97	17.9	195
ECM 6	Premium Efficiency Motors	194	0.1	0.0	\$39.79	\$710.97	\$0.00	\$710.97	17.9	195

ECM 6: Premium Efficiency Motors

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
194	0.1	0.0	\$39.79	\$710.97	\$0.00	\$710.97	17.9	195

Measure Description

We recommend replacing the 5 hp standard efficiency motor with *NEMA Premium™* efficiency motor. Our evaluation assumes that existing motors will be replaced with motor of equivalent size and type. Although occasionally additional savings can be achieved by downsizing motor to better meet the motor's current load requirements. The base case motor efficiencies are estimated from nameplate information and our best estimates of motor run hours. Efficiencies of proposed motor upgrades are obtained from the *New Jersey's Clean Energy Program Protocols to Measure Resource Savings (2016)*. Savings are based on the difference between baseline and proposed efficiencies and the assumed annual operating hours.

5 ENERGY EFFICIENT PRACTICES

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of many low cost or no-cost energy efficiency strategies. By employing certain behavioral and operational changes and performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and energy and O&M costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

Perform Regular Lighting Maintenance

To sustain optimal lighting levels, lighting fixtures should undergo routine maintenance. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust on lamps, fixtures and reflective surfaces. Together, these factors can reduce total illumination by 20%-60% or more, while operating fixtures continue drawing full power. To limit this reduction, lamps, reflectors and diffusers should be thoroughly cleaned of dirt, dust, oil, and smoke film buildup approximately every 6–12 months.

Develop a Lighting Maintenance Schedule

In addition to routine fixture cleaning, development of a maintenance schedule can both ensure maintenance is performed regularly and can reduce the overall cost of fixture re-lamping and re-ballasting. By re-lamping and re-ballasting fixtures in groups, lighting levels are better maintained and the number of site visits by a lighting technician or contractor can be minimized, decreasing the overall cost of maintenance.

Ensure Lighting Controls Are Operating Properly

Lighting controls are very cost effective energy efficient devices, when installed and operating correctly. As part of a lighting maintenance schedule, lighting controls should be tested annually to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight sensors, maintenance involves cleaning of sensor lenses and confirming setpoints and sensitivity are appropriately configured.

Reduce Motor Short Cycling

Frequent stopping and starting of motors subjects rotors and other parts to substantial stress. This can result in component wear, reducing efficiency, and increasing maintenance costs. Adjust the load on the motor to limit the amount of unnecessary stopping and starting to improve motor performance.

Perform Routine Motor Maintenance

Motors consist of many moving parts whose collective degradation can contribute to a significant loss of motor efficiency. To prevent damage to motor components, routine maintenance should be performed. This maintenance consists of cleaning surfaces and ventilation openings on motors to prevent overheating, lubricating moving parts to reduce friction, inspecting belts and pulleys for wear and to ensure they are at proper alignment and tension, and cleaning and lubricating bearings. Consult a licensed technician to assess these and other motor maintenance strategies.

Perform Regular Water Heater Maintenance

At least once a year, drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Once a year check for any leaks or heavy corrosion on the pipes and valves. For gas water heaters, check the draft hood and make sure it is placed properly, with a few inches of air space between the tank and where it connects to the vent. Look for any corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional. For electric water heaters, look for any signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank. For water heaters over three to four years old have a technician inspect the sacrificial anode annually.

Plug Load Controls

There are a variety of ways to limit the energy use of plug loads including increasing occupant awareness, removing under-utilized equipment, installing hardware controls, and using software controls. Some control steps to take are to enable the most aggressive power settings on existing devices or install load sensing or occupancy sensing (advanced) power strips.

Water Conservation

Installing low-flow faucets or faucet aerators, low-flow showerheads, and kitchen sink pre-rinse spray valves saves both energy and water. These devices save energy by reducing the overall amount of hot water used hence reducing the energy used to heat the water. The flow ratings for EPA WaterSense™ (<http://www3.epa.gov/watersense/products>) labeled devices are 1.5 gpm for bathroom faucets, 2.0 gpm for showerheads, and 1.28 gpm for pre-rinse spray valves.

Installing dual flush or low-flow toilets and low-flow or waterless urinals are additional ways to reduce the sites water use, however, these devices do not provide energy savings at the site level. Any reduction in water use does however ultimately reduce grid level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users. The EPA WaterSense™ ratings for urinals is 0.5 gallons per flush (gpf) and toilets that use as little as 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

6 ON-SITE GENERATION MEASURES

On-site generation measure options include both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey’s Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State’s electrical needs to be met by renewable sources by 2050.

Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before deciding to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.


6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility’s electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.

A preliminary screening based on the facility’s electric demand, size and location of free area, and shading elements shows that the facility has a Low potential for installing a PV array.

In order to be cost-effective, a solar PV array needs certain minimum criteria, such as flat or south-facing rooftop or other unshaded space on which to place the PV panels. In our opinion, the facility does appear not meet these minimum criteria for cost-effective PV installation.

Figure 19 - Photovoltaic Screening



For more information on solar PV technology and commercial solar markets in New Jersey, or to find a qualified solar installer, who can provide a more detailed assessment of the specific costs and benefits of solar develop of the site, please visit the following links below:

- **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- **NJ Solar Market FAQs:** <http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-fags>
- **Approved Solar Installers in the NJ Market:** http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1

6.2 Combined Heat and Power

Combined heat and power (CHP) is the on-site generation of electricity along with the recovery of heat energy, which is put to beneficial use. Common technologies for CHP include reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines. Electric generation from a CHP system is typically interconnected to local power distribution systems. Heat is recovered from exhaust and ancillary cooling systems and interconnected to the existing hot water (or steam) distribution systems.


CHP systems are typically used to produce a portion of the electric power used onsite by a facility, with the balance of electric power needs supplied by grid purchases. The heat is used to supplement (or supplant) existing boilers for space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for space cooling. The key criteria used for screening, however, is the amount of time the system operates at full load and the facility’s ability to use the recovered heat. Facilities with continuous use for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has a Low potential for installing a cost-effective CHP system.

Low or infrequent thermal load, and lack of space near the existing boilers are the most significant factors contributing to the low potential for CHP at the site. In our opinion, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation.

For a list of qualified firms in New Jersey specializing in commercial CHP cost assessment and installation, go to: http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/.

Figure 20 - Combined Heat and Power Screening



7 DEMAND RESPONSE

Demand Response (DR) is a program designed to reduce the electric load of commercial facilities when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability.

By enabling grid operators to call upon Curtailment Service Providers and commercial facilities to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants receive payments whether or not their facility is called upon to curtail their electric usage.

Typically, an electric customer needs to can reduce their electric demand, within minutes, by at least 100 kW or more to participate in a DR program. Customers with a greater capability to quickly curtail their demand during peak hours will receive higher payments. Customers with back-up generators onsite may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in a DR programs often find it to be a valuable source of revenue for their facility because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature set points on thermostats, so that air conditioning units run less frequently, or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a demand response activity in most situations.

The first step toward participation in a DR program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business (<http://www.pjm.com/markets-and-operations/demand-response/csps.aspx>). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity (<http://www.pjm.com/training/training%20material.aspx>), along with a variety of other DR program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

The facility has no potential for DR curtailment.

8 PROJECT FUNDING / INCENTIVES

The NJCEP can provide the incentive programs described below, and other benefits to ratepayers, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey’s Electricity Restructuring Law (1999), which requires all customers of investor-owned electric and gas utilities to pay a surcharge on their monthly energy bills. As a customer of a state-regulated electric or gas utility and therefore a contributor to the fund, your organization is eligible to participate in the LGEA program and eligible to receive incentive payment for qualifying energy efficiency measures. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 21 for a list of the eligible programs identified for each recommended ECM.

Figure 21 - ECM Incentive Program Eligibility

Energy Conservation Measure		SmartStart Prescriptive	SmartStart Custom	Direct Install	Pay For Performance Existing Buildings	Large Energy Users Program	Combined Heat & Power and Fuel Cell
ECM 1	Install LED Fixtures	X		X			
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	X		X			
ECM 3	Retrofit Fixtures with LED Lamps	X		X			
ECM 4	Install LED Exit Signs			X			
ECM 5	Install Occupancy Sensor Lighting Controls	X		X			
ECM 6	Premium Efficiency Motors			X			

SmartStart is generally well-suited for implementation of individual measures or small group of measures. It provides flexibility to install measures at your own pace using in-house staff or a preferred contractor. Direct Install caters to small to mid-size facilities that can bundle multiple ECMs together. This can greatly simplify participation and may lead to higher incentive amounts, but requires the use of pre-approved contractors. The Pay for Performance (P4P) program is a “whole-building” energy improvement program designed for larger facilities. It requires implementation of multiple measures meeting minimum savings thresholds, as well as use of pre-approved consultants. The Large Energy Users Program (LEUP) is available to New Jersey’s largest energy users giving them flexibility to install as little or as many measures, in a single facility or several facilities, with incentives capped based on the entity’s annual energy consumption. LEUP applicants can use in-house staff or a preferred contractor.

Generally, the incentive values provided throughout the report assume the SmartStart program is utilized because it provides a consistent basis for comparison of available incentives for various measures, though in many cases incentive amounts may be higher through participation in other programs.

Brief descriptions of all relevant financing and incentive programs are in the sections below. Further information, including most current program availability, requirements, and incentive levels can be found at: www.njcleanenergy.com/ci.

8.1 SmartStart

Overview

The SmartStart program offers incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives from year to year for various energy efficiency equipment based on market trends and new technologies.

Equipment with Prescriptive Incentives Currently Available:

Electric Chillers

Electric Unitary HVAC

Gas Cooling

Gas Heating

Gas Water Heating

Ground Source Heat Pumps

Lighting

Lighting Controls

Refrigeration Doors

Refrigeration Controls

Refrigerator/Freezer Motors

Food Service Equipment

Variable Frequency Drives

Most equipment sizes and types are served by this program. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades.

Incentives

The SmartStart prescriptive incentive program provides fixed incentives for specific energy efficiency measures, whereas the custom SmartStart program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentive offerings for specific devices.

Since your facility is an existing building, only the retrofit incentives have been applied in this report. Custom measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at 50% of the total installed incremental project cost, or a project cost buy down to a one year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

How to Participate

To participate in the SmartStart program you will need to apply for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: www.njcleanenergy.com/SSB.

8.2 Direct Install

Overview

Direct Install is a turnkey program available to existing small to medium-sized facilities with an average peak electric demand that does not exceed 200 kW over the recent 12-month period. You work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives and controls.

Incentives

The program pays up to 70% of the total installed cost of eligible measures, up to \$125,000 per project. Each entity is limited to incentives up to \$250,000 per fiscal year.

How to Participate

To participate in Direct Install, you will need to contact the participating contractor assigned to the region of the state where your facility is located. A complete list of Direct Install program partners is provided on the Direct Install website linked below. The contractor will be paid the measure incentives directly by the program which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the program, subject to program caps and eligibility, while the remaining 30% of the cost is paid to the contractor by the customer.

Detailed program descriptions and applications can be found at: www.njcleanenergy.com/DI.

8.3 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) is an alternate method for New Jersey's government agencies to finance the implementation of energy conservation measures. An ESIP is a type of "performance contract," whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. This is done in a manner that ensures that annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive in year one, and every year thereafter. ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs can be leveraged to help further reduce the total project cost of eligible measures.

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an Energy Services Company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is utilized for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the Energy Savings Plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Entities should carefully consider all alternatives to develop an approach that best meets their needs. A detailed program description and application can be found at: www.njcleanenergy.com/ESIP.

Please note that ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you may utilize NJCEP incentive programs to help further reduce costs when developing the ESP. You should refer to the ESIP guidelines at the link above for further information and guidance on next steps.

9 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

9.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities could charge Cost of Service and customers were given the ability to choose a third party (i.e., non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third party supplier, consider shopping for a reduced rate from third party electric suppliers. If your facility is purchasing electricity from a third party supplier, review and compare prices at the end of the current contract or every couple of years.

A list of third party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

9.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate monthly. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third party supplier, consider shopping for a reduced rate from third party natural gas suppliers. If your facility is purchasing natural gas from a third party supplier, review and compare prices at the end of the current contract or every couple of years.

A list of third party natural gas suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

Appendix A: Equipment Inventory & Recommendations

Lighting Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Front Entrance	2	Compact Fluorescent: CFL Screw in	Day light Dimming	23	4,380	Relamp	No	2	LED Screw-In Lamps: LED Screw-In Lamps	Day light Dimming	11	4,380	0.02	105	0.0	\$21.55	\$107.51	\$0.00	4.99
Maintenance Room	2	Linear Fluorescent - T12: 8' T12 (75W) - 2L	Wall Switch	158	1,344	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,344	0.21	392	0.0	\$80.34	\$234.00	\$20.00	2.66
Maintenance Room	6	Incandescent: Screw in	Wall Switch	100	1,344	Relamp	Yes	6	LED Screw-In Lamps: LED Screw-In Lamps	Occupancy Sensor	13	941	0.44	828	0.0	\$169.83	\$438.52	\$50.00	2.29
Maintenance Room	1	Linear Fluorescent - T12: 4' T12 (40W) - 1L	Wall Switch	46	1,344	Relamp & Reballast	No	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	1,344	0.03	48	0.0	\$9.81	\$98.00	\$5.00	9.48
Pump Room	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,344	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,344	0.05	100	0.0	\$20.55	\$117.00	\$20.00	4.72
Pump Room	1	Incandescent: Screw in	Wall Switch	100	1,344	Relamp	No	1	LED Screw-In Lamps: LED Screw-In Lamps	Wall Switch	13	1,344	0.07	132	0.0	\$27.09	\$53.75	\$5.00	1.80
Exterior Lights	6	Metal Halide: (1) 175W Lamp	Day light Dimming	215	4,380	Fixture Replacement	No	6	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Day light Dimming	52	4,380	0.80	4,841	0.0	\$992.46	\$2,344.06	\$600.00	1.76
Exterior Lights	2	Metal Halide: (1) 50W Lamp	Day light Dimming	72	4,380	Fixture Replacement	No	2	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Day light Dimming	15	4,380	0.09	564	0.0	\$115.69	\$781.35	\$200.00	5.03
Water Treatment Room	5	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	1,344	Relamp & Reballast	Yes	5	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	941	0.28	514	0.0	\$105.40	\$701.00	\$70.00	5.99
Community Pool	7	Incandescent: Screw in	Day light Dimming	100	4,380	Relamp	No	7	LED Screw-In Lamps: LED Screw-In Lamps	Day light Dimming	13	4,380	0.50	3,014	0.0	\$618.00	\$376.27	\$35.00	0.55
Community Pool	3	LED - Fixtures: LED - Fixtures	Day light Dimming	50	4,380	None	No	3	LED - Fixtures: LED - Fixtures	Day light Dimming	50	4,380	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Community Pool	3	Metal Halide: (1) 70W Lamp	Wall Switch	95	1,344	Fixture Replacement	No	3	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Wall Switch	21	1,344	0.18	337	0.0	\$69.13	\$1,172.03	\$300.00	12.61
Workshop	4	Linear Fluorescent - T12: 8' T12 (75W) - 2L	Wall Switch	158	1,344	Relamp & Reballast	Yes	4	LED - Linear Tubes: (2) 8' Lamps	Occupancy Sensor	72	941	0.35	654	0.0	\$134.02	\$924.00	\$20.00	6.75
Utility Room	1	Linear Fluorescent - T12: 8' T12 (75W) - 2L	Wall Switch	158	1,344	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 8' Lamps	Wall Switch	72	1,344	0.07	131	0.0	\$26.78	\$202.00	\$0.00	7.54
Utility Room	2	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	88	1,344	Relamp & Reballast	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,344	0.10	179	0.0	\$36.74	\$234.00	\$20.00	5.82
Women Restroom	4	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,344	Relamp	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	941	0.14	253	0.0	\$51.94	\$504.00	\$75.00	8.26
Women Locker Room	11	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,344	Relamp	Yes	11	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	941	0.37	697	0.0	\$142.83	\$913.50	\$145.00	5.38
Women Locker Room	1	Exit Signs: Fluorescent	None	12	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	6	8,760	0.00	59	0.0	\$12.18	\$107.56	\$0.00	8.83
Main Lobby	3	Incandescent: Screw in	Wall Switch	100	1,344	Relamp	No	3	LED Screw-In Lamps: LED Screw-In Lamps	Wall Switch	13	1,344	0.21	396	0.0	\$81.27	\$161.26	\$15.00	1.80
Main Lobby	2	Exit Signs: Fluorescent	None	12	8,760	Fixture Replacement	No	2	LED Exit Signs: 2 W Lamp	None	6	8,760	0.01	119	0.0	\$24.35	\$215.11	\$0.00	8.83
Main Lobby	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,344	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,344	0.03	50	0.0	\$10.28	\$58.50	\$10.00	4.72
Men Restroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,344	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,344	0.03	50	0.0	\$10.28	\$58.50	\$10.00	4.72
Men Locker Room	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,344	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	941	0.41	760	0.0	\$155.82	\$972.00	\$155.00	5.24
Men Locker Room	2	Exit Signs: Fluorescent	None	12	8,760	Fixture Replacement	No	2	LED Exit Signs: 2 W Lamp	None	6	8,760	0.01	119	0.0	\$24.35	\$215.11	\$0.00	8.83
Men Locker Room	1	Incandescent: Screw in	Wall Switch	100	1,344	Relamp	No	1	LED Screw-In Lamps: LED Screw-In Lamps	Wall Switch	13	1,344	0.07	132	0.0	\$27.09	\$53.75	\$5.00	1.80

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Resting Room	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,344	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,344	0.03	50	0.0	\$10.28	\$58.50	\$10.00	4.72
First Aid Room	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,344	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,344	0.03	50	0.0	\$10.28	\$58.50	\$10.00	4.72
Stairwell	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	62	1,344	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,344	0.03	50	0.0	\$10.28	\$58.50	\$10.00	4.72
Manager Office	2	Compact Fluorescent: 2 pin - Circle	Wall Switch	30	1,344	Fixture Replacement	No	2	LED - Fixtures: Downlight Solid State Retrofit	Wall Switch	13	1,344	0.03	52	0.0	\$10.59	\$127.30	\$10.00	11.08
Storage Room	2	Incandescent: Screw in	Wall Switch	100	1,344	Relamp	No	2	LED Screw-In Lamps: LED Screw-In Lamps	Wall Switch	13	1,344	0.14	264	0.0	\$54.18	\$107.51	\$10.00	1.80
Snack Bar	8	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	1,344	Relamp	Yes	8	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	941	0.48	892	0.0	\$182.85	\$1,031.07	\$195.00	4.57
Snack Bar	1	Exit Signs: Fluorescent	None	12	8,760	Fixture Replacement	No	1	LED Exit Signs: 2 W Lamp	None	6	8,760	0.00	59	0.0	\$12.18	\$107.56	\$0.00	8.83
Snack Bar	2	Incandescent: Screw in	Wall Switch	100	1,344	Relamp	No	2	LED Screw-In Lamps: LED Screw-In Lamps	Wall Switch	13	1,344	0.14	264	0.0	\$54.18	\$107.51	\$10.00	1.80

Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Maintenance Room	Sump Pump	1	Process Pump	0.3	78.0%	No	1,120	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Maintenance Room	Baby Pool	1	Water Supply Pump	5.0	86.0%	No	2,016	No	86.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Maintenance Room	Baby Pool	1	Water Supply Pump	5.0	84.0%	No	2,016	Yes	86.5%	No		0.07	194	0.0	\$39.79	\$710.97	\$0.00	17.87
Pump Room	Training Pool	1	Water Supply Pump	5.0	86.0%	No	2,016	No	86.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Pump Room	Sump Pump	1	Process Pump	1.3	78.0%	No	1,120	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Pump Room	Chlorine	4	Process Pump	0.1	78.0%	No	1,120	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Slid Area	Slid Area	2	Water Supply Pump	15.0	91.0%	No	2,016	No	91.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Main Pool	Main Pool	1	Water Supply Pump	20.0	93.0%	No	2,128	No	93.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Diving Pool	Diving Pool	1	Water Supply Pump	15.0	91.0%	No	2,016	No	91.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Chlorine Room	Chlorine Room	2	Process Pump	1.0	84.0%	No	1,120	No	84.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Chlorine Room	Chlorine Room	1	Exhaust Fan	0.3	78.0%	No	2,016	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Pump Room	Pump Room	1	Exhaust Fan	0.5	78.0%	No	2,016	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Utility Room	DHW Booster Pump	1	Process Pump	0.1	78.0%	No	1,120	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Locker Rooms	Locker Rooms	4	Exhaust Fan	2.0	84.0%	No	2,016	No	84.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Snack Bar	Snack Bar	2	Exhaust Fan	0.5	78.0%	No	2,016	No	78.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions						Energy Impact & Financial Analysis						
		System Quantity	System Type	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Utility Room	Community Pool	1	Storage Tank Water Heater (> 50 Gal)	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Utility Room	Snack Bar	1	Storage Tank Water Heater (≤ 50 Gal)	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Commercial Refrigerator/Freezer Inventory & Recommendations

Location	Existing Conditions			Proposed Condi	Energy Impact & Financial Analysis							
	Quantity	Refrigerator/ Freezer Type	ENERGY STAR Qualified?	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years	
Snack Bar	1	Stand-Up Refrigerator, Solid Door (31 - 50 cu. ft.)	Yes	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00	
Snack Bar	1	Stand-Up Refrigerator, Solid Door (>50 cu. ft.)	Yes	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00	

Commercial Ice Maker Inventory & Recommendations

Location	Existing Conditions			Proposed Condi	Energy Impact & Financial Analysis							
	Quantity	Ice Maker Type	ENERGY STAR Qualified?	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years	
Snack Bar	1	Ice Making Head (<450 lbs/day), Batch	Yes	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00	

Cooking Equipment Inventory & Recommendations

Location	Existing Conditions			Proposed Conditions	Energy Impact & Financial Analysis						
	Quantity	Equipment Type	High Efficiency Equipment?	Install High Efficiency Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Snack Bar	1	Electric Convection Oven (Half Size)	Yes	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Snack Bar	2	Gas Fryer	Yes	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Snack Bar	1	Gas Convection Oven (Full Size)	Yes	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Snack Bar	2	Gas Griddle (3 Feet Width)	Yes	No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Plug Load Inventory

Location	Existing Conditions			
	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
Community Pool	4	Refrigerator	175.0	Yes
Community Pool	5	Computer with LCD monitors	191.0	Yes
Community Pool	2	Microwave	800.0	No
Community Pool	1	Toaster	600.0	No
Community Pool	10	Movable Electric Heater	1,500.0	No
Community Pool	1	Electric Washing Machine	1,000.0	No
Community Pool	1	Electric Washing Machine	1,100.0	No
Main Lobby	3	Ventilation Fan	1,200.0	No
Manager Office	2	Ventilation Fan	1,200.0	No

Appendix B: ENERGY STAR® Statement of Energy Performance



LEARN MORE AT energystar.gov

ENERGY STAR® Statement of Energy Performance

N/A Community Pool

Primary Property Type: Other - Recreation
 Gross Floor Area (ft²): 9,500
 Built: 1946

For Year Ending: December 31, 2016
 Date Generated: May 28, 2018

ENERGY STAR® Score¹

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information		
Property Address Community Pool 187 Boyden Avenue Maplewood, New Jersey 07040	Property Owner Township of Maplewood 574 Valley Street Maplewood, NJ 07040 (973) 762-8120	Primary Contact Joseph Manning 574 Valley Street Maplewood, NJ 07040 (973) 762-8120 Ext. 2000 twpadmin@twp.maplewood.nj.us
Property ID: 6359506		

Energy Consumption and Energy Use Intensity (EUI)				
Site EUI 74.6 kBtu/ft²	Annual Energy by Fuel		National Median Comparison	
	Natural Gas (kBtu)	171,738 (24%)		National Median Site EUI (kBtu/ft²)
	Electric - Grid (kBtu)	536,963 (76%)	National Median Source EUI (kBtu/ft²)	96.8
			% Diff from National Median Source EUI	103%
Source EUI 196.5 kBtu/ft²			Annual Emissions	
			Greenhouse Gas Emissions (Metric Tons CO2e/year)	69

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: _____ Date: _____

Licensed Professional

 () - _____



Professional Engineer Stamp (if applicable)