



# Local Government Energy Audit: Energy Audit Report



Copyright ©201 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

## **Public Works**

**Ocean Township**

200 Wells Mills Rd  
Waretown, NJ 08758

Ocean Township

November 6, 2018

Final Report by:  
**TRC Energy Services**

## Disclaimer

---

The intent of this energy analysis report is to identify energy savings opportunities and recommend upgrades to the facility's energy using equipment and systems. Approximate savings are included in this report to help make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. Further design and analysis may be necessary in order to implement some of the measures recommended in this report.

The energy conservation measures and estimates of energy savings have been reviewed for technical accuracy. However, estimates of final energy savings are not guaranteed, because final savings may depend on behavioral factors and other uncontrollable variables. TRC Energy Services (TRC) and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

Estimated installation costs are based on TRC's experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from *RS Means*. The owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for certain measures and conditions, TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. The owner of the facility should review available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

# Table of Contents

---

<b>1</b>	<b>Executive Summary.....</b>	<b>1</b>
1.1	Facility Summary .....	1
1.2	Your Cost Reduction Opportunities.....	1
	Energy Conservation Measures.....	1
	Energy Efficient Practices .....	3
	On-Site Generation Measures.....	3
1.3	Implementation Planning.....	3
<b>2</b>	<b>Facility Information and Existing Conditions .....</b>	<b>5</b>
2.1	Project Contacts .....	5
2.2	General Site Information.....	5
2.3	Building Occupancy .....	5
2.4	Building Envelope .....	6
2.5	On-Site Generation.....	6
2.6	Energy-Using Systems .....	6
	Lighting System .....	6
	Heating System .....	7
	Cooling System .....	7
	Domestic Hot Water Heating System.....	8
	Motors 8	
	Building Plug Load .....	8
2.7	Water-Using Systems .....	8
<b>3</b>	<b>Site Energy Use and Costs.....</b>	<b>9</b>
3.1	Total Cost of Energy .....	9
3.2	Electricity Usage .....	10
3.3	Natural Gas Usage .....	11
3.4	Benchmarking.....	12
3.5	Energy End-Use Breakdown .....	13
<b>4</b>	<b>Energy Conservation Measures .....</b>	<b>14</b>
4.1	Recommended ECMs .....	14
4.1.1	Lighting Upgrades.....	15
	ECM 1: Install LED Fixtures .....	15
	ECM 2:Retrofit Fluorescent Fixtures with LED Lamps and Drivers.....	16
	ECM 3: Retrofit Fixtures with LED Lamps.....	16
4.1.2	Lighting Control Measures .....	17
	ECM 4: Install Occupancy Sensor Lighting Controls .....	17
<b>5</b>	<b>Energy Efficient Practices .....</b>	<b>18</b>
	Reduce Air Leakage .....	18
	Close Doors and Windows .....	18
	Perform Proper Lighting Maintenance.....	18
	Develop a Lighting Maintenance Schedule .....	18

Turn Off Unneeded Motors.....	18
Perform Routine Motor Maintenance .....	19
Practice Proper Use of Thermostat Schedules and Temperature Resets .....	19
Clean Evaporator/Condenser Coils on AC Systems .....	19
Clean and/or Replace HVAC Filters .....	19
Check for and Seal Duct Leakage .....	19
Perform Proper Furnace Maintenance .....	19
Perform Proper Water Heater Maintenance .....	20
Plug Load Controls.....	20
Water Conservation .....	20
<b>6 On-Site Generation Measures .....</b>	<b>21</b>
6.1 Photovoltaic.....	21
<b>7 Demand Response .....</b>	<b>23</b>
<b>8 Project Funding / Incentives .....</b>	<b>24</b>
8.1 SmartStart .....	25
8.2 Direct Install .....	26
8.3 Energy Savings Improvement Program.....	26
8.4 SREC Registration Program.....	27
8.5 Demand Response Energy Aggregator.....	27
<b>9 Energy Purchasing and Procurement Strategies .....</b>	<b>28</b>
9.1 Retail Electric Supply Options.....	28
9.2 Retail Natural Gas Supply Options .....	28

Appendix A: Equipment Inventory & Recommendations

Appendix B: ENERGY STAR® Statement of Energy Performance

# Table of Figures

---

Figure 1 – Previous 12 Month Utility Costs..... 2

Figure 2 – Potential Post-Implementation Costs ..... 2

Figure 3 – Summary of Energy Reduction Opportunities ..... 2

Figure 4 – Photovoltaic Potential..... 3

Figure 5 – Project Contacts ..... 5

Figure 6 - Building Schedule..... 5

Figure 7 - Utility Summary ..... 9

Figure 8 - Energy Cost Breakdown ..... 9

Figure 9 - Electric Usage & Demand..... 10

Figure 10 - Electric Usage & Demand..... 10

Figure 11 - Natural Gas Usage..... 11

Figure 12 - Natural Gas Usage..... 11

Figure 13 - Energy Use Intensity Comparison – Existing Conditions..... 12

Figure 14 - Energy Use Intensity Comparison – Following Installation of Recommended Measures ..... 12

Figure 15B - Energy Use Intensity Comparison – Existing Conditions (Without Well Pump Motor Usage)13

Figure 16B - Energy Use Intensity Comparison – Following Installation of Recommended Measures (Without Well Pump Motor Usage)..... 13

Figure 17 - Energy Balance (% and kBtu/SF) ..... 13

Figure 18 – Summary of Recommended ECMs..... 14

Figure 19 – Summary of Lighting Upgrade ECMs..... 15

Figure 20 – Summary of Lighting Control ECMs ..... 17

Figure 21 - Photovoltaic Screening ..... 22

Figure 22 - ECM Incentive Program Eligibility..... 24

# I EXECUTIVE SUMMARY

---

The New Jersey Board of Public Utilities (NJBPU) has sponsored this Local Government Energy Audit (LGEA) Report for Public Works.

The goal of an LGEA report is to provide you with information on how your facility uses energy, identify energy conservation measures (ECMs) that can reduce your energy use, and provide information and assistance to help facilities implement ECMs. The LGEA report also contains valuable information on financial incentives from New Jersey's Clean Energy Program (NJCEP) for implementing ECMs.

This study was conducted by TRC Energy Services (TRC), as part of a comprehensive effort to assist New Jersey local governments in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

## I.1 Facility Summary

The Public Works building is a 9,720 square foot complex comprised of multiple garage bay buildings and office space. There are a total of five buildings at the Department of Public Works (DPW) which are in operation year round. There is an office building, DPW garage, vehicle service garage, maintenance garage and well pump building. The general office areas and garages are occupied on between 6:00 AM and 2:30 PM, Monday through Friday. The well pump building houses the well pumps for the town which operate almost 24 hours a day during the summer and less in the winter. On average, the DPW buildings are occupied by 15 people.


A thorough description of the facility and our observations are located in Section 2.

## I.2 Your Cost Reduction Opportunities


### Energy Conservation Measures

TRC evaluated four measures which together represent an opportunity for Public Works to reduce annual energy costs by \$3,768 and annual greenhouse gas emissions by 28,136 lbs CO<sub>2</sub>e. We estimate that if all recommended measures are implemented, the project would pay for itself in energy savings in 6.9 years. A breakdown of current utility costs is shown in Figure 1. The estimated reduction in utility costs for the proposed measures is shown in Figure 2. Together these measures represent an opportunity to reduce Public Works annual energy use by 6%.

**Figure 1 – Previous 12 Month Utility Costs**



**Figure 2 – Potential Post-Implementation Costs**



A detailed description of Public Works existing energy use can be found in Section 3.

Estimates of the total cost, energy savings, and financial incentives for the proposed energy efficient upgrades are summarized below in Figure 3. A brief description of each category can be found below and a description of savings opportunities can be found in Section 4.

**Figure 3 – Summary of Energy Reduction Opportunities**

Energy Conservation Measure	Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>		<b>24,525</b>	<b>6.9</b>	<b>0.0</b>	<b>\$3,307.80</b>	<b>\$27,691.87</b>	<b>\$4,290.00</b>	<b>\$23,401.87</b>	<b>7.1</b>	<b>24,697</b>
ECM 1   Install LED Fixtures	Yes	12,913	2.8	0.0	\$1,741.60	\$16,825.03	\$2,645.00	\$14,180.03	8.1	13,003
ECM 2   Retrofit Fluorescent Fixtures with LED Lamps and Drivers	Yes	1,425	0.9	0.0	\$192.25	\$3,030.00	\$0.00	\$3,030.00	15.8	1,435
ECM 3   Retrofit Fixtures with LED Lamps	Yes	10,187	3.2	0.0	\$1,373.95	\$7,836.83	\$1,645.00	\$6,191.83	4.5	10,258
<b>Lighting Control Measures</b>		<b>3,415</b>	<b>1.2</b>	<b>0.0</b>	<b>\$460.65</b>	<b>\$3,164.00</b>	<b>\$390.00</b>	<b>\$2,774.00</b>	<b>6.0</b>	<b>3,439</b>
ECM 4   Install Occupancy Sensor Lighting Controls	Yes	3,415	1.2	0.0	\$460.65	\$3,164.00	\$390.00	\$2,774.00	6.0	3,439
<b>TOTALS</b>		<b>27,941</b>	<b>8.0</b>	<b>0.0</b>	<b>\$3,768.45</b>	<b>\$30,855.87</b>	<b>\$4,680.00</b>	<b>\$26,175.87</b>	<b>6.9</b>	<b>28,136</b>

\* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

**Lighting Upgrades** generally involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measures save energy by reducing the power used by the lighting components due to improved electrical efficiency.

**Lighting Controls** measures generally involve the installation of automated controls to turn off lights or reduce light output when not needed. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

## Energy Efficient Practices

TRC also identified 14 low cost (or no cost) energy efficient practices. A facility’s energy performance can be significantly improved by employing certain behavioral or operational adjustments and by performing better routine maintenance on building systems. These practices can extend equipment lifetime, improve occupant comfort, provide better health and safety, as well as reduce annual energy and operation and maintenance costs (O&M). Potential opportunities identified at Public Works include:

- Reduce Air Leakage
- Close Doors and Windows
- Perform Proper Lighting Maintenance
- Develop a Lighting Maintenance Schedule
- Turn Off Unneeded Motors
- Perform Routine Motor Maintenance
- Practice Proper Use of Thermostat Schedules and Temperature Resets
- Clean Evaporator/Condenser Coils on AC Systems
- Clean and/or Replace HVAC Filters
- Check for and Seal Duct Leakage
- Perform Proper Furnace Maintenance
- Perform Proper Water Heater Maintenance
- Install Plug Load Controls
- Water Conservation

For details on these energy efficient practices, please refer to Section 5.

## On-Site Generation Measures

TRC evaluated the potential for installing on-site generation for Public Works. Based on the configuration of the site and its loads there is a high potential for installing a photovoltaic (PV) array.

*Figure 4 – Photovoltaic Potential*

Potential	High	
System Potential	71	kW DC STC
Electric Generation	84,587	kWh/yr
Displaced Cost	\$7,360	/yr
Installed Cost	\$203,100	

For details on our evaluation and on-site generation potential, please refer to Section 6.

## **I.3 Implementation Planning**

To realize the energy savings from the ECMs listed in this report, a project implementation plan must be developed. Available capital must be considered and decisions need to be made whether it is best to pursue individual ECMs separately, groups of ECMs, or a comprehensive approach where all ECMs are implemented together, possibly in conjunction with other facility upgrades or improvements.

Rebates, incentives, and financing are available from NJCEP, as well as other sources, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any measure, please review the relevant incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives prior to purchasing materials or commencing with installation.

The ECMs outlined in this report may qualify under the following program(s):

- SmartStart (SS)
- Direct Install (DI)
- Energy Savings Improvement Program (ESIP)

For facilities wanting to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate in this program you may utilize internal resources, or an outside firm or contractor, to do the final design of the ECM(s) and do the installation. Program pre-approval is required for some SmartStart incentives, so only after receiving pre-approval should you proceed with ECM installation. The incentive estimates listed above in Figure 3 are based on the SmartStart program. More details on this program and others are available in Section 8.

This facility may also qualify for the Direct Install program which can provide turnkey installation of multiple measures, through an authorized network of participating contractors. This program can provide substantially higher incentives than SmartStart, up to 70% of the cost of selected measures, although measure eligibility will have to be assessed and be verified by the designated DI contractor and, in most cases, they will perform the installation work.

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the Energy Savings Improvement Program (ESIP). Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. An LGEA report (or other approved energy audit) is required for participation in ESIP. Please refer to Section 8.3 for additional information on the ESIP Program.

The Demand Response Energy Aggregator is a (non-NJCEP) program designed to reduce electric loads at commercial facilities, when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. Demand Response (DR) service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability. By enabling grid operators to call upon commercial facilities to reduce their electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and facilities receive payments whether or not they are called upon to curtail their load during times of peak demand. Refer to Section 7 for additional information on this program.

Additional information on relevant incentive programs is located in Section 8. You may also check the following website for more details: [www.njcleanenergy.com/ci](http://www.njcleanenergy.com/ci).

## 2 FACILITY INFORMATION AND EXISTING CONDITIONS

### 2.1 Project Contacts

Figure 5 – Project Contacts

Name	Role	E-Mail	Phone #
<b>Customer</b>			
Diane Ambrosio	Business Administrator	clerk@twpoceanj.gov	609-693-3302
Dan Kehoe	Foreman - Public Works		609-839-7701
Matt Ambrosio	Superintendent - Public Works		609-618-0892
<b>TRC Energy Services</b>			
Aimee Lalonde	Auditor	alalonde@trcsolutions.com	(732) 855-0033

### 2.2 General Site Information

On June 27, 2017, TRC performed an energy audit at the Public Works building located in Waretown, New Jersey. TRC’s team met with Diane Ambrosio, Business Administrator; Dan Kehoe, Forman, Public Works; and Matt Ambrosio, Superintendent – Public Works to review the facility operations and help focus our investigation on specific energy-using systems.

The Public Works building is a 9,720 square foot complex comprised of multiple garage bay buildings and office space. There are a total of five buildings at the Department of Public Works (DPS) which are in operation year round. There is an office building, DPW garage, vehicle service garage, maintenance garage and well pump building.

The building was constructed in 1958. Space heating equipment at the Public Works building consists of aging and inefficient equipment in need of an upgrade. We would recommend replacing the existing gas-fired forced air unit heaters with new modulating gas-fired infrared heaters, however, the current gas usage is low and therefore, the savings would not justify the cost to install new systems. Infrared heaters would likely improve comfort conditions in the garage while reducing gas use but are unlikely to payback on energy savings alone.

### 2.3 Building Occupancy

The general office areas and garages are occupied on average between 6:00 AM and 2:30 PM, Monday through Friday. The well pump building houses the well pumps for the town which operate almost 24 hours a day during the summer and less in the winter. On average the DPW buildings are occupied by 15 people.

Figure 6 - Building Schedule

Building Name	Weekday/Weekend	Operating Schedule
Public Works	Weekday	6:00 AM - 2:30 PM
Public Works	Weekend	No Use

## 2.4 Building Envelope

The buildings are constructed of concrete block and structural steel with exterior cladding. The buildings have pitched roofs which are in good condition and are sloped toward the south. The buildings have double-pane windows which are in good condition and show little sign of excessive infiltration. The exterior doors and overhead doors are constructed of metal and in good condition.



## 2.5 On-Site Generation


Public Works does not have any on-site electric generation capacity. Please refer to Section 6 for further details.

## 2.6 Energy-Using Systems

Please see Appendix A: Equipment Inventory & Recommendations for an inventory of the facility's equipment.

### Lighting System


Lighting at the facility is provided mostly by 32-Watt linear fluorescent T8 lamps with electronic ballasts. The maintenance garage is lit by 75-Watt linear T12 lamps and magnetic ballasts. The exterior of the buildings include high pressure sodium wall pack fixtures and pole-mounted shoe box fixtures. The reclaimed water pool structure also has interior high pressure sodium lamp fixtures. The fixtures throughout the buildings are manually controlled via wall switches. The exterior lighting is controlled by a timeclock.



## Heating System

The DPW garage is heated by a forced air furnace that is in fair condition and standard efficiency. There are also three, gas-fired unit heaters which are standard efficiency. These are controlled by a programmable dial thermostat. Heating season temperature set point is about 68°F degrees and not set back.

The vehicle service garage is heated by four, gas-fired unit heaters which are rarely used. They are controlled by a manual dial thermostat, however, it is usually set to only 62°F throughout the winter. The gas meter data was not provided for this building and therefore, this equipment is not included within the analysis of this report. It is mentioned here only for added detail. Additionally, there are electric baseboard heaters in the restroom and mechanical space.



## Cooling System

The office and break room area are cooled by a split AC system with an outdoor condensing unit. The system is set to 72°F degrees in the summer months with no setbacks. The system is about ten years-old and is moderately efficient. An office in the garage is cooled by a portable AC unit that is in good condition and relatively efficient.



## Domestic Hot Water Heating System

The domestic hot water heating system for the facility consists of two gas-fired storage tank water heaters. These are in good condition and of standard efficiency. There is a low load for domestic hot water, typically just for faucets in restrooms. Fixtures are fit with low flow aerators or are older manual sinks without the ability to be retrofitted with low flow aerators.



## Motors

The garage doors are powered by overhead door opener motors. Additionally, the facility has unit heater supply fan motors and exhaust fan motors. All motors appear to be in good condition. The well pump building houses the water pumps which are large (100 HP), are highly efficient, and are controlled by variable frequency drives. The pump motors are by far the largest energy using equipment in the complex, and they are in good condition and appear to be controlled properly. These motors also skew the benchmark for the facility. The energy consumption is much higher than a typical garage/warehouse which does not include these well pump motors.



## Building Plug Load

The plug loads include general office and café equipment.

## 2.7 Water-Using Systems

There are a few restrooms throughout the buildings. These are fit with low-flow aerators or are old and manual sinks without the ability to be retrofitted with low-flow aerators.

### 3 SITE ENERGY USE AND COSTS

Utility data for electricity and natural gas was analyzed to identify opportunities for savings. In addition, data for electricity and natural gas was evaluated to determine the annual energy performance metrics for the building in energy cost per square foot and energy usage per square foot. These metrics are an estimate of the relative energy efficiency of this building. There are a number of factors that could cause the energy use of this building to vary from the “typical” energy usage profile for facilities with similar characteristics. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and energy efficient behavior of occupants all contribute to benchmarking scores. Please refer to the Benchmarking section within Section 3.4 for additional information.

#### 3.1 Total Cost of Energy


The following energy consumption and cost data is based on the last 12-month period of utility billing data that was provided for each utility. A profile of the annual energy consumption and energy cost of the facility was developed from this information.

**Figure 7 - Utility Summary**

Utility Summary for Public Works		
Fuel	Usage	Cost
Electricity	442,934 kWh	\$59,740
Natural Gas	1,310 Therms	\$1,330
Total		\$61,070

The current annual energy cost for this facility is \$61,070 as shown in the chart below.

**Figure 8 - Energy Cost Breakdown**



### 3.2 Electricity Usage

Electricity is provided by JCP&L. The average electric cost over the past 12 months was \$0.135/kWh, which is the blended rate that includes energy supply, distribution, and other charges. This rate is used throughout the analyses in this report to assess energy costs and savings. The facility pays electrical demand charges. The monthly electricity consumption and peak demand are shown in the chart below.

Figure 9 - Electric Usage & Demand




Figure 10 - Electric Usage & Demand

Electric Billing Data for Public Works						
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost	TRC Estimated Usage?
9/28/15	32	48,960	134	\$743	\$6,473	No
10/27/15	29	27,760	128	\$663	\$3,847	No
11/25/15	29	21,840	119	\$612	\$3,129	No
12/29/15	34	25,760	113	\$576	\$3,544	No
1/29/16	31	28,360	120	\$616	\$3,879	Yes
2/26/16	28	30,960	127	\$656	\$4,214	No
3/28/16	31	26,400	116	\$596	\$3,680	No
4/27/16	30	35,680	128	\$663	\$4,816	No
5/25/16	28	39,040	120	\$616	\$5,155	No
6/23/16	29	47,040	138	\$766	\$6,325	No
7/26/16	33	57,120	139	\$777	\$7,501	No
8/25/16	30	52,800	140	\$783	\$7,013	No
Totals	364	441,720	140.2	\$8,067	\$59,576	
Annual	365	442,934	140.2	\$8,089	\$59,740	

### 3.3 Natural Gas Usage

Natural gas is provided by NJ Natural Gas. The average gas cost for the past 12 months is \$1.015/therm, which is the blended rate used throughout the analyses in this report. The monthly gas consumption is shown in the chart below.

Figure 11 - Natural Gas Usage




Figure 12 - Natural Gas Usage

Gas Billing Data for Public Works				
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost	TRC Estimated Usage?
10/2/15	29	0	\$7	No
11/3/15	32	44	\$62	No
12/7/15	34	75	\$149	No
1/6/16	30	91	\$81	No
2/8/16	33	269	\$205	Yes
3/4/16	25	357	\$262	No
4/5/16	32	191	\$192	No
5/6/16	31	174	\$177	No
6/4/16	29	40	\$60	No
7/8/16	34	27	\$48	No
8/5/16	28	21	\$44	No
9/2/16	28	20	\$42	Yes
<b>Totals</b>	<b>365</b>	<b>1,310</b>	<b>\$1,330</b>	<b>2</b>
<b>Annual</b>	<b>365</b>	<b>1,310</b>	<b>\$1,330</b>	

### 3.4 Benchmarking

This facility was benchmarked using *Portfolio Manager*<sup>®</sup>, an online tool created and managed by the United States Environmental Protection Agency (EPA) through the ENERGY STAR<sup>®</sup> program. *Portfolio Manager*<sup>®</sup> analyzes your building’s consumption data, cost information, and operational use details and then compares its performance against a national median for similar buildings of its type. Metrics provided by this analysis are Energy Use Intensity (EUI) and an ENERGY STAR<sup>®</sup> score for select building types.

The EUI is a measure of a facility’s energy consumption per square foot, and it is the standard metric for comparing buildings’ energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more or less energy than similar buildings of its type on a square foot basis. EUI is presented in terms of “site energy” and “source energy.” Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

**Figure 13 - Energy Use Intensity Comparison – Existing Conditions**

Energy Use Intensity Comparison - Existing Conditions		
	Public Works	National Median Building Type: Garage
Source Energy Use Intensity (kBtu/ft <sup>2</sup> )	502.4	123.1
Site Energy Use Intensity (kBtu/ft <sup>2</sup> )	169.0	78.8

Implementation of all recommended measures in this report would improve the building’s estimated EUI significantly, as shown in the table below:

**Figure 14 - Energy Use Intensity Comparison – Following Installation of Recommended Measures**

Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	Public Works	National Median Building Type: Garage
Source Energy Use Intensity (kBtu/ft <sup>2</sup> )	471.6	123.1
Site Energy Use Intensity (kBtu/ft <sup>2</sup> )	159.2	78.8

Many types of commercial buildings are also eligible to receive an ENERGY STAR<sup>®</sup> score. This score is a percentile ranking from 1 to 100. It compares your building’s energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75% of all similar buildings nationwide and may be eligible for ENERGY STAR<sup>®</sup> certification. Your building is not is one of the building categories that are eligible to receive a score.

As previously mentioned, the well pump motors skew the benchmark for the facility. The energy consumption is much higher than a typical garage/warehouse which does not include these well pump motors. Removing this energy usage may provide some insight to the typical building loads (lighting, HVAC, domestic hot water and plug loads).

**Figure 15B - Energy Use Intensity Comparison – Existing Conditions (Without Well Pump Motor Usage)**

Energy Use Intensity Comparison - Existing Conditions		
	Public Works	National Median Building Type: Garage
Source Energy Use Intensity (kBtu/ft <sup>2</sup> )	95.3	123.1
Site Energy Use Intensity (kBtu/ft <sup>2</sup> )	39.3	78.8

**Figure 16B - Energy Use Intensity Comparison – Following Installation of Recommended Measures (Without Well Pump Motor Usage)**


Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	Public Works	National Median Building Type: Garage
Source Energy Use Intensity (kBtu/ft <sup>2</sup> )	64.6	123.1
Site Energy Use Intensity (kBtu/ft <sup>2</sup> )	29.5	78.8

### 3.5 Energy End-Use Breakdown

In order to provide a complete overview of energy consumption across building systems, an energy balance was performed at this facility. An energy balance utilizes standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building to determine their proportional contribution to overall building energy usage. This chart of energy end uses highlights the relative contribution of each equipment category to total energy usage. This can help determine where the greatest benefits might be found from energy efficiency measures.

Note that the majority of the site energy used by “Motor Driven Systems” shown in the chart below are associated with the well pumps. The well pumps are the main driver behind the high EUI values for this facility complex.

**Figure 17 - Energy Balance (% and kBtu/SF)**



## 4 ENERGY CONSERVATION MEASURES

### Level of Analysis

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information to the Public Works regarding financial incentives for which they may qualify to implement the recommended measures. For this audit report, most measures have received only a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to demonstrate project cost-effectiveness and help prioritize energy measures. Savings are based on the New Jersey Clean Energy Program Protocols to Measure Resource Savings dated June 29, 2016, approved by the New Jersey Board of Public Utilities. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances. A higher level of investigation may be necessary to support any custom SmartStart or Pay for Performance, or Direct Install incentive applications. Financial incentives for the ECMs identified in this report have been calculated based the NJCEP prescriptive SmartStart program. Some measures and proposed upgrade projects may be eligible for higher incentives than those shown below through other NJCEP programs as described in Section 8.

The following sections describe the evaluated measures.

### 4.1 Recommended ECMs

The measures below have been evaluated by the auditor and are recommended for implementation at the facility.

*Figure 18 – Summary of Recommended ECMs*

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>		<b>24,525</b>	<b>6.9</b>	<b>0.0</b>	<b>\$3,307.80</b>	<b>\$27,691.87</b>	<b>\$4,290.00</b>	<b>\$23,401.87</b>	<b>7.1</b>	<b>24,697</b>
ECM 1	Install LED Fixtures	12,913	2.8	0.0	\$1,741.60	\$16,825.03	\$2,645.00	\$14,180.03	8.1	13,003
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	1,425	0.9	0.0	\$192.25	\$3,030.00	\$0.00	\$3,030.00	15.8	1,435
ECM 3	Retrofit Fixtures with LED Lamps	10,187	3.2	0.0	\$1,373.95	\$7,836.83	\$1,645.00	\$6,191.83	4.5	10,258
<b>Lighting Control Measures</b>		<b>3,415</b>	<b>1.2</b>	<b>0.0</b>	<b>\$460.65</b>	<b>\$3,164.00</b>	<b>\$390.00</b>	<b>\$2,774.00</b>	<b>6.0</b>	<b>3,439</b>
ECM 4	Install Occupancy Sensor Lighting Controls	3,415	1.2	0.0	\$460.65	\$3,164.00	\$390.00	\$2,774.00	6.0	3,439
<b>TOTALS</b>		<b>27,941</b>	<b>8.0</b>	<b>0.0</b>	<b>\$3,768.45</b>	<b>\$30,855.87</b>	<b>\$4,680.00</b>	<b>\$26,175.87</b>	<b>6.9</b>	<b>28,136</b>

\* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

## 4.1.1 Lighting Upgrades

Our recommendations for upgrades to existing lighting fixtures are summarized in Figure 19 below.

**Figure 19 – Summary of Lighting Upgrade ECMs**

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>		<b>24,525</b>	<b>6.9</b>	<b>0.0</b>	<b>\$3,307.80</b>	<b>\$27,691.87</b>	<b>\$4,290.00</b>	<b>\$23,401.87</b>	<b>7.1</b>	<b>24,697</b>
ECM 1	Install LED Fixtures	12,913	2.8	0.0	\$1,741.60	\$16,825.03	\$2,645.00	\$14,180.03	8.1	13,003
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	1,425	0.9	0.0	\$192.25	\$3,030.00	\$0.00	\$3,030.00	15.8	1,435
ECM 3	Retrofit Fixtures with LED Lamps	10,187	3.2	0.0	\$1,373.95	\$7,836.83	\$1,645.00	\$6,191.83	4.5	10,258

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

### **ECM 1: Install LED Fixtures**

#### *Summary of Measure Economics*

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
Interior	38	0.0	0.0	\$5.07	\$418.17	\$45.00	\$373.17	73.6	38
Exterior	12,875	2.8	0.0	\$1,736.53	\$16,406.87	\$2,600.00	\$13,806.87	8.0	12,965

#### *Measure Description*

We recommend replacing the linear fluorescent T8 fixture that is in poor condition with a new LED fixture. This provides an opportunity for energy savings, however, resulting in a long payback based on the assumed low run hours of these fixtures. This measure is recommended based on the existing condition of the fixture, and because the general cost effectiveness of the lighting measures allows the economics of this one fixture to be blended in.

We also recommend replacing the high pressure sodium lamp wall pack, pole mounted shoebox fixtures and flood fixtures new LED flood fixtures. The proposed lighting equipment are new high performance LEDs which have much longer lifespans. Therefore this measure saves energy by reducing the electrical demand and use of the light fixtures, improves light output as well as reduces required maintenance.

## **ECM 2:Retrofit Fluorescent Fixtures with LED Lamps and Drivers**

### *Summary of Measure Economics*

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
Interior	1,425	0.9	0.0	\$192.25	\$3,030.00	\$0.00	\$3,030.00	15.8	1,435
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

### *Measure Description*

We recommend retrofitting existing T12 fluorescent fixtures by removing fluorescent tubes and ballasts and replacing them with LEDs and LED drivers (if necessary), which are designed to be used retrofitted fluorescent fixtures. The measure uses the existing fixture housing but replaces the rest of the components with more efficient lighting technology. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of fluorescent tubes.

## **ECM 3: Retrofit Fixtures with LED Lamps**

### *Summary of Measure Economics*

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
Interior	10,187	3.2	0.0	\$1,373.95	\$7,836.83	\$1,645.00	\$6,191.83	4.5	10,258
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

### *Measure Description*

We recommend re-lamping existing linear fluorescent T8 fixtures by removing fluorescent tubes and replacing them with LEDs (assuming the existing ballasts are compatible with the proposed LED lamps). This measure uses the existing fixture housing but replaces the lamps with more efficient lighting technology. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space. Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tubes.

## 4.1.2 Lighting Control Measures

Our recommendation for upgrades to existing lighting controls is summarized in Figure 20 below.

**Figure 20 – Summary of Lighting Control ECMs**

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Control Measures</b>	<b>3,415</b>	<b>1.2</b>	<b>0.0</b>	<b>\$460.65</b>	<b>\$3,164.00</b>	<b>\$390.00</b>	<b>\$2,774.00</b>	<b>6.0</b>	<b>3,439</b>
ECM 4   Install Occupancy Sensor Lighting Controls	3,415	1.2	0.0	\$460.65	\$3,164.00	\$390.00	\$2,774.00	6.0	3,439

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

### ECM 4: Install Occupancy Sensor Lighting Controls

#### *Summary of Measure Economics*

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO <sub>2</sub> e Emissions Reduction (lbs)
3,415	1.2	0.0	\$460.65	\$3,164.00	\$390.00	\$2,774.00	6.0	3,439

#### *Measure Description*

We recommend installing occupancy sensors to control lighting fixtures that are currently controlled by manual switches in garage bays, office and restrooms. Lighting sensors detect occupancy using ultrasonic and/or infrared sensors. For most spaces, we recommend lighting controls use dual technology sensors, which can eliminate the possibility of any lights turning off unexpectedly. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Some controls also provide dimming options and all modern occupancy controls can be easily over-ridden by room occupants to allow them to manually turn fixtures on or off, as desired. Energy savings results from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are recommended for single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in locations without local switching or where wall switches are not in the line-of-sight of the main work area and in large spaces. We recommend a comprehensive approach to lighting design that upgrades both the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

## 5 ENERGY EFFICIENT PRACTICES

---

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of many low cost or no-cost energy efficiency strategies. By employing certain behavioral and operational changes and performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and energy and O&M costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

### **Reduce Air Leakage**

Air leakage, or infiltration, occurs when outside air enters a building uncontrollably through cracks and openings. Properly sealing such cracks and openings can significantly reduce heating and cooling costs, improve building durability, and create a healthier indoor environment. This includes caulking or installing weather stripping around leaky doors and windows allowing for better control of indoor air quality through controlled ventilation.

### **Close Doors and Windows**

Ensure doors and windows are closed in conditioned spaces. Leaving doors and windows open leads to a significant increase in heat transfer between conditioned spaces and the outside air. Reducing a facility's air changes per hour (ACH) can lead to increased occupant comfort as well as significant heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

### **Perform Proper Lighting Maintenance**

In order to sustain optimal lighting levels, lighting fixtures should undergo routine maintenance. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust on lamps, fixtures and reflective surfaces. Together, these factors can reduce total illumination by 20%-60% or more, while operating fixtures continue drawing full power. To limit this reduction, lamps, reflectors and diffusers should be thoroughly cleaned of dirt, dust, oil, and smoke film buildup approximately every 6–12 months.

### **Develop a Lighting Maintenance Schedule**

In addition to routine fixture cleaning, development of a maintenance schedule can both ensure maintenance is performed regularly and can reduce the overall cost of fixture re-lamping and re-ballasting. By re-lamping and re-ballasting fixtures in groups, lighting levels are better maintained and the number of site visits by a lighting technician or contractor can be minimized, decreasing the overall cost of maintenance.

### **Turn Off Unneeded Motors**

Electric motors often run unnecessarily, and this is an overlooked opportunity to save energy. These motors should be identified and turned off when appropriate. For example, exhaust fans often run unnecessarily when ventilation requirements are already met. Reducing run hours for these motors can result in significant energy savings. Whenever possible, use automatic devices such as twist timers or occupancy sensors to ensure that motors are turned off when not needed.

## **Perform Routine Motor Maintenance**

Motors consist of many moving parts whose collective degradation can contribute to a significant loss of motor efficiency. In order to prevent damage to motor components, routine maintenance should be performed. This maintenance consists of cleaning surfaces and ventilation openings on motors to prevent overheating, lubricating moving parts to reduce friction, inspecting belts and pulleys for wear and to ensure they are at proper alignment and tension, and cleaning and lubricating bearings. Consult a licensed technician to assess these and other motor maintenance strategies.

## **Practice Proper Use of Thermostat Schedules and Temperature Resets**

Ensure thermostats are correctly set back. By employing proper set back temperatures and schedules, facility heating and cooling costs can be reduced dramatically during periods of low or no occupancy. As such, thermostats should be programmed for a setback of 5°F-10°F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced further by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

## **Clean Evaporator/Condenser Coils on AC Systems**

Dirty evaporators and condensers coils cause a restriction to air flow and restrict heat transfer. This results in increased evaporator and condenser fan load and a decrease in cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

## **Clean and/or Replace HVAC Filters**

Air filters work to reduce the amount of indoor air pollution and increase occupant comfort. Over time, filters become less and less effective as particulate buildup increases. In addition to health concerns related to clogged filters, filters that have reached saturation also restrict air flow through the facility's air conditioning or heat pump system, increasing the load on the distribution fans and decreasing occupant comfort levels. Filters should be checked monthly and cleaned or replaced when appropriate.

## **Check for and Seal Duct Leakage**

Duct leakage in commercial buildings typically accounts for 5% to 25% of the supply airflow. In the case of rooftop air handlers, duct leakage can occur to the outside of the building, significantly increasing cooling and heating costs. By sealing sources of leakage, cooling, heating, and ventilation energy use can be reduced significantly, depending on the severity of air leakage.

## **Perform Proper Furnace Maintenance**

Preventative furnace maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. Following the manufacturer's instructions, a yearly tune-up should include tasks such as checking for gas/carbon monoxide leaks; changing the air and fuel filters; checking components for cracks, corrosion, dirt, or debris build-up; ensuring the ignition system is working properly; testing and adjusting operation and safety controls; inspecting the electrical connections; and ensuring proper lubrication for motors and bearings.

## **Perform Proper Water Heater Maintenance**

At least once a year, drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Once a year check for any leaks or heavy corrosion on the pipes and valves. For gas water heaters, check the draft hood and make sure it is placed properly, with a few inches of air space between the tank and where it connects to the vent. Look for any corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional. For electric water heaters, look for any signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank. For water heaters over three to four years old have a technician inspect the sacrificial anode annually.

## **Plug Load Controls**

There are a variety of ways to limit the energy use of plug loads including increasing occupant awareness, removing under-utilized equipment, installing hardware controls, and using software controls. Some control steps to take are to enable the most aggressive power settings on existing devices or install load sensing or occupancy sensing (advanced) power strips. For additional information refer to or “Plug Load Best Practices Guide” <http://www.advancedbuildings.net/plug-load-best-practices-guide-offices>.

## **Water Conservation**

Installing low-flow faucets or faucet aerators, low-flow showerheads, and kitchen sink pre-rinse spray valves saves both energy and water. These devices save energy by reducing the overall amount of hot water used hence reducing the energy used to heat the water. The flow ratings for EPA WaterSense™ (<http://www3.epa.gov/watersense/products>) labeled devices are 1.5 gallons per minute (gpm) for bathroom faucets, 2.0 gpm for showerheads, and 1.28 gpm for pre-rinse spray valves.

Installing dual flush or low-flow toilets and low-flow or waterless urinals are additional ways to reduce the sites water use, however, these devices do not provide energy savings at the site level. Any reduction in water use does however ultimately reduce grid level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users. The EPA WaterSense™ ratings for urinals is 0.5 gallons per flush (gpf) and toilets that use as little as 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

## 6 ON-SITE GENERATION MEASURES

---

On-Site Generation measure options include both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey's Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State's electrical needs to be met by renewable sources by 2050.

Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before making a decision to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.


### 6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility's electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.

A preliminary screening based on the facility's electric demand, size and location of free area, and shading elements shows that the facility has a High potential for installing a PV array.

The amount of free area, ease of installation (location), and the lack of shading elements contribute to the high potential for PV at the site. A PV array located on the roof of the main building/ground next to the building/over the main parking lot may be feasible. If Public Works is interested in pursuing the installation of PV, we recommended a full feasibility study be conducted.

**Figure 21 - Photovoltaic Screening**



Potential	High	
System Potential	71	kW DC STC
Electric Generation	84,587	kWh/yr
Displaced Cost	\$7,360	/yr
Installed Cost	\$203,100	

Solar projects must register their projects in the SREC (Solar Renewable Energy Certificate) Registration Program (SRP) prior to the start of construction in order to establish the project’s eligibility to earn SRECs. Registration of the intent to participate in New Jersey’s solar marketplace provides market participants with information about developed new solar projects and insight into future SREC pricing. Refer to Section 8.4 for additional information.

For more information on solar PV technology and commercial solar markets in New Jersey, or to find a qualified solar installer, who can provide a more detailed assessment of the specific costs and benefits of solar develop of the site, please visit the following links below:

- **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- **NJ Solar Market FAQs:** <http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs>
- **Approved Solar Installers in the NJ Market:** [http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved\\_vendorsearch/?id=60&start=1](http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1)

## 7 DEMAND RESPONSE

---

Demand Response (DR) is a program designed to reduce the electric load of commercial facilities when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability.

By enabling grid operators to call upon Curtailment Service Providers and commercial facilities to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants receive payments whether or not their facility is called upon to curtail their electric usage.

Typically an electric customer needs to be capable of reducing their electric demand, within minutes, by at least 100 kW or more in order to participate in a DR program. Customers with a greater capability to quickly curtail their demand during peak hours will receive higher payments. Customers with back-up generators onsite may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in a DR programs often find it to be a valuable source of revenue for their facility because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature set points on thermostats, so that air conditioning units run less frequently, or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, in order to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a demand response activity in most situations.

The first step toward participation in a DR program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business (<http://www.pjm.com/markets-and-operations/demand-response/csps.aspx>). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity (<http://www.pjm.com/training/training%20material.aspx>), along with a variety of other DR program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

## 8 PROJECT FUNDING / INCENTIVES

The NJCEP is able to provide the incentive programs described below, and other benefits to ratepayers, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey’s Electricity Restructuring Law (1999), which requires all customers of investor-owned electric and gas utilities to pay a surcharge on their monthly energy bills. As a customer of a state-regulated electric or gas utility and therefore a contributor to the fund your organization is eligible to participate in the LGEA program and also eligible to receive incentive payment for qualifying energy efficiency measures. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 22 for a list of the eligible programs identified for each recommended ECM.

**Figure 22 - ECM Incentive Program Eligibility**

Energy Conservation Measure		SmartStart Prescriptive	SmartStart Custom	Direct Install	Pay For Performance Existing Buildings	Large Energy Users Program	Combined Heat & Power and Fuel Cell
ECM 1	Install LED Fixtures	x		x			
ECM 2	Retrofit Fixtures with LED Lamps	x		x			
ECM 3	Install Occupancy Sensor Lighting Controls	x		x			

SmartStart is generally well-suited for implementation of individual measures or small group of measures. It provides flexibility to install measures at your own pace using in-house staff or a preferred contractor. Direct Install caters to small to mid-size facilities that can bundle multiple ECMs together. This can greatly simplify participation and may lead to higher incentive amounts, but requires the use of pre-approved contractors. The Pay for Performance (P4P) program is a “whole-building” energy improvement program designed for larger facilities. It requires implementation of multiple measures meeting minimum savings thresholds, as well as use of pre-approved consultants. The Large Energy Users Program (LEUP) is available to New Jersey’s largest energy users giving them flexibility to install as little or as many measures, in a single facility or several facilities, with incentives capped based on the entity’s annual energy consumption. LEUP applicants can use in-house staff or a preferred contractor.

Generally, the incentive values provided throughout the report assume the SmartStart program is utilized because it provides a consistent basis for comparison of available incentives for various measures, though in many cases incentive amounts may be higher through participation in other programs.

Brief descriptions of all relevant financing and incentive programs are located in the sections below. Further information, including most current program availability, requirements, and incentive levels can be found at: [www.njcleanenergy.com/ci](http://www.njcleanenergy.com/ci).

## 8.1 SmartStart

### Overview

The SmartStart program offers incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives from year to year for various energy efficiency equipment based on market trends and new technologies.

### **Equipment with Prescriptive Incentives Currently Available:**

*Electric Chillers*

*Electric Unitary HVAC*

*Gas Cooling*

*Gas Heating*

*Gas Water Heating*

*Ground Source Heat Pumps*

*Lighting*

*Lighting Controls*

*Refrigeration Doors*

*Refrigeration Controls*

*Refrigerator/Freezer Motors*

*Food Service Equipment*

*Variable Frequency Drives*

Most equipment sizes and types are served by this program. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades.

### Incentives

The SmartStart prescriptive incentive program provides fixed incentives for specific energy efficiency measures, whereas the custom SmartStart program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentive offerings for specific devices.

Since your facility is an existing building, only the retrofit incentives have been applied in this report. Custom measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at 50% of the total installed incremental project cost, or a project cost buy down to a one year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

### How to Participate

To participate in the SmartStart program you will need to submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: [www.njcleanenergy.com/SSB](http://www.njcleanenergy.com/SSB).

## 8.2 Direct Install

### Overview

Direct Install is a turnkey program available to existing small to medium-sized facilities with an average peak electric demand that does not exceed 200 kW over the recent 12-month period. You work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives and controls.

### Incentives

The program pays up to **70%** of the total installed cost of eligible measures, up to \$125,000 per project. Direct Install participants will also be held to a fiscal year cap of \$250,000 per entity.

### How to Participate

The program pays up to 70% of the total installed cost of eligible measures, up to \$125,000 per project. Each entity is limited to incentives up to \$250,000 per fiscal year.

Detailed program descriptions and applications can be found at: [www.njcleanenergy.com/DI](http://www.njcleanenergy.com/DI).

## 8.3 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) is an alternate method for New Jersey's government agencies to finance the implementation of energy conservation measures. An ESIP is a type of "performance contract," whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. This is done in a manner that ensures that annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive in year one, and every year thereafter. ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs can be leveraged to help further reduce the total project cost of eligible measures.

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an Energy Services Company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is utilized for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the Energy Savings Plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Entities should carefully consider all alternatives to develop an approach that best meets their needs. A detailed program description and application can be found at: [www.njcleanenergy.com/ESIP](http://www.njcleanenergy.com/ESIP).

Please note that ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you may utilize NJCEP incentive programs to help further reduce costs when developing the ESP. You should refer to the ESIP guidelines at the link above for further information and guidance on next steps.

## 8.4 SREC Registration Program

The SREC (Solar Renewable Energy Certificate) Registration Program (SRP) is used to register the intent to install solar projects in New Jersey. Rebates are not available for solar projects, but owners of solar projects MUST register their projects in the SRP prior to the start of construction in order to establish the project's eligibility to earn SRECs. Registration of the intent to participate in New Jersey's solar marketplace provides market participants with information about the pipeline of anticipated new solar capacity and insight into future SREC pricing.

After the registration is accepted, construction is complete, and final paperwork has been submitted and is deemed complete, the project is issued a New Jersey certification number which enables it to generate New Jersey SRECs. SRECs are generated once the solar project has been authorized to be energized by the Electric Distribution Company (EDC).

Each time a solar installation generates 1,000 kilowatt-hours (kWh) of electricity, an SREC is earned. Solar project owners report the energy production to the SREC Tracking System. This reporting allows SRECs to be placed in the customer's electronic account. SRECs can then be sold on the SREC Tracking System, providing revenue for the first 15 years of the project's life.

Electricity suppliers, the primary purchasers of SRECs, are required to pay a Solar Alternative Compliance Payment (SACP) if they do not meet the requirements of New Jersey's Solar RPS. One way they can meet the RPS requirements is by purchasing SRECs. As SRECs are traded in a competitive market, the price may vary significantly. The actual price of an SREC during a trading period can and will fluctuate depending on supply and demand.

Information about the SRP can be found at: [www.njcleanenergy.com/srec](http://www.njcleanenergy.com/srec).

## 8.5 Demand Response Energy Aggregator

The first step toward participation in a Demand Response (DR) program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business ([www.pjm.com/markets-and-operations/demand-response/csps.aspx](http://www.pjm.com/markets-and-operations/demand-response/csps.aspx)). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity ([www.pjm.com/training/trainingmaterial.aspx](http://www.pjm.com/training/trainingmaterial.aspx)), along with a variety of other program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding the program rules and requirements for metering and controls, a facility's ability to temporarily reduce electric load, as well as the payments involved in participating in the program. Also, these providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment to help ensure compliance of all terms and conditions of a DR contract.

See Section 7 for additional information.

## 9 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

---

### 9.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third party (i.e., non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third party supplier, consider shopping for a reduced rate from third party electric suppliers. If your facility is purchasing electricity from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: [www.state.nj.us/bpu/commercial/shopping.html](http://www.state.nj.us/bpu/commercial/shopping.html).

### 9.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate on a monthly basis. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third party supplier, consider shopping for a reduced rate from third party natural gas suppliers. If your facility is purchasing natural gas from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party natural gas suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: [www.state.nj.us/bpu/commercial/shopping.html](http://www.state.nj.us/bpu/commercial/shopping.html).

# Appendix A: Equipment Inventory & Recommendations

## Lighting Inventory & Recommendations

Existing Conditions						Proposed Conditions							Energy Impact & Financial Analysis						
Location	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
DPW Garage Bay #1	24	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,210	Relamp	Yes	24	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,547	1.22	3,893	0.0	\$525.08	\$2,823.20	\$550.00	4.33
2nd Floor Storage	3	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,210	Relamp	No	3	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	2,210	0.12	394	0.0	\$53.08	\$285.40	\$60.00	4.25
Garage Bay #2	18	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,210	Relamp	Yes	18	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,547	0.97	3,095	0.0	\$417.44	\$2,252.40	\$430.00	4.37
Bathroom	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,210	Relamp	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,547	0.11	344	0.0	\$46.38	\$306.27	\$40.00	5.74
Bathroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	2,210	Fixture Replacement	Yes	1	LED - Fixtures: Ambient - 4' - Direct Fixture	Occupancy Sensor	15	1,547	0.02	50	0.0	\$6.79	\$418.17	\$45.00	54.93
Office	4	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,210	Relamp	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,547	0.21	688	0.0	\$92.76	\$496.53	\$100.00	4.27
Exterior	4	High-Pressure Sodium: (1) 250W Lamp	None	295	2,210	Fixture Replacement	No	4	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	None	115	2,210	0.53	1,687	0.0	\$227.49	\$1,562.71	\$400.00	5.11
Parking Lots	4	High-Pressure Sodium: (1) 400W Lamp	None	465	2,210	Fixture Replacement	No	4	LED - Fixtures: Outdoor Pole/Arm-Mounted Area/Roadway Fixture	None	185	2,210	0.82	2,624	0.0	\$353.87	\$7,811.97	\$400.00	20.95
Vehicle Service Garage Bay #1	14	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,210	Relamp	Yes	14	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,547	0.75	2,407	0.0	\$324.67	\$1,871.87	\$350.00	4.69
Office	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,210	Relamp	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,547	0.11	344	0.0	\$46.38	\$306.27	\$60.00	5.31
Bathroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,210	Relamp	Yes	1	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,547	0.05	172	0.0	\$23.19	\$95.13	\$20.00	3.24
Bathroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	32	2,210	Relamp	Yes	1	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	1,547	0.02	51	0.0	\$6.90	\$151.90	\$5.00	21.28
Garage Bay #2	14	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	114	2,210	Relamp	Yes	14	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	1,547	0.75	2,407	0.0	\$324.67	\$1,871.87	\$350.00	4.69
Maintenance Garage	15	Linear Fluorescent - T12: 8' T12 (75W) - 2L	Wall Switch	158	1,105	Relamp & Reballast	Yes	15	LED - Linear Tubes: (2) 8' Lamps	Occupancy Sensor	72	774	1.18	1,890	0.0	\$254.97	\$3,570.00	\$70.00	13.73
Exterior	5	High-Pressure Sodium: (1) 150W Lamp	None	188	4,015	Fixture Replacement	No	5	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	None	78	4,015	0.40	2,341	0.0	\$315.70	\$1,953.39	\$500.00	4.60
Reclaimed Water Pool	8	High-Pressure Sodium: (1) 100W Lamp	None	138	4,015	Fixture Replacement	No	8	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	None	45	4,015	0.54	3,166	0.0	\$427.06	\$3,125.42	\$800.00	5.45
Exterior	5	High-Pressure Sodium: (1) 250W Lamp	None	295	4,015	Fixture Replacement	No	5	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	None	115	4,015	0.66	3,830	0.0	\$516.61	\$1,953.39	\$500.00	2.81

### Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Well Pump Bldgs	Water	2	Other	100.0	90.0%	Yes	3,960	No	90.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
DPW Garage	Overhead Doors	2	Other	0.5	60.0%	No	500	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
DPW Garage	Overhead Doors	4	Other	0.5	60.0%	No	100	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Vehicle Service Garage	Overhead Doors	6	Other	0.5	60.0%	No	10	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Maintenance Garage	Overhead Doors	4	Other	0.5	60.0%	No	1	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Restrooms	Exhaust Fans	2	Exhaust Fan	0.3	60.0%	No	500	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Garages	Exhaust Fans	4	Exhaust Fan	0.5	60.0%	No	200	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Reclaimed Water Pool	Exhaust Fans	2	Exhaust Fan	0.5	60.0%	No	8,760	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Garages	Unit Heater Supply Fans	1	Supply Fan	0.5	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Garages	Unit Heater Supply Fans	3	Supply Fan	0.3	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Garages	Unit Heater Supply Fans	3	Supply Fan	0.3	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Garages	Unit Heater Supply Fans	2	Supply Fan	0.3	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Garages	Unit Heater Supply Fans	2	Supply Fan	0.3	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Garages	Unit Heater Supply Fans	2	Supply Fan	0.3	60.0%	No	2,745	No	60.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

### Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions										Energy Impact & Financial Analysis						
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Exterior	Office	1	Split-System AC	2.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Garage	Office	1	Window AC	1.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Garage	Restroom	1	Electric Resistance Heat		8.53	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mechanical Space	Mechanical Space	2	Electric Resistance Heat		8.53	No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

### Fuel Heating Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions			Proposed Conditions						Energy Impact & Financial Analysis						
		System Quantity	System Type	Output Capacity per Unit (MBh)	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
DPW Garage	Garage	1	Furnace	250.00	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
DPW Garage	Garage	3	Warm Air Unit Heater	200.00	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
DPW Garage	Garage	3	Warm Air Unit Heater	200.00	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Vehicle Service Garage	Garage	2	Warm Air Unit Heater	100.00	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Vehicle Service Garage	Garage	2	Warm Air Unit Heater	100.00	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Maintenance Garage	Garage	2	Warm Air Unit Heater	100.00	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

### DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions						Energy Impact & Financial Analysis						
		System Quantity	System Type	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Mechanical Room	Restrooms	1	Storage Tank Water Heater (≤ 50 Gal)	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Mechanical Room	Restrooms	1	Storage Tank Water Heater (≤ 50 Gal)	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

**Plug Load Inventory**

Existing Conditions				
Location	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
Public Works Bldgs	4	Computer	120.0	
Public Works Bldgs	1	Microwave	1,500.0	
Public Works Bldgs	1	Mini Fridge	260.0	
Public Works Bldgs	1	Large Fan	200.0	
Public Works Bldgs	1	TV	120.0	

# Appendix B: ENERGY STAR<sup>®</sup> Statement of Energy Performance

**ENERGY STAR<sup>®</sup> Statement of Energy Performance**

LEARN MORE AT [energystar.gov](http://energystar.gov)

N/A

**Public Works**

**Primary Property Type:** Repair Services (Vehicle, Shoe, Locksmith, etc.)

**Gross Floor Area (ft<sup>2</sup>):** 21,428

**Built:** 1950

**ENERGY STAR<sup>®</sup> Score<sup>1</sup>**

**For Year Ending:** July 31, 2016  
**Date Generated:** October 31, 2018

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information

Property Address	Property Owner	Primary Contact
Public Works 200 Wells Mills Rd Waretown, New Jersey 08758	Ocean Township 50 Railroad Ave Waretown, NJ 08758 609-693-3302	Diane Ambrosio 50 Railroad Ave Waretown, NJ 08758 609-693-3302 clerk@twpoceanj.gov

Property ID: 5969850

Energy Consumption and Energy Use Intensity (EUI)

Site EUI	Annual Energy by Fuel	National Median Comparison
<b>75.6 kBtu/ft<sup>2</sup></b>	Electric - Grid (kBtu) 1,490,011 (92%) Natural Gas (kBtu) 128,750 (8%)	National Median Site EUI (kBtu/ft <sup>2</sup> ) 36.4 National Median Source EUI (kBtu/ft <sup>2</sup> ) 96.9 % Diff from National Median Source EUI 108%
Source EUI	Annual Emissions	
<b>201 kBtu/ft<sup>2</sup></b>	Greenhouse Gas Emissions (Metric Tons CO <sub>2</sub> e/year) 158	

Signature & Stamp of Verifying Professional

I \_\_\_\_\_ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

**Licensed Professional**

Aimee Lalonde  
1430 Broadway  
10th Floor  
New York, NY 10018  
3479132422  
alalonde@trcsolutions.com

Professional Engineer Stamp  
(if applicable)