



Local Government Energy Audit: Energy Audit Report



Copyright ©2016 TRC Energy Services. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Northfield Fire Station **Township of Livingston**

2 East Hobart Gap Road
Livingston, NJ 07039

June 20, 2018

Final Report by:

TRC Energy Services

Disclaimer

The intent of this energy analysis report is to identify energy savings opportunities and recommend upgrades to the facility's energy using equipment and systems. Approximate savings are included in this report to help make decisions about reducing energy use at the facility. This report, however, is not intended to serve as a detailed engineering design document. Further design and analysis may be necessary in order to implement some of the measures recommended in this report.

The energy conservation measures and estimates of energy savings have been reviewed for technical accuracy. However, estimates of final energy savings are not guaranteed, because final savings may depend on behavioral factors and other uncontrollable variables. TRC Energy Services (TRC) and New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

Estimated installation costs are based on TRC's experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from *RS Means*. The owner of the facility is encouraged to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Since actual installed costs can vary widely for certain measures and conditions, TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. The owner of the facility should review available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

Table of Contents

1	Executive Summary.....	1
1.1	Facility Summary	1
1.2	Your Cost Reduction Opportunities.....	1
	Energy Conservation Measures.....	1
	Energy Efficient Practices	2
	On-Site Generation Measures.....	3
1.3	Implementation Planning.....	3
2	Facility Information and Existing Conditions	4
2.1	Project Contacts	4
2.2	General Site Information.....	4
2.3	Building Occupancy	4
2.4	Building Envelope	4
2.5	On-Site Generation.....	5
2.6	Energy-Using Systems	5
	Lighting System	5
	Hot Water (or Steam) Heating System.....	5
	Direct Expansion Air Conditioning System (DX)	6
	Domestic Hot Water Heating System.....	6
2.7	Water-Using Systems	6
3	Site Energy Use and Costs.....	7
3.1	Total Cost of Energy	7
3.2	Electricity Usage	8
3.3	Natural Gas Usage	9
3.4	Benchmarking.....	10
3.5	Energy End-Use Breakdown	12
4	Energy Conservation Measures	13
4.1	Recommended ECMs	13
4.1.1	Lighting Upgrades.....	14
	ECM 1: Retrofit Fixtures with LED Lamps.....	14
4.1.2	Lighting Control Measures	15
	ECM 2: Install Occupancy Sensor Lighting Controls	15
4.1.3	Domestic Hot Water Heating System Upgrades	16
	ECM 3: Install Low-Flow DHW Devices.....	16
5	Energy Efficient Practices	17
	Perform Lighting Maintenance	17
	Develop a Lighting Maintenance Schedule	17
	Practice Proper Use of Thermostat Schedules and Temperature Resets	17
	Water Conservation	17

- 6 On-Site Generation Measures 18**
 - 6.1 Photovoltaic..... 18
 - 6.2 Combined Heat and Power 20
- 7 Demand Response 21**
- 8 Project Funding / Incentives 22**
 - 8.1 SmartStart 23
 - 8.2 Direct Install 24
 - 8.3 Energy Savings Improvement Program 25
 - 8.4 Combined Heat and Power Program..... 26
- 9 Energy Purchasing and Procurement Strategies 27**
 - 9.1 Retail Electric Supply Options..... 27
 - 9.2 Retail Natural Gas Supply Options 27

Appendix A: Equipment Inventory & Recommendations

Appendix B: ENERGY STAR® Statement of Energy Performance

Table of Figures

Figure 1 – Previous 12 Month Utility Costs..... 1

Figure 2 – Potential Post-Implementation Costs 1

Figure 3 – Summary of Energy Reduction Opportunities 2

Figure 4 – Project Contacts 4

Figure 5 - Building Schedule..... 4

Figure 6 - Utility Summary 7

Figure 7 - Energy Cost Breakdown 7

Figure 8 - Electric Usage & Demand..... 8

Figure 9 - Electric Usage & Demand..... 8

Figure 10 - Natural Gas Usage..... 9

Figure 11 - Natural Gas Usage..... 9

Figure 12 - Energy Use Intensity Comparison – Existing Conditions..... 10

Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures 10

Figure 14 - Energy Balance (% and kBtu/SF) 12

Figure 15 – Summary of Recommended ECMs..... 13

Figure 16 – Summary of Lighting Upgrade ECMs..... 14

Figure 17 – Summary of Lighting Control ECMs 15

Figure 18 - Summary of Domestic Water Heating ECMs 16

Figure 19 - Photovoltaic Screening 18

Figure 20 - Combined Heat and Power Screening 20

Figure 21 - ECM Incentive Program Eligibility 22

I EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) Report for Northfield Fire Station.

The goal of an LGEA report is to provide you with information on how your facility uses energy, identify energy conservation measures (ECMs) that can reduce your energy use, and provide information and assistance to help facilities implement ECMs. The LGEA report also contains valuable information on financial incentives from New Jersey’s Clean Energy Program (NJCEP) for implementing ECMs.

This study was conducted by TRC Energy Services (TRC), as part of a comprehensive effort to assist New Jersey local governments in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

I.1 Facility Summary

Northfield Fire Station is a 4,955 square foot two-story facility and is comprised of various space types including offices, conference rooms, kitchen, and fire station garage. The facility was opened in 1952 and is used on an as needed basis by the firefighters and volunteer firefighters.

Lighting at Northfield Fire Station consists of a mix of T8 lighting with efficient exterior LED lights. The heating and cooling systems are all in good condition and are less than five years old. A thorough description of the facility and our observations are located in Section 2.

I.2 Your Cost Reduction Opportunities

Energy Conservation Measures

TRC evaluated three measures which together represent an opportunity for Northfield Fire Station to reduce annual energy costs by \$712 and annual greenhouse gas emissions by 5,521 lbs CO₂e. We estimate that if all measures were implemented as recommended, the project would pay for itself in 7.7 years. The breakdown of existing and potential utility costs after project implementation are illustrated in Figure 1 and Figure 2, respectively. Together these measures represent an opportunity to reduce Northfield Fire Station’s annual energy use by 10%.

Figure 1 – Previous 12 Month Utility Costs





Figure 2 – Potential Post-Implementation Costs



A detailed description of Northfield Fire Station’s existing energy use can be found in Section 3.

Estimates of the total cost, energy savings, and financial incentives for the proposed energy efficient upgrades are summarized below in Figure 3. A brief description of each category can be found below and a description of savings opportunities can be found in Section 4.

Figure 3 – Summary of Energy Reduction Opportunities

Energy Conservation Measure		Recommend?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades			4,667	2.2	0.0	\$625.28	\$5,366.36	\$390.00	\$4,976.36	8.0	4,700
ECM 1	Retrofit Fixtures with LED Lamps	Yes	4,667	2.2	0.0	\$625.28	\$5,366.36	\$390.00	\$4,976.36	8.0	4,700
Lighting Control Measures			391	0.2	0.0	\$52.40	\$540.00	\$70.00	\$470.00	9.0	394
ECM 2	Install Occupancy Sensor Lighting Controls	Yes	391	0.2	0.0	\$52.40	\$540.00	\$70.00	\$470.00	9.0	394
Domestic Water Heating Upgrade			0	0.0	3.7	\$34.33	\$14.34	\$0.00	\$14.34	0.4	428
ECM 3	Install Low-Flow Domestic Hot Water Devices	Yes	0	0.0	3.7	\$34.33	\$14.34	\$0.00	\$14.34	0.4	428
TOTALS			5,058	2.3	3.7	\$712.00	\$5,920.70	\$460.00	\$5,460.70	7.7	5,521

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Lighting Upgrades generally involve the replacement of existing lighting components such as lamps and ballasts (or the entire fixture) with higher efficiency lighting components. These measure save energy by reducing the power used by the lighting components due to improved electrical efficiency.

Lighting Controls measures generally involve the installation of automated controls to turn off lights or reduce light output when not needed. Automated control reduces reliance on occupant behavior for adjusting lights. These measures save energy by reducing the amount of time lights are on.

Domestic Hot Water upgrade measures generally involve replacing older inefficient domestic water heating systems with modern energy efficient systems. New domestic hot water heating systems can provide equivalent, or greater, water heating capacity compared to older systems at a reduced energy cost. These measures save energy by reducing the fuel used for domestic hot water heating due to improved heating efficiency or reducing standby losses.

Energy Efficient Practices

TRC also identified four low cost (or no cost) energy efficient practices. A facility’s energy performance can be significantly improved by employing certain behavioral or operational adjustments and by performing better routine maintenance on building systems. These practices can extend equipment lifetime, improve occupant comfort, provide better health and safety, as well as reduce annual energy and O&M costs. Potential opportunities identified at Northfield Fire Station include:

- Perform Lighting Maintenance
- Develop a Lighting Maintenance Schedule
- Practice Proper Use of Thermostat Schedules and Temperature Resets
- Water Conservation

For details on these energy efficient practices, please refer to Section 5.

On-Site Generation Measures

TRC evaluated the potential for installing on-site generation for Northfield Fire Station. Based on the configuration of the site and its loads there is a low potential for installing any PV and combined heat and power self-generation measures.

For details on our evaluation and on-site generation potential, please refer to Section 6.

I.3 Implementation Planning

To realize the energy savings from the ECMs listed in this report, a project implementation plan must be developed. Available capital must be considered and decisions need to be made whether it is best to pursue individual ECMs separately, groups of ECMs, or a comprehensive approach where all ECMs are implemented together, possibly in conjunction with other facility upgrades or improvements.

Rebates, incentives, and financing are available from NJCEP, as well as other sources, to help reduce the costs associated with the implementation of energy efficiency projects. Prior to implementing any measure, please review the relevant incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives prior to purchasing materials or commencing with installation.

The ECMs outlined in this report may qualify under the following program(s):

- SmartStart
- Direct Install
- Energy Savings Improvement Program (ESIP)
- Combined Heat and Power Program (CHP)

For facilities wanting to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate in this program you may utilize internal resources, or an outside firm or contractor, to do the final design of the ECM(s) and do the installation. Program pre-approval is required for some SmartStart incentives, so only after receiving pre-approval should you proceed with ECM installation. The incentive estimates listed above in Figure 3 are based on the SmartStart program. More details on this program and others are available in Section 8.

This facility may also qualify for the Direct Install program which can provide turnkey installation of multiple measures, through an authorized network of participating contractors. This program can provide substantially higher incentives than SmartStart, up to 70% of the cost of selected measures, although measure eligibility will have to be assessed and be verified by the designated Direct Install contractor and, in most cases, they will perform the installation work.

Additional information on relevant incentive programs is located in Section 8 or: www.njcleanenergy.com/ci.

2 FACILITY INFORMATION AND EXISTING CONDITIONS

2.1 Project Contacts

Figure 4 – Project Contacts

Name	Role	E-Mail	Phone #
Customer			
Russell A. Jones	Deputy Township Manager	rjones@livingstonnj.org	(973) 992-5000
Designated Representative			
Esther Lin	Intern	intern2@livingstonnj.org	(973) 992-5000 x5305
TRC Energy Services			
Ignacio Badilla	Auditor	ibadilla@trcsolutions.com	(732) 855-0033

2.2 General Site Information

On April 25, 2017, TRC performed an energy audit at Northfield Fire Station located in Livingston, New Jersey. TRC’s team met with Frank Denick to review the facility operations and help focus our investigation on specific energy-using systems.

Northfield Fire Station is a 4,955 square foot two-story facility and is comprised of various space types including offices, conference rooms, kitchen, and fire station garage. The facility was opened in 1952 and is used on an as needed basis by the firefighters and volunteer firefighters.

Lighting at Northfield Fire Station consists of a mix of T8 lighting and efficient exterior LED lights. There are some incandescent lamps scattered throughout the facility in lower use areas. The HVAC systems are all in good condition and less than five years old.

2.3 Building Occupancy

The facility has no set schedule as there are no permanent staff. The facility is used on an as needed basis by the firemen and volunteer firemen.

Figure 5 - Building Schedule

Building Name	Weekday/Weekend	Operating Schedule
Northfield Fire Station	Weekday	Varies
Northfield Fire Station	Weekend	Varies

2.4 Building Envelope

The building façade is brick with and has a flat three tiered roof with black membrane finish. The windows are double paned with vinyl frames and appear to be in good condition with no excessive infiltration detected. The doors are aluminum with glass panels and no visible signs of infiltration were detected along the weather stripping.

2.5 On-Site Generation

Northfield Fire Station does not have any on-site electric generation capacity.

2.6 Energy-Using Systems

Please see Appendix A: Equipment Inventory & Recommendations for an inventory of the facility's equipment.


Lighting System

Lighting at the facility is provided mostly by 32-Watt linear fluorescent T8 lamps with electronic ballasts as well as some incandescent lamps. The exterior lighting at the facility was replaced by LED wall packs and LED A-lamps. Only the front light is on a photocell while the other lights are switch operated and rarely used.



Hot Water (or Steam) Heating System

The hot water system consists of one Lochinvar CBN399 hot water natural draft boiler with a 327 kBtu/hr output capacity. The boiler was installed in approximately 2013 and is good condition. The boiler provides hot water to radiators in the kitchen, upper level meeting room, and stairwells. The garage is heated by five unit heaters, the nameplates were inaccessible but they are reported to be in working condition. The boiler zones are controlled by two non-programmable thermostats kept on a minimum setting as the building has unpredictable use.




Direct Expansion Air Conditioning System (DX)

The upper level is cooled by two Fujitsu energy efficient mini-split air conditioners with a Seasonal Energy Efficiency Ratio (SEER) of 16. These units are approximately four years old and in good condition. The top floor meeting/conference area is only part of the building that is conditioned.



Domestic Hot Water Heating System

The facility has a 40 gallon Bradford White gas fired domestic water heater with an input rating of 40 kbtu/hr and a nominal efficiency of 80%. The water heater is also approximately four years old and in good condition.



2.7 Water-Using Systems

There are two restrooms at this facility and both have faucets with flow rates of 2.5 gallons per minute (gpm).

3 SITE ENERGY USE AND COSTS

Utility data for electricity and natural gas was analyzed to identify opportunities for savings. In addition, data for electricity and natural gas was evaluated to determine the annual energy performance metrics for the building in energy cost per square foot and energy usage per square foot. These metrics are an estimate of the relative energy efficiency of this building. There are a number of factors that could cause the energy use of this building to vary from the “typical” energy usage profile for facilities with similar characteristics. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and energy efficient behavior of occupants all contribute to benchmarking scores. Please refer to the Benchmarking section within Section 3.4 for additional information.

3.1 Total Cost of Energy


The following energy consumption and cost data is based on the last 12-month period of utility billing data that was provided for each utility. A profile of the annual energy consumption and energy cost of the facility was developed from this information.

Figure 6 - Utility Summary

Utility Summary for Northfield Fire Station		
Fuel	Usage	Cost
Electricity	21,084 kWh	\$2,825
Natural Gas	1,298 Therms	\$1,219
Total		\$4,044

The current annual energy cost for this facility is \$4,044 as shown in the chart below.

Figure 7 - Energy Cost Breakdown



3.2 Electricity Usage

Electricity is provided by PSE&G. The average electric cost over the past 12 months was \$0.134/kWh, which is the blended rate that includes energy supply, distribution, and other charges. This rate is used throughout the analyses in this report to assess energy costs and savings. The facility has a peak demand of 11.9 kW and is billed demand charges. The monthly electricity consumption and peak demand are shown in the chart below.

Figure 8 - Electric Usage & Demand




Figure 9 - Electric Usage & Demand

Electric Billing Data for Northfield Fire Station					
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost
6/25/15	30	1,452	7	\$31	\$189
7/27/15	32	1,512	8	\$36	\$197
8/25/15	29	1,512	12	\$52	\$197
9/24/15	30	1,644	12	\$52	\$214
10/23/15	29	1,428	12	\$52	\$186
11/23/15	31	1,836	12	\$52	\$277
12/24/15	31	2,004	10	\$41	\$275
1/27/16	34	2,400	8	\$36	\$315
2/25/16	29	1,968	11	\$78	\$272
3/28/16	32	1,944	11	\$47	\$271
4/26/16	29	1,692	2	\$11	\$206
5/25/16	29	1,692	7	\$32	\$226
Totals	365	21,084	11.9	\$519	\$2,825
Annual	365	21,084	11.9	\$519	\$2,825

3.3 Natural Gas Usage

Natural gas is provided by PSE&G. The average gas cost for the past 12 months is \$0.939/therm, which is the blended rate used throughout the analyses in this report. The monthly gas consumption is shown in the chart below.

Figure 10 - Natural Gas Usage




Figure 11 - Natural Gas Usage

Gas Billing Data for Northfield Fire Station			
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost
6/25/15	30	60	\$57
7/27/15	32	12	\$21
8/25/15	29	3	\$14
9/24/15	30	2	\$13
10/23/15	29	3	\$14
11/23/15	31	25	\$31
12/24/15	31	58	\$58
1/27/16	34	118	\$154
2/25/16	29	218	\$192
3/28/16	32	365	\$311
4/26/16	29	294	\$245
5/25/16	29	140	\$110
Totals	365	1,298	\$1,219
Annual	365	1,298	\$1,219

3.4 Benchmarking

This facility was benchmarked using Portfolio Manager, an online tool created and managed by the United States Environmental Protection Agency (EPA) through the ENERGY STAR® program. Portfolio Manager analyzes your building’s consumption data, cost information, and operational use details and then compares its performance against a national median for similar buildings of its type. Metrics provided by this analysis are Energy Use Intensity (EUI) and an ENERGY STAR® score for select building types.

The EUI is a measure of a facility’s energy consumption per square foot, and it is the standard metric for comparing buildings’ energy performance. Comparing the EUI of a building with the national median EUI for that building type illustrates whether that building uses more or less energy than similar buildings of its type on a square foot basis. EUI is presented in terms of “site energy” and “source energy.” Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

Figure 12 - Energy Use Intensity Comparison – Existing Conditions

Energy Use Intensity Comparison - Existing Conditions		
	Northfield Fire Station	National Median Building Type: Fire/Police Station
Source Energy Use Intensity (kBtu/ft ²)	73.1	154.4
Site Energy Use Intensity (kBtu/ft ²)	40.7	88.3

Implementation of all recommended measures in this report would improve the building’s estimated EUI significantly, as shown in the table below:

Figure 13 - Energy Use Intensity Comparison – Following Installation of Recommended Measures

Energy Use Intensity Comparison - Following Installation of Recommended Measures		
	Northfield Fire Station	National Median Building Type: Fire/Police Station
Source Energy Use Intensity (kBtu/ft ²)	61.4	154.4
Site Energy Use Intensity (kBtu/ft ²)	36.5	88.3

Many types of commercial buildings are also eligible to receive an ENERGY STAR® score. This score is a percentile ranking from 1 to 100. It compares your building’s energy performance to similar buildings nationwide. A score of 50 represents median energy performance, while a score of 75 means your building performs better than 75 percent of all similar buildings nationwide and may be eligible for ENERGY STAR® certification. Your building is not one of the building categories that are eligible to receive a score as fire houses are not currently one of the supported building types.

A Portfolio Manager Statement of Energy Performance (SEP) was generated for this facility, see Appendix B: ENERGY STAR® Statement of Energy Performance.


For more information on ENERGY STAR® certification go to: <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.

A Portfolio Manager account has been created online for your facility and you will be provided with the login information for the account. We encourage you to update your utility information in Portfolio Manager regularly, so that you can keep track of your building's performance. Free online training is available to help you use ENERGY STAR® Portfolio Manager to track your building's performance at: <https://www.energystar.gov/buildings/training>.

3.5 Energy End-Use Breakdown

In order to provide a complete overview of energy consumption across building systems, an energy balance was performed at this facility. An energy balance utilizes standard practice engineering methods to evaluate all components of the various electric and fuel-fired systems found in a building to determine their proportional contribution to overall building energy usage. This chart of energy end uses highlights the relative contribution of each equipment category to total energy usage. This can help determine where the greatest benefits might be found from energy efficiency measures.

Figure 14 - Energy Balance (% and kBtu/SF)



4 ENERGY CONSERVATION MEASURES

Level of Analysis

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information to the Northfield Fire Station regarding financial incentives for which they may qualify to implement the recommended measures. For this audit report, most measures have received only a preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to demonstrate project cost-effectiveness and help prioritize energy measures. Savings are based on the New Jersey Clean Energy Program Protocols to Measure Resource Savings dated June 29, 2016, approved by the New Jersey Board of Public Utilities. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances. A higher level of investigation may be necessary to support any custom SmartStart, Pay for Performance, or Direct Install incentive applications. Financial incentives for the ECMs identified in this report have been calculated based the NJCEP prescriptive SmartStart program. Some measures and proposed upgrade projects may be eligible for higher incentives than those shown below through other NJCEP programs as described in Section 8.

The following sections describe the evaluated measures.

4.1 Recommended ECMs

The measures below have been evaluated by the auditor and are recommended for implementation at the facility.

Figure 15 – Summary of Recommended ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		4,667	2.2	0.0	\$625.28	\$5,366.36	\$390.00	\$4,976.36	8.0	4,700
ECM 1	Retrofit Fixtures with LED Lamps	4,667	2.2	0.0	\$625.28	\$5,366.36	\$390.00	\$4,976.36	8.0	4,700
Lighting Control Measures		391	0.2	0.0	\$52.40	\$540.00	\$70.00	\$470.00	9.0	394
ECM 2	Install Occupancy Sensor Lighting Controls	391	0.2	0.0	\$52.40	\$540.00	\$70.00	\$470.00	9.0	394
Domestic Water Heating Upgrade		0	0.0	3.7	\$34.33	\$14.34	\$0.00	\$14.34	0.4	428
ECM 3	Install Low-Flow Domestic Hot Water Devices	0	0.0	3.7	\$34.33	\$14.34	\$0.00	\$14.34	0.4	428
TOTALS		5,058	2.3	3.7	\$712.00	\$5,920.70	\$460.00	\$5,460.70	7.7	5,521

* - All incentives presented in this table are based on NJ Smart Start Building equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

4.1.1 Lighting Upgrades

Our recommendations for upgrades to existing lighting fixtures are summarized in Figure 16 below.

Figure 16 – Summary of Lighting Upgrade ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		4,667	2.2	0.0	\$625.28	\$5,366.36	\$390.00	\$4,976.36	8.0	4,700
ECM 1	Retrofit Fixtures with LED Lamps	4,667	2.2	0.0	\$625.28	\$5,366.36	\$390.00	\$4,976.36	8.0	4,700

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM I: Retrofit Fixtures with LED Lamps

Summary of Measure Economics

Interior/ Exterior	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Interior	4,667	2.2	0.0	\$625.28	\$5,366.36	\$390.00	\$4,976.36	8.0	4,700
Exterior	0	0.0	0.0	\$0.00	\$0.00	\$0.00	\$0.00	0.0	0

Measure Description

We recommend retrofitting existing incandescent and linear fluorescents with LED lamps. Many LED tube lamps are direct replacements for existing fluorescent lamps and can be installed while leaving the fluorescent fixture ballast in place. LED bulbs can be used in existing fixtures as a direct replacement for most other lighting technologies. This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space.

Additional savings from lighting maintenance can be anticipated since LEDs have lifetimes which are more than twice that of a fluorescent tubes and more than ten times longer than many incandescent lamps.

4.1.2 Lighting Control Measures

Our recommendations for lighting control measures are summarized in Figure 17 below.

Figure 17 – Summary of Lighting Control ECMs

Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures	391	0.2	0.0	\$52.40	\$540.00	\$70.00	\$470.00	9.0	394
ECM 2 Install Occupancy Sensor Lighting Controls	391	0.2	0.0	\$52.40	\$540.00	\$70.00	\$470.00	9.0	394

During lighting upgrade planning and design, we recommend a comprehensive approach that considers both the efficiency of the lighting fixtures and how they are controlled.

ECM 2: Install Occupancy Sensor Lighting Controls

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
391	0.2	0.0	\$52.40	\$540.00	\$70.00	\$470.00	9.0	394

Measure Description

We recommend installing occupancy sensors to control lighting fixtures that are currently controlled by manual switches in the meeting room and kitchen areas. Lighting sensors detect occupancy using ultrasonic and/or infrared sensors. For most spaces, we recommend lighting controls use dual technology sensors, which can eliminate the possibility of any lights turning off unexpectedly. Lighting systems are enabled when an occupant is detected. Fixtures are automatically turned off after an area has been vacant for a preset period. Some controls also provide dimming options and all modern occupancy controls can be easily over-ridden by room occupants to allow them to manually turn fixtures on or off, as desired. Energy savings results from only operating lighting systems when they are required.

Occupancy sensors may be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are recommended for single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in locations without local switching or where wall switches are not in the line-of-sight of the main work area and in large spaces. We recommend a comprehensive approach to lighting design that upgrades both the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

4.1.3 Domestic Hot Water Heating System Upgrades

Our recommendations for domestic water heating system improvements are summarized in Figure 18 below.

Figure 18 - Summary of Domestic Water Heating ECMs

Energy Conservation Measure		Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
Domestic Water Heating Upgrade		0	0.0	3.7	\$34.33	\$14.34	\$0.00	\$14.34	0.4	428
ECM 3	Install Low-Flow Domestic Hot Water Devices	0	0.0	3.7	\$34.33	\$14.34	\$0.00	\$14.34	0.4	428

ECM 3: Install Low-Flow DHW Devices

Summary of Measure Economics

Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)	Estimated Net Cost (\$)	Simple Payback Period (yrs)	CO ₂ e Emissions Reduction (lbs)
0	0.0	3.7	\$34.33	\$14.34	\$0.00	\$14.34	0.4	428

Measure Description

We recommend installing low-flow domestic hot water devices to reduce overall hot water demand. Energy demand from domestic hot water heating systems can be reduced by reducing water usage in general. Faucet aerators can reduce hot water usage, relative to aerators, which saves energy.

Low-flow devices reduce the overall water flow from the fixture, while still adequate pressure for washing. This reduces the amount of water used per day resulting in energy and water savings.

5 ENERGY EFFICIENT PRACTICES

In addition to the quantifiable savings estimated in Section 4, a facility's energy performance can also be improved through application of many low cost or no-cost energy efficiency strategies. By employing certain behavioral and operational changes and performing routine maintenance on building systems, equipment lifetime can be extended; occupant comfort, health and safety can be improved; and energy and O&M costs can be reduced. The recommendations below are provided as a framework for developing a whole building maintenance plan that is customized to your facility. Consult with qualified equipment specialists for details on proper maintenance and system operation.

Perform Lighting Maintenance

In order to sustain optimal lighting levels, lighting fixtures should undergo routine maintenance. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust on lamps, fixtures and reflective surfaces. Together, these factors can reduce total illumination by 20% - 60% or more, while operating fixtures continue drawing full power. To limit this reduction, lamps, reflectors and diffusers should be thoroughly cleaned of dirt, dust, oil, and smoke film buildup approximately every 6 – 12 months.

Develop a Lighting Maintenance Schedule

In addition to routine fixture cleaning, development of a maintenance schedule can both ensure maintenance is performed regularly and can reduce the overall cost of fixture re-lamping and re-ballasting. By re-lamping and re-ballasting fixtures in groups, lighting levels are better maintained and the number of site visits by a lighting technician or contractor can be minimized, decreasing the overall cost of maintenance.

Practice Proper Use of Thermostat Schedules and Temperature Resets

Ensure thermostats are correctly set back. By employing proper set back temperatures and schedules, facility heating and cooling costs can be reduced dramatically during periods of low or no occupancy. As such, thermostats should be programmed for a setback of 5°F -10°F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced further by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

Water Conservation

Installing low-flow faucets or faucet aerators, low-flow showerheads, and kitchen sink pre-rinse spray valves saves both energy and water. These devices save energy by reducing the overall amount of hot water used hence reducing the energy used to heat the water. The flow ratings for EPA WaterSense™ (<http://www3.epa.gov/watersense/products>) labeled devices are 1.5 gpm for bathroom faucets, 2.0 gpm for showerheads, and 1.28 gpm for pre-rinse spray valves.

Installing dual flush or low-flow toilets and low-flow or waterless urinals are additional ways to reduce the sites water use, however, these devices do not provide energy savings at the site level. Any reduction in water use does, however, ultimately reduce grid level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users. The EPA WaterSense™ ratings for urinals is 0.5 gallons per flush (gpf) and toilets that use as little as 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

Refer to Section 4.1.3 for any low-flow ECM recommendations.

6 ON-SITE GENERATION MEASURES

On-site generation measure options include both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) on-site technologies that generate power to meet all or a portion of the electric energy needs of a facility, often repurposing any waste heat where applicable. Also referred to as distributed generation, these systems contribute to Greenhouse Gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, resulting in the electric system reliability through improved transmission and distribution system utilization.

The State of New Jersey’s Energy Master Plan (EMP) encourages new distributed generation of all forms and specifically focuses on expanding use of combined heat and power (CHP) by reducing financial, regulatory and technical barriers and identifying opportunities for new entries. The EMP also outlines a goal of 70% of the State’s electrical needs to be met by renewable sources by 2050.

Preliminary screenings were performed to determine the potential that a generation project could provide a cost-effective solution for your facility. Before making a decision to implement, a feasibility study should be conducted that would take a detailed look at existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.


6.1 Photovoltaic

Sunlight can be converted into electricity using photovoltaics (PV) modules. Modules are racked together into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is interconnected to the facility’s electrical distribution system. The amount of unobstructed area available determines how large of a solar array can be installed. The size of the array combined with the orientation, tilt, and shading elements determines the energy produced.

A preliminary screening based on the facility’s electric demand, size and location of free area, and shading elements shows that the facility has a low potential for installing a PV array.

In order to be cost-effective, a solar PV array needs certain minimum criteria, while there is good light the roof is only 2,500 square feet and the building load is small throughout most of the year.

Figure 19 - Photovoltaic Screening



For more information on solar PV technology and commercial solar markets in New Jersey, or to find a qualified solar installer, who can provide a more detailed assessment of the specific costs and benefits of solar develop of the site, please visit the following links below:

- **Basic Info on Solar PV in NJ:** <http://www.njcleanenergy.com/whysolar>
- **NJ Solar Market FAQs:** <http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs>
- **Approved Solar Installers in the NJ Market:** http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1

6.2 Combined Heat and Power

Combined heat and power (CHP) is the on-site generation of electricity along with the recovery of heat energy, which is put to beneficial use. Common technologies for CHP include reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines. Electric generation from a CHP system is typically interconnected to local power distribution systems. Heat is recovered from exhaust and ancillary cooling systems and interconnected to the existing hot water (or steam) distribution systems.


CHP systems are typically used to produce a portion of the electric power used onsite by a facility, with the balance of electric power needs supplied by grid purchases. The heat is used to supplement (or supplant) existing boilers for the purpose of space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for the purpose of space cooling. The key criteria used for screening, however, is the amount of time the system operates at full load and the facility's ability to use the recovered heat. Facilities with continuous use for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has a low potential for installing a cost-effective CHP system.

The low thermal load, and lack of space near the existing boilers are the most significant factors contributing to the potential for CHP at the site. In our opinion, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation.

For a list of qualified firms in New Jersey specializing in commercial CHP cost assessment and installation, go to: http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/.

Figure 20 - Combined Heat and Power Screening



Please see Section 8.4 for additional information in the Combined Heat & Power Program.

7 DEMAND RESPONSE

Demand Response (DR) is a program designed to reduce the electric load of commercial facilities when electric wholesale prices are high or when the reliability of the electric grid is threatened due to peak demand. Demand Response service providers (a.k.a. Curtailment Service Providers) are registered with PJM, the independent system operator (ISO) for mid-Atlantic state region that is charged with maintaining electric grid reliability.

By enabling grid operators to call upon Curtailment Service Providers and commercial facilities to reduce electric usage during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment Service Providers provide regular payments to medium and large consumers of electric power for their participation in DR programs. Program participation is voluntary and participants receive payments whether or not their facility is called upon to curtail their electric usage.

Typically an electric customer needs to be capable of reducing their electric demand, within minutes, by at least 100 kW or more in order to participate in a DR program. Customers with a greater capability to quickly curtail their demand during peak hours will receive higher payments. Customers with back-up generators onsite may also receive additional DR payments for their generating capacity if they agree to run the generators for grid support when called upon. Eligible customers who have chosen to participate in a DR programs often find it to be a valuable source of revenue for their facility because the payments can significantly offset annual electric costs.

Participating customers can often quickly reduce their peak load through simple measures, such as temporarily raising temperature set points on thermostats, so that air conditioning units run less frequently, or agreeing to dim or shut off less critical lighting. This usually requires some level of building automation and controls capability to ensure rapid load reduction during a DR curtailment event. DR program participants may need to install smart meters or may need to also sub-meter larger energy-using equipment, such as chillers, in order to demonstrate compliance with DR program requirements.

DR does not include the reduction of electricity consumption based on normal operating practice or behavior. For example, if a company's normal schedule is to close for a holiday, the reduction of electricity due to this closure or scaled-back operation is not considered a demand response activity in most situations.

The first step toward participation in a DR program is to contact a Curtailment Service Provider. A list of these providers is available on PJM's website and it includes contact information for each company, as well as the states where they have active business (<http://www.pjm.com/markets-and-operations/demand-response/csps.aspx>). PJM also posts training materials that are developed for program members interested in specific rules and requirements regarding DR activity (<http://www.pjm.com/training/training%20material.aspx>), along with a variety of other DR program information.

Curtailment Service Providers typically offer free assessments to determine a facility's eligibility to participate in a DR program. They will provide details regarding program rules and requirements for metering and controls, assess a facility's ability to temporarily reduce electric load, and provide details on payments to be expected for participation in the program. Providers usually offer multiple options for DR to larger facilities and may also install controls or remote monitoring equipment of their own to help ensure compliance with all terms and conditions of a DR contract.

8 PROJECT FUNDING / INCENTIVES

The NJCEP is able to provide the incentive programs described below, and other benefits to ratepayers, because of the Societal Benefits Charge (SBC) Fund. The SBC was created by the State of New Jersey’s Electricity Restructuring Law (1999), which requires all customers of investor-owned electric and gas utilities to pay a surcharge on their monthly energy bills. As a customer of a state-regulated electric or gas utility and therefore a contributor to the fund your organization is eligible to participate in the LGEA program and also eligible to receive incentive payment for qualifying energy efficiency measures. Also available through the NJBPU are some alternative financing programs described later in this section. Please refer to Figure 21 for a list of the eligible programs identified for each recommended ECM.

Figure 21 - ECM Incentive Program Eligibility

Energy Conservation Measure		SmartStart Prescriptive	SmartStart Custom	Direct Install	Pay For Performance Existing Buildings	Large Energy Users Program	Combined Heat & Power and Fuel Cell
ECM 1	Retrofit Fixtures with LED Lamps	x		x			
ECM 2	Install Occupancy Sensor Lighting Controls	x		x			
ECM 3	Install Low-Flow Domestic Hot Water Devices	x		x			

SmartStart is generally well-suited for implementation of individual measures or small group of measures. It provides flexibility to install measures at your own pace using in-house staff or a preferred contractor. Direct Install caters to small to mid-size facilities that can bundle multiple ECMs together. This can greatly simplify participation and may lead to higher incentive amounts, but requires the use of pre-approved contractors.

Generally, the incentive values provided throughout the report assume the SmartStart program is utilized because it provides a consistent basis for comparison of available incentives for various measures, though in many cases incentive amounts may be higher through participation in other programs.

Brief descriptions of all relevant financing and incentive programs are located in the sections below. Further information, including most current program availability, requirements, and incentive levels can be found at: www.njcleanenergy.com/ci.

8.1 SmartStart

Overview

The SmartStart program offers incentives for installing prescriptive and custom energy efficiency measures at your facility. Routinely the program adds, removes or modifies incentives from year to year for various energy efficiency equipment based on market trends and new technologies.

Equipment with Prescriptive Incentives Currently Available:

Electric Chillers

Electric Unitary HVAC

Gas Cooling

Gas Heating

Gas Water Heating

Ground Source Heat Pumps

Lighting

Lighting Controls

Refrigeration Doors

Refrigeration Controls

Refrigerator/Freezer Motors

Food Service Equipment

Variable Frequency Drives

Most equipment sizes and types are served by this program. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades.

Incentives

The SmartStart prescriptive incentive program provides fixed incentives for specific energy efficiency measures, whereas the custom SmartStart program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentive offerings for specific devices.

Since your facility is an existing building, only the retrofit incentives have been applied in this report. Custom measure incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings, capped at 50% of the total installed incremental project cost, or a project cost buy down to a one year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

How to Participate

To participate in the SmartStart program you will need to submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. Applicants may work with a contractor of their choosing and can also utilize internal personnel, which provides added flexibility to the program. Using internal personnel also helps improve the economics of the ECM by reducing the labor cost that is included in the tables in this report.

Detailed program descriptions, instructions for applying and applications can be found at: www.njcleanenergy.com/SSB.

8.2 Direct Install

Overview

Direct Install is a turnkey program available to existing small to medium-sized facilities with a peak electric demand that does not exceed 200 kW for any recent 12-month period. You will work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives and controls.

Incentives

The program pays up to 70% of the total installed cost of eligible measures, up to \$125,000 per project. Direct Install participants will also be held to a fiscal year cap of \$250,000 per entity.

How to Participate

To participate in the Direct Install program you will need to contact the participating contractor who is located in the region of the state where your facility is located. A complete list of Direct Install program partners is provided on the Direct Install website linked below. The contractor will be paid the measure incentives directly by the program which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the program, subject to program caps and eligibility, while the remaining 30% of the cost is paid to the contractor by the customer.

Since Direct Install offers a free assessment of eligible measures, Direct Install is also available to small businesses and other commercial facilities too that may not be eligible for the more detailed facility audits provided by LGEA.

Detailed program descriptions and applications can be found at: www.njcleanenergy.com/DI.

8.3 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) is an alternate method for New Jersey's government agencies to finance the implementation of energy conservation measures. An ESIP is a type of "performance contract," whereby school districts, counties, municipalities, housing authorities and other public and state entities enter in to contracts to help finance building energy upgrades. This is done in a manner that ensures that annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive in year one, and every year thereafter. ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs can be leveraged to help further reduce the total project cost of eligible measures.

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an Energy Services Company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is utilized for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the Energy Savings Plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Entities should carefully consider all alternatives to develop an approach that best meets their needs. A detailed program description and application can be found at: www.njcleanenergy.com/ESIP.

Please note that ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you may utilize NJCEP incentive programs to help further reduce costs when developing the ESP. You should refer to the ESIP guidelines at the link above for further information and guidance on next steps.

8.4 Combined Heat and Power Program

Overview

One of the goals of the State of New Jersey is to enhance energy efficiency through on-site power generation with recovery and productive use of waste heat, and to reduce existing and new demands to the electric power grid. The Combined Heat & Power (CHP) program provides incentives for eligible CHP or Waste Heat to Power (WHP) projects. Eligible CHP or Waste Heat to Power (WHP) projects must achieve an annual system efficiency of at least 65% (Lower Heating Value - LHV), based on total energy input and total utilized energy output. Mechanical energy may be included in the efficiency evaluation.

Incentives

Eligible Technologies	Size (Installed Rated Capacity)	Incentive (\$/kW)	% of Total Cost Cap per Project ³	\$ Cap per Project ³	
Powered by non-renewable or renewable fuel source ⁴	≤500 kW	\$2,000	30-40% ²	\$2 million	
	Gas Internal Combustion Engine	>500 kW - 1 MW			\$1,000
	Gas Combustion Turbine	> 1 MW - 3 MW	\$550	30%	\$3 million
	Microturbine	>3 MW	\$350		
	Fuel Cells with Heat Recovery	>3 MW	\$350		
Waste Heat to Power*	<1 MW	\$1,000	30%	\$2 million	
	> 1MW	\$500		\$3 million	

*Waste Heat to Power: Powered by non-renewable fuel source, heat recovery or other mechanical recovery from existing equipment utilizing new electric generation equipment (e.g. steam turbine).

Check the NJCEP website for details on program availability, incentive levels, and requirements.

How to Participate

You work with a qualified developer or consulting firm to complete the CHP Application. Once the application is approved the project can be installed. Information about the CHP program can be found at: www.njcleanenergy.com/CHP.

9 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

9.1 Retail Electric Supply Options

In 1999, New Jersey State Legislature passed the Electric Discount & Energy Competition Act (EDECA) to restructure the electric power industry in New Jersey. This law deregulated the retail electric markets, allowing all consumers to shop for service from competitive electric suppliers. The intent was to create a more competitive market for electric power supply in New Jersey. As a result, utilities were allowed to charge Cost of Service and customers were given the ability to choose a third party (i.e., non-utility) energy supplier.

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third party supplier, consider shopping for a reduced rate from third party electric suppliers. If your facility is purchasing electricity from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party electric suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

9.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey has also been deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate on a monthly basis. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier is typically dependent upon whether a customer seeks budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility is not purchasing natural gas from a third party supplier, consider shopping for a reduced rate from third party natural gas suppliers. If your facility is purchasing natural gas from a third party supplier, review and compare prices at the end of the current contract or every couple years.

A list of third party natural gas suppliers, who are licensed by the state to provide service in New Jersey, can be found online at: www.state.nj.us/bpu/commercial/shopping.html.

Appendix A: Equipment Inventory & Recommendations

Lighting Inventory & Recommendations

Location	Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Rear Exterior	3	LED Screw-In Lamps: A19	None	10	500	None	No	3	LED Screw-In Lamps: A19	None	10	500	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Rear Exterior	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	None	78	500	None	No	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	None	78	500	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Side Exterior	1	LED Screw-In Lamps: A19	None	10	500	None	No	1	LED Screw-In Lamps: A19	None	10	500	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Front	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	None	38	3,850	None	No	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	None	38	3,850	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Side Exterior	2	LED Screw-In Lamps: A19	None	10	500	None	No	2	LED Screw-In Lamps: A19	None	10	500	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Left	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	None	38	500	None	No	1	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	None	38	500	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
upstairs	4	Linear Fluorescent - T8: 4' T8 (32W) - 3L	None	93	1,560	Relamp	No	4	LED - Linear Tubes: (3) 4' Lamps	None	44	1,560	0.16	349	0.0	\$46.76	\$300.80	\$60.00	5.15
conference room	12	Linear Fluorescent - T8: 4' T8 (32W) - 3L	None	93	1,560	Relamp	Yes	12	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,092	0.61	1,323	0.0	\$177.27	\$1,172.40	\$215.00	5.40
conference room	2	Incandescent: A19	None	100	1,560	Relamp	No	2	LED Screw-In Lamps: A19	None	10	1,560	0.15	317	0.0	\$42.51	\$107.51	\$10.00	2.29
mens	1	Linear Fluorescent - T8: 4' T8 (32W) - 3L	None	93	1,560	Relamp	No	1	LED - Linear Tubes: (3) 4' Lamps	None	44	1,560	0.04	87	0.0	\$11.69	\$75.20	\$15.00	5.15
garage	12	Linear Fluorescent - T8: 8' T8 (59W) - 2L	None	110	1,560	Relamp	No	12	LED - Linear Tubes: (2) 8' Lamps	None	72	1,560	0.37	804	0.0	\$107.70	\$1,320.00	\$0.00	12.26
rear garage	17	Linear Fluorescent - T8: 8' T8 (59W) - 2L	None	110	1,560	Relamp	No	17	LED - Linear Tubes: (2) 8' Lamps	None	72	1,560	0.53	1,139	0.0	\$152.57	\$1,870.00	\$0.00	12.26
kitchen	5	Linear Fluorescent - T8: 4' T8 (32W) - 3L	None	93	1,560	Relamp	Yes	5	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	1,092	0.25	551	0.0	\$73.86	\$646.00	\$110.00	7.26
closet	2	Linear Fluorescent - T8: 4' T8 (32W) - 2L	None	62	1,560	Relamp	No	2	LED - Linear Tubes: (2) 4' Lamps	None	29	1,560	0.05	116	0.0	\$15.59	\$117.00	\$20.00	6.22
closet	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	None	62	1,560	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	None	29	1,560	0.03	58	0.0	\$7.79	\$58.50	\$10.00	6.22
bathroom	1	Linear Fluorescent - T8: 4' T8 (32W) - 3L	None	93	1,560	Relamp	No	1	LED - Linear Tubes: (3) 4' Lamps	None	44	1,560	0.04	87	0.0	\$11.69	\$75.20	\$15.00	5.15
bathroom	1	Incandescent: A19	None	100	1,560	Relamp	No	1	LED Screw-In Lamps: A19	None	10	1,560	0.07	159	0.0	\$21.26	\$53.75	\$5.00	2.29
boiler room	1	Linear Fluorescent - T8: 8' T8 (59W) - 2L	None	110	1,560	Relamp	No	1	LED - Linear Tubes: (2) 8' Lamps	None	72	1,560	0.03	67	0.0	\$8.97	\$110.00	\$0.00	12.26

Motor Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Annual Operating Hours	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Low Roof / Middle Roof	Conference Room	2	Exhaust Fan	3.0	91.5%	No	100	No	91.5%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Low Roof	Kitchen	1	Exhaust Fan	1.0	75.0%	No	500	No	75.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Middle Roof	Bathrooms	1	Exhaust Fan	0.3	75.0%	No	500	No	75.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Boiler Room	Circulator pumps	2	Other	0.1	65.0%	No	2,745	No	65.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Boiler Room	Building	1	Heating Hot Water Pump	1.0	85.0%	No	2,745	No	85.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00
Garage/ Tools	Garage - Tools	6	Supply Fan	0.5	75.0%	No	2,745	No	75.0%	No		0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions				Proposed Conditions							Energy Impact & Financial Analysis							
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Install Dual Enthalpy Economizer?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Low Roof	Conference Room	2	Split-System AC	3.00		No							No	0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Fuel Heating Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions			Proposed Conditions							Energy Impact & Financial Analysis							
		System Quantity	System Type	Output Capacity per Unit (MBh)	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years		
Boiler Room	Building	1	Non-Condensing Hot Water Boiler	327.00	No								0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions		Proposed Conditions						Energy Impact & Financial Analysis						
		System Quantity	System Type	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Boiler Room	Facility	1	Storage Tank Water Heater (≤ 50 Gal)	No						0.00	0	0.0	\$0.00	\$0.00	\$0.00	0.00

Low-Flow Device Recommendations

Location	Recommendation Inputs				Energy Impact & Financial Analysis							
	Device Quantity	Device Type	Existing Flow Rate (gpm)	Proposed Flow Rate (gpm)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years	
Bathrooms	2	Faucet Aerator (Lavatory)	2.50	1.00	0.00	0	3.7	\$34.33	\$14.34	\$0.00	0.42	

Plug Load Inventory

Location	Existing Conditions			Energy Rate (W)	ENERGY STAR Qualified?
	Quantity	Equipment Description			
Kitchen	1	Microwave		1,500.0	No
Kitchen	1	Refrigerator		250.0	No
Kitchen/Conference	2	TV		200.0	No
Garage	1	Vending Machine		350.0	No

Appendix B: ENERGY STAR® Statement of Energy Performance


ENERGY STAR® Statement of Energy Performance

N/A

Northfield Fire Station

Primary Property Type: Fire Station
Gross Floor Area (ft²): 4,955
Built: 1952

For Year Ending: April 30, 2016
Date Generated: October 13, 2017

ENERGY STAR® Score¹

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information		
Property Address Northfield Fire Station 2 East Hobart Gap Road Livingston, New Jersey 07039	Property Owner _____ () - _____	Primary Contact Ignacio Badilla 1430 Broadway 10th Floor New York, NY 10018 2015721187 ibadilla@trcsolutions.com
Property ID: 6073775		

Energy Consumption and Energy Use Intensity (EUI)					
Site EUI 40.9 kBtu/ft²	Annual Energy by Fuel		National Median Comparison		
	Electric - Grid (kBtu)	72,307 (36%)		National Median Site EUI (kBtu/ft²)	85.9
	Natural Gas (kBtu)	130,149 (64%)		National Median Source EUI (kBtu/ft²)	154.4
Source EUI 73.4 kBtu/ft²			% Diff from National Median Source EUI	-52%	
		Annual Emissions			
		Greenhouse Gas Emissions (Metric Tons CO2e/year)	15		

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

Signature: _____ Date: _____

Licensed Professional

() - _____



Professional Engineer Stamp
(if applicable)