



# Local Government Energy Audit Report

Sanitation Division

November 17, 2021

*Prepared for:*

City of Trenton  
707 Calhoun Street  
Trenton, NJ 08638

*Prepared by:*

TRC  
900 Route 9 North  
Woodbridge, NJ 07095

# Disclaimer

---

The goal of this audit report is to identify potential energy efficiency opportunities and help prioritize specific measures for implementation. Most energy conservation measures have received preliminary analysis of feasibility that identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to establish a basis for further discussion and to help prioritize energy measures.

TRC reviewed the energy conservation measures and estimates of energy savings for technical accuracy. Actual, achieved energy savings depend on behavioral factors and other uncontrollable variables and, therefore, estimates of final energy savings are not guaranteed. TRC and the New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

TRC bases estimated material and labor costs primarily on RS Means cost manuals as well as on our experience at similar facilities. This approach is based on standard cost estimating manuals and is vendor neutral. Cost estimates include material and labor pricing associated with one for one equipment replacements. Cost estimates do not include demolition or removal of hazardous waste. The actual implementation costs for energy savings projects are anticipated to be significantly higher based on the specific conditions at your site(s). We strongly recommend that you work with your design engineer or contractor to develop actual project costs for your specific scope of work for the installation of high efficiency equipment. We encourage you to obtain multiple estimates when considering measure installations. Actual installation costs can vary widely based on selected products and installers. TRC and NJBPU do not guarantee cost estimates and shall in no event be held liable should actual installed costs vary from these material and labor estimates.

Incentive values provided in this report are estimated based of previously run state efficiency programs. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. Please review all available utility program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

The customer and their respective contractor(s) are responsible to implement energy conservation measures in complete conformance with all applicable local, state, and federal requirements.

Copyright ©2021 TRC. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

# Table of Contents

---

<b>1</b>	<b>Executive Summary.....</b>	<b>1</b>
1.1	<b>Planning Your Project .....</b>	<b>4</b>
	Pick Your Installation Approach .....	4
	Options from Around the State.....	5
<b>2</b>	<b>Existing Conditions.....</b>	<b>6</b>
2.1	Site Overview.....	6
2.2	Building Occupancy .....	6
2.3	Building Envelope .....	6
2.4	Building Envelope .....	7
2.5	Air Handling Systems .....	8
	Unitary Electric HVAC Equipment .....	8
	Unitary Heating Equipment.....	8
2.6	Domestic Hot Water .....	8
2.7	Plug Load & Vending Machines.....	9
2.8	Water-Using Systems .....	9
<b>3</b>	<b>Energy Use and Costs .....</b>	<b>10</b>
3.1	Electricity .....	12
3.2	Natural Gas .....	13
3.3	Benchmarking.....	14
	Tracking Your Energy Performance.....	15
<b>4</b>	<b>Energy Conservation Measures .....</b>	<b>16</b>
4.1	Lighting .....	19
	ECM 1: Retrofit Fluorescent Fixtures with LED Lamps and Drivers.....	19
	ECM 2: Retrofit Fixtures with LED Lamps.....	19
4.2	Lighting Controls.....	20
	ECM 3: Install Occupancy Sensor Lighting Controls .....	20
	ECM 4: Install High/Low Lighting Controls .....	20
4.3	Unitary HVAC.....	21
	ECM 5: Install High Efficiency Air Conditioning Units.....	21
4.4	Gas-Fired Heating .....	21
	ECM 6: Install High Efficiency Furnaces.....	21
4.5	HVAC Improvements .....	22
	ECM 7: Install Pipe Insulation.....	22
4.6	Domestic Water Heating .....	22
	ECM 8: Install Low-Flow DHW Devices.....	22
4.7	Custom Measures.....	23

ECM 9: Building Envelope Improvements .....	23
<b>5 Energy Efficient Best Practices .....</b>	<b>24</b>
Energy Tracking with ENERGY STAR® Portfolio Manager® .....	24
Weatherization.....	24
Doors and Windows .....	24
Lighting Maintenance.....	25
HVAC Filter Cleaning and Replacement .....	25
Furnace Maintenance .....	25
Label HVAC Equipment .....	25
Optimize HVAC Equipment Schedules .....	26
Water Heater Maintenance .....	26
Water Conservation .....	27
Procurement Strategies .....	27
<b>6 On-site Generation .....</b>	<b>28</b>
6.1 Solar Photovoltaic .....	29
6.2 Combined Heat and Power .....	31
<b>7 Project Funding and Incentives.....</b>	<b>32</b>
7.1 Utility Energy Efficiency Programs .....	32
<b>8 New Jersey’s Clean Energy Programs .....</b>	<b>33</b>
8.1 Combined Heat and Power .....	34
8.2 Energy Savings Improvement Program .....	35
8.3 Transition Incentive (TI) Program.....	36
<b>9 Project Development .....</b>	<b>37</b>
<b>10 Energy Purchasing and Procurement Strategies .....</b>	<b>38</b>
10.1 Retail Electric Supply Options.....	38
10.2 Retail Natural Gas Supply Options .....	38
<b>Appendix A: Equipment Inventory &amp; Recommendations .....</b>	<b>A-1</b>
<b>Appendix B: ENERGY STAR® Statement of Energy Performance.....</b>	<b>B-1</b>
<b>Appendix C: Glossary .....</b>	<b>C-1</b>

## ENERGY EFFICIENCY INCENTIVE & REBATE TRANSITION

---

For the purposes of your LGEA, estimated incentives and rebates are included as placeholders for planning purposes. New Jersey utilities are rolling out their own energy efficiency programs, which your project may be eligible for depending on individual measures, quantities, and size of the building.

In 2018, Governor Murphy signed into law the landmark legislation known as the [Clean Energy Act](#). The law called for a significant overhaul of New Jersey's clean energy systems by building sustainable infrastructure in order to fight climate change and reduce carbon emissions, which will in turn create well-paying local jobs, grow the state's economy, and improve public health while ensuring a cleaner environment for current and future residents.

These "next generation" energy efficiency programs feature new ways of managing and delivering programs historically administered by New Jersey's Clean Energy Program™ (NJCEP). All of the investor-owned gas and electric utility companies will now also offer complementary energy efficiency programs and incentives directly to customers like you. NJCEP will still offer programs for new construction, renewable energy, the Energy Savings Improvement Program (ESIP), and large energy users.


New utility programs are expected to start rolling out in the spring and summer of 2021. Keep up to date with developments by visiting the [NJCEP website](#).

The infographic features logos for Atlantic City Electric, Jersey Central Power & Light, PSEG, Rockland Electric Company, Elizabethtown Gas, South Jersey Gas, and New Jersey Natural Gas. Below the logos, the text reads: "Program areas to be served by the Utilities:" followed by a list of areas: Existing Buildings (residential, commercial, industrial, government) and Efficient Products (HVAC, Appliance Rebates, Appliance Recycling). A separate box titled "Proposed New Programs & Features:" lists: Dedicated multi-family program, More financing options, and Quick home energy check-ups.


# 1 EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) report for Sanitation Division. This report provides you with information about your facility's energy use, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help make changes in your facility. TRC conducted this study as part of a comprehensive effort to assist New Jersey school districts and local governments in controlling their energy costs and to help protect our environment by reducing statewide energy consumption.

## BUILDING PERFORMANCE REPORT



ENERGY STAR® Benchmarking Score	N/A <i>(1-100 scale)</i>	A standard energy use benchmark is not available for this facility type. This report contains suggestions about how to improve building performance and reduce energy costs.
---------------------------------	-----------------------------	--



*Figure 1 - Energy Use by System*


## POTENTIAL IMPROVEMENTS



This energy audit considered a range of potential energy improvements in your building. Costs and savings will vary between improvements. Presented below are two potential scopes of work for your consideration.


### Scenario 1: Full Package (all evaluated measures)

Installation Cost	\$68,726	100.0
Potential Rebates & Incentives <sup>1</sup>	\$4,155	80.0
Annual Cost Savings	\$7,614	60.0
Annual Energy Savings	Electricity: 39,642 kWh Natural Gas: 2,388 Therms	40.0
Greenhouse Gas Emission Savings	34 Tons	20.0
Simple Payback	8.5 Years	0.0
Site Energy Savings (all utilities)	21%	



### Scenario 2: Cost Effective Package<sup>2</sup>

Installation Cost	\$6,934	100.0
Potential Rebates & Incentives	\$1,155	80.0
Annual Cost Savings	\$5,137	60.0
Annual Energy Savings	Electricity: 38,682 kWh Natural Gas: -49 Therms	40.0
Greenhouse Gas Emission Savings	19 Tons	20.0
Simple Payback	1.1 Years	0.0
Site Energy Savings (all utilities)	7%	



### On-site Generation Potential

Photovoltaic	None
Combined Heat and Power	None

<sup>1</sup> Incentives are based on previously run state rebate programs. Contact your utility provider for current program incentives that may apply.

<sup>2</sup> A cost-effective measure is defined as one where the simple payback does not exceed two-thirds of the expected proposed equipment useful life. Simple payback is based on the net measure cost after potential incentives.

#	Energy Conservation Measure	Cost Effective?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>			<b>22,619</b>	<b>3.5</b>	<b>-5</b>	<b>\$2,982</b>	<b>\$4,914</b>	<b>\$181</b>	<b>\$4,733</b>	<b>1.6</b>	<b>22,168</b>
ECM 1	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	Yes	238	0.0	0	\$31	\$84	\$10	\$74	2.4	233
ECM 2	Retrofit Fixtures with LED Lamps	Yes	22,381	3.5	-5	\$2,950	\$4,829	\$171	\$4,658	1.6	21,935
<b>Lighting Control Measures</b>			<b>16,064</b>	<b>2.5</b>	<b>-4</b>	<b>\$2,118</b>	<b>\$1,833</b>	<b>\$840</b>	<b>\$993</b>	<b>0.5</b>	<b>15,743</b>
ECM 3	Install Occupancy Sensor Lighting Controls	Yes	3,010	0.5	-1	\$397	\$1,158	\$165	\$993	2.5	2,950
ECM 4	Install High/Low Lighting Controls	Yes	13,054	2.0	-3	\$1,721	\$675	\$675	\$0	0.0	12,794
<b>Unitary HVAC Measures</b>			<b>960</b>	<b>0.5</b>	<b>0</b>	<b>\$129</b>	<b>\$5,642</b>	<b>\$0</b>	<b>\$5,642</b>	<b>43.8</b>	<b>967</b>
ECM 5	Install High Efficiency Air Conditioning Units	No	960	0.5	0	\$129	\$5,642	\$0	\$5,642	43.8	967
<b>Gas Heating (HVAC/Process) Replacement</b>			<b>0</b>	<b>0.0</b>	<b>98</b>	<b>\$942</b>	<b>\$19,248</b>	<b>\$3,000</b>	<b>\$16,248</b>	<b>17.3</b>	<b>11,450</b>
ECM 6	Install High Efficiency Furnaces	No	0	0.0	98	\$942	\$19,248	\$3,000	\$16,248	17.3	11,450
<b>HVAC System Improvements</b>			<b>0</b>	<b>0.0</b>	<b>3</b>	<b>\$29</b>	<b>\$173</b>	<b>\$120</b>	<b>\$53</b>	<b>1.8</b>	<b>351</b>
ECM 7	Install Pipe Insulation	Yes	0	0.0	3	\$29	\$173	\$120	\$53	1.8	351
<b>Domestic Water Heating Upgrade</b>			<b>0</b>	<b>0.0</b>	<b>1</b>	<b>\$9</b>	<b>\$14</b>	<b>\$14</b>	<b>\$0</b>	<b>0.0</b>	<b>111</b>
ECM 8	Install Low-Flow DHW Devices	Yes	0	0.0	1	\$9	\$14	\$14	\$0	0.0	111
<b>Custom Measures</b>			<b>0</b>	<b>0.0</b>	<b>146</b>	<b>\$1,406</b>	<b>\$36,902</b>	<b>\$0</b>	<b>\$36,902</b>	<b>26.2</b>	<b>17,095</b>
ECM 9	Building Envelope Improvements	No	0	0.0	146	\$1,406	\$36,902	\$0	\$36,902	26.2	17,095
<b>TOTALS (COST EFFECTIVE MEASURES)</b>			<b>38,682</b>	<b>6.0</b>	<b>-5</b>	<b>\$5,137</b>	<b>\$6,934</b>	<b>\$1,155</b>	<b>\$5,779</b>	<b>1.1</b>	<b>38,373</b>
<b>TOTALS (ALL MEASURES)</b>			<b>39,642</b>	<b>6.6</b>	<b>239</b>	<b>\$7,614</b>	<b>\$68,726</b>	<b>\$4,155</b>	<b>\$64,571</b>	<b>8.5</b>	<b>67,885</b>

\* - All incentives presented in this table are included as placeholders and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 2 – Evaluated Energy Improvements

For more detail on each evaluated energy improvement and a break out of cost-effective improvements, see **Section 4: Energy Conservation Measures**.



## 1.1 Planning Your Project

Careful planning makes for a successful energy project. When considering this scope of work, you will have some decisions to make, such as:

- ◆ How will the project be funded and/or financed?
- ◆ Is it best to pursue individual ECMs, groups of ECMs, or use a comprehensive approach where all ECMs are installed together?
- ◆ Are there other facility improvements that should happen at the same time?

### Pick Your Installation Approach

Utility run energy efficiency programs and New Jersey's Clean Energy Programs give you the flexibility to do a little or a lot. Rebates, incentives, and financing are available to help reduce both your installation costs and your energy bills. If you are planning to take advantage of these programs, make sure to review incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives before purchasing materials or starting installation.

For details on these programs please visit [New Jersey's Clean Energy Program website](#) or contact your utility provider.



## **Options from Around the State**

### *Financing and Planning Support with the Energy Savings Improvement Program (ESIP)*

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the ESIP. Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as attractive financing for implementing ECMs. You have already taken the first step as an LGEA customer, because this report is required to participate in ESIP.

### *Resiliency with Return on Investment through Combined Heat & Power (CHP)*

The CHP program provides incentives for combined heat and power (aka cogeneration) and waste heat to power projects. Combined heat and power systems generate power on-site and recover heat from the generation system to meet on-site thermal loads. Waste heat to power systems use waste heat to generate power. You will work with a qualified developer who will design a system that meets your building's heating and cooling needs.

### *Ongoing Electric Savings with Demand Response*

The Demand Response Energy Aggregator program reduces electric loads at commercial facilities when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. By enabling commercial facilities to reduce electric demand during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment service providers provide regular payments to medium and large consumers of electric power for their participation in demand response (DR) programs. Program participation is voluntary, and facilities receive payments regardless of whether they are called upon to curtail their load during times of peak demand.

## 2 EXISTING CONDITIONS

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) Report for Sanitation Division. This report provides information on how your facility uses energy, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help you implement the ECMs.

TRC conducted this study as part of a comprehensive effort to assist New Jersey educational and local government facilities in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

### 2.1 Site Overview

On April 6, 2021, TRC performed an energy audit at the Sanitation Division located in Trenton, New Jersey. TRC met with facility staff to review the facility operations and help focus our investigation on specific energy-using systems.

The Sanitation Division is a one-story, 23,328 square foot building built in 1912. Spaces include offices, garage, restrooms, and mechanical space. The facility has two garage areas. One is the mechanic's space and the other large garage is used to store trucks and equipment.

### 2.2 Building Occupancy

The facility is occupied year-round. Approximately 80 employees work out of the facility with another ten working full time in the facility.

Building Name	Weekday/Weekend	Operating Schedule
Sanitation Division	Weekday	6:45 AM - 3:15 PM
	Weekend	Saturday -6:45 AM - 3:15 PM, Sunday - closed

*Figure 3 - Building Occupancy Schedule*

### 2.3 Building Envelope


Building walls are concrete block over structural steel. They appear uninsulated. The roof is flat with an underlayment of wood joists and plywood decking. The office has two large single glazed windows with wood frames. The doors are metal with metal frames in fair condition.



*Building Exterior*



*Building Exterior*



*Interior Structure*



*Passenger Doors*



*Garage Doors*



*Garage Doors*



*Passenger Doors*



*Office Windows*



*Boarded Window Opening*

## 2.4 Building Envelope


The interior lighting system uses 32-Watt linear fluorescent T8 lamps. Additionally, there are some LED corn cob, high bay retrofits; and new LED fixtures in the office spaces. The large garage includes HID lamps and several 8-foot T-12 strip fixtures. Exit signs are LED.

Exterior wall pack fixtures were recently replaced with LED sources. They are controlled by photocells. The utility maintains several pole mounted flood lights around the facility.

Recently implemented lighting retrofits are saving approximately 14,000 kWh/year.



*Fluorescent Wrap*




*LED Flat Panel*



*EXIT Sign*



*HID Lamp*



*T-12 Strip*



*LED Wall Pack Fixtures*

## 2.5 Air Handling Systems

### Unitary Electric HVAC Equipment

The office space is conditioned by a gas-fired furnace connected to a split-system air conditioning (AC) unit. The indoor furnace is in good condition. A ductless mini split system provides additional cooling for the office space. It is in poor condition. These units are not ENERGY STAR® labeled.



*Furnace*



*Ductless Mini split AC*



*Ductless Mini split AC*

### Unitary Heating Equipment

Both garages are heated by suspended gas fired furnaces. These vary in capacity between 200 and 400 MBh. The units in the mechanic's garage are in fair condition. The units in the large garage are newer and are controlled by a digital thermostat.



*Gas-fired Hanging Furnace*



*Gas-fired Hanging Furnace*



*Thermostat*

## 2.6 Domestic Hot Water

Hot water is produced by a 40 gallon, 40 MBh gas-fired storage water heater. The domestic hot water pipes are not insulated.



*Gas-fired storage water heater*



*Gas-fired storage water heater*



*Gas-fired storage water heater*

## 2.7 Plug Load & Vending Machines

The location is doing a great job managing their electrical plug loads. This report makes additional suggestions for ECMs in this area as well as Energy Efficient Best Practices.

There are four computer workstations throughout the facility. Plug loads throughout the building include general café and office equipment. There are several residential-style refrigerators throughout the building. These vary in condition and efficiency. The mechanics garage has various tools used to service trucks as well as a lift and air purifying equipment.



*Air Purifier*



*Printer*



*Residential-style Refrigerator*



*Residential-style Refrigerators*


## 2.8 Water-Using Systems

There are two restrooms with toilets and sinks. Faucet flow rates are at 2.2 gallons per minute (gpm) or higher.

### 3 ENERGY USE AND COSTS

Twelve months of utility billing data are used to develop annual energy consumption and cost data. This information creates a profile of the annual energy consumption and energy costs.


Utility Summary		
Fuel	Usage	Cost
Electricity	124,636 kWh	\$16,706
Natural Gas	13,895 Therms	\$13,380
<b>Total</b>		<b>\$30,086</b>



An energy balance identifies and quantifies energy use in your various building systems. This can highlight areas with the most potential for improvement. This energy balance was developed using calculated energy use for each of the end uses noted in the figure.

The energy auditor collects information regarding equipment operating hours, capacity, efficiency, and other operational parameters from facility staff, drawings, and on-site observations. This information is used as the inputs to calculate the existing conditions energy use for the site. The calculated energy use is then compared to the historical energy use and the initial inputs are revised, as necessary, to balance the calculated energy use to the historical energy use.

We noted that several light fixtures were upgraded to use more efficient sources *after* the 12-month period of electrical billing data that was used for the energy balance but *before* we conducted our site audit. For the energy balance, we assumed the power draw prior to the retrofit for these fixtures so we could properly assess energy use of the building systems against the historical data. The summary tables do not include savings for the fixtures that had already been retrofit when we arrived on site. However, the report does note the approximate savings you've achieved from the already implemented lighting retrofits in Section 2.4 above.




*Figure 4 - Energy Balance*



### 3.1 Electricity

PSE&G delivers electricity under rate class General Lighting & Power (LP).




Electric Billing Data					
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost
3/16/19	29	10,200	31	\$121	\$1,346
4/16/19	31	10,040	25	\$99	\$1,452
5/16/19	30	9,840	20	\$79	\$1,477
6/17/19	32	10,280	21	\$292	\$1,599
7/17/19	30	9,800	23	\$320	\$1,493
8/5/19	19	14,160	26	\$353	\$1,765
9/4/19	30	4,280	26	\$235	\$815
10/3/19	29	10,040	49	\$96	\$1,213
11/3/19	31	9,680	37	\$50	\$1,195
12/4/19	31	9,320	26	\$101	\$1,176
1/6/20	33	12,160	29	\$115	\$1,426
2/4/20	29	11,080	7	\$28	\$1,246
<b>Totals</b>	<b>354</b>	<b>120,880</b>	<b>49</b>	<b>\$1,889</b>	<b>\$16,202</b>
<b>Annual</b>	<b>365</b>	<b>124,636</b>	<b>49</b>	<b>\$1,947</b>	<b>\$16,706</b>

Notes:

- Peak demand of 49 kW occurred in October 2019.
- Average demand over the past 12 months was 27 kW.
- The average electric cost over the past 12 months was \$0.134/kWh, which is the blended rate that includes energy supply, distribution, demand, and other charges. This report uses this blended rate to estimate energy cost savings.

### 3.2 Natural Gas

PSE&G delivers natural gas under rate class General Gas Service (GSG).



Gas Billing Data			
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost
3/14/19	28	2,875	\$2,447
4/16/19	33	887	\$746
5/16/19	30	223	\$290
6/17/19	32	26	\$169
7/17/19	30	23	\$166
8/15/19	29	22	\$165
9/4/19	20	16	\$111
10/3/19	29	24	\$168
11/3/19	31	1,172	\$1,209
12/4/19	32	2,320	\$2,250
1/3/20	30	2,895	\$2,667
2/3/20	31	3,031	\$2,625
<b>Totals</b>	<b>355</b>	<b>13,514</b>	<b>\$13,013</b>
<b>Annual</b>	<b>365</b>	<b>13,895</b>	<b>\$13,380</b>

Notes:

- The average gas cost for the past 12 months is \$0.963/therm, which is the blended rate used throughout the analysis.


### 3.3 Benchmarking

Your building was benchmarked using the United States Environmental Protection Agency's (EPA) *Portfolio Manager*<sup>®</sup> software. Benchmarking compares your building's energy use to that of similar buildings across the country, while neutralizing variations due to location, occupancy, and operating hours. Some building types can be scored with a 1-100 ranking of a building's energy performance relative to the national building market. A score of 50 represents the national average and a score of 100 is best.

This ENERGY STAR<sup>®</sup> benchmarking score provides a comprehensive snapshot of your building's energy performance. It assesses the building's physical assets, operations, and occupant behavior, which is compiled into a quick and easy-to-understand score.

<b>Benchmarking Score</b>	<b>[N/A]</b>
---------------------------	--------------

Due to its unique characteristics, this building type is not able to receive a benchmarking score. This report contains suggestions about how to improve building performance and reduce energy costs.



*Figure 5 - Energy Use Intensity Comparison<sup>3</sup>*

Energy use intensity (EUI) measures energy consumption per square foot and is the standard metric for comparing buildings' energy performance. A lower EUI means better performance and less energy consumed. A number of factors can cause a building to vary from the "typical" energy usage. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and occupant behavior all contribute to a building's energy use and the benchmarking score.

<sup>3</sup> Based on all evaluated ECMs

### **Tracking Your Energy Performance**

Keeping track of your energy use on a monthly basis is one of the best ways to keep energy costs in check. Update your utility information in Portfolio Manager® regularly, so that you can keep track of your building's performance.

**We have created a Portfolio Manager® account for your facility and we have already entered the monthly utility data shown above for you. Account login information for your account will be sent via email.**

Free online training is available to help you use ENERGY STAR® Portfolio Manager® to track your building's performance at: <https://www.energystar.gov/buildings/training>.

For more information on ENERGY STAR® and Portfolio Manager®, visit their website<sup>4</sup>.

---

<sup>4</sup> <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.

## 4 ENERGY CONSERVATION MEASURES

---

The goal of this audit report is to identify and evaluate potential energy efficiency improvements and provide information about the cost effectiveness of those improvements. Most energy conservation measures have received preliminary analysis of feasibility, which identifies expected ranges of savings. This level of analysis is typically sufficient to demonstrate project cost-effectiveness and help prioritize energy measures.

Calculations of energy use and savings are based on the current version of the *New Jersey's Clean Energy Program Protocols to Measure Resource Savings*, which is approved by the NJBPU. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances.

Operation and maintenance costs for the proposed new equipment will generally be lower than the current costs for the existing equipment—especially if the existing equipment is at or past its normal useful life. We have conservatively assumed there to be no impact on overall maintenance costs over the life of the equipment.

Financial incentives are based on previously run state rebate programs. New utility programs are expected to start rolling out in the spring and summer of 2021. Keep up to date with developments by visiting the [NJCEP website](#). Some measures and proposed upgrades may be eligible for higher incentives than those shown below.

For a detailed list of the locations and recommended energy conservation measures for all inventoried equipment, see **Appendix A: Equipment Inventory & Recommendations**.

#	Energy Conservation Measure	Cost Effective?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>			<b>22,619</b>	<b>3.5</b>	<b>-5</b>	<b>\$2,982</b>	<b>\$4,914</b>	<b>\$181</b>	<b>\$4,733</b>	<b>1.6</b>	<b>22,168</b>
ECM 1	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	Yes	238	0.0	0	\$31	\$84	\$10	\$74	2.4	233
ECM 2	Retrofit Fixtures with LED Lamps	Yes	22,381	3.5	-5	\$2,950	\$4,829	\$171	\$4,658	1.6	21,935
<b>Lighting Control Measures</b>			<b>16,064</b>	<b>2.5</b>	<b>-4</b>	<b>\$2,118</b>	<b>\$1,833</b>	<b>\$840</b>	<b>\$993</b>	<b>0.5</b>	<b>15,743</b>
ECM 3	Install Occupancy Sensor Lighting Controls	Yes	3,010	0.5	-1	\$397	\$1,158	\$165	\$993	2.5	2,950
ECM 4	Install High/Low Lighting Controls	Yes	13,054	2.0	-3	\$1,721	\$675	\$675	\$0	0.0	12,794
<b>Unitary HVAC Measures</b>			<b>960</b>	<b>0.5</b>	<b>0</b>	<b>\$129</b>	<b>\$5,642</b>	<b>\$0</b>	<b>\$5,642</b>	<b>43.8</b>	<b>967</b>
ECM 5	Install High Efficiency Air Conditioning Units	No	960	0.5	0	\$129	\$5,642	\$0	\$5,642	43.8	967
<b>Gas Heating (HVAC/Process) Replacement</b>			<b>0</b>	<b>0.0</b>	<b>98</b>	<b>\$942</b>	<b>\$19,248</b>	<b>\$3,000</b>	<b>\$16,248</b>	<b>17.3</b>	<b>11,450</b>
ECM 6	Install High Efficiency Furnaces	No	0	0.0	98	\$942	\$19,248	\$3,000	\$16,248	17.3	11,450
<b>HVAC System Improvements</b>			<b>0</b>	<b>0.0</b>	<b>3</b>	<b>\$29</b>	<b>\$173</b>	<b>\$120</b>	<b>\$53</b>	<b>1.8</b>	<b>351</b>
ECM 7	Install Pipe Insulation	Yes	0	0.0	3	\$29	\$173	\$120	\$53	1.8	351
<b>Domestic Water Heating Upgrade</b>			<b>0</b>	<b>0.0</b>	<b>1</b>	<b>\$9</b>	<b>\$14</b>	<b>\$14</b>	<b>\$0</b>	<b>0.0</b>	<b>111</b>
ECM 8	Install Low-Flow DHW Devices	Yes	0	0.0	1	\$9	\$14	\$14	\$0	0.0	111
<b>Custom Measures</b>			<b>0</b>	<b>0.0</b>	<b>146</b>	<b>\$1,406</b>	<b>\$36,902</b>	<b>\$0</b>	<b>\$36,902</b>	<b>26.2</b>	<b>17,095</b>
ECM 9	Building Envelope Improvements	No	0	0.0	146	\$1,406	\$36,902	\$0	\$36,902	26.2	17,095
<b>TOTALS</b>			<b>39,642</b>	<b>6.6</b>	<b>239</b>	<b>\$7,614</b>	<b>\$68,726</b>	<b>\$4,155</b>	<b>\$64,571</b>	<b>8.5</b>	<b>67,885</b>

\* - All incentives presented in this table are included as placeholders and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 6 – All Evaluated ECMs

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>		<b>22,619</b>	<b>3.5</b>	<b>-5</b>	<b>\$2,982</b>	<b>\$4,914</b>	<b>\$181</b>	<b>\$4,733</b>	<b>1.6</b>	<b>22,168</b>
ECM 1	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	238	0.0	0	\$31	\$84	\$10	\$74	2.4	233
ECM 2	Retrofit Fixtures with LED Lamps	22,381	3.5	-5	\$2,950	\$4,829	\$171	\$4,658	1.6	21,935
<b>Lighting Control Measures</b>		<b>16,064</b>	<b>2.5</b>	<b>-4</b>	<b>\$2,118</b>	<b>\$1,833</b>	<b>\$840</b>	<b>\$993</b>	<b>0.5</b>	<b>15,743</b>
ECM 3	Install Occupancy Sensor Lighting Controls	3,010	0.5	-1	\$397	\$1,158	\$165	\$993	2.5	2,950
ECM 4	Install High/Low Lighting Controls	13,054	2.0	-3	\$1,721	\$675	\$675	\$0	0.0	12,794
<b>HVAC System Improvements</b>		<b>0</b>	<b>0.0</b>	<b>3</b>	<b>\$29</b>	<b>\$173</b>	<b>\$120</b>	<b>\$53</b>	<b>1.8</b>	<b>351</b>
ECM 7	Install Pipe Insulation	0	0.0	3	\$29	\$173	\$120	\$53	1.8	351
<b>Domestic Water Heating Upgrade</b>		<b>0</b>	<b>0.0</b>	<b>1</b>	<b>\$9</b>	<b>\$14</b>	<b>\$14</b>	<b>\$0</b>	<b>0.0</b>	<b>111</b>
ECM 8	Install Low-Flow DHW Devices	0	0.0	1	\$9	\$14	\$14	\$0	0.0	111
<b>TOTALS</b>		<b>38,682</b>	<b>6.0</b>	<b>-5</b>	<b>\$5,137</b>	<b>\$6,934</b>	<b>\$1,155</b>	<b>\$5,779</b>	<b>1.1</b>	<b>38,373</b>

\* - All incentives presented in this table are included as placeholders and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 7 – Cost Effective ECMs

## 4.1 Lighting

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>		<b>22,619</b>	<b>3.5</b>	<b>-5</b>	<b>\$2,982</b>	<b>\$4,914</b>	<b>\$181</b>	<b>\$4,733</b>	<b>1.6</b>	<b>22,168</b>
ECM 1	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	238	0.0	0	\$31	\$84	\$10	\$74	2.4	233
ECM 2	Retrofit Fixtures with LED Lamps	22,381	3.5	-5	\$2,950	\$4,829	\$171	\$4,658	1.6	21,935

When considering lighting upgrades, we suggest using a comprehensive design approach that simultaneously upgrades lighting fixtures and controls to maximize energy savings and improve occupant lighting. Comprehensive design will also consider appropriate lighting levels for different space types to make sure that the right amount of light is delivered where needed. If conversion to LED light sources are proposed, we suggest converting all of a specific lighting type (e.g., linear fluorescent) to LED lamps to minimize the number of lamp types in use at the facility, which should help reduce future maintenance costs.

### **ECM 1: Retrofit Fluorescent Fixtures with LED Lamps and Drivers**

Retrofit fluorescent fixtures by removing the fluorescent tubes and ballasts and replacing them with LED tubes and LED drivers (if necessary), which are designed to be used in retrofitted fluorescent fixtures.

The measure uses the existing fixture housing but replaces the electric components with more efficient lighting technology which use less power than other lighting technologies but provides equivalent lighting output. Maintenance savings may also be achieved since LED tubes last longer than fluorescent tubes and therefore do not need to be replaced as often.

**Affected building areas:** T-12 fixtures, Garage 2.

### **ECM 2: Retrofit Fixtures with LED Lamps**

Replace fluorescent or HID with LED lamps. Many LED tubes are direct replacements for existing fluorescent tubes and can be installed while leaving the fluorescent fixture ballast in place. LED lamps can be used in existing fixtures as a direct replacement for most other lighting technologies.

This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space. Maintenance savings may also be available, as longer-lasting LEDs lamps will not need to be replaced as often as the existing lamps.

**Affected building areas:** Garage 1, Garage 2, and restrooms.



## 4.2 Lighting Controls

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Control Measures</b>		<b>16,064</b>	<b>2.5</b>	<b>-4</b>	<b>\$2,118</b>	<b>\$1,833</b>	<b>\$840</b>	<b>\$993</b>	<b>0.5</b>	<b>15,743</b>
ECM 3	Install Occupancy Sensor Lighting Controls	3,010	0.5	-1	\$397	\$1,158	\$165	\$993	2.5	2,950
ECM 4	Install High/Low Lighting Controls	13,054	2.0	-3	\$1,721	\$675	\$675	\$0	0.0	12,794

Lighting controls reduce energy use by turning off or lowering lighting fixture power levels when not in use. A comprehensive approach to lighting design should upgrade the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

### **ECM 3: Install Occupancy Sensor Lighting Controls**

Install occupancy sensors to control lighting fixtures in areas that are frequently unoccupied, even for short periods. For most spaces, we recommend that lighting controls use dual technology sensors, which reduce the possibility of lights turning off unexpectedly.

Occupancy sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Most occupancy sensor lighting controls allow users to manually turn fixtures on/off, as needed. Some controls can also provide dimming options.

Occupancy sensors can be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are best suited to single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in large spaces, locations without local switching, and where wall switches are not in the line-of-sight of the main work area.

This measure provides energy savings by reducing the lighting operating hours.

**Affected building areas:** offices, Garages 1 and 2, and restrooms.

### **ECM 4: Install High/Low Lighting Controls**

Install occupancy sensors to provide dual level lighting control for lighting fixtures in spaces that are infrequently occupied but may require some level of continuous lighting for safety or security reasons.

Lighting fixtures with these controls operate at default low levels when the area is unoccupied to provide minimal lighting to meet security or safety code requirements for egress. Sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Fixtures automatically switch back to low level after a predefined period of vacancy. In parking lots and parking garages with significant ambient lighting, this control can sometimes be combined with photocell controls to turn the lights off when there is sufficient daylight.

The controller lowers the light level by dimming the fixture output. Therefore, the controlled fixtures need to have a dimmable ballast or driver. This will need to be considered when selecting retrofit lamps and bulbs for the areas proposed for high/low control.

This measure provides energy savings by reducing the light fixture power draw when reduced light output is appropriate.

**Affected building areas:** Garages 1 and 2.

For this type of measure the occupancy sensors will generally be ceiling or fixture mounted. Sufficient sensor coverage must be provided to ensure that lights turn on in each area as an occupant approaches.

### 4.3 Unitary HVAC

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Unitary HVAC Measures</b>		<b>960</b>	<b>0.5</b>	<b>0</b>	<b>\$129</b>	<b>\$5,642</b>	<b>\$0</b>	<b>\$5,642</b>	<b>43.8</b>	<b>967</b>
ECM 5	Install High Efficiency Air Conditioning Units	960	0.5	0	\$129	\$5,642	\$0	\$5,642	43.8	967

Replacing the unitary HVAC units has a long payback period and may not be justifiable based simply on energy considerations. However, most of the units at this facility are nearing or have reached the end of their normal useful life. Typically, the marginal cost of purchasing a high efficiency unit can be justified by the marginal savings from the improved efficiency. When the ductless mini split system AC is eventually replaced, consider purchasing equipment that exceeds the minimum efficiency required by building codes.

#### **ECM 5: Install High Efficiency Air Conditioning Units**

We evaluated replacing standard efficiency packaged air conditioning units with high efficiency packaged air conditioning units. All of the replacement units will incorporate efficient gas furnaces. The magnitude of energy savings for this measure depends on the relative efficiency of the older unit versus the new high efficiency unit, the average cooling and heating load and the estimated annual operating hours.

**Affected units:** office space.

### 4.4 Gas-Fired Heating

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Gas Heating (HVAC/Process) Replacement</b>		<b>0</b>	<b>0.0</b>	<b>98</b>	<b>\$942</b>	<b>\$19,248</b>	<b>\$3,000</b>	<b>\$16,248</b>	<b>17.3</b>	<b>11,450</b>
ECM 6	Install High Efficiency Furnaces	0	0.0	98	\$942	\$19,248	\$3,000	\$16,248	17.3	11,450

#### **ECM 6: Install High Efficiency Furnaces**

We evaluated replacing standard efficiency furnaces with condensing furnaces. Improved combustion technology and heat exchanger design optimize heat recovery from the combustion gases which can significantly improve furnace efficiency. Savings result from improved system efficiency.

Note: these units produce acidic condensate that requires proper drainage.

**Affected units:** Garage 1.

## 4.5 HVAC Improvements

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>HVAC System Improvements</b>		<b>0</b>	<b>0.0</b>	<b>3</b>	<b>\$29</b>	<b>\$173</b>	<b>\$120</b>	<b>\$53</b>	<b>1.8</b>	<b>351</b>
ECM 7	Install Pipe Insulation	0	0.0	3	\$29	\$173	\$120	\$53	1.8	351

### **ECM 7: Install Pipe Insulation**

Install insulation on domestic hot water system piping. Distribution system losses are dependent on system fluid temperature, the size of the distribution system, and the level of insulation of the piping. Significant energy savings can be achieved when insulation has not been well maintained. When the insulation is exposed to water, when the insulation has been removed from some areas of the pipe, or when valves have not been properly insulated system efficiency can be significantly reduced. This measure saves energy by reducing heat transfer in the distribution system.

**Affected Systems:** domestic hot water piping.

## 4.6 Domestic Water Heating

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Domestic Water Heating Upgrade</b>		<b>0</b>	<b>0.0</b>	<b>1</b>	<b>\$9</b>	<b>\$14</b>	<b>\$14</b>	<b>\$0</b>	<b>0.0</b>	<b>111</b>
ECM 8	Install Low-Flow DHW Devices	0	0.0	1	\$9	\$14	\$14	\$0	0.0	111

### **ECM 8: Install Low-Flow DHW Devices**

Install low-flow devices to reduce overall hot water demand. The following low flow devices are recommended to reduce hot water usage:

Device	Flow Rate
Faucet aerators (lavatory)	0.5 gpm
Faucet aerator (kitchen)	1.5 gpm
Showerhead	2.0 gpm
Pre-rinse spray valve (kitchen)	1.28 gpm

Low-flow devices reduce the overall water flow from the fixture, while still providing adequate pressure for washing.

Additional cost savings may result from reduced water usage.

## 4.7 Custom Measures

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Custom Measures</b>		<b>0</b>	<b>0.0</b>	<b>146</b>	<b>\$1,406</b>	<b>\$36,902</b>	<b>\$0</b>	<b>\$36,902</b>	<b>26.2</b>	<b>17,095</b>
ECM 9	Building Envelope Improvements	0	0.0	146	\$1,406	\$36,902	\$0	\$36,902	26.2	17,095

### **ECM 9: Building Envelope Improvements**

Heat flows from warmer to cooler areas until there is no longer a temperature difference. In your building, this means that in winter, heat flows directly from all heated spaces to adjacent unheated attics, garages, basements, and to the outdoors. Heat flow can also move indirectly through interior ceilings, walls, and floors--wherever there is a difference in temperature. During the cooling season, heat flows from the outdoors to the interior of a house.

To maintain comfort, the heat lost in the winter must be replaced by your heating system and the heat gained in the summer must be removed by your cooling system. Properly insulating your facility will decrease this heat flow by providing an effective resistance to the flow of heat.

An insulating material's resistance to conductive heat flow is measured or rated in terms of its thermal resistance or R-value -- the higher the R-value, the greater the insulating effectiveness. The R-value depends on the type of insulation, its thickness, and its density. Installing more insulation increases the R-value and the resistance to heat flow. In general, increased insulation thickness will proportionally increase the R-value.

For more information: <https://www.energy.gov/energysaver/weatherize/insulation>.

#### *Install Exterior Wall Insulation*

We recommend the installation of rigid board wall insulation on all the building exposed surfaces to reduce heat loss through walls.

Foam board or rigid foam insulation made from polystyrene or similar materials can be added to the building exterior. The material provides high insulating value for relatively little thickness but must be properly weatherproofed.

## 5 ENERGY EFFICIENT BEST PRACTICES

---

A whole building maintenance plan will extend equipment life; improve occupant comfort, health, and safety; and reduce energy and maintenance costs.

Operation and maintenance (O&M) plans enhance the operational efficiency of HVAC and other energy intensive systems and could save between 5 to 20 percent of the energy usage in your building without substantial capital investment. A successful plan includes your records of energy usage trends and costs, building equipment lists, current maintenance practices, planned capital upgrades, and incorporates your ideas for improved building operation. Your plan will address goals for energy-efficient operation, provide detail on how to reach the goals, and will outline procedures for measuring and reporting whether goals have been achieved.

You may already be doing some of these things— see our list below for potential additions to your maintenance plan. Be sure to consult with qualified equipment specialists for details on proper maintenance and system operation.

### **Energy Tracking with ENERGY STAR® Portfolio Manager®**



You've heard it before - you can't manage what you don't measure. ENERGY STAR® Portfolio Manager® is an online tool that you can use to measure and track energy and water consumption, as well as greenhouse gas emissions<sup>5</sup>. Your account has already been established. Now you can continue to keep tabs on your energy performance every month.

### **Weatherization**

Caulk or weather strip leaky doors and windows to reduce drafts and loss of heated or cooled air. Sealing cracks and openings can reduce heating and cooling costs, improve building durability, and create a healthier indoor environment. Materials used may include caulk, polyurethane foam, and other weather-stripping materials. There is an energy savings opportunity by reducing the uncontrolled air exchange between the outside and inside of the building. Blower door assisted comprehensive building air sealing will reduce the amount of air exchange which will in turn reduce the load on the buildings heating and cooling equipment and thus providing energy savings and increased occupant comfort.

### **Doors and Windows**

Close exterior doors and windows in heated and cooled areas. Leaving doors and windows open leads to a loss of heat during the winter and chilled air during the summer. Reducing air changes per hour (ACH) can lead to increased occupant comfort as well as heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

---

<sup>5</sup> <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/use-portfolio-manager>.

## **Lighting Maintenance**



- Clean lamps, reflectors and lenses of dirt, dust, oil, and smoke buildup every six to twelve months. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust. Together, this can reduce total light output by up to 60% while still drawing full power.
- In addition to routine cleaning, developing a maintenance schedule can ensure that maintenance is performed regularly, and it can reduce the overall cost of fixture re-lamping and re-ballasting. Group re-lamping and re-ballasting maintains lighting levels and minimizes the number of site visits by a lighting technician or contractor, decreasing the overall cost of maintenance.

## **HVAC Filter Cleaning and Replacement**

Air filters should be checked regularly (often monthly) and cleaned or replaced when appropriate. Air filters reduce indoor air pollution, increase occupant comfort, and help keep equipment operating efficiently. If the building has a building management system, consider installing a differential pressure switch across filters to send an alarm about premature fouling or overdue filter replacement. Over time, filters become less and less effective as particulate buildup increases. Dirty filters also restrict air flow through the air conditioning or heat pump system, which increases the load on the distribution fans.

## **Furnace Maintenance**

Preventative maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. Following the manufacturer's instructions, a yearly tune-up should: check for gas / carbon monoxide leaks; change the air and fuel filters; check components for cracks, corrosion, dirt, or debris build-up; ensure the ignition system is working properly; test and adjust operation and safety controls; inspect electrical connections; and lubricate motors and bearings.

## **Label HVAC Equipment**

For improved coordination in maintenance practices, we recommend labeling or re-labeling the site HVAC equipment. Maintain continuity in labeling by following labeling conventions as indicated in the facility drawings or EMS building equipment list. Use weatherproof or heatproof labeling or stickers for permanence, but do not cover over original equipment nameplates, which should be kept clean and readable whenever possible. Besides equipment, label piping for service and direction of flow when possible. Ideally, maintain a log of HVAC equipment, including nameplate information, asset tag designation, areas served, installation year, service dates, and other pertinent information.

This investment in your equipment will enhance collaboration and communication between your staff and your contracted service providers and may help you with regulatory compliance.

## **Optimize HVAC Equipment Schedules**

Energy Management Systems (EMS) typically provide advanced controls for building HVAC systems, including chillers, boilers, air handling units, rooftop units and exhaust fans. The EMS monitors and reports operational status, schedules equipment 'start' and 'stop' times, locks out equipment operation based on outside air or space temperature, and often optimizes damper and valve operation based on complex algorithms. These EMS features, when in proper adjustment, can improve comfort for building occupants and save substantial energy.

Know your EMS scheduling capabilities. Regularly monitor HVAC equipment operating schedules and match them to building operating hours in order to eliminate unnecessary equipment operation and save energy. Monitoring should be performed often at sites with frequently changing usage patterns – daily in some cases. We recommend using the 'Optimal Start' feature of the EMS, if available, to optimize the building warmup sequence. Most EMS scheduling programs provide for "Holiday" schedules which can be used during reduced use or shutdown periods. Finally, many systems are equipped with a one-time override function which can be used to provide additional space conditioning due to a one-time, special event. When available this override feature should be used rather than changing the base operating schedule.

## **Water Heater Maintenance**

The lower the supply water temperature that is used for hand washing sinks, the less energy is needed to heat the water. Reducing the temperature results in energy savings and the change is often unnoticeable to users. Be sure to review the domestic water temperature requirements for sterilizers and dishwashers as you investigate reducing the supply water temperature.

Also, preventative maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. At least once a year, follow manufacturer instructions to drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Annual checks should include checks for:

- Leaks or heavy corrosion on the pipes and valves.
- Corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot, or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional.
- For electric water heaters, look for signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank.
- For water heaters more than three years old, have a technician inspect the sacrificial anode annually.

## **Water Conservation**



Installing dual flush or low-flow toilets and low-flow/waterless urinals are ways to reduce water use. The EPA WaterSense® ratings for urinals is 0.5 gallons per flush (gpf) and for flush valve toilets is 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

For more information regarding water conservation go to the EPA's WaterSense® website<sup>6</sup> or download a copy of EPA's "WaterSense® at Work: Best Management Practices for Commercial and Institutional Facilities"<sup>7</sup> to get ideas for creating a water management plan and best practices for a wide range of water using systems.

Water conservation devices that do not reduce hot water consumption will not provide energy savings at the site level, but they may significantly affect your water and sewer usage costs. Any reduction in water use does however ultimately reduce grid-level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users.

If the facility has detached buildings with a master water meter for the entire campus, check for unnatural wet areas in the lawn or water seeping in the foundation at water pipe penetrations through the foundation. Periodically check overnight meter readings when the facility is unoccupied, and there is no other scheduled water usage.

Manage irrigation systems to use water more effectively outside the building. Adjust spray patterns so that water lands on intended lawns and plantings and not on pavement and walls. Consider installing an evapotranspiration irrigation controller that will prevent over-watering.

## **Procurement Strategies**

Purchasing efficient products reduces energy costs without compromising quality. Consider modifying your procurement policies and language to require ENERGY STAR® or WaterSense® products where available.

---

<sup>6</sup> <https://www.epa.gov/watersense>.

<sup>7</sup> <https://www.epa.gov/watersense/watersense-work-0>.



## 6 ON-SITE GENERATION

---

You don't have to look far in New Jersey to see one of the thousands of solar electric systems providing clean power to homes, businesses, schools, and government buildings. On-site generation includes both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) technologies that generate power to meet all or a portion of the facility's electric energy needs. Also referred to as distributed generation, these systems contribute to greenhouse gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, which results in improved electric grid reliability through better use of transmission and distribution systems.

Preliminary screenings were performed to determine if an on-site generation measure could be a cost-effective solution for your facility. Before deciding to install an on-site generation system, we recommend conducting a feasibility study to analyze existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.

## 6.1 Solar Photovoltaic

Photovoltaic (PV) panels convert sunlight into electricity. Individual panels are combined into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is then connected to the building's electrical distribution system.

A preliminary screening based on the facility's electric demand, size and location of free area, and shading elements shows that the facility has no potential for installing a PV array.

This facility does not appear to meet the minimum criteria for a cost-effective solar PV installation. To be cost-effective, a solar PV array needs certain minimum criteria, such as sufficient and sustained electric demand and sufficient flat or south-facing rooftop or other unshaded space on which to place the PV panels.

The graphic below displays the results of the PV potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.




Figure 8 - Photovoltaic Screening

### Transition Incentive (TI) Program

The TI program is a bridge between the Legacy SREC Program and a to-be determined Successor Incentive Program. The program is used to register the intent to install solar projects in New Jersey. Rebates are not available for solar projects, but owners of solar projects *must* register their projects prior to the start of construction to establish the project's eligibility to earn TRECs (Transition Incentive Renewable Energy Certificates). The Transition Incentive is structured as a factorized renewable energy certificate. The factors allow the TI Program to provide differentiated financial incentives for different types of solar installation.

Get more information about solar power in New Jersey or find a qualified solar installer who can help you decide if solar is right for your building:

**Transition Incentive (TI) Program:** <https://www.njcleanenergy.com/renewable-energy/programs/transition-incentive-program>

- **Basic Info on Solar PV in NJ:** [www.njcleanenergy.com/whysolar](http://www.njcleanenergy.com/whysolar).
- **NJ Solar Market FAQs:** [www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs](http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs).
- **Approved Solar Installers in the NJ Market:** [www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved\\_vendorsearch/?id=60&start=1](http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1).

## 6.2 Combined Heat and Power

Combined heat and power (CHP) generates electricity at the facility and puts waste heat energy to good use. Common types of CHP systems are reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines.

CHP systems typically produce a portion of the electric power used on-site, with the balance of electric power needs supplied by the local utility company. The heat is used to supplement (or replace) existing boilers and provide space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for space cooling.

The key criteria used for screening is the amount of time that the CHP system would operate at full load and the facility's ability to use the recovered heat. Facilities with a continuous need for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has no potential for installing a cost-effective CHP system.

Based on a preliminary analysis, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation. The lack of gas service, low or infrequent thermal load, and lack of space for siting the equipment are the most significant factors contributing to the lack of CHP potential.

The graphic below displays the results of the CHP potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.




Figure 9 - Combined Heat and Power Screening

Find a qualified firm that specializes in commercial CHP cost assessment and installation: [http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved\\_vendorsearch/](http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/).

## 7 PROJECT FUNDING AND INCENTIVES

Ready to improve your building's performance? Your utility provider may be able to help.

### 7.1 Utility Energy Efficiency Programs

The infographic features logos for Atlantic City Electric, Jersey Central Power & Light, PSEG, Rockland Electric Company, Elizabethtown Gas, South Jersey Gas, and New Jersey Natural Gas. Below the logos, it lists program areas to be served by utilities and proposed new programs and features.

**Program areas to be served by the Utilities:**

- Existing Buildings (residential, commercial, industrial, government)
- Efficient Products
  - HVAC
  - Appliance Rebates
  - Appliance Recycling

**Proposed New Programs & Features:**

- Dedicated multi-family program
- More financing options
- Quick home energy check-ups

New utility programs are expected to start rolling out in the spring and summer of 2021. Keep up to date with developments by visiting the [NJCEP website](#).

## 8 NEW JERSEY'S CLEAN ENERGY PROGRAMS

---

New Jersey's Clean Energy Program will continue to offer some energy efficiency programs.



---

**Program areas staying with NJCEP:**

- New Construction (residential, commercial, industrial, government)
- Large Energy Users
- Combined Heat & Power & Fuel Cells
- State Facilities
- Local Government Energy Audits
- Energy Savings Improvement Program
- Solar & Community Solar

## 8.1 Combined Heat and Power

The Combined Heat & Power (CHP) program provides incentives for eligible CHP or waste heat to power (WHP) projects. Eligible CHP or WHP projects must achieve an annual system efficiency of at least 65% (lower heating value, or LHV), based on total energy input and total utilized energy output. Mechanical energy may be included in the efficiency evaluation.

### Incentives

Eligible Technologies	Size (Installed Rated Capacity) <sup>1</sup>	Incentive (\$/kW)	% of Total Cost Cap per Project <sup>3</sup>	\$ Cap per Project <sup>3</sup>
Powered by non-renewable or renewable fuel source <sup>4</sup>	≤500 kW	\$2,000	30-40% <sup>2</sup>	\$2 million
	Gas Internal Combustion Engine	>500 kW - 1 MW		
Gas Combustion Turbine	> 1 MW - 3 MW	\$550	30%	\$3 million
Microturbine	>3 MW	\$350		
Fuel Cells with Heat Recovery				
Waste Heat to Power*	<1 MW	\$1,000	30%	\$2 million
	> 1MW	\$500		\$3 million

\*Waste Heat to Power: Powered by non-renewable fuel source, heat recovery or other mechanical recovery from existing equipment utilizing new electric generation equipment (e.g. steam turbine).

Check the NJCEP website for details on program availability, current incentive levels, and requirements.

### How to Participate

You work with a qualified developer or consulting firm to complete the CHP application. Once the application is approved the project can be installed. Information about the CHP program can be found at [www.njcleanenergy.com/CHP](http://www.njcleanenergy.com/CHP).

## 8.2 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) serves New Jersey's government agencies by financing energy projects. An ESIP is a type of performance contract, whereby school districts, counties, municipalities, housing authorities and other public and state entities enter into contracts to help finance building energy upgrades. Annual payments are lower than the savings projected from the ECMs, ensuring that ESIP projects are cash flow positive for the life of the contract.

ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs described above can also be used to help further reduce the total project cost of eligible measures.

### How to Participate

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an energy services company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is used for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the energy savings plan (ESP) can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Carefully consider all alternatives to develop an approach that best meets your needs. A detailed program descriptions and application can be found at [www.njcleanenergy.com/ESIP](http://www.njcleanenergy.com/ESIP).

*ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you can use NJCEP incentive programs to help further reduce costs when developing the energy savings plan. Refer to the ESIP guidelines at the link above for further information and guidance on next steps.*



### 8.3 Transition Incentive (TI) Program

The TI program is a bridge between the Legacy SREC Program and a to-be determined Successor Incentive Program. The program is used to register the intent to install solar projects in New Jersey. Rebates are not available for solar projects, but owners of solar projects *must* register their projects prior to the start of construction to establish the project’s eligibility to earn TRECs (Transition Incentive Renewable Energy Certificates). The Transition Incentive is structured as a factorized renewable energy certificate. The factors allow the TI Program to provide differentiated financial incentives for different types of solar installations. NJBPU calculates the value of a Transition Renewable Energy Certificate (TREC) by multiplying the base compensation rate (\$152/MWh) by the project’s assigned factor (i.e.  $\$152 \times 0.85 = \$129.20/\text{MWh}$ ). The TREC factors are defined based on the chart below:

Project Type	Factor
Subsection (t): landfill, brownfield, areas of historic fill	1.00
Grid supply (Subsection (r)) rooftop	1.00
Net metered non-residential rooftop and carport	1.00
Community solar	0.85
Grid supply (Subsection (r)) ground mount	0.60
Net metered residential ground mount	0.60
Net metered residential rooftop and carport	0.60
Net metered non-residential ground mount	0.60

After the registration is accepted, construction is complete, and final paperwork has been submitted and is deemed complete, the project is issued a New Jersey certification number, which enables it to generate New Jersey TRECs.

Eligible projects may generate TRECs for 15 years following the commencement of commercial operations (also referred to as the “Transition Incentive Qualification Life”). After 15 years, projects may be eligible for a NJ Class I REC.

TRECs will be used by the identified compliance entities to satisfy a compliance obligation tied to a new Transition Incentive Renewable Portfolio Standard ("TI-RPS"), which will exist in parallel with, and completely separate from, the existing Solar RPS for Legacy SRECs. The TI-RPS is a carve-out of the current Class I RPS requirement. The creation of TRECs is based upon metered generation supplied to PJM-EIS General Attribute Tracking System ("GATS") by the owners of eligible facilities or their agents. GATS would create one TREC for each MWh of energy produced from a qualified facility.

TRECs will be purchased monthly by a TREC Administrator who will allocate the TRECs to the Load Serving Entities (BGS Providers and Third-Party Suppliers) annually based on their market share of retail electricity sold during the relevant Energy Year.

Solar projects help the State of New Jersey reach renewable energy goals outlined in the state’s Energy Master Plan. The Transition Incentive Program online portal is now open to new applications effective May 1, 2020. There are instructions on “How and When to Transfer my SRP Registration to the Transition Incentive Program”. If you are considering installing solar photovoltaics on your building, visit the following link for more information:

<https://www.njcleanenergy.com/renewable-energy/programs/transition-incentive-program>

## 9 PROJECT DEVELOPMENT

Energy conservation measures (ECMs) have been identified for your site and their energy and economic analyses are provided within this LGEA report. The next steps with project development are to set goals and create a comprehensive project plan. The graphic below provides an overview of the process flow for a typical energy efficiency or renewable energy project. We recommend implementing as many ECMs as possible prior to undertaking a feasibility study for a renewable project. The cyclical nature of this process flow demonstrates the ongoing work required to continually improve building energy efficiency over time. If your building(s) scope of work is relatively simple to implement or small in scope, the measurement and verification (M&V) step may not be required. It should be noted through a typical project cycle, there will be changes in costs based on specific scopes of work, contractor selections, design considerations, construction, etc. The estimated costs provided throughout this LGEA report demonstrate the unburdened turn-key material and labor cost only. There will be contingencies and additional costs at the time of implementation. We recommend comprehensive project planning includes the review of multiple bids for project work, incorporate potential operational & maintenance (O&M) cost savings and maximize your incentive potential.




Figure 3 – Project Development Cycle

## 10 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

---

### 10.1 Retail Electric Supply Options

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third-party supplier, consider shopping for a reduced rate from third-party electric suppliers. If your facility already buys electricity from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party electric suppliers is available at the NJBPU website<sup>8</sup>.

### 10.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey is also deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate monthly. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third-party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier typically depends on whether a customer prefers budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third-party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility does not already purchase natural gas from a third-party supplier, consider shopping for a reduced rate from third-party natural gas suppliers. If your facility already purchases natural gas from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party natural gas suppliers is available at the NJBPU website<sup>9</sup>.

---

<sup>8</sup> [www.state.nj.us/bpu/commercial/shopping.html](http://www.state.nj.us/bpu/commercial/shopping.html).

<sup>9</sup> [www.state.nj.us/bpu/commercial/shopping.html](http://www.state.nj.us/bpu/commercial/shopping.html).

# APPENDIX A: EQUIPMENT INVENTORY & RECOMMENDATIONS

## Lighting Inventory & Recommendations

Location	Existing Conditions						Proposed Conditions							Energy Impact & Financial Analysis							
	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Exterior 1	5	Metal Halide: (1) 250W Lamp	Photocell		295	4,380		Already retrofit	No		Photocell		4,380								
Garage 1	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Garage 1	8	Metal Halide: (1) 400W Lamp	Wall Switch	S	458	4,243	4	Already retrofit	Yes	8		High/Low Control	458	2,928	0.7	4,820	-1	\$635	\$225	\$225	0.0
Garage 1	1	Linear Fluorescent - T12: 8' T12 (75W) - 1L	Wall Switch	S	92	4,243	1	Relamp & Reballast	No	1	LED - Linear Tubes: (1) 8' Lamp	Wall Switch	36	4,243	0.0	238	0	\$31	\$84	\$10	2.4
Garage 1	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	4,243	2, 3	Relamp	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	2,928	0.1	628	0	\$83	\$262	\$60	2.4
Garage 2	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Garage 2	10	Metal Halide: (1) 400W Lamp	Wall Switch	S	458	4,243	4	Already retrofit	Yes	10		High/Low Control	458	2,928	0.9	6,024	-1	\$794	\$225	\$225	0.0
Garage 2	12	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,243	2, 3	Relamp	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,928	0.3	2,138	0	\$282	\$708	\$155	2.0
Garage 2	14	Metal Halide: (1) 400W Lamp	Wall Switch	S	458	4,243	2, 4	Relamp	Yes	14	LED Lamps - E39: ≤125 W Lamp	High/Low Control	120	2,928	3.5	22,289	-5	\$2,938	\$4,416	\$225	1.4
Office - Enclosed 2	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Office - Enclosed 2	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	4,243	3	Already retrofit	Yes	2		Occupancy Sensor	114	2,928	0.0	300	0	\$40	\$116	\$20	2.4
Office - Enclosed 3	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	4,243	3	Already retrofit	Yes	2		Occupancy Sensor	114	2,928	0.0	300	0	\$40	\$116	\$20	2.4
Office - Open Plan 1	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Office - Open Plan 1	8	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	4,243	3	Already retrofit	Yes	8		Occupancy Sensor	114	2,928	0.2	1,200	0	\$158	\$270	\$35	1.5
Restroom - Female 1	1	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	4,243		Already retrofit	No			Wall Switch		4,243							
Restroom - Female 1	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	4,243	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	4,243	0.0	140	0	\$18	\$37	\$10	1.4
Restroom - Male 1	1	Compact Fluorescent: (1) 23W Spiral Plug-In Lamp	Wall Switch	S	23	500	2	Relamp	No	1	LED Lamps: A LAMP	Wall Switch	10	500	0.0	7	0	\$1	\$17	\$1	18.9
Restroom - Male 1	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Restroom - Male 1	4	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	4,243	3	Already retrofit	Yes	4		Occupancy Sensor	114	2,928	0.1	600	0	\$79	\$270	\$35	3.0

**Motor Inventory & Recommendations**

Location	Area(s)/System(s) Served	Existing Conditions									Proposed Conditions					Energy Impact & Financial Analysis						
		Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Manufacturer	Model	Remaining Useful Life	Annual Operating Hours	ECM #	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Garage 2	Garage 2	6	Other	0.5	65.0%	No	Unknown	Unknown	W	2,745		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Garage 2	Garage 2	4	Fan Coil Unit	0.3	65.0%	No	Unknown	Unknown	W	3,500		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Garage 2	Garage 2	2	Exhaust Fan	0.1	60.0%	No	Unknown	Unknown	W	3,500		No	60.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Garage 1	Garage 1	3	Fan Coil Unit	0.3	65.0%	No	Unknown	Unknown	W	2,745		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Exterior 1	Fuel pump	2	Other	1.0	80.0%	No	Unknown	Unknown	W	2,745		No	80.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Garage 1	Garage 1	2	Ventilation Fan	1.0	80.0%	No	Unknown	Unknown	W	400		No	80.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Garage	Garage	1	Air Compressor	2.0	86.0%	No	Unknown	Unknown	W	1,200		No	86.0%	No		0.0	0	0	\$0	\$0	\$0	0.0

**Packaged HVAC Inventory & Recommendations**

Location	Area(s)/System(s) Served	Existing Conditions									Proposed Conditions								Energy Impact & Financial Analysis						
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (MBh)	Cooling Mode Efficiency (SEER/IEER/EER)	Heating Mode Efficiency	Manufacturer	Model	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (MBh)	Cooling Mode Efficiency (SEER/IEER/EER)	Heating Mode Efficiency	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Garage 1	Garage 1	3	Forced Air Furnace		160.00		0.8 AFUE	Modine	Unknown	W	6	Yes	3	Forced Air Furnace		160.00		0.97 AFUE	0.0	0	98	\$942	\$19,248	\$3,000	17.3
Exterior 1	Office	1	Ductless Mini-Split AC	2.00		10.00		Fujitsu	AOU24C1	B	5	Yes	1	Ductless Mini-Split AC	2.00		18.00		0.5	960	0	\$129	\$5,642	\$0	43.8
Garage 2	Garage 2	2	Forced Air Furnace		320.00		0.8 AFUE	Dayton	Unknown	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Garage 1	Office	1	Split-System	2.50	80.00	11.00	0.8 AFUE	York	CF30BXA1A	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Restroom - Male 1	Restroom - Male 1	1	Electric Resistance Heat		12.60		1 COP	Qmark	MUH0521	W		No							0.0	0	0	\$0	\$0	\$0	0.0

**Pipe Insulation Recommendations**

Location	Area(s)/System(s) Affected	Recommendation Inputs			Energy Impact & Financial Analysis						
		ECM #	Length of Uninsulated Pipe (ft)	Pipe Diameter (in)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Restroom	Restroom	7	30	0.75	0.0	0	3	\$29	\$173	\$120	1.8

**DHW Inventory & Recommendations**

Location	Area(s)/System(s) Served	Existing Conditions					Proposed Conditions						Energy Impact & Financial Analysis						
		System Quantity	System Type	Manufacturer	Model	Remaining Useful Life	ECM #	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives
Restroom 1	Restrooms	1	Storage Tank Water Heater (≤ 50 Gal)	Bradford White	RG240SGN	W		No					0.0	0	0	\$0	\$0	\$0	0.0

**Low-Flow Device Recommendations**

Location	Recommendation Inputs				Energy Impact & Financial Analysis							
	ECM #	Device Quantity	Device Type	Existing Flow Rate (gpm)	Proposed Flow Rate (gpm)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Sanitation Division	8	2	Faucet Aerator (Lavatory)	2.20	0.50	0.0	0	1	\$9	\$14	\$14	0.0

**Plug Load Inventory**

Existing Conditions						
Location	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified ?	Manufacturer	Model
Sanitation Division	1	Coffee machine	900	No	Cooks	Unknown
Sanitation Division	4	Desktop	270	No	Lenova	Unknown
Sanitation Division	1	Electric space heater	800	No	Unknown	Unknown
Sanitation Division	2	Portable fan	200	No	Unknown	Unknown
Sanitation Division	1	Microwave	1,000	No	Unknown	Unknown
Sanitation Division	1	Paper shredder	100	No	Unknown	Unknown
Sanitation Division	2	Printer	600	Yes	Brother	Unknown
Sanitation Division	1	Copier	1,000	Yes	Xerox	Unknown
Sanitation Division	2	Residential refrigerator	152	Yes	Unknown	Unknown
Sanitation Division	1	Toaster	1,000	No	Unknown	Unknown
Sanitation Division	1	Water cooler	90	No	Unknown	Unknown
Sanitation Division	2	Electric Purifiers	1,000	No	Unknown	Unknown
Sanitation Division	6	Various Tools Plug Load	900	No	Unknown	Unknown
Sanitation Division	1	Lift	2,000	No	Unknown	Unknown

**Custom (High Level) Measure Analysis**

Building Envelope Improvements

Existing Conditions			Proposed Conditions			Energy Impact & Financial Analysis										
Description	Conduction Loss (kBtu/yr)	Infiltration Loss (kBtu/yr)	Description	Conduction Loss (kBtu/yr)	Infiltration Loss (kBtu/yr)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&I Cost (\$)	Base Incentives	Enhanced Incentives	Total Incentives	Total Net Cost	Payback w/o Incentives in Years	Payback w/ Incentives in Years
Existing Building Envelope with Opportunities for Improvement	498,166	746,117	Install Exterior Wall Insulation	363,691	746,117	0.00	0	146	\$1,406	\$36,902	\$0	\$0	\$0	\$36,902	26.25	26.25

# APPENDIX B: ENERGY STAR® STATEMENT OF ENERGY PERFORMANCE

EUI is presented in terms of *site energy* and *source energy*. Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

## ENERGY STAR® Statement of Energy Performance

LEARN MORE AT [energystar.gov](http://energystar.gov)

N/A

### Trenton Sanitation Division

**Primary Property Type:** Other - Public Services  
**Gross Floor Area (ft²):** 23,328  
**Built:** 1912

**For Year Ending:** February 29, 2020  
**Date Generated:** February 08, 2021

**ENERGY STAR®**  
Score<sup>1</sup>

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information		
<b>Property Address</b> Trenton Sanitation Division 707 Calhoun Street Trenton, New Jersey 08638	<b>Property Owner</b> City of Trenton 319 East State Street Trenton, NJ 08618 (609) 989-3615	<b>Primary Contact</b> Hoggarth Stephen 319 East State Street Trenton, NJ 08618 (609) 989-3615 hstephen@trentonnj.org
<b>Property ID:</b> 14444484		

Energy Consumption and Energy Use Intensity (EUI)			
<b>Site EUI</b> 80.2 kBtu/ft²	<b>Annual Energy by Fuel</b>		<b>National Median Comparison</b>
	Natural Gas (kBtu)	1,445,533 (77%)	National Median Site EUI (kBtu/ft²) 61.6
	Electric - Grid (kBtu)	425,804 (23%)	National Median Source EUI (kBtu/ft²) 89.3
			% Diff from National Median Source EUI 30%
<b>Source EUI</b> 116.2 kBtu/ft²			<b>Annual Emissions</b>
			Greenhouse Gas Emissions (Metric Tons CO2e/year) 118

### Signature & Stamp of Verifying Professional

I \_\_\_\_\_ (Name) verify that the above information is true and correct to the best of my knowledge.

LP Signature: \_\_\_\_\_ Date: \_\_\_\_\_

**Licensed Professional**

\_\_\_\_\_  
( ) - \_\_\_\_\_  
\_\_\_\_\_



Professional Engineer or Registered Architect Stamp (if applicable)



## APPENDIX C: GLOSSARY

TERM	DEFINITION
<b>Blended Rate</b>	Used to calculate fiscal savings associated with measures. The blended rate is calculated by dividing the amount of your bill by the total energy use. For example, if your bill is \$22,217.22, and you used 266,400 kilowatt-hours, your blended rate is 8.3 cents per kilowatt-hour.
<b>Btu</b>	<i>British thermal unit</i> : a unit of energy equal to the amount of heat required to increase the temperature of one pound of water by one-degree Fahrenheit.
<b>CHP</b>	<i>Combined heat and power</i> . Also referred to as cogeneration.
<b>COP</b>	<i>Coefficient of performance</i> : a measure of efficiency in terms of useful energy delivered divided by total energy input.
<b>Demand Response</b>	Demand response reduces or shifts electricity usage at or among participating buildings/sites during peak energy use periods in response to time-based rates or other forms of financial incentives.
<b>DCV</b>	<i>Demand control ventilation</i> : a control strategy to limit the amount of outside air introduced to the conditioned space based on actual occupancy need.
<b>US DOE</b>	<i>United States Department of Energy</i>
<b>EC Motor</b>	<i>Electronically commutated motor</i>
<b>ECM</b>	<i>Energy conservation measure</i>
<b>EER</b>	<i>Energy efficiency ratio</i> : a measure of efficiency in terms of cooling energy provided divided by electric input.
<b>EUI</b>	<i>Energy Use Intensity</i> : measures energy consumption per square foot and is a standard metric for comparing buildings' energy performance.
<b>Energy Efficiency</b>	Reducing the amount of energy necessary to provide comfort and service to a building/area. Achieved through the installation of new equipment and/or optimizing the operation of energy use systems. Unlike conservation, which involves some reduction of service, energy efficiency provides energy reductions without sacrifice of service.
<b>ENERGY STAR®</b>	ENERGY STAR® is the government-backed symbol for energy efficiency. The ENERGY STAR® program is managed by the EPA.
<b>EPA</b>	<i>United States Environmental Protection Agency</i>
<b>Generation</b>	The process of generating electric power from sources of primary energy (e.g., natural gas, the sun, oil).
<b>GHG</b>	<i>Greenhouse gas</i> gases that are transparent to solar (short-wave) radiation but opaque to long-wave (infrared) radiation, thus preventing long-wave radiant energy from leaving Earth's atmosphere. The net effect is a trapping of absorbed radiation and a tendency to warm the planet's surface.
<b>gpf</b>	<i>Gallons per flush</i>

<b>gpm</b>	<i>Gallon per minute</i>
<b>HID</b>	<i>High intensity discharge</i> : high-output lighting lamps such as high-pressure sodium, metal halide, and mercury vapor.
<b>hp</b>	<i>Horsepower</i>
<b>HPS</b>	<i>High-pressure sodium</i> : a type of HID lamp
<b>HSPF</b>	<i>Heating seasonal performance factor</i> : a measure of efficiency typically applied to heat pumps. Heating energy provided divided by seasonal energy input.
<b>HVAC</b>	<i>Heating, ventilating, and air conditioning</i>
<b>IHP 2014</b>	US DOE Integral Horsepower rule. The current ruling regarding required electric motor efficiency.
<b>IPLV</b>	<i>Integrated part load value</i> : a measure of the part load efficiency usually applied to chillers.
<b>kBtu</b>	One thousand British thermal units
<b>kW</b>	<i>Kilowatt</i> : equal to 1,000 Watts.
<b>kWh</b>	<i>Kilowatt-hour</i> : 1,000 Watts of power expended over one hour.
<b>LED</b>	<i>Light emitting diode</i> : a high-efficiency source of light with a long lamp life.
<b>LGEA</b>	<i>Local Government Energy Audit</i>
<b>Load</b>	The total power a building or system is using at any given time.
<b>Measure</b>	A single activity, or installation of a single type of equipment, that is implemented in a building system to reduce total energy consumption.
<b>MH</b>	<i>Metal halide</i> : a type of HID lamp
<b>MBh</b>	<i>Thousand Btu per hour</i>
<b>MBtu</b>	<i>One thousand British thermal units</i>
<b>MMBtu</b>	<i>One million British thermal units</i>
<b>MV</b>	<i>Mercury Vapor</i> : a type of HID lamp
<b>NJBPU</b>	<i>New Jersey Board of Public Utilities</i>
<b>NJCEP</b>	<i>New Jersey's Clean Energy Program</i> : NJCEP is a statewide program that offers financial incentives, programs and services for New Jersey residents, business owners and local governments to help them save energy, money and the environment.
<b>psig</b>	Pounds per square inch gauge
<b>Plug Load</b>	Refers to the amount of power used in a space by products that are powered by means of an ordinary AC plug.
<b>PV</b>	<i>Photovoltaic</i> : refers to an electronic device capable of converting incident light directly into electricity (direct current).

<b>SEER</b>	<i>Seasonal energy efficiency ratio</i> : a measure of efficiency in terms of annual cooling energy provided divided by total electric input.
<b>SEP</b>	<i>Statement of energy performance</i> : a summary document from the ENERGY STAR® Portfolio Manager®.
<b>Simple Payback</b>	The amount of time needed to recoup the funds expended in an investment or to reach the break-even point between investment and savings.
<b>SREC</b>	<i>Solar renewable energy credit</i> : a credit you can earn from the state for energy produced from a photovoltaic array.
<b>TREC</b>	<i>Transition Incentive Renewable Energy Certificate</i> : a factorized renewable energy certificate you can earn from the state for energy produced from a photovoltaic array.
<b>T5, T8, T12</b>	A reference to a linear lamp diameter. The number represents increments of 1/8 <sup>th</sup> of an inch.
<b>Temperature Setpoint</b>	The temperature at which a temperature regulating device (thermostat, for example) has been set.
<b>therm</b>	100,000 Btu. Typically used as a measure of natural gas consumption.
<b>tons</b>	A unit of cooling capacity equal to 12,000 Btu/hr.
<b>Turnkey</b>	Provision of a complete product or service that is ready for immediate use
<b>VAV</b>	<i>Variable air volume</i>
<b>VFD</b>	<i>Variable frequency drive</i> : a controller used to vary the speed of an electric motor.
<b>WaterSense®</b>	The symbol for water efficiency. The WaterSense® program is managed by the EPA.
<b>Watt (W)</b>	Unit of power commonly used to measure electricity use.