



Local Government Energy Audit Report

Police Headquarters

January 20, 2022

Prepared for:

Township of Morris

49 Woodland Ave

Morris Township, NJ 07960

Prepared by:

TRC

317 George Street

New Brunswick, NJ 08901

Disclaimer

The goal of this audit report is to identify potential energy efficiency opportunities and help prioritize specific measures for implementation. Most energy conservation measures have received preliminary analysis of feasibility that identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to establish a basis for further discussion and to help prioritize energy measures.

TRC reviewed the energy conservation measures and estimates of energy savings for technical accuracy. Actual, achieved energy savings depend on behavioral factors and other uncontrollable variables and, therefore, estimates of final energy savings are not guaranteed. TRC and the New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

TRC bases estimated material and labor costs primarily on RS Means cost manuals as well as on our experience at similar facilities. This approach is based on standard cost estimating manuals and is vendor neutral. Cost estimates include material and labor pricing associated with one for one equipment replacements. Cost estimates do not include demolition or removal of hazardous waste. The actual implementation costs for energy savings projects are anticipated to be significantly higher based on the specific conditions at your site(s). We strongly recommend that you work with your design engineer or contractor to develop actual project costs for your specific scope of work for the installation of high efficiency equipment. We encourage you to obtain multiple estimates when considering measure installations. Actual installation costs can vary widely based on selected products and installers. TRC and NJBPU do not guarantee cost estimates and shall in no event be held liable should actual installed costs vary from these material and labor estimates.

Incentive values provided in this report are estimated based of previously run state efficiency programs. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. Please review all available utility program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

The customer and their respective contractor(s) are responsible to implement energy conservation measures in complete conformance with all applicable local, state, and federal requirements.

Copyright ©2022 TRC. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Table of Contents

1	Executive Summary	1
1.1	Planning Your Project	4
	Pick Your Installation Approach	4
	Options from Around the State	5
2	Existing Conditions	6
2.1	Site Overview.....	6
2.2	Building Occupancy	6
2.3	Building Envelope	6
2.4	Lighting Systems	7
2.5	Air Handling Systems	8
	Unitary Heating Equipment	8
	Air Handling Units (AHUs).....	8
2.6	Heating Hot Water Systems.....	9
2.7	Domestic Hot Water	9
2.8	Plug Load & Vending Machines	10
2.9	Water-Using Systems	10
3	Energy Use and Costs	11
3.1	Electricity	13
3.2	Natural Gas.....	14
3.3	Benchmarking.....	15
	Tracking Your Energy Performance.....	16
4	Energy Conservation Measures	17
4.1	Lighting.....	20
	ECM 1: Retrofit Fluorescent Fixtures with LED Lamps and Drivers	20
	ECM 2: Retrofit Fixtures with LED Lamps	20
4.2	Lighting Controls.....	21
	ECM 3: Install Occupancy Sensor Lighting Controls.....	21
	ECM 4: Install High/Low Lighting Controls	22
4.3	Variable Frequency Drives (VFD)	22
	ECM 5: Install VFDs on Constant Volume (CV) Fans.....	22
	ECM 6: Install VFDs on Heating Water Pumps.....	23
4.4	HVAC Improvements	23
	ECM 7: Install Pipe Insulation	23
4.5	Domestic Water Heating	24
	ECM 8: Install Low-Flow DHW Devices.....	24
4.6	Custom Measures.....	24
	ECM 9: Install Heat Pump Water Heater.....	24

5	Energy Efficient Best Practices	25
	Energy Tracking with ENERGY STAR® Portfolio Manager®.....	25
	Weatherization.....	25
	Doors and Windows	25
	Window Treatments/Coverings.....	26
	Lighting Maintenance.....	26
	Lighting Controls	26
	Motor Maintenance	26
	Fans to Reduce Cooling Load	26
	AC System Evaporator/Condenser Coil Cleaning.....	26
	HVAC Filter Cleaning and Replacement	27
	Ductwork Maintenance	27
	Boiler Maintenance	27
	Water Heater Maintenance.....	28
	Compressed Air System Maintenance	28
	Plug Load Controls.....	29
	Computer Power Management Software	29
	Water Conservation	29
	Procurement Strategies.....	30
6	On-site Generation	31
6.1	Solar Photovoltaic.....	32
6.2	Combined Heat and Power.....	34
7	Project Funding and Incentives	35
7.1	Utility Energy Efficiency Programs.....	35
8	New Jersey's Clean Energy Programs	36
8.1	Large Energy Users	37
8.2	Combined Heat and Power.....	38
8.3	Successor Solar Incentive Program (SuSI).....	39
8.4	Energy Savings Improvement Program.....	40
9	Project Development	41
10	Energy Purchasing and Procurement Strategies	42
10.1	Retail Electric Supply Options.....	42
10.2	Retail Natural Gas Supply Options.....	42
	Appendix A: Equipment Inventory & Recommendations	A-1
	Appendix B: ENERGY STAR® Statement of Energy Performance	B-1
	Appendix C: Glossary	C-1



ENERGY EFFICIENCY INCENTIVE & REBATE TRANSITION

For the purposes of your LGEA, estimated incentives and rebates are included as placeholders for planning purposes. New Jersey utilities are rolling out their own energy efficiency programs, which your project may be eligible for depending on individual measures, quantities, and size of the building.

In 2018, Governor Murphy signed into law the landmark legislation known as the [Clean Energy Act](#). The law called for a significant overhaul of New Jersey's clean energy systems by building sustainable infrastructure in order to fight climate change and reduce carbon emissions, which will in turn create well-paying local jobs, grow the state's economy, and improve public health while ensuring a cleaner environment for current and future residents.


These next generation energy efficiency programs feature new ways of managing and delivering programs historically administered by New Jersey's Clean Energy Program™ (NJCEP). All of the investor-owned gas and electric utility companies will now also offer complementary energy efficiency programs and incentives directly to customers like you. NJCEP will still offer programs for new construction, renewable energy, the Energy Savings Improvement Program (ESIP), and large energy users.

New utility programs are under development. Keep up to date with developments by visiting the [NJCEP website](#).

1 EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) report for Police Headquarters. This report provides you with information about your facility's energy use, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help make changes in your facility. TRC conducted this study as part of a comprehensive effort to assist New Jersey school districts and local governments in controlling their energy costs and to help protect our environment by reducing statewide energy consumption.

BUILDING PERFORMANCE REPORT



ENERGY STAR® Benchmarking Score	N/A <i>(1-100 scale)</i>	A standard energy use benchmark is not available for this facility type. This report contains suggestions about how to improve building performance and reduce energy costs.
---------------------------------	-----------------------------	--




Figure 1 - Energy Use by System


POTENTIAL IMPROVEMENTS



This energy audit considered a range of potential energy improvements in your building. Costs and savings will vary between improvements. Presented below are two potential scopes of work for your consideration.


Scenario 1: Full Package (all evaluated measures)

Installation Cost	\$39,570
Potential Rebates & Incentives ¹	\$4,486
Annual Cost Savings	\$6,865
Annual Energy Savings	Electricity: 60,465 kWh Natural Gas: 87 Therms
Greenhouse Gas Emission Savings	31 Tons
Simple Payback	5.1 Years
Site Energy Savings (all utilities)	15%



Scenario 2: Cost Effective Package²

Installation Cost	\$28,432
Potential Rebates & Incentives	\$4,386
Annual Cost Savings	\$6,567
Annual Energy Savings	Electricity: 57,811 kWh Natural Gas: 87 Therms
Greenhouse Gas Emission Savings	30 Tons
Simple Payback	3.7 Years
Site Energy Savings (all utilities)	14%



On-site Generation Potential

Photovoltaic	None
Combined Heat and Power	None

¹ Incentives are based on previously run state rebate programs. Contact your utility provider for current program incentives that may apply.

² A cost-effective measure is defined as one where the simple payback does not exceed two-thirds of the expected proposed equipment useful life. Simple payback is based on the net measure cost after potential incentives.

#	Energy Conservation Measure	Cost Effective?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades			36,191	8.6	-7	\$4,005	\$4,325	\$2,010	\$2,315	0.6	35,610
ECM 1	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	Yes	28,024	7.0	-6	\$3,097	\$3,200	\$1,600	\$1,600	0.5	27,521
ECM 2	Retrofit Fixtures with LED Lamps	Yes	8,167	1.6	-1	\$908	\$1,125	\$410	\$715	0.8	8,089
Lighting Control Measures			7,593	1.5	-2	\$839	\$5,999	\$1,860	\$4,139	4.9	7,457
ECM 3	Install Occupancy Sensor Lighting Controls	Yes	1,914	0.9	0	\$211	\$3,974	\$535	\$3,439	16.3	1,879
ECM 4	Install High/Low Lighting Controls	Yes	5,680	0.5	-1	\$628	\$2,025	\$1,325	\$700	1.1	5,578
Variable Frequency Drive (VFD) Measures			10,198	2.6	0	\$1,146	\$25,112	\$500	\$24,612	21.5	10,270
ECM 5	Install VFDs on Constant Volume (CV) Fans	Yes	7,544	2.4	0	\$847	\$13,974	\$400	\$13,574	16.0	7,597
ECM 6	Install VFDs on Heating Water Pumps	No	2,654	0.2	0	\$298	\$11,138	\$100	\$11,038	37.0	2,672
HVAC System Improvements			1,312	0.0	10	\$235	\$265	\$92	\$173	0.7	2,524
ECM 7	Install Pipe Insulation	Yes	1,312	0.0	10	\$235	\$265	\$92	\$173	0.7	2,524
Domestic Water Heating Upgrade			278	0.0	7	\$92	\$43	\$24	\$19	0.2	1,123
ECM 8	Install Low-Flow DHW Devices	Yes	278	0.0	7	\$92	\$43	\$24	\$19	0.2	1,123
Custom Measures			4,893	0.0	0	\$549	\$3,827	\$0	\$3,827	7.0	4,927
ECM 9	Install Heat Pump Water Heater	Yes	4,893	0.0	0	\$549	\$3,827	\$0	\$3,827	7.0	4,927
TOTALS (COST EFFECTIVE MEASURES)			57,811	12.4	9	\$6,567	\$28,432	\$4,386	\$24,046	3.7	59,239
TOTALS (ALL MEASURES)			60,465	12.6	9	\$6,865	\$39,570	\$4,486	\$35,084	5.1	61,911

* - All incentives presented in this table are included as placeholders and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 2 – Evaluated Energy Improvements

For more detail on each evaluated energy improvement and a break out of cost-effective improvements, see **Section 4: Energy Conservation Measures**.

1.1 Planning Your Project

Careful planning makes for a successful energy project. When considering this scope of work, you will have some decisions to make, such as:

- ◆ How will the project be funded and/or financed?
- ◆ Is it best to pursue individual ECMs, groups of ECMs, or use a comprehensive approach where all ECMs are installed together?
- ◆ Are there other facility improvements that should happen at the same time?

Pick Your Installation Approach

Utility-run energy efficiency programs, such as New Jersey's Clean Energy Programs, give you the flexibility to do a little or a lot. Rebates, incentives, and financing are available to help reduce both your installation costs and your energy bills. If you are planning to take advantage of these programs, make sure to review incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives *before* purchasing materials or starting installation.

For details on these programs please visit [New Jersey's Clean Energy Program website](#) or contact your utility provider.



Options from Around the State

Financing and Planning Support with the Energy Savings Improvement Program (ESIP)

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the ESIP. Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as attractive financing for implementing ECMs. You have already taken the first step as an LGEA customer, because this report is required to participate in ESIP.

Resiliency with Return on Investment through Combined Heat and Power (CHP)

The CHP program provides incentives for combined heat and power (i.e., cogeneration) and waste heat to power projects. Combined heat and power systems generate power on-site and recover heat from the generation system to meet on-site thermal loads. Waste heat to power systems use waste heat to generate power. You will work with a qualified developer who will design a system that meets your building's heating and cooling needs.

Successor Solar Incentive Program (SuSI)

New Jersey is committed to supporting solar energy. Solar projects help the state reach the renewable goals outlined in the state's Energy Master Plan. The SuSI program is used to register and certify solar projects in New Jersey. Rebates are not available, but certified solar projects are able to earn one SREC II (Solar Renewable Energy Certificates II) for each megawatt-hour of solar electricity produced from a qualifying solar facility.

Ongoing Electric Savings with Demand Response

The Demand Response Energy Aggregator program reduces electric loads at commercial facilities when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. By enabling commercial facilities to reduce electric demand during times of peak demand, the grid is made more reliable, and overall transmission costs are reduced for all ratepayers. Curtailment service providers provide regular payments to medium and large consumers of electric power for their participation in demand response (DR) programs. Program participation is voluntary, and facilities receive payments regardless of whether they are called upon to curtail their load during times of peak demand.

Large Energy User Program (LEUP)

LEUP designed to promote self-investment in energy efficiency and combined heat and power or fuel cell projects. It incentivizes owners/users of buildings to upgrade or install energy conserving measures in existing buildings to help offset the capital costs associated with the project. The efficiency upgrades are customized to meet the requirements of the customers' existing facilities, while advancing the State's energy efficiency, conservation, and greenhouse gas reduction goals.

2 EXISTING CONDITIONS

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) Report for Police Headquarters. This report provides information on how your facility uses energy, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help you implement the ECMs.

TRC conducted this study as part of a comprehensive effort to assist New Jersey educational and local government facilities in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

2.1 Site Overview

On June 29, 2021, TRC performed an energy audit at Police Headquarters located in Morris Township, New Jersey. TRC met with John DeZao to review the facility operations and help focus our investigation on specific energy-using systems.

Police Headquarters is a two-story, 11,109 square foot building built in 1965. Spaces include gymnasium, offices, corridors, stairwells, locker rooms, jail cells, and electrical/mechanical rooms.

2.2 Building Occupancy

The facility is occupied year-round with a typical weekday and weekend occupancy of 50 staff.

Building Name	Weekday/Weekend	Operating Schedule
Police Headquarters	Weekday	24/7
	Weekend	Sat: 24/7 Sun: Closed


Figure 3 - Building Occupancy Schedule

2.3 Building Envelope

The walls are made of concrete masonry units (CMUs) and painted CMU interior finish. Wooden trusses support a pitched roof with asphalt shingles. Roof encloses semi-conditioned space (e.g., a space that is not intentionally heated but escaping heat from HVAC equipment causes the space to be conditioned). Most of the windows are double pane and aluminum frames. The glass-to-frame seals are in good condition. The operable window weather seals are in good condition, showing little evidence of excessive wear. Exterior doors have aluminum frames and are in good condition with worn door seals. Degraded window and door seals increase drafts and outside air infiltration.



Right-Side of the Building



Exterior Door



Window



Left-Side of the Building

2.4 Lighting Systems

The primary interior lighting system uses 40-Watt linear fluorescent T12 lamps. There are also several 32-Watt T8 fixtures. Typically, T8 fluorescent lamps use electronic ballasts and T12 fluorescent lamps use magnetic ballasts. Additionally, there are some incandescent, U-bend fluorescent T8 lamps, and LED general purpose lamps. A few replacement LED fixtures have been installed. All exit signs are LED.

Fixture types include 1-lamp, 2-lamp, or 4-lamp, 2-foot or 4-foot-long troffer, recessed and surface mounted fixtures. Most fixtures are in good condition. Interior lighting levels were generally sufficient. Most lighting fixtures are controlled manually and the remainder by occupancy sensors.



Two-lamp LED Fixture



Fluorescent T12 Fixture



LED 2-foot x 4-foot Panel



LED High Bay

Exterior fixtures include wall packs, flood lights, and decorative outdoor fixture with LED lamps and incandescent lamps. Exterior fixtures are timer and photocell controlled.



Metal Halide Wallpack



*Decorative Outdoor Fixture
with Incandescent*

2.5 Air Handling Systems

Unitary Heating Equipment

The men's locker room is heated by electric resistance heaters, each with a capacity of 5 MBh. These units are in good condition. Equipment is controlled by a programmable Honeywell thermostat.



Electric Resistance Heater



Electric Resistance Heater

Air Handling Units (AHUs)

The building is mainly conditioned by five air handling units arranged in a split air conditioning (AC) system configuration. One unit is equipped with a supply fan motor, a hot water heating coil and a DX coil for cooling. The other four units are each equipped with a supply fan motor and DX coil for cooling and ventilation only. The AHUs are physically located in the mechanical rooms. Supply fans are assumed to be driven by 2 hp constant speed standard efficiency motors.

These systems include outdoor condensing units that have cooling capacities ranging between 1.5 tons and 10 tons with efficiencies that range between 11 EER and 13 EER. All appear in good condition.

One AHU provides heat through hot water heating coils with a rated capacity of 120 MBh. The heating coil is supplied by the hot water boiler which is described in the section that follows.

The HVAC systems are controlled by programmable thermostats.



Outdoor Condensing Units



One of the AHU's

2.6 Heating Hot Water Systems

Two Hydro Therm non-condensing hot water boilers serve most of the building heating load. The first floor is served by a 400 MBh capacity unit and the second floor by a unit with 480 MBh of heating capacity. The burners are non-modulating with a nominal efficiency of 80%. The boilers are configured in a manual control scheme. Both installed in 1982, they are in fair condition. The hydronic distribution system is a heating-only system.

The boilers are configured in a constant flow primary distribution with two, 0.75 hp constant speed hot water pumps operating with an automated control scheme. The boilers provide hot water to the air handling units and to a unit heater located in the garage. Supply and return piping appear to be insulated.



First-Floor Hot Water Boiler



Second-Floor Hot Water Boiler

2.7 Domestic Hot Water

Hot water is produced by three systems. There is a 40 gallon, 40 MBh gas-fired storage water heater, a 40-gallon, 4.5 kW electric storage water heater, and a 30-gallon, 4.5 kW electric storage water heater.

The domestic hot water pipes are not completely insulated but the insulation that is present is in good condition.



Electric Storage Water Heater



Gas-Fired Storage Water Heater

2.8 Plug Load & Vending Machines

You may wish to consider paying particular attention to minimizing your plug load usage. This report makes suggestions for ECMs in this area as well as Energy Efficient Best Practices.

There are 33 computer workstations throughout the facility. Plug loads throughout the building include general café and office equipment.

There are several residential-style refrigerators throughout the building. These vary in condition and efficiency.



Residential Refrigerator



Desktop




Medium Sized Printer



Microwave and Toaster Oven

2.9 Water-Using Systems

There are four restrooms with toilets, urinals, and sinks. Faucet flow rates are at 2.2 gallons per minute (gpm) or higher.



Locker Room Restroom Faucet




Women's Restroom Faucet

3 ENERGY USE AND COSTS

Twelve months of utility billing data are used to develop annual energy consumption and cost data. This information creates a profile of the annual energy consumption and energy costs.

Utility Summary		
Fuel	Usage	Cost
Electricity	163,871 kWh	\$18,407
Natural Gas	9,016 Therms	\$7,660
Total		\$26,067



An energy balance identifies and quantifies energy use in your various building systems. This can highlight areas with the most potential for improvement. This energy balance was developed using calculated energy use for each of the end uses noted in the figure.

The energy auditor collects information regarding equipment operating hours, capacity, efficiency, and other operational parameters from facility staff, drawings, and on-site observations. This information is used as the inputs to calculate the existing conditions energy use for the site. The calculated energy use is then compared to the historical energy use and the initial inputs are revised, as necessary, to balance the calculated energy use to the historical energy use.





Figure 4 - Energy Balance

3.1 Electricity

JCP&L delivers electricity under rate class General service Secondary 3 Phase.




Electric Billing Data					
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost
8/14/19	30	18,080	49	\$256	\$2,077
9/16/19	33	17,440	46	\$241	\$2,000
10/15/19	29	14,400	39	\$161	\$1,728
11/14/19	30	11,360	31	\$128	\$1,293
12/16/19	32	12,800	31	\$126	\$1,412
1/15/20	30	12,320	29	\$119	\$1,335
2/13/20	29	12,160	30	\$122	\$1,319
3/16/20	32	12,640	30	\$123	\$1,366
4/15/20	30	11,520	29	\$120	\$1,259
5/13/20	28	10,160	31	\$131	\$1,143
6/15/20	33	17,680	41	\$203	\$1,926
7/15/20	30	13,760	46	\$241	\$1,599
Totals	366	164,320	49	\$1,970	\$18,457
Annual	365	163,871	49	\$1,965	\$18,407

Notes:

- Peak demand of 49 kW occurred in July 2019.
- Average demand over the past 12 months was 36 kW.
- The average electric cost over the past 12 months was \$0.112/kWh, which is the blended rate that includes energy supply, distribution, demand, and other charges. This report uses this blended rate to estimate energy cost savings.

3.2 Natural Gas

PSE&G delivers natural gas under rate class General Service Gas Heating (GSG HTG).



Gas Billing Data			
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost
8/19/19	30	164	\$139
9/18/19	30	179	\$151
10/17/19	29	177	\$153
11/15/19	29	702	\$629
12/18/19	33	1,352	\$1,190
1/21/20	34	2,001	\$1,750
2/20/20	30	1,613	\$1,350
3/19/20	28	1,101	\$907
4/20/20	32	870	\$703
5/18/20	28	545	\$441
6/18/20	31	168	\$136
7/20/20	32	170	\$134
Totals	366	9,040	\$7,681
Annual	365	9,016	\$7,660

Notes:

- The average gas cost for the past 12 months is \$0.850/therm, which is the blended rate used throughout the analysis.

3.3 Benchmarking

Your building was benchmarked using the United States Environmental Protection Agency's (EPA) *Portfolio Manager*® software. Benchmarking compares your building's energy use to that of similar buildings across the country, while neutralizing variations due to location, occupancy, and operating hours. Some building types can be scored with a 1-100 ranking of a building's energy performance relative to the national building market. A score of 50 represents the national average and a score of 100 is best.

This ENERGY STAR® benchmarking score provides a comprehensive snapshot of your building's energy performance. It assesses the building's physical assets, operations, and occupant behavior, which is compiled into a quick and easy-to-understand score.

Benchmarking Score	N/A
---------------------------	------------

Due to its unique characteristics, this building type is not able to receive a benchmarking score. This report contains suggestions about how to improve building performance and reduce energy costs.




Figure 5 - Energy Use Intensity Comparison³

Energy use intensity (EUI) measures energy consumption per square foot and is the standard metric for comparing buildings' energy performance. A lower EUI means better performance and less energy consumed. A number of factors can cause a building to vary from the "typical" energy usage. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and occupant behavior all contribute to a building's energy use and the benchmarking score.

³ Based on all evaluated ECMs

Tracking Your Energy Performance

Keeping track of your energy use on a monthly basis is one of the best ways to keep energy costs in check. Update your utility information in Portfolio Manager® regularly, so that you can keep track of your building's performance.

We have created a Portfolio Manager® account for your facility and we have already entered the monthly utility data shown above for you. Account login information for your account will be sent via email.

Free online training is available to help you use ENERGY STAR® Portfolio Manager® to track your building's performance at: <https://www.energystar.gov/buildings/training>.

For more information on ENERGY STAR® and Portfolio Manager®, visit their website⁴.

⁴ <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.

4 ENERGY CONSERVATION MEASURES

The goal of this audit report is to identify and evaluate potential energy efficiency improvements and provide information about the cost effectiveness of those improvements. Most energy conservation measures have received preliminary analysis of feasibility, which identifies expected ranges of savings. This level of analysis is typically sufficient to demonstrate project cost-effectiveness and help prioritize energy measures.

Calculations of energy use and savings are based on the current version of the *New Jersey's Clean Energy Program Protocols to Measure Resource Savings*, which is approved by the NJBPU. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances.

Operation and maintenance costs for the proposed new equipment will generally be lower than the current costs for the existing equipment—especially if the existing equipment is at or past its normal useful life. We have conservatively assumed there to be no impact on overall maintenance costs over the life of the equipment.

Financial incentives are based on previously run state rebate programs. New utility programs are expected to start rolling out in the spring and summer of 2021. Keep up to date with developments by visiting the [NJCEP website](#). Some measures and proposed upgrades may be eligible for higher incentives than those shown below.

For a detailed list of the locations and recommended energy conservation measures for all inventoried equipment, see **Appendix A: Equipment Inventory & Recommendations**.

#	Energy Conservation Measure	Cost Effective?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades			36,191	8.6	-7	\$4,005	\$4,325	\$2,010	\$2,315	0.6	35,610
ECM 1	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	Yes	28,024	7.0	-6	\$3,097	\$3,200	\$1,600	\$1,600	0.5	27,521
ECM 2	Retrofit Fixtures with LED Lamps	Yes	8,167	1.6	-1	\$908	\$1,125	\$410	\$715	0.8	8,089
Lighting Control Measures			7,593	1.5	-2	\$839	\$5,999	\$1,860	\$4,139	4.9	7,457
ECM 3	Install Occupancy Sensor Lighting Controls	Yes	1,914	0.9	0	\$211	\$3,974	\$535	\$3,439	16.3	1,879
ECM 4	Install High/Low Lighting Controls	Yes	5,680	0.5	-1	\$628	\$2,025	\$1,325	\$700	1.1	5,578
Variable Frequency Drive (VFD) Measures			10,198	2.6	0	\$1,146	\$25,112	\$500	\$24,612	21.5	10,270
ECM 5	Install VFDs on Constant Volume (CV) Fans	Yes	7,544	2.4	0	\$847	\$13,974	\$400	\$13,574	16.0	7,597
ECM 6	Install VFDs on Heating Water Pumps	No	2,654	0.2	0	\$298	\$11,138	\$100	\$11,038	37.0	2,672
HVAC System Improvements			1,312	0.0	10	\$235	\$265	\$92	\$173	0.7	2,524
ECM 7	Install Pipe Insulation	Yes	1,312	0.0	10	\$235	\$265	\$92	\$173	0.7	2,524
Domestic Water Heating Upgrade			278	0.0	7	\$92	\$43	\$24	\$19	0.2	1,123
ECM 8	Install Low-Flow DHW Devices	Yes	278	0.0	7	\$92	\$43	\$24	\$19	0.2	1,123
Custom Measures			4,893	0.0	0	\$549	\$3,827	\$0	\$3,827	7.0	4,927
ECM 9	Install Heat Pump Water Heater	Yes	4,893	0.0	0	\$549	\$3,827	\$0	\$3,827	7.0	4,927
TOTALS			60,465	12.6	9	\$6,865	\$39,570	\$4,486	\$35,084	5.1	61,911

* - All incentives presented in this table are included as placeholders and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 6 – All Evaluated ECMs

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		36,191	8.6	-7	\$4,005	\$4,325	\$2,010	\$2,315	0.6	35,610
ECM 1	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	28,024	7.0	-6	\$3,097	\$3,200	\$1,600	\$1,600	0.5	27,521
ECM 2	Retrofit Fixtures with LED Lamps	8,167	1.6	-1	\$908	\$1,125	\$410	\$715	0.8	8,089
Lighting Control Measures		7,593	1.5	-2	\$839	\$5,999	\$1,860	\$4,139	4.9	7,457
ECM 3	Install Occupancy Sensor Lighting Controls	1,914	0.9	0	\$211	\$3,974	\$535	\$3,439	16.3	1,879
ECM 4	Install High/Low Lighting Controls	5,680	0.5	-1	\$628	\$2,025	\$1,325	\$700	1.1	5,578
Variable Frequency Drive (VFD) Measures		7,544	2.4	0	\$847	\$13,974	\$400	\$13,574	16.0	7,597
ECM 5	Install VFDs on Constant Volume (CV) Fans	7,544	2.4	0	\$847	\$13,974	\$400	\$13,574	16.0	7,597
HVAC System Improvements		1,312	0.0	10	\$235	\$265	\$92	\$173	0.7	2,524
ECM 7	Install Pipe Insulation	1,312	0.0	10	\$235	\$265	\$92	\$173	0.7	2,524
Domestic Water Heating Upgrade		278	0.0	7	\$92	\$43	\$24	\$19	0.2	1,123
ECM 8	Install Low-Flow DHW Devices	278	0.0	7	\$92	\$43	\$24	\$19	0.2	1,123
Custom Measures		4,893	0.0	0	\$549	\$3,827	\$0	\$3,827	7.0	4,927
ECM 9	Install Heat Pump Water Heater	4,893	0.0	0	\$549	\$3,827	\$0	\$3,827	7.0	4,927
TOTALS		57,811	12.4	9	\$6,567	\$28,432	\$4,386	\$24,046	3.7	59,239

* - All incentives presented in this table are included as placeholders and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 7 – Cost Effective ECMs

4.1 Lighting

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		36,191	8.6	-7	\$4,005	\$4,325	\$2,010	\$2,315	0.6	35,610
ECM 1	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	28,024	7.0	-6	\$3,097	\$3,200	\$1,600	\$1,600	0.5	27,521
ECM 2	Retrofit Fixtures with LED Lamps	8,167	1.6	-1	\$908	\$1,125	\$410	\$715	0.8	8,089

When considering lighting upgrades, we suggest using a comprehensive design approach that simultaneously upgrades lighting fixtures and controls to maximize energy savings and improve occupant lighting. Comprehensive design will also consider appropriate lighting levels for different space types to make sure that the right amount of light is delivered where needed. If conversion to LED light sources are proposed, we suggest converting all of a specific lighting type (e.g. linear fluorescent) to LED lamps to minimize the number of lamp types in use at the facility, which should help reduce future maintenance costs.

ECM 1: Retrofit Fluorescent Fixtures with LED Lamps and Drivers

Retrofit fluorescent fixtures by removing the fluorescent tubes and ballasts and replacing them with LED tubes and LED drivers (if necessary), which are designed to be used in retrofitted fluorescent fixtures.

The measure uses the existing fixture housing but replaces the electric components with more efficient lighting technology which use less power than other lighting technologies but provides equivalent lighting output. Maintenance savings may also be achieved since LED tubes last longer than fluorescent tubes and therefore do not need to be replaced as often.

Affected building areas: T-12 fixtures in detective bureau, electrical room, entrance, evidence room, gymnasium, interrogation room, front office, corridors, locker rooms, processing room, break room, storage rooms, stairwells, squad room, boiler room, emergency services, and training room.

ECM 2: Retrofit Fixtures with LED Lamps

Replace fluorescent or incandescent lamps with LED lamps. Many LED tubes are direct replacements for existing fluorescent tubes and can be installed while leaving the fluorescent fixture ballast in place. LED lamps can be used in existing fixtures as a direct replacement for most other lighting technologies.

This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space. Maintenance savings may also be available, as longer-lasting LEDs lamps will not need to be replaced as often as the existing lamps.

Affected building areas: T-8 and incandescent fixtures in entrance area, building exterior, jail cells, storage rooms, locker rooms, squad room, assistant chief office, boiler room, captain's office, chief office, conference rooms, corridors, and restrooms.

4.2 Lighting Controls

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures		7,593	1.5	-2	\$839	\$5,999	\$1,860	\$4,139	4.9	7,457
ECM 3	Install Occupancy Sensor Lighting Controls	1,914	0.9	0	\$211	\$3,974	\$535	\$3,439	16.3	1,879
ECM 4	Install High/Low Lighting Controls	5,680	0.5	-1	\$628	\$2,025	\$1,325	\$700	1.1	5,578

Lighting controls reduce energy use by turning off or lowering lighting fixture power levels when not in use. A comprehensive approach to lighting design should upgrade the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

ECM 3: Install Occupancy Sensor Lighting Controls

Install occupancy sensors to control lighting fixtures in areas that are frequently unoccupied, even for short periods. For most spaces, we recommend that lighting controls use dual technology sensors, which reduce the possibility of lights turning off unexpectedly.

Occupancy sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Most occupancy sensor lighting controls allow users to manually turn fixtures on/off, as needed. Some controls can also provide dimming options.

Occupancy sensors can be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are best suited to single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in large spaces, locations without local switching, and where wall switches are not in the line-of-sight of the main work area.

This measure provides energy savings by reducing the lighting operating hours.

Affected building areas: detective bureau, evidence room, gymnasium, locker rooms, break room, storage rooms, squad room, emergency services, offices, and training room

ECM 4: Install High/Low Lighting Controls

Install occupancy sensors to provide dual level lighting control for lighting fixtures in spaces that are infrequently occupied but may require some level of continuous lighting for safety or security reasons.

Lighting fixtures with these controls operate at default low levels when the area is unoccupied to provide minimal lighting to meet security or safety code requirements for egress. Sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Fixtures automatically switch back to low level after a predefined period of vacancy. In parking lots and parking garages with significant ambient lighting, this control can sometimes be combined with photocell controls to turn the lights off when there is sufficient daylight.

The controller lowers the light level by dimming the fixture output. Therefore, the controlled fixtures need to have a dimmable ballast or driver. This will need to be considered when selecting retrofit lamps and bulbs for the areas proposed for high/low control.

This measure provides energy savings by reducing the light fixture power draw when reduced light output is appropriate.

Affected building areas: entrance, garage, front office, corridors, and stairwells.

For this type of measure the occupancy sensors will generally be ceiling or fixture mounted. Sufficient sensor coverage must be provided to ensure that lights turn on in each area as an occupant approaches.

4.3 Variable Frequency Drives (VFD)

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Variable Frequency Drive (VFD) Measures		10,198	2.6	0	\$1,146	\$25,112	\$500	\$24,612	21.5	10,270
ECM 5	Install VFDs on Constant Volume (CV) Fans	7,544	2.4	0	\$847	\$13,974	\$400	\$13,574	16.0	7,597
ECM 6	Install VFDs on Heating Water Pumps	2,654	0.2	0	\$298	\$11,138	\$100	\$11,038	37.0	2,672

Variable frequency drives control motors for fans, pumps, and process equipment based on the actual output required of the driven equipment. Energy savings result from more efficient control of motor energy usage when equipment operates at partial load. The magnitude of energy savings depends on the estimated amount of time that the motor would operate at partial load. For equipment with proposed VFDs, we have included replacing the controlled motor with a new inverter duty rated motor to conservatively account for the cost of an inverter duty rated motor.

ECM 5: Install VFDs on Constant Volume (CV) Fans

Install VFDs to control constant volume fan motor speeds. This converts a constant-volume, single-zone air handling system into a variable-air-volume (VAV) system. A separate VFD is usually required to control the return fan motor or dedicated exhaust fan motor, if the air handler has one.

Zone thermostats signal the VFD to adjust fan speed to maintain the appropriate temperature in the zone, while maintaining a constant supply air temperature.

For air handlers with direct expansion (DX) cooling systems, the minimum air flow across the cooling coil required to prevent the coil from freezing must be determined during the final project design. The control system programming should maintain the minimum air flow whenever the compressor is operating. Prior to implementation, verify minimum fan speed in cooling mode with the manufacturer. Note that savings will vary depending on the operating characteristics of each AHU.

Energy savings result from reducing the fan speed (and power) when conditions allow for reduced air flow.

Affected air handlers: AHU's 1, 2, 3 and the unit on the first floor.

ECM 6: Install VFDs on Heating Water Pumps

We evaluated installing variable frequency drives (VFD) to control heating water pumps. Two-way valves must serve the hot water coils and the hot water loop must have a differential pressure sensor installed. If three-way valves or a bypass leg are used in the hot water distribution, they will need to be modified when this measure is implemented. As the hot water valves close, the differential pressure increases and the VFD modulates the pump speed to maintain a differential pressure setpoint.

Energy savings result from reducing pump motor speed (and power) as hot water valves close. The magnitude of energy savings is based on the estimated amount of time that the system will operate at reduced load.

Affected pumps: heating hot water pumps.

4.4 HVAC Improvements

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
HVAC System Improvements		1,312	0.0	10	\$235	\$265	\$92	\$173	0.7	2,524
ECM 7	Install Pipe Insulation	1,312	0.0	10	\$235	\$265	\$92	\$173	0.7	2,524

ECM 7: Install Pipe Insulation

Install insulation on domestic hot water system piping. Distribution system losses are dependent on system fluid temperature, the size of the distribution system, and the level of insulation of the piping. Significant energy savings can be achieved when insulation has not been well maintained. When the insulation is exposed to water, when the insulation has been removed from some areas of the pipe, or when valves have not been properly insulated system efficiency can be significantly reduced. This measure saves energy by reducing heat transfer in the distribution system.

Affected Systems: domestic hot water piping

4.5 Domestic Water Heating

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Domestic Water Heating Upgrade		278	0.0	7	\$92	\$43	\$24	\$19	0.2	1,123
ECM 8	Install Low-Flow DHW Devices	278	0.0	7	\$92	\$43	\$24	\$19	0.2	1,123

ECM 8: Install Low-Flow DHW Devices

Install low-flow devices to reduce overall hot water demand. The following low flow devices are recommended to reduce hot water usage:

Device	Flow Rate
Faucet aerators (lavatory)	0.5 gpm
Faucet aerator (kitchen)	1.5 gpm

Low-flow devices reduce the overall water flow from the fixture, while still providing adequate pressure for washing.

Additional cost savings may result from reduced water usage.

4.6 Custom Measures

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Custom Measures		4,893	0.0	0	\$549	\$3,827	\$0	\$3,827	7.0	4,927
ECM 9	Install Heat Pump Water Heater	4,893	0.0	0	\$549	\$3,827	\$0	\$3,827	7.0	4,927

ECM 9: Install Heat Pump Water Heater

A typical electric water heater uses electric resistance coils to heat water at a coefficient of performance (COP) of 1. Heat pump water heaters (HPWH) use a refrigeration cycle to transfer heat from the air to the domestic water. The typical average COP for a HPWH is about 2.5 so they require significantly less electricity to produce the same amount of hot water as a traditional electric water heater. HPWH also reject cold air. As such, they need to be in an unconditioned space with good ventilation. Ideal locations are garages or large enclosed, unconditioned storage areas.

Most HPWH operate effectively down to an air temperature of 40 °F. Below that temperature, an electric resistance booster heater is typically required to achieve full heating capacity. It is critical that the HPWH controls are set up so that the electric resistance heat only engages when the air temperature is too cold for the HPWH to extract heat from it.

HPWH operate most effectively when the temperature difference between the incoming and outgoing water is high. Generally, this means that cold make-up water should be piped to the bottom of the tank and return water should be piped to the top of the tank in order to maintain stratification within the storage tank. Water should be drawn from the bottom of the tank to be heated. If there is a DHW recirculation pump, it should only be operated during high hot water demand periods.

Affected Systems: two electric domestic water heaters.

5 ENERGY EFFICIENT BEST PRACTICES

A whole building maintenance plan will extend equipment life; improve occupant comfort, health, and safety; and reduce energy and maintenance costs.

Operation and maintenance (O&M) plans enhance the operational efficiency of HVAC and other energy intensive systems and could save between 5% to 20% of the energy usage in your building without substantial capital investment. A successful plan includes your records of energy usage trends and costs, building equipment lists, current maintenance practices, planned capital upgrades, and incorporates your ideas for improved building operation. Your plan will address goals for energy-efficient operation, provide detail on how to reach the goals, and will outline procedures for measuring and reporting whether goals have been achieved.

You may already be doing some of these things— see our list below for potential additions to your maintenance plan. Be sure to consult with qualified equipment specialists for details on proper maintenance and system operation.

Energy Tracking with ENERGY STAR® Portfolio Manager®



You've heard it before - you can't manage what you don't measure. ENERGY STAR® Portfolio Manager® is an online tool that you can use to measure and track energy and water consumption, as well as greenhouse gas emissions⁵. Your account has already been established. Now you can continue to keep tabs on your energy performance every month.

Weatherization

Caulk or weather strip leaky doors and windows to reduce drafts and loss of heated or cooled air. Sealing cracks and openings can reduce heating and cooling costs, improve building durability, and create a healthier indoor environment. Materials used may include caulk, polyurethane foam, and other weather-stripping materials. There is an energy savings opportunity by reducing the uncontrolled air exchange between the outside and inside of the building. Blower door assisted comprehensive building air sealing will reduce the amount of air exchange which will in turn reduce the load on the buildings heating and cooling equipment and thus providing energy savings and increased occupant comfort.

Doors and Windows

Close exterior doors and windows in heated and cooled areas. Leaving doors and windows open leads to a loss of heat during the winter and chilled air during the summer. Reducing air changes per hour (ACH) can lead to increased occupant comfort as well as heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

⁵ <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/use-portfolio-manager>.

Window Treatments/Coverings

Use high-reflectivity films or cover windows with shades or shutters to reduce solar heat gain and reduce the load on cooling and heating systems. Older, single pane windows and east or west-facing windows are especially prone to solar heat gain. In addition, use shades or shutters at night during cold weather to reduce heat loss.

Lighting Maintenance



- Clean lamps, reflectors and lenses of dirt, dust, oil, and smoke buildup every six to twelve months. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust. Together, this can reduce total light output by up to 60% while still drawing full power.
- In addition to routine cleaning, developing a maintenance schedule can ensure that maintenance is performed regularly, and it can reduce the overall cost of fixture re-lamping and re-ballasting. Group re-lamping and re-ballasting maintains lighting levels and minimizes the number of site visits by a lighting technician or contractor, decreasing the overall cost of maintenance.

Lighting Controls

As part of a lighting maintenance schedule, test lighting controls to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight and photocell sensors, maintenance involves cleaning sensor lenses and confirming that setpoints and sensitivity are configured properly. Adjust exterior lighting time clock controls seasonally as needed to match your lighting requirements.

Motor Maintenance

Motors have many moving parts. As these parts degrade over time, the efficiency of the motor is reduced. Routine maintenance prevents damage to motor components. Routine maintenance should include cleaning surfaces and ventilation openings on motors to prevent overheating, lubricating moving parts to reduce friction, inspecting belts and pulleys for wear and to ensure they are at proper alignment and tension, and cleaning and lubricating bearings. Consult a licensed technician to assess these and other motor maintenance strategies.

Fans to Reduce Cooling Load

Install ceiling fans to supplement your cooling system. Thermostat settings can typically be increased by 4°F with no change in overall occupant comfort due to the wind chill effect of moving air.

AC System Evaporator/Condenser Coil Cleaning

Dirty evaporator and condenser coils restrict air flow and restrict heat transfer. This increases the loads on the evaporator and condenser fan and decreases overall cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

HVAC Filter Cleaning and Replacement

Air filters should be checked regularly (often monthly) and cleaned or replaced when appropriate. Air filters reduce indoor air pollution, increase occupant comfort, and help keep equipment operating efficiently. If the building has a building management system, consider installing a differential pressure switch across filters to send an alarm about premature fouling or overdue filter replacement. Over time, filters become less and less effective as particulate buildup increases. Dirty filters also restrict air flow through the air conditioning or heat pump system, which increases the load on the distribution fans.

Ductwork Maintenance

Duct maintenance has two primary goals: keep the ducts clean to avoid air quality problems and seal leaks to save energy. Check for cleanliness, obstructions that block airflow, water damage, and leaks. Ducts should be inspected at least every two years.

The biggest symptoms of clogged air ducts are differing temperatures throughout the building and areas with limited airflow from supply registers. If a particular air duct is clogged, then air flow will only be cut off to some rooms in the building - not all of them. The reduced airflow will make it more difficult for those areas to reach the temperature setpoint which will cause the HVAC system to run longer to cool or heat that area properly. If you suspect clogged air ducts, ensure that all areas in front of supply registers are clear of items that may block or restrict air flow, and check for fire dampers or balancing dampers that have failed closed.

Duct leakage in commercial buildings can account for 5% to 25% of the supply airflow. In the case of rooftop air handlers, duct leakage can occur to the outside of the building wasting conditioned air. Check ductwork for leakage. Eliminating duct leaks can improve ventilation system performance and reduce heating and cooling system operation.

Distribution system losses are dependent on-air system temperature, the size of the distribution system, and the level of insulation of the ductwork. Significant energy savings can be achieved when insulation has not been well maintained. When the insulation is missing or worn, the system efficiency can be significantly reduced. This measure saves energy by reducing heat transfer in the distribution system.

Boiler Maintenance

Many boiler problems develop slowly over time, so regular inspection and maintenance is essential to keeping the heating system running efficiently and preventing expensive repairs. Annual tune-ups should include a combustion analysis to analyze the exhaust from the boilers and to ensure the boiler is operating safely and efficiently. Boilers should be cleaned according to the manufacturer's instructions to remove soot and scale from the boiler tubes to improve heat transfer.

Water Heater Maintenance

The lower the supply water temperature that is used for hand washing sinks, the less energy is needed to heat the water. Reducing the temperature results in energy savings and the change is often unnoticeable to users. Be sure to review the domestic water temperature requirements for sterilizers and dishwashers as you investigate reducing the supply water temperature.

Also, preventative maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. At least once a year, follow manufacturer instructions to drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Annual checks should include checks for:

- Leaks or heavy corrosion on the pipes and valves.
- Corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot, or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional.
- For electric water heaters, look for signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank.
- For water heaters more than three years old, have a technician inspect the sacrificial anode annually.


Compressed Air System Maintenance

Compressed air systems require periodic maintenance to operate at peak efficiency. A maintenance plan for compressed air systems should include:

- Inspection, cleaning, and replacement of inlet filter cartridges
- Cleaning of drain traps
- Daily inspection of lubricant levels to reduce unwanted friction
- Inspection of belt condition and tension
- Check for leaks and adjust loose connections
- Overall system cleaning

Contact a qualified technician for help with setting up periodic maintenance schedule.

Plug Load Controls



Reducing plug loads is a common way to decrease your electrical use. Limiting the energy use of plug loads can include increasing occupant awareness, removing under-used equipment, installing hardware controls, and using software controls. Consider enabling the most aggressive power settings on existing devices or install load sensing or occupancy sensing (advanced) power strips⁶. Your local utility may offer incentives or rebates for this equipment.

Computer Power Management Software

Many computers consume power during nights, weekends, and holidays. Screen savers are commonly confused as a power management strategy. This contributes to avoidable, excessive electrical energy consumption. There are innovative power management software packages available that are designed to deliver significant energy saving and provide ongoing tracking measurements. A central power management platform helps enforce energy savings policies as well as identify and eliminate underutilized devices.

Water Conservation



Installing dual flush or low-flow toilets and low-flow/waterless urinals are ways to reduce water use. The EPA WaterSense[®] ratings for urinals is 0.5 gallons per flush (gpf) and for flush valve toilets is 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

For more information regarding water conservation go to the EPA's WaterSense[®] website⁷ or download a copy of EPA's "WaterSense[®] at Work: Best Management Practices for Commercial and Institutional Facilities"⁸ to get ideas for creating a water management plan and best practices for a wide range of water using systems.

Water conservation devices that do not reduce hot water consumption will not provide energy savings at the site level, but they may significantly affect your water and sewer usage costs. Any reduction in water use does however ultimately reduce grid-level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users.

If the facility has detached buildings with a master water meter for the entire campus, check for unnatural wet areas in the lawn or water seeping in the foundation at water pipe penetrations through the foundation. Periodically check overnight meter readings when the facility is unoccupied, and there is no other scheduled water usage.

⁶ For additional information refer to "Assessing and Reducing Plug and Process Loads in Office Buildings" <http://www.nrel.gov/docs/fy13osti/54175.pdf>, or "Plug Load Best Practices Guide" <http://www.advancedbuildings.net/plug-load-best-practices-guide-offices>.

⁷ <https://www.epa.gov/watersense>.

⁸ <https://www.epa.gov/watersense/watersense-work-0>.



Manage irrigation systems to use water more effectively outside the building. Adjust spray patterns so that water lands on intended lawns and plantings and not on pavement and walls. Consider installing an evapotranspiration irrigation controller that will prevent over-watering.

Procurement Strategies

Purchasing efficient products reduces energy costs without compromising quality. Consider modifying your procurement policies and language to require ENERGY STAR® or WaterSense® products where available.

6 ON-SITE GENERATION

You don't have to look far in New Jersey to see one of the thousands of solar electric systems providing clean power to homes, businesses, schools, and government buildings. On-site generation includes both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) technologies that generate power to meet all or a portion of the facility's electric energy needs. Also referred to as distributed generation, these systems contribute to greenhouse gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, which results in improved electric grid reliability through better use of transmission and distribution systems.

Preliminary screenings were performed to determine if an on-site generation measure could be a cost-effective solution for your facility. Before deciding to install an on-site generation system, we recommend conducting a feasibility study to analyze existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.

6.1 Solar Photovoltaic

Photovoltaic (PV) panels convert sunlight into electricity. Individual panels are combined into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is then connected to the building's electrical distribution system.

A preliminary screening based on the facility's electric demand, size and location of free area, and shading elements shows that the facility has no potential for installing a PV array.

This facility does not appear to meet the minimum criteria for a cost-effective solar PV installation. To be cost-effective, a solar PV array needs certain minimum criteria, such as sufficient and sustained electric demand and sufficient flat or south-facing rooftop or other unshaded space on which to place the PV panels.

The graphic below displays the results of the PV potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.




Figure 8 - Photovoltaic Screening

Successor Solar Incentive Program (SuSI)

The SuSI program replaces the SREC Registration Program (SRP) and the Transition Incentive (TI) program. The SuSI program is used to register and certify solar projects in New Jersey. Rebates are not available for solar projects. Solar projects may qualify to earn SREC- IIs (Solar Renewable Energy Certificates-II), however, the project owners *must* register their solar projects prior to the start of construction to establish the project's eligibility.

Get more information about solar power in New Jersey or find a qualified solar installer who can help you decide if solar is right for your building:

Successor Solar Incentive Program (SuSI): <https://www.njcleanenergy.com/renewable-energy/programs/susi-program>

- **Basic Info on Solar PV in NJ:** www.njcleanenergy.com/whysolar
- **NJ Solar Market FAQs:** www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs.
- **Approved Solar Installers in the NJ Market:** www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1

6.2 Combined Heat and Power

Combined heat and power (CHP) generates electricity at the facility and puts waste heat energy to good use. Common types of CHP systems are reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines.

CHP systems typically produce a portion of the electric power used on-site, with the balance of electric power needs supplied by the local utility company. The heat is used to supplement (or replace) existing boilers and provide space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for space cooling.

The key criteria used for screening is the amount of time that the CHP system would operate at full load and the facility's ability to use the recovered heat. Facilities with a continuous need for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has no potential for installing a cost-effective CHP system.

Based on a preliminary analysis, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation. The lack of gas service, low or infrequent thermal load, and lack of space for siting the equipment are the most significant factors contributing to the lack of CHP potential.

The graphic below displays the results of the CHP potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.




Figure 9 - Combined Heat and Power Screening

Find a qualified firm that specializes in commercial CHP cost assessment and installation: http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/.

7 PROJECT FUNDING AND INCENTIVES

Ready to improve your building’s performance? Your utility provider may be able to help.

7.1 Utility Energy Efficiency Programs

The Clean Energy Act, signed into law by Governor Murphy in 2018, requires New Jersey’s investor-owned gas and electric utilities to reduce their customers’ use by set percentages over time. To help reach these targets the New Jersey Board of Public Utilities approved a comprehensive suite of energy efficiency programs to be run by the utility companies.

The infographic features logos for Atlantic City Electric, Jersey Central Power & Light, PSEG, Rockland Electric Company, Elizabethtown Gas, South Jersey Gas, and New Jersey Natural Gas. Below the logos, the text reads: "Program areas to be served by the Utilities:" followed by a list of areas and a box for proposed new programs.

Program areas to be served by the Utilities:

- Existing Buildings (residential, commercial, industrial, government)
- Efficient Products
 - HVAC
 - Appliance Rebates
 - Appliance Recycling

Proposed New Programs & Features:

- Dedicated multi-family program
- More financing options
- Quick home energy check-ups

These new utility programs are rolling out in the spring and summer of 2021. Keep up to date with developments by visiting:

<https://www.njcleanenergy.com/transition>

8 NEW JERSEY'S CLEAN ENERGY PROGRAMS

New Jersey's Clean Energy Program will continue to offer some energy efficiency programs.



Program areas staying with NJCEP:

- New Construction (residential, commercial, industrial, government)
- Large Energy Users
- Combined Heat & Power & Fuel Cells
- State Facilities
- Local Government Energy Audits
- Energy Savings Improvement Program
- Solar & Community Solar

8.1 Large Energy Users

The Large Energy Users Program (LEUP) is designed to foster self-directed investment in energy projects. This program is offered to New Jersey's largest energy customers that annually contribute at least \$200,000 to the NJCEP aggregate of all buildings/sites. This equates to roughly \$5 million in energy costs in the prior fiscal year.

Incentives

Incentives are based on the specifications below. The maximum incentive per entity is the lesser of:

- \$4 million
- 75% of the total project(s) cost
- 90% of total NJCEP fund contribution in previous year
- \$0.33 per projected kWh saved; \$3.75 per projected Therm saved annually

How to Participate

To participate in LEUP, you will first need submit an enrollment application. This program requires all qualified and approved applicants to submit an energy plan that outlines the proposed energy efficiency work for review and approval. Applicants may submit a Draft Energy Efficiency Plan (DEEP), or a Final Energy Efficiency Plan (FEEP). Once the FEEP is approved, the proposed work can begin.

Detailed program descriptions, instructions for applying, and applications can be found at: www.njcleanenergy.com/LEUP

8.2 Combined Heat and Power

The Combined Heat & Power (CHP) program provides incentives for eligible CHP or waste heat to power (WHP) projects. Eligible CHP or WHP projects must achieve an annual system efficiency of at least 65% (lower heating value, or LHV), based on total energy input and total utilized energy output. Mechanical energy may be included in the efficiency evaluation.

Incentives

Eligible Technologies	Size (Installed Rated Capacity) ¹	Incentive (\$/kW)	% of Total Cost Cap per Project ³	\$ Cap per Project ³
Powered by non-renewable or renewable fuel source ⁴	≤500 kW	\$2,000	30-40% ²	\$2 million
	Gas Internal Combustion Engine	>500 kW - 1 MW		
Gas Combustion Turbine	> 1 MW - 3 MW	\$550	30%	\$3 million
Microturbine	>3 MW	\$350		
Fuel Cells with Heat Recovery				
Waste Heat to Power*	<1 MW	\$1,000	30%	\$2 million
	> 1MW	\$500		\$3 million

*Waste Heat to Power: Powered by non-renewable fuel source, heat recovery or other mechanical recovery from existing equipment utilizing new electric generation equipment (e.g. steam turbine).

Check the NJCEP website for details on program availability, current incentive levels, and requirements.

How to Participate

You work with a qualified developer or consulting firm to complete the CHP application. Once the application is approved the project can be installed. Information about the CHP program can be found at www.njcleanenergy.com/CHP.

8.3 Successor Solar Incentive Program (SuSI)

The SuSI program replaces the SREC Registration Program (SRP) and the Transition Incentive (TI) program. The program is used to register and certify solar projects in New Jersey. Rebates are not available for solar projects, but owners of solar projects *must* register their projects prior to the start of construction to establish the project’s eligibility to earn SREC-IIs (Solar Renewable Energy Certificates-II). SuSI consists of two sub-programs. The Administratively Determined Incentive (ADI) Program and the Competitive Solar Incentive (CSI) Program.

Administratively Determined Incentive (ADI) Program

The ADI Program provides administratively set incentives for net metered residential projects, net metered non-residential projects 5 MW or less, and all community solar projects.

After the registration is accepted, construction is complete, and a complete final as-built packet has been submitted, the project is issued a New Jersey certification number, which enables it to generate New Jersey SREC- IIs.

Market Segments	Size MW dc	Incentive Value (\$/SREC II)	Public Entities Incentive Value - \$20 Adder (\$/SRECII)
Net Metered Residential	All types and sizes	\$90	N/A
Small Net Metered Non-Residential located on Rooftop, Carport, Canopy and Floating Solar	Projects smaller than 1 MW	\$100	\$120
Large Net Metered Non-Residential located on Rooftop, Carport, Canopy and Floating Solar	Projects 1 MW to 5 MW	\$90	\$110
Small Net Metered Non-Residential Ground Mount	Projects smaller than 1 MW	\$85	\$105
Large Net Metered Non-Residential Ground Mount	Projects 1 MW to 5 MW	\$80	\$100
LMI Community Solar	Up to 5 MW	\$90	N/A
Non-LMI Community Solar	Up to 5 MW	\$70	N/A
Interim Subsection (t)	All types and sizes	\$100	N/A

Eligible projects may generate SREC-IIs for 15 years following the commencement of commercial operations which is defined as permission to operate (PTO) from the Electric Distribution Company. After 15 years, projects may be eligible for a NJ Class I REC.

SREC-IIs will be purchased monthly by the SREC-II Program Administrator who will allocate the SREC-IIs to the Load Serving Entities (BGS Providers and Third-Party Suppliers) annually based on their market share of retail electricity sold during the relevant Energy Year.

The ADI Program online portal is now open to new registrations effective August 28, 2021.

Competitive Solar Incentive Program

The Competitive Solar Incentive (CSI) Program will provide competitively set incentives for grid supply projects and net metered non-residential projects greater than 5MW. The program is currently under development with the goal of holding the first solicitation by early-to-mid 2022. For updates, please continue to check the [Solar Proceedings](#) page on the New Jersey’s Clean Energy Program website.

Solar projects help the State of New Jersey reach renewable energy goals outlined in the state’s Energy Master Plan.

If you are considering installing solar photovoltaics on your building, visit the following link for more information: <https://nicleanenergy.com/renewable-energy/programs/susi-program>.

8.4 Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) serves New Jersey's government agencies by financing energy projects. An ESIP is a type of performance contract, whereby school districts, counties, municipalities, housing authorities, and other public and state entities enter into contracts to help finance building energy upgrades. Annual payments are lower than the savings projected from the energy conservation measures (ECMs), ensuring that ESIP projects are cash flow positive for the life of the contract.

ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs described above can also be used to help further reduce the total project cost of eligible measures.

How to Participate

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an energy services company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is used for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the energy savings plan can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Carefully consider all alternatives to develop an approach that best meets your needs. A detailed program description and application can be found at www.njcleanenergy.com/ESIP.

ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you can use NJCEP incentive programs to help further reduce costs when developing the energy savings plan. Refer to the ESIP guidelines at the link above for further information and guidance on next steps.

9 PROJECT DEVELOPMENT

Energy conservation measures (ECMs) have been identified for your site and their energy and economic analyses are provided within this LGEA report. The next steps with project development are to set goals and create a comprehensive project plan. The graphic below provides an overview of the process flow for a typical energy efficiency or renewable energy project. We recommend implementing as many ECMs as possible prior to undertaking a feasibility study for a renewable project. The cyclical nature of this process flow demonstrates the ongoing work required to continually improve building energy efficiency over time. If your building(s) scope of work is relatively simple to implement or small in scope, the measurement and verification (M&V) step may not be required. It should be noted through a typical project cycle, there will be changes in costs based on specific scopes of work, contractor selections, design considerations, construction, etc. The estimated costs provided throughout this LGEA report demonstrate the unburdened turn-key material and labor cost only. There will be contingencies and additional costs at the time of implementation. We recommend comprehensive project planning includes the review of multiple bids for project work, incorporate potential operational & maintenance (O&M) cost savings and maximize your incentive potential.




Figure 10 – Project Development Cycle

10 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

10.1 Retail Electric Supply Options

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third-party supplier, consider shopping for a reduced rate from third-party electric suppliers. If your facility already buys electricity from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party electric suppliers is available at the NJBPU website⁹.

10.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey is also deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate monthly. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third-party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier typically depends on whether a customer prefers budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third-party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility does not already purchase natural gas from a third-party supplier, consider shopping for a reduced rate from third-party natural gas suppliers. If your facility already purchases natural gas from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party natural gas suppliers is available at the NJBPU website¹⁰.

⁹ www.state.nj.us/bpu/commercial/shopping.html.

¹⁰ www.state.nj.us/bpu/commercial/shopping.html.

APPENDIX A: EQUIPMENT INVENTORY & RECOMMENDATIONS

Lighting Inventory & Recommendations

Location	Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis								
	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Detective bureau	11	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	S	160	1,095	1, 3	Relamp & Reballast	Yes	11	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	756	1.2	1,561	0	\$172	\$710	\$255	2.6
Electrical Room 1	2	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	S	160	183	1	Relamp & Reballast	No	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	183	0.2	40	0	\$4	\$80	\$40	9.0
Entrance	1	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	S	160	7,488	1, 4	Relamp & Reballast	Yes	1	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	58	5,167	0.1	970	0	\$107	\$265	\$55	2.0
Entrance	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	S	62	8,760	2, 4	Relamp	Yes	1	LED - Linear Tubes: (2) U-Lamp	High/Low Control	33	6,044	0.0	371	0	\$41	\$20	\$10	0.2
Evidence room	6	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	S	40	1,095	1, 3	Relamp & Reballast	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	756	0.1	142	0	\$16	\$236	\$80	10.0
Exterior 1	2	Halogen Incandescent: (1) 250W A19 Screw-In Lamp	Timeclock		250	4,380	2	Relamp	No	2	LED Lamps: Screw-in LED	Timeclock	38	4,380	0.0	1,862	0	\$209	\$34	\$2	0.2
Exterior 1	4	Incandescent: (1) 60W A19 Screw-In Lamp	Timeclock		60	4,380	2	Relamp	No	4	LED Lamps: Screw-in LED	Timeclock	9	4,380	0.0	894	0	\$100	\$69	\$4	0.6
Exterior 1	2	LED - Fixtures: Wall Pack	Photocell		9	4,380		None	No	2	LED - Fixtures: Wall Pack	Photocell	9	4,380	0.0	0	0	\$0	\$0	\$0	0.0
Exterior 1	4	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Timeclock		75	4,380		None	No	4	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Timeclock	75	4,380	0.0	0	0	\$0	\$0	\$0	0.0
Exterior 1	4	LED - Fixtures: Outdoor Pole/Arm-Mounted Decorative Fixture	Photocell		50	4,380		None	No	4	LED - Fixtures: Outdoor Pole/Arm-Mounted Decorative Fixture	Photocell	50	4,380	0.0	0	0	\$0	\$0	\$0	0.0
Garage 1	2	LED - Fixtures: Linear Strip	Wall Switch	S	32	8,760	4	None	Yes	2	LED - Fixtures: Linear Strip	High/Low Control	32	6,044	0.0	188	0	\$21	\$0	\$0	0.0
Garage 1	3	LED Lamps: (2) 18W Tubular Lamps	Wall Switch	S	36	8,760	4	None	Yes	3	LED Lamps: (2) 18W Tubular Lamps	High/Low Control	36	6,044	0.0	317	0	\$35	\$225	\$105	3.4
Garage 1	6	LED Lamps: (2) 8.5W Tubular Lamps	Wall Switch	S	17	8,760	4	None	Yes	6	LED Lamps: (2) 8.5W Tubular Lamps	High/Low Control	17	6,044	0.0	299	0	\$33	\$225	\$210	0.5
Gymnasium 1	1	LED - Fixtures: Linear Strip	Wall Switch	S	64	1,095	3	None	Yes	1	LED - Fixtures: Linear Strip	Occupancy Sensor	64	756	0.0	23	0	\$3	\$0	\$0	0.0
Gymnasium 1	5	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	S	80	1,095	1, 3	Relamp & Reballast	Yes	5	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	756	0.3	355	0	\$39	\$370	\$85	7.3
Interrogation room corner	2	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	S	160	1,095	1	Relamp & Reballast	No	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	1,095	0.2	241	0	\$27	\$80	\$40	1.5
Jail cells	4	Incandescent: (1) 60W A19 Screw-In Lamp	Wall Switch	S	60	1,095	2	Relamp	No	4	LED Lamps: Screw-in LED	Wall Switch	9	1,095	0.2	241	0	\$27	\$69	\$4	2.4
Janitorial 1	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	183	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	183	0.0	7	0	\$1	\$20	\$10	13.9
Key 27 boiler room	1	LED Lamps: (1) 17W MR16 Plug-In Lamp	Wall Switch	S	17	183		None	No	1	LED Lamps: (1) 17W MR16 Plug-In Lamp	Wall Switch	17	183	0.0	0	0	\$0	\$0	\$0	0.0
Main front office	12	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	S	160	8,760	1, 4	Relamp & Reballast	Yes	12	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	58	6,044	1.3	13,621	-3	\$1,505	\$705	\$465	0.2
Main hallway	6	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	6	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Main hallway	2	LED Lamps: (2) 18W Tubular Lamps	Wall Switch	S	36	8,760	4	None	Yes	2	LED Lamps: (2) 18W Tubular Lamps	High/Low Control	36	6,044	0.0	211	0	\$23	\$225	\$70	6.6
Main hallway	6	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	S	160	8,760	1, 4	Relamp & Reballast	Yes	6	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	58	6,044	0.6	6,811	-1	\$753	\$465	\$330	0.2
Men's locker room	11	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	S	80	365	1, 3	Relamp & Reballast	Yes	11	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	252	0.6	260	0	\$29	\$452	\$150	10.5
Men's locker room	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	365	2, 3	Relamp	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	252	0.0	17	0	\$2	\$20	\$10	5.5

Location	Existing Conditions						Proposed Conditions								Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Men's locker room bathroom	1	Incandescent: (1) 60W A19 Screw-In Lamp	Wall Switch	S	60	183	2	Relamp	No	1	LED Lamps: Screw-in LED	Wall Switch	9	183	0.0	10	0	\$1	\$17	\$1	14.6
Men's locker room bathroom	2	Linear Fluorescent - T12: 4' T12 (40W) - 1L	Wall Switch	S	40	183	1	Relamp & Reballast	No	2	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	183	0.0	10	0	\$1	\$20	\$10	9.0
Processing room	1	LED - Fixtures: Ambient 2x4 Fixture	Wall Switch	S	40	1,095		None	No	1	LED - Fixtures: Ambient 2x4 Fixture	Wall Switch	40	1,095	0.0	0	0	\$0	\$0	\$0	0.0
Processing room	2	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	S	160	1,095	1	Relamp & Reballast	No	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	1,095	0.2	241	0	\$27	\$80	\$40	1.5
Small break room	2	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	S	160	1,095	1, 3	Relamp & Reballast	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	756	0.2	284	0	\$31	\$196	\$60	4.3
Small storage	2	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	S	160	183	1	Relamp & Reballast	No	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	183	0.2	40	0	\$4	\$80	\$40	9.0
Squad room	7	Incandescent: (1) 60W A19 Screw-In Lamp	Wall Switch	S	60	1,095	2, 3	Relamp	Yes	7	LED Lamps: Screw-in LED	Occupancy Sensor	9	756	0.3	445	0	\$49	\$391	\$42	7.1
Squad room	5	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,095	3	None	Yes	5	LED Lamps: (1) 10W A19 Screw-In Lamp	Occupancy Sensor	10	756	0.0	18	0	\$2	\$270	\$35	116.0
Squad room	3	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	S	40	1,095		None	No	3	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	40	1,095	0.0	0	0	\$0	\$0	\$0	0.0
Squad room	1	LED Lamps: (2) 18W Tubular Lamps	Wall Switch	S	36	1,095	3	None	Yes	1	LED Lamps: (2) 18W Tubular Lamps	Occupancy Sensor	36	756	0.0	13	0	\$1	\$0	\$0	0.0
Squad room	5	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	S	80	1,095	1, 3	Relamp & Reballast	Yes	5	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	756	0.3	355	0	\$39	\$370	\$85	7.3
Squad room	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	1,095	2, 3	Relamp	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	756	0.0	50	0	\$5	\$20	\$10	1.8
Squad room	2	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	S	62	1,095	2, 3	Relamp	Yes	2	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	756	0.1	93	0	\$10	\$40	\$20	2.0
Stairs 1	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Stairs 1	4	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch		80	8,760	1, 4	Relamp & Reballast	Yes	4	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	6,044	0.2	2,270	0	\$251	\$305	\$180	0.5
Stairs 2	3	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch		80	8,760	1, 4	Relamp & Reballast	Yes	3	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	29	6,044	0.2	1,703	0	\$188	\$285	\$135	0.8
Stem to stern	2	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	S	160	1,095	1	Relamp & Reballast	No	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	1,095	0.2	241	0	\$27	\$80	\$40	1.5
Women's locker room	3	LED - Fixtures: Ambient 2x2 Fixture	Wall Switch	S	30	365		None	No	3	LED - Fixtures: Ambient 2x2 Fixture	Wall Switch	30	365	0.0	0	0	\$0	\$0	\$0	0.0
Assistant chief office	3	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	4,380	2, 3	Relamp	Yes	3	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	3,022	0.2	1,050	0	\$116	\$390	\$95	2.5
Boiler room 2	1	Incandescent: (1) 60W A19 Screw-In Lamp	Wall Switch	S	60	183	2	Relamp	No	1	LED Lamps: Screw-in LED	Wall Switch	9	183	0.0	10	0	\$1	\$17	\$1	14.6
Boiler room 2	12	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	S	80	183	1	Relamp & Reballast	No	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	183	0.5	121	0	\$13	\$240	\$120	9.0
Captain office	2	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	4,380	2, 3	Relamp	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	3,022	0.1	700	0	\$77	\$350	\$75	3.6
Chief office	3	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	4,380	2, 3	Relamp	Yes	3	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	3,022	0.2	1,050	0	\$116	\$390	\$95	2.5
Closest	1	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	S	80	183	1	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	183	0.0	10	0	\$1	\$20	\$10	9.0
Closest 2	1	Incandescent: (1) 60W A19 Screw-In Lamp	Wall Switch	S	60	183	2	Relamp	No	1	LED Lamps: Screw-in LED	Wall Switch	9	183	0.0	10	0	\$1	\$17	\$1	14.6

Location	Existing Conditions						Proposed Conditions								Energy Impact & Financial Analysis						
	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Conference 1	4	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	S	114	1,095	2, 3	Relamp	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	756	0.3	350	0	\$39	\$430	\$115	8.1
Corridor 3	4	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	4	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Corridor 3	1	LED - Fixtures: Ambient 2x2 Fixture	Wall Switch	S	30	8,760	4	None	Yes	1	LED - Fixtures: Ambient 2x2 Fixture	High/Low Control	30	6,044	0.0	88	0	\$10	\$0	\$0	0.0
Corridor 3	7	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Wall Switch	S	62	8,760	2, 4	Relamp	Yes	7	LED - Linear Tubes: (2) U-Lamp	High/Low Control	33	6,044	0.2	2,598	-1	\$287	\$365	\$295	0.2
Division commander	2	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	S	160	4,380	1, 3	Relamp & Reballast	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	3,022	0.2	1,135	0	\$125	\$350	\$75	2.2
Emergency services	2	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	S	160	1,095	1, 3	Relamp & Reballast	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	756	0.2	284	0	\$31	\$350	\$75	8.8
Lounge 2	1	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	S	30	183		None	No	1	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	30	183	0.0	0	0	\$0	\$0	\$0	0.0
Lounge 2	1	U-Bend Fluorescent - T8: U T8 (32W) - 2L	Occupancy Sensor	S	62	183	2	Relamp	No	1	LED - Linear Tubes: (2) U-Lamp	Occupancy Sensor	33	183	0.0	6	0	\$1	\$20	\$10	15.8
Restroom - Female 1	1	LED - Fixtures: Ambient 2x4 Fixture	Wall Switch	S	40	183		None	No	1	LED - Fixtures: Ambient 2x4 Fixture	Wall Switch	40	183	0.0	0	0	\$0	\$0	\$0	0.0
Restroom -male 1	1	Linear Fluorescent - T8: 4' T8 (32W) - 2L	Wall Switch	S	62	183	2	Relamp	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	183	0.0	7	0	\$1	\$20	\$10	13.9
Support service manager	2	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	S	160	4,380	1, 3	Relamp & Reballast	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	3,022	0.2	1,135	0	\$125	\$350	\$75	2.2
Training room	1	LED - Fixtures: Ambient 2x4 Fixture	Wall Switch	S	40	1,095	3	None	Yes	1	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	40	756	0.0	15	0	\$2	\$0	\$0	0.0
Training room	7	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	S	160	1,095	1, 3	Relamp & Reballast	Yes	7	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	58	756	0.7	993	0	\$110	\$550	\$175	3.4
Training room storage	1	Linear Fluorescent - T12: 4' T12 (40W) - 4L	Wall Switch	S	160	183	1	Relamp & Reballast	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	183	0.1	20	0	\$2	\$40	\$20	9.0

Motor Inventory & Recommendations

		Existing Conditions									Proposed Conditions					Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Manufacturer	Model	Remaining Useful Life	Annual Operating Hours	ECM #	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Garage 1	Air compressor	1	Air Compressor	5.0	85.0%	No	ABAC/AMERICAN IMC, Inc.	318VN	W	1,095		No	85.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Garage 1	Garage 1	1	Exhaust Fan	0.5	75.0%	No			W	2,745		No	75.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Garage 2	Unit heater	2	Fan Coil Unit	0.1	65.0%	No			W	2,745		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Key 27 boiler room	Boiler	1	Heating Hot Water Pump	0.8	75.0%	No	Bell and Gossett	1M61	W	4,380	6	No	81.1%	Yes	1	0.1	1,327	0	\$149	\$5,569	\$50	37.0
Boiler room 2	Boiler	1	Heating Hot Water Pump	0.8	75.0%	No	Bell and Gossett	VG48T17D173B	W	4,380	6	No	81.1%	Yes	1	0.1	1,327	0	\$149	\$5,569	\$50	37.0
Garage 1	Garage doors	6	Other	0.2	65.0%	No			W	2,745		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Key 27 boiler room	AHU on first floor	1	Supply Fan	2.0	84.0%	No			W	2,745	5	No	85.5%	Yes	1	0.6	1,886	0	\$212	\$3,493	\$100	16.0
Boiler room 2	AHU 3	1	Supply Fan	2.0	84.0%	No			W	2,745	5	No	85.5%	Yes	1	0.6	1,886	0	\$212	\$3,493	\$100	16.0
Boiler room 2	AHU 2	1	Supply Fan	2.0	84.0%	No			W	2,745	5	No	85.5%	Yes	1	0.6	1,886	0	\$212	\$3,493	\$100	16.0
Boiler room 2	AHU 1	1	Supply Fan	2.0	84.0%	No			W	2,745	5	No	85.5%	Yes	1	0.6	1,886	0	\$212	\$3,493	\$100	16.0

Packaged HVAC Inventory & Recommendations

		Existing Conditions									Proposed Conditions							Energy Impact & Financial Analysis							
Location	Area(s)/System(s) Served	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (MBh)	Cooling Mode Efficiency (SEER/IEER/EER)	Heating Mode Efficiency	Manufacturer	Model	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (MBh)	Cooling Mode Efficiency (SEER/IEER/EER)	Heating Mode Efficiency	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Men's locker room	Men's locker room	1	Electric Resistance Heat		5.00		1 COP			W		No							0.0	0	0	\$0	\$0	\$0	0.0
Men's locker room bathroom	Men's locker room bathroom	1	Electric Resistance Heat		5.00		1 COP	Empire		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Boiler room 2	Locker Room	1	Split-System	10.00		11.00		Daikin	DX11SA1203AB	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Boiler room 2	Second Floor	1	Split-System	10.00		11.00		Goodman	GSX111203AA	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Boiler room 2	Record Room	1	Split-System	7.50		11.00		Goodman	GSX110903AA	W		No							0.0	0	0	\$0	\$0	\$0	0.0
OIC Office	Front Office	1	Split-System	2.00		13.00		Goodman	GSX130241BA	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Key 27 boiler room	Computer Room	1	Split-System	1.50	120.00	13.00		Guardian	GCGD18S21S2XC	W		No							0.0	0	0	\$0	\$0	\$0	0.0

Space Heating Boiler Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions							Energy Impact & Financial Analysis					
		System Quantity	System Type	Output Capacity per Unit (MBh)	Manufacturer	Model	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives
Key 27 boiler room	First floor	1	Non-Condensing Hot Water Boiler	400	Hydro Therm	MR-500B	W		No					0.0	0	0	\$0	\$0	\$0	0.0
Boiler room 2	Second floor	1	Non-Condensing Hot Water Boiler	480	Hydro Therm	MR-600B	W		No					0.0	0	0	\$0	\$0	\$0	0.0

Pipe Insulation Recommendations

Location	Area(s)/System(s) Affected	Recommendation Inputs			Energy Impact & Financial Analysis						
		ECM #	Length of Uninsulated Pipe (ft)	Pipe Diameter (in)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Key 27 boiler room	Storage Tank Water Heater (≤ 50 Gal)	8	30	0.75	0.0	0	10	\$87	\$173	\$60	1.3
Boiler room 2	Storage Tank Water Heater (≤ 50 Gal)	8	10	0.75	0.0	815	0	\$92	\$58	\$20	0.4
Boiler room 2	Storage Tank Water Heater (≤ 50 Gal)	8	6	0.75	0.0	497	0	\$56	\$35	\$12	0.4

DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis					
		System Quantity	System Type	Manufacturer	Model	Remaining Useful Life	ECM #	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives
Key 27 boiler room	Locker Rooms	1	Storage Tank Water Heater (≤ 50 Gal)	State Industries	PRX 40 NBRT971	W		No					0.0	0	0	\$0	\$0	\$0	0.0
Boiler room 2	Restrooms	1	Storage Tank Water Heater (≤ 50 Gal)	Rheem	82V40-2	W		No					0.0	0	0	\$0	\$0	\$0	0.0
Boiler room 2	Lounges	1	Storage Tank Water Heater (≤ 50 Gal)	Rheem	82V30-2	W		No					0.0	0	0	\$0	\$0	\$0	0.0

Low-Flow Device Recommendations

Location	Recommendation Inputs				Energy Impact & Financial Analysis							
	ECM #	Device Quantity	Device Type	Existing Flow Rate (gpm)	Proposed Flow Rate (gpm)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Garage 1	9	1	Faucet Aerator (Lavatory)	2.50	0.50	0.0	0	1	\$5	\$7	\$4	0.7
Men's locker room bathroom	9	1	Faucet Aerator (Lavatory)	2.20	0.50	0.0	0	3	\$24	\$7	\$4	0.1
Squad room	9	1	Faucet Aerator (Lavatory)	2.20	0.50	0.0	0	1	\$8	\$7	\$4	0.4
Women's locker room	9	1	Faucet Aerator (Lavatory)	2.20	0.50	0.0	0	3	\$24	\$7	\$4	0.1
Restroom - Female 1	9	1	Faucet Aerator (Lavatory)	2.20	0.50	0.0	139	0	\$16	\$7	\$4	0.2
Restroom -male 1	9	1	Faucet Aerator (Lavatory)	2.20	0.50	0.0	139	0	\$16	\$7	\$4	0.2

Plug Load Inventory

Existing Conditions						
Location	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified ?	Manufacturer	Model
Detective bureau	2	Coffee Machine	1,000	No		
Lounge 2	1	Coffee Machine	1,000	No		
Detective bureau	7	Desktop	270	No		
Main front office	7	Desktop	270	No		
Processing room	2	Desktop	270	No		
Squad room	6	Desktop	270	No		
Assistant chief office	2	Desktop	270	No		
Captain office	2	Desktop	270	No		
Chief office	2	Desktop	270	No		
Division commander	2	Desktop	270	No		
Support service manager	2	Desktop	270	No		
Training room	1	Desktop	270	No		
Detective bureau	1	Microwave	1,000	No		
Small break room	1	Microwave	1,000	No		
Squad room	1	Microwave	1,000	No		
Lounge 2	1	Microwave	1,000	No		
Squad room	2	Base Radio	100	No		
Detective bureau	1	Paper Shredder	500	No		
Detective bureau	1	Printer (Medium/Small)	300	No		
Main front office	1	Printer (Medium/Small)	300	No		
Processing room	1	Printer (Medium/Small)	300	No		
Squad room	2	Printer (Medium/Small)	300	No		
Assistant chief office	1	Printer (Medium/Small)	300	No		
Captain office	1	Printer (Medium/Small)	300	No		
Chief office	1	Printer (Medium/Small)	300	No		
Division commander	1	Printer (Medium/Small)	300	No		
Support service manager	1	Printer (Medium/Small)	300	No		
Squad room	1	Printer/Copier (Large)	600	No		
Conference 1	1	Printer/Copier (Large)	600	No		
Training room	1	Projector	300	No		
Detective bureau	1	Refrigerator (Mini)	212	No		
Evidence room	1	Refrigerator (Mini)	212	No		
Small break room	1	Refrigerator (Mini)	212	No		
Squad room	2	Refrigerator (Mini)	212	No		
Assistant chief office	1	Refrigerator (Mini)	212	No		

Existing Conditions						
Location	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified ?	Manufacturer	Model
Lounge 2	1	Refrigerator (Residential)	250	No		
Detective bureau	1	Scanner/Fax Machine	250	No		
Main front office	1	Scanner/Fax Machine	250	No		
Squad room	1	Scanner/Fax Machine	250	No		
Gymnasium 1	1	Television	212	No		
Squad room	3	Television	212	No		
Training room	2	Television	212	No		
Lounge 2	1	Toaster	1,000	No		
Small break room	1	Toaster Oven	2,000	No		
Lounge 2	1	Toaster Oven	2,000	No		
Detective bureau	1	Water Cooler	700	No		
Lounge 2	1	Water Cooler	700	No		

Custom (High Level) Measure Analysis

Heat Pump Water Heater

Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis										
Description	Area(s)/System(s) Served	SF of Area Served	Fuel Type	Input Capacity per Unit (kW)	Tank Capacity per Unit (Gal)	Description	COP	Tank Capacity per Unit (Gal)	Estimated Unit Cost	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Base Incentives	Enhanced Incentives	Total NJCEP Incentives	Total Net Cost	Payback w/o Incentives in Years	Payback w/ Incentives in Years
Storage Tank Water Heater (≤50 Gal)	Restrooms	500	Electric	4.5	40	Heat Pump Water Heater	2.5	40	\$2,069.90	0.00	1,882	0	\$211	\$2,070	\$0	\$0	\$0	\$2,070	9.81	9.81

APPENDIX B: ENERGY STAR® STATEMENT OF ENERGY PERFORMANCE

EUI is presented in terms of *site energy* and *source energy*. Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

ENERGY STAR® Statement of Energy Performance

LEARN MORE AT energystar.gov

N/A

Township of Morris Police Headquarters

Primary Property Type: Police Station
Gross Floor Area (ft²): 11,109
Built: 1965

For Year Ending: June 30, 2020
Date Generated: July 27, 2021

ENERGY STAR® Score¹

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information		
Property Address Township of Morris Police Headquarters 49 Woodland Avenue Morris Township, New Jersey 07960	Property Owner TwpofMorris 50 Woodland Avenue PO Box 7603 Convent Station, NJ 07961 973-326-7360	Primary Contact Timothy Quinn 50 Woodland Avenue PO Box 7603 Convent Station, NJ 07961 973-326-7360 tquinn@morristwp.com
Property ID: 15134242		

Energy Consumption and Energy Use Intensity (EUI)			
Site EUI 132.2 kBtu/ft²	Annual Energy by Fuel		National Median Comparison
	Natural Gas (kBtu)	906,657 (62%)	National Median Site EUI (kBtu/ft²) 72.6
	Electric - Grid (kBtu)	562,165 (38%)	National Median Source EUI (kBtu/ft²) 124.9
			% Diff from National Median Source EUI 82%
Source EUI 227.4 kBtu/ft²			Annual Emissions
			Greenhouse Gas Emissions (Metric Tons CO2e/year) 102

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

LP Signature: _____ Date: _____

Licensed Professional



Professional Engineer or Registered Architect Stamp (if applicable)

APPENDIX C: GLOSSARY

TERM	DEFINITION
Blended Rate	Used to calculate fiscal savings associated with measures. The blended rate is calculated by dividing the amount of your bill by the total energy use. For example, if your bill is \$22,217.22, and you used 266,400 kilowatt-hours, your blended rate is 8.3 cents per kilowatt-hour.
Btu	<i>British thermal unit</i> : a unit of energy equal to the amount of heat required to increase the temperature of one pound of water by one-degree Fahrenheit.
CHP	<i>Combined heat and power</i> . Also referred to as cogeneration.
COP	<i>Coefficient of performance</i> : a measure of efficiency in terms of useful energy delivered divided by total energy input.
Demand Response	Demand response reduces or shifts electricity usage at or among participating buildings/sites during peak energy use periods in response to time-based rates or other forms of financial incentives.
DCV	<i>Demand control ventilation</i> : a control strategy to limit the amount of outside air introduced to the conditioned space based on actual occupancy need.
US DOE	<i>United States Department of Energy</i>
EC Motor	<i>Electronically commutated motor</i>
ECM	<i>Energy conservation measure</i>
EER	<i>Energy efficiency ratio</i> : a measure of efficiency in terms of cooling energy provided divided by electric input.
EUI	<i>Energy Use Intensity</i> : measures energy consumption per square foot and is a standard metric for comparing buildings' energy performance.
Energy Efficiency	Reducing the amount of energy necessary to provide comfort and service to a building/area. Achieved through the installation of new equipment and/or optimizing the operation of energy use systems. Unlike conservation, which involves some reduction of service, energy efficiency provides energy reductions without sacrifice of service.
ENERGY STAR®	ENERGY STAR® is the government-backed symbol for energy efficiency. The ENERGY STAR® program is managed by the EPA.
EPA	<i>United States Environmental Protection Agency</i>
Generation	The process of generating electric power from sources of primary energy (e.g., natural gas, the sun, oil).
GHG	<i>Greenhouse gas</i> gases that are transparent to solar (short-wave) radiation but opaque to long-wave (infrared) radiation, thus preventing long-wave radiant energy from leaving Earth's atmosphere. The net effect is a trapping of absorbed radiation and a tendency to warm the planet's surface.
gpf	<i>Gallons per flush</i>

gpm	<i>Gallon per minute</i>
HID	<i>High intensity discharge: high-output lighting lamps such as high-pressure sodium, metal halide, and mercury vapor.</i>
hp	<i>Horsepower</i>
HPS	<i>High-pressure sodium: a type of HID lamp</i>
HSPF	<i>Heating seasonal performance factor: a measure of efficiency typically applied to heat pumps. Heating energy provided divided by seasonal energy input.</i>
HVAC	<i>Heating, ventilating, and air conditioning</i>
IHP 2014	<i>US DOE Integral Horsepower rule. The current ruling regarding required electric motor efficiency.</i>
IPLV	<i>Integrated part load value: a measure of the part load efficiency usually applied to chillers.</i>
kBtu	<i>One thousand British thermal units</i>
kW	<i>Kilowatt: equal to 1,000 Watts.</i>
kWh	<i>Kilowatt-hour: 1,000 Watts of power expended over one hour.</i>
LED	<i>Light emitting diode: a high-efficiency source of light with a long lamp life.</i>
LGEA	<i>Local Government Energy Audit</i>
Load	<i>The total power a building or system is using at any given time.</i>
Measure	<i>A single activity, or installation of a single type of equipment, that is implemented in a building system to reduce total energy consumption.</i>
MH	<i>Metal halide: a type of HID lamp</i>
MBh	<i>Thousand Btu per hour</i>
MBtu	<i>One thousand British thermal units</i>
MMBtu	<i>One million British thermal units</i>
MV	<i>Mercury Vapor: a type of HID lamp</i>
NJBPU	<i>New Jersey Board of Public Utilities</i>
NJCEP	<i>New Jersey's Clean Energy Program: NJCEP is a statewide program that offers financial incentives, programs and services for New Jersey residents, business owners and local governments to help them save energy, money and the environment.</i>
psig	<i>Pounds per square inch gauge</i>
Plug Load	<i>Refers to the amount of power used in a space by products that are powered by means of an ordinary AC plug.</i>
PV	<i>Photovoltaic: refers to an electronic device capable of converting incident light directly into electricity (direct current).</i>

SEER	<i>Seasonal energy efficiency ratio</i> : a measure of efficiency in terms of annual cooling energy provided divided by total electric input.
SEP	<i>Statement of energy performance</i> : a summary document from the ENERGY STAR® Portfolio Manager®.
Simple Payback	The amount of time needed to recoup the funds expended in an investment or to reach the break-even point between investment and savings.
SREC	<i>Solar renewable energy credit</i> : a credit you can earn from the state for energy produced from a photovoltaic array.
TREC	<i>Transition Incentive Renewable Energy Certificate</i> : a factorized renewable energy certificate you can earn from the state for energy produced from a photovoltaic array.
T5, T8, T12	A reference to a linear lamp diameter. The number represents increments of 1/8 th of an inch.
Temperature Setpoint	The temperature at which a temperature regulating device (thermostat, for example) has been set.
therm	100,000 Btu. Typically used as a measure of natural gas consumption.
tons	A unit of cooling capacity equal to 12,000 Btu/hr.
Turnkey	Provision of a complete product or service that is ready for immediate use
VAV	<i>Variable air volume</i>
VFD	<i>Variable frequency drive</i> : a controller used to vary the speed of an electric motor.
WaterSense®	The symbol for water efficiency. The WaterSense® program is managed by the EPA.
Watt (W)	Unit of power commonly used to measure electricity use.