



# Local Government Energy Audit Report

Lawrence Branch Library

July 29, 2020

*Prepared for:*

Mercer County

2751 Brunswick Pike

Lawrenceville, NJ 08648

*Prepared by:*

TRC

900 Route 9 North

Woodbridge, NJ 07095

## Disclaimer

---

The goal of this audit report is to identify potential energy efficiency opportunities, help prioritize specific measures for implementation, and provide information about financial incentives that may be available. Most energy conservation measures have received preliminary analysis of feasibility that identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to establish a basis for further discussion and to help prioritize energy measures.

TRC reviewed the energy conservation measures and estimates of energy savings for technical accuracy. Actual, achieved energy savings depend on behavioral factors and other uncontrollable variables and, therefore, estimates of final energy savings are not guaranteed. TRC and the New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

TRC bases estimated installation costs on our experience at similar facilities, pricing from local contractors and vendors, and/or cost estimates from RS Means. Cost estimates include material and labor pricing associated with installation of primary recommended equipment only. Cost estimates do not include demolition or removal of hazardous waste. We encourage the owner of the facility to independently confirm these cost estimates and to obtain multiple estimates when considering measure installations. Actual installation costs can vary widely based on individual measures and conditions. TRC and NJBPU do not guarantee installed cost estimates and shall in no event be held liable should actual installed costs vary from estimates.

New Jersey's Clean Energy Program (NJCEP) incentive values provided in this report are estimates based on program information available at the time of the report. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. Please review all available program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

The customer and their respective contractor(s) are responsible to implement energy conservation measures in complete conformance with all applicable local, state and federal requirements.

Copyright ©2020 TRC. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

# Table of Contents

---

<b>1</b>	<b>Executive Summary.....</b>	<b>1</b>
1.1	Planning Your Project .....	4
	Pick Your Installation Approach .....	4
	More Options from Around the State .....	6
<b>2</b>	<b>Existing Conditions.....</b>	<b>7</b>
2.1	Site Overview.....	7
2.2	Building Occupancy .....	7
2.3	Building Envelope .....	8
2.4	Lighting Systems.....	9
2.5	Air Handling Systems .....	10
	Packaged Units .....	10
	Standalone Heating Equipment .....	10
2.6	Domestic Hot Water .....	11
2.7	Plug Load & Vending Machines .....	11
2.8	Water-Using Systems .....	12
<b>3</b>	<b>Energy Use and Costs .....</b>	<b>13</b>
3.1	Electricity .....	15
3.2	Natural Gas .....	16
3.3	Benchmarking.....	17
	Tracking Your Energy Performance .....	18
<b>4</b>	<b>Energy Conservation Measures .....</b>	<b>19</b>
4.1	Lighting .....	21
	ECM 1: Install LED Fixtures .....	21
	ECM 2: Retrofit Fluorescent Fixtures with LED Lamps and Drivers .....	21
	ECM 3: Retrofit Fixtures with LED Lamps .....	22
4.2	Lighting Controls.....	22
	ECM 4: Install Occupancy Sensor Lighting Controls .....	22
	ECM 5: Install High/Low Lighting Controls .....	23
4.3	Variable Frequency Drives (VFD).....	23
	ECM 6: Install VFDs on Constant Volume (CV) Fans .....	23
4.4	Electric Unitary HVAC .....	24
	ECM 7: Install High Efficiency Air Conditioning Units.....	24
	ECM 8: Install High Efficiency Heat Pumps.....	24
4.5	Gas-Fired Heating .....	25
	ECM 9: Install High Efficiency Furnaces.....	25
	ECM 10: Install High Efficiency Unit Heaters.....	25
4.6	Custom Measures.....	26

ECM 11: Installation of an Energy Management System .....	26
<b>5 Energy Efficient Best Practices .....</b>	<b>27</b>
Energy Tracking with ENERGY STAR® Portfolio Manager® .....	27
Weatherization.....	27
Doors and Windows .....	27
Lighting Maintenance.....	27
Lighting Controls .....	28
Motor Maintenance .....	28
Thermostat Schedules and Temperature Resets .....	28
Economizer Maintenance .....	28
AC System Evaporator/Condenser Coil Cleaning .....	28
HVAC Filter Cleaning and Replacement .....	28
Duct Sealing.....	29
Furnace Maintenance .....	29
Water Heater Maintenance .....	29
Water Conservation .....	30
Procurement Strategies .....	30
<b>6 On-site Generation .....</b>	<b>31</b>
6.1 Solar Photovoltaic .....	32
6.2 Combined Heat and Power .....	33
<b>7 Project Funding and Incentives.....</b>	<b>34</b>
7.1 SmartStart .....	35
7.2 Direct Install .....	36
7.3 Pay for Performance - Existing Buildings.....	37
7.4 Combined Heat and Power .....	38
7.5 SREC Registration Program.....	39
<b>8 Energy Purchasing and Procurement Strategies .....</b>	<b>40</b>
8.1 Retail Electric Supply Options.....	40
8.2 Retail Natural Gas Supply Options .....	40
<b>Appendix A: Equipment Inventory &amp; Recommendations .....</b>	<b>A-1</b>
<b>Appendix B: ENERGY STAR® Statement of Energy Performance.....</b>	<b>B-1</b>
<b>Appendix C: Glossary .....</b>	<b>C-1</b>

# 1 EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBPB) has sponsored this Local Government Energy Audit (LGEA) report for Lawrence Branch Library. This report provides you with information about your facility's energy use, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help make changes in your facility. TRC conducted this study as part of a comprehensive effort to assist New Jersey school districts and local governments in controlling their energy costs and to help protect our environment by reducing statewide energy consumption.


## BUILDING PERFORMANCE REPORT



Costs: \$91,949

Annual Utilities  
Electricity:  
433,904 kWh

Natural Gas:  
11,295 Therms



ENERGY STAR®  
Benchmarking Score

N/A  
(1-100 scale)

A standard energy use benchmark is not available for this facility type. This report contains suggestions about how to improve building performance and reduce energy costs.




Figure 1 - Energy Use by System


## POTENTIAL IMPROVEMENTS



This energy audit considered a range of potential energy improvements in your building. Costs and savings will vary between improvements. Presented below are two potential scopes of work for your consideration.


### Scenario 1: Full Package (all evaluated measures)

Installation Cost	\$487,282
Potential Rebates & Incentives <sup>1</sup>	\$58,101
Annual Cost Savings	\$30,436
Annual Energy Savings	Electricity: 158,788 kWh Natural Gas: 889 Therms
Greenhouse Gas Emission Savings	85 Tons
Simple Payback	14.1 Years
Site Energy Savings (all utilities)	24%



### Scenario 2: Cost Effective Package<sup>2</sup>

Installation Cost	\$89,873
Potential Rebates & Incentives	\$29,421
Annual Cost Savings	\$20,243
Annual Energy Savings	Electricity: 109,814 kWh
Greenhouse Gas Emission Savings	54 Tons
Simple Payback	3.0 Years
Site Energy Savings (all utilities)	14%



### On-site Generation Potential

Photovoltaic	High
Combined Heat and Power	None

<sup>1</sup> Incentives are based on current SmartStart Prescriptive incentives. Other Program incentives may apply.

<sup>2</sup> A cost-effective measure is defined as one where the simple payback does not exceed two-thirds of the expected proposed equipment useful life. Simple payback is based on the net measure cost after potential incentives.

#	Energy Conservation Measure	Cost Effective?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>			<b>56,124</b>	<b>14.1</b>	<b>-11</b>	<b>\$10,335</b>	<b>\$38,624</b>	<b>\$17,066</b>	<b>\$21,558</b>	<b>2.1</b>	<b>55,203</b>
ECM 1	Install LED Fixtures	Yes	7,881	1.3	-1	\$1,458	\$13,615	\$6,000	\$7,615	5.2	7,826
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	Yes	5,872	1.7	-1	\$1,081	\$2,971	\$760	\$2,211	2.0	5,767
ECM 3	Retrofit Fixtures with LED Lamps	Yes	42,371	11.1	-9	\$7,797	\$22,038	\$10,306	\$11,732	1.5	41,611
<b>Lighting Control Measures</b>			<b>40,575</b>	<b>10.5</b>	<b>-9</b>	<b>\$7,467</b>	<b>\$39,427</b>	<b>\$9,755</b>	<b>\$29,672</b>	<b>4.0</b>	<b>39,847</b>
ECM 4	Install Occupancy Sensor Lighting Controls	Yes	37,648	9.8	-8	\$6,928	\$36,952	\$9,530	\$27,422	4.0	36,972
ECM 5	Install High/Low Lighting Controls	Yes	2,928	0.6	-1	\$539	\$2,475	\$225	\$2,250	4.2	2,875
<b>Variable Frequency Drive (VFD) Measures</b>			<b>13,114</b>	<b>3.3</b>	<b>0</b>	<b>\$2,441</b>	<b>\$11,822</b>	<b>\$2,600</b>	<b>\$9,222</b>	<b>3.8</b>	<b>13,206</b>
ECM 6	Install VFDs on Constant Volume (CV) Fans	Yes	13,114	3.3	0	\$2,441	\$11,822	\$2,600	\$9,222	3.8	13,206
<b>Electric Unitary HVAC Measures</b>			<b>38,969</b>	<b>34.6</b>	<b>0</b>	<b>\$7,253</b>	<b>\$264,132</b>	<b>\$21,480</b>	<b>\$242,652</b>	<b>33.5</b>	<b>39,242</b>
ECM 7	Install High Efficiency Air Conditioning Units	No	5,945	7.7	0	\$1,107	\$94,626	\$7,724	\$86,902	78.5	5,987
ECM 8	Install High Efficiency Heat Pumps	No	33,024	26.9	0	\$6,147	\$169,506	\$13,756	\$155,750	25.3	33,255
<b>Gas Heating (HVAC/Process) Replacement</b>			<b>0</b>	<b>0.0</b>	<b>53</b>	<b>\$526</b>	<b>\$21,277</b>	<b>\$7,200</b>	<b>\$14,077</b>	<b>26.8</b>	<b>6,218</b>
ECM 9	Install High Efficiency Furnaces	No	0	0.0	50	\$492	\$19,524	\$7,200	\$12,324	25.0	5,822
ECM 10	Install High Efficiency Unit Heaters	No	0	0.0	3	\$33	\$1,753	\$0	\$1,753	52.4	396
<b>Custom Measures</b>			<b>10,004</b>	<b>0.0</b>	<b>56</b>	<b>\$2,413</b>	<b>\$112,000</b>	<b>\$0</b>	<b>\$112,000</b>	<b>46.4</b>	<b>16,590</b>
ECM 11	Installation of an Energy Management System	No	10,004	0.0	56	\$2,413	\$112,000	\$0	\$112,000	46.4	16,590
<b>TOTALS (COST EFFECTIVE MEASURES)</b>			<b>109,814</b>	<b>27.8</b>	<b>-20</b>	<b>\$20,243</b>	<b>\$89,873</b>	<b>\$29,421</b>	<b>\$60,452</b>	<b>3.0</b>	<b>108,257</b>
<b>TOTALS (ALL MEASURES)</b>			<b>158,788</b>	<b>62.4</b>	<b>89</b>	<b>\$30,436</b>	<b>\$487,282</b>	<b>\$58,101</b>	<b>\$429,181</b>	<b>14.1</b>	<b>170,306</b>

\* - All incentives presented in this table are based on NJ SmartStart equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 2 – Evaluated Energy Improvements

For more detail on each evaluated energy improvement and a break out of cost-effective improvements, see **Section 4: Energy Conservation Measures**.

## 1.1 Planning Your Project

Careful planning makes for a successful energy project. When considering this scope of work, you will have some decisions to make, such as:

- ◆ How will the project be funded and/or financed?
- ◆ Is it best to pursue individual ECMs, groups of ECMs, or use a comprehensive approach where all ECMs are installed together?
- ◆ Are there other facility improvements that should happen at the same time?

### Pick Your Installation Approach

New Jersey's Clean Energy Programs give you the flexibility to do a little or a lot. Rebates, incentives, and financing are available to help reduce both your installation costs and your energy bills. If you are planning to take advantage of these programs, make sure to review incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives before purchasing materials or starting installation.

The potential ECMs identified for this building likely qualify for multiple incentive and funding programs. Based on current program rules and requirements, your measures are likely to qualify for the following programs:

Energy Conservation Measure		SmartStart	Direct Install	Pay For Performance
ECM 1	Install LED Fixtures	X	X	
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	X	X	
ECM 3	Retrofit Fixtures with LED Lamps	X	X	
ECM 4	Install Occupancy Sensor Lighting Controls	X	X	
ECM 5	Install High/Low Lighting Controls	X	X	
ECM 6	Install VFDs on Constant Volume (CV) Fans	X	X	
ECM 7	Install High Efficiency Air Conditioning Units	X	X	
ECM 8	Install High Efficiency Heat Pumps	X	X	
ECM 9	Install High Efficiency Furnaces	X	X	
ECM 10	Install High Efficiency Unit Heaters		X	
ECM 11	Installation of an Energy Management System		X	

*Figure 3 – Funding Options*



## New Jersey's Clean Energy Programs At-A-Glance

	<b>SmartStart</b> Flexibility to install at your own pace	<b>Direct Install</b> Turnkey installation	<b>Pay for Performance</b> Whole building upgrades
<b>Who should use it?</b>	Buildings installing individual measures or small group of measures.	Small to mid-size facilities that can bundle multiple measures together.  Average peak demand should be below 200 kW.  Not suitable for significant building shell issues.	Mid to large size facilities looking to implement as many measures as possible at one time.  Peak demand should be over 200 kW.
<b>How does it work?</b>	Use in-house staff or your preferred contractor.	Pre-approved contractors pass savings along to you via reduced material and labor costs.	Whole-building approach to energy upgrades designed to reduce energy use by at least 15%. The more you save, the higher the incentives.
<b>What are the Incentives?</b>	Fixed incentives for specific energy efficiency measures.	Incentives pay up to 70% of eligible costs, up to \$125,000 per project.  You pay the remaining 30% directly to the contractor.	Up to 25% of installation cost, calculated based on level of energy savings per square foot.
<b>How do I participate?</b>	Submit an application for the specific equipment to be installed.	Contact a participating contractor in your region.	Contact a pre-qualified Partner to develop your Energy Reduction Plan and set your energy savings targets.

Take the next step by visiting [www.njcleanenergy.com](http://www.njcleanenergy.com) for program details, applications, and to contact a qualified contractor.

### *Individual Measures with SmartStart*

For facilities wishing to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the SmartStart program. To participate, you can use internal resources or an outside firm or contractor to perform the final design of the ECM(s) and install the equipment. Program pre-approval is required for some SmartStart incentives, so only after receiving pre-approval should you proceed with ECM installation.

### *Turnkey Installation with Direct Install*

The Direct Install program provides turnkey installation of multiple measures through an authorized network of participating contractors. This program can provide substantially higher incentives than SmartStart, up to 70% of the cost of selected measures. Direct Install contractors will assess and verify individual measure eligibility, and, in most cases, they perform the installation work. The Direct Install program is available to sites with an average peak demand of less than 200 kW.

### *Whole Building Approach with Pay for Performance*

Pay for Performance can be a good option for medium to large sized facilities to achieve deep energy savings. Pay for Performance allows you to install as many measures as possible under a single project as well as address measures that may not qualify for other programs. Many facilities pursuing an Energy Savings Improvement Program (ESIP) loan also use this program. Pay for Performance works for larger customers with a peak demand over 200 kW. The minimum installed scope of work must include at least two unique measures resulting in at least 15% energy savings, where lighting cannot make up the majority of the savings.

## **More Options from Around the State**

### *Financing and Planning Support with the Energy Savings Improvement Program (ESIP)*

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the ESIP. Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as, attractive financing for implementing ECMs. You have already taken the first step as an LGEA customer, because this report is required to participate in ESIP.

### *Resiliency with Return on Investment through Combined Heat & Power (CHP)*

The CHP program provides incentives for combined heat and power (aka cogeneration) and waste heat to power projects. Combined heat and power systems generate power on-site and recover heat from the generation system to meet on-site thermal loads. Waste heat to power systems use waste heat to generate power. You will work with a qualified developer who will design a system that meets your building's heating and cooling needs.

### *Ongoing Electric Savings with Demand Response*

The Demand Response Energy Aggregator program reduces electric loads at commercial facilities when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. By enabling commercial facilities to reduce electric demand during times of peak demand, the grid is made more reliable and overall transmission costs are reduced for all ratepayers. Curtailment service providers provide regular payments to medium and large consumers of electric power for their participation in demand response (DR) programs. Program participation is voluntary, and facilities receive payments regardless of whether they are called upon to curtail their load during times of peak demand.

## 2 EXISTING CONDITIONS

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) Report for Lawrence Branch Library. This report provides information on how your facility uses energy, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help you implement the ECMs. This report also contains valuable information on financial incentives from New Jersey's Clean Energy Program (NJCEP) for implementing ECMs.


TRC conducted this study as part of a comprehensive effort to assist New Jersey educational and local government facilities in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

### 2.1 Site Overview


On January 8, 2020, TRC performed an energy audit at Lawrence Branch Library located in Lawrenceville, New Jersey. TRC met with Bob Reali to review the facility operations and help focus our investigation on specific energy-using systems.

Lawrence Branch Library is a one-story, 56,000 square feet building built in 1983. Spaces include: mezzanine, work shop, receiving and supply rooms, garage, acquisition and catalogue rooms, administrative offices, computer and IT Labs, lobbies, lounge room, children activities room, lower stacks, skylight areas, reading areas, restrooms and storage rooms. The building was expanded in 1997 to gain an additional 7,000 square feet of library spaces. The building also houses the Mercer County library administrative offices.

During the last five years, the County has retrofitted most of the interior and exterior lighting systems to LED fixtures. Most of the rooftop units are beyond their useful life and have been evaluated for replacement.



*Main Area*



*Center Skylight*

### 2.2 Building Occupancy

The facility is occupied year-round. Typical weekday occupancy is 23 staff.

Building Name	Weekday/Weekend	Operating Schedule
Mercer County Public Library - Lawrence Branch	Weekday	8:30 AM - 9:00 PM
	Weekend	8:30 AM - 5:00 PM (Saturday) 12:00 PM - 5:00 PM (Sunday)

*Figure 4 - Building Occupancy Schedule*

## 2.3 Building Envelope

Building walls are concrete block over structural steel. The building's newer addition walls are finished with brick veneer and gypsum drywall interior finish, while the original building façade is finished with concrete masonry units.

Steel trusses support the roof, which is a combination of flat and curved steel roof sections. The flat roof is a prestressed concrete deck and finished with insulated layer with a black membrane covering. It supports the HVAC equipment. There is also a center skylight, pitched roof section.

Windows are typically double glazed and have aluminum frames. The glass-to-frame seals are in fair to good condition. The window weather seals are in good condition, showing little evidence of excessive wear. Exterior doors have aluminum frames and are in good condition with undamaged door seals. Exit doors are constructed of metal. Portions of the newer addition exterior doors have signs of insulation damage.



*Building Walls – Newer Addition*



*Building Walls - Newer Addition*



*Building Wall & Windows - Original Building*




*Building Wall and Windows - Original Building*



*Flat Roof*



*Curved Roof*



*Windows & Exterior Doors - Newer Addition*



*Windows and Exterior Doors - Newer Addition*



*Main Entrance Doors*




*Sign of Insulation Damage*

## 2.4 Lighting Systems

The primary interior lighting system uses both LED linear tubes and LED panel fixtures. There are also several 32-Watt T8 and 40-Watt T12 fixtures. Typically, T8 fluorescent lamps use electronic ballasts and T12 fluorescent lamps use magnetic ballasts.

Linear fluorescent fixture types include 1-lamp, 4-foot or 8-foot long troffer, recessed, and surface mounted fixtures. They are found in the computer lab, storage room, non-fiction stacks, circulation area, children stacks, and east lobby. The ramp area is lit with 18-Watt LED screw in lamps. Remaining interior areas are lit either with LED tubes or LED panel fixtures. Most fixtures are in good condition. All exit signs are LED. Interior lighting levels were generally sufficient. Light fixtures in some office areas are controlled by occupancy sensors. Most lighting fixtures are controlled by wall switches.


Exterior lighting is mainly provided by LED wall mounted, recessed, and parking lot pole mounted fixtures. Additionally, there are wall sconce, walkway pole mounted, and front step light fixtures with metal halide lamps. Two ground mounted up-light fixtures are used to illuminate the flag. LED fixtures, except for those in the parking lot, are controlled with photocells. Metal halide fixtures and the LED parking lot lights are controlled with timers.




*LED Tubes*



*LED Tubes*




*T8 and T12 Fixtures*



*LED Screen in Lamps*



*Occupancy Sensor*



*Timer*



*Wall Sconce Fixture*



*Parking Lot LED*



*Walkway Metal Halide*



*Wall Pack LED Fixture*



*LED Fixture*



*LED Fixture*

## 2.5 Air Handling Systems

### Packaged Units

The library is served by 11 packaged roof top units (RTUs) and 23 packaged heat pumps. The packaged RTUs range in size from 5 tons to 12.5 tons. These units are constant air volume, and the newer Trane RTUs are equipped with economizers. The RTUs are equipped with gas-fired furnace sections that have heating capacities ranging from 41 MBh to 203 MBh. The packaged heat pumps range in size from 2 tons to 6 tons and have heating capacities ranging from 22.4 MBh to 50.5 MBh. Most of the packaged RTUs and heat pumps are beyond their useful life and have been evaluated for replacement. There are controlled with programmable thermostats.

### Standalone Heating Equipment

The mezzanine is heated using a 140 MBh Reznor roof mounted furnace that is beyond its useful life and appears in fair condition, while the garage is served with an old 60 MBh Reznor warm air heater. The Reznor units are controlled via local thermostats.

The Reznor warm air heater is connected to a roof mounted exhaust fan. There are also several roof mounted exhaust fans that serve restrooms and other areas. The exhaust fans are controlled with a timeclock.

Refer to Appendix A for detailed information about each unit.



*Newer Trane  
Packaged RTUs*



*Old Carrier  
Packaged RTUs*



*Old Carrier Heat  
Pumps*



*Newer Trane Heat  
Pumps*



*Reznor Heater*



*Programmable  
Thermostat*



*Local Thermostat*



*Reznor Furnace*



*Exhaust Fans*

## 2.6 Domestic Hot Water

Hot water is produced with three 19-gallon, 2.5 kW electric storage water heaters located in the Janitorial closets and above the ceiling respectively. The water heaters are in good condition. The domestic hot water pipes are insulated, and the insulation is in good condition.



*Electric Water Heaters*


## 2.7 Plug Load & Vending Machines

The location is doing a great job managing their electrical plug loads. This report makes additional suggestions for ECMs in this area as well as Energy Efficient Best Practices.

There are 124 computer work stations throughout the facility. Plug loads throughout the building include general café and office equipment. There are three residential-style refrigerators in the building that are used by staff. The units are standard efficiency and in good condition.



*Copier*



*Water Cooler*

## 2.8 Water-Using Systems

There are seven restrooms with toilets, urinals, and sinks. Faucet flow are rated as low flow.




*Sink*

### 3 ENERGY USE AND COSTS

Twelve months of utility billing data are used to develop annual energy consumption and cost data. This information creates a profile of the annual energy consumption and energy costs.

Utility Summary		
Fuel	Usage	Cost
Electricity	433,904 kWh	\$80,763
Natural Gas	11,295 Therms	\$11,187
Total		\$91,949



An energy balance identifies and quantifies energy use in your various building systems. This can highlight areas with the most potential for improvement. This energy balance was developed using calculated energy use for each of the end uses noted in the figure.

The energy auditor collects information regarding equipment operating hours, capacity, efficiency, and other operational parameters from facility staff, drawings, and on-site observations. This information is used as the inputs to calculate the existing conditions energy use for the site. The calculated energy use is then compared to the historical energy use and the initial inputs are revised, as necessary, to balance the calculated energy use to the historical energy use.





Figure 5 - Energy Balance

### 3.1 Electricity

PSE&G delivers electricity under rate class GLP.




Electric Billing Data					
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost
5/14/18	31	34,057	156	\$559	\$6,497
6/15/18	30	34,221	131	\$581	\$7,375
7/14/18	31	46,952	172	\$2,072	\$8,413
8/15/18	31	44,728	168	\$2,031	\$8,098
9/14/18	30	41,822	169	\$2,039	\$7,850
10/15/18	31	34,970	141	\$505	\$5,755
11/13/18	30	28,683	95	\$346	\$5,207
12/14/18	31	33,952	129	\$483	\$5,979
1/15/19	31	35,421	136	\$511	\$6,397
2/14/19	28	39,106	148	\$554	\$6,897
3/15/19	31	34,371	135	\$505	\$6,595
4/14/19	30	25,621	97	\$364	\$5,700
<b>Totals</b>	<b>365</b>	<b>433,904</b>	<b>172</b>	<b>\$10,551</b>	<b>\$80,763</b>
<b>Annual</b>	<b>365</b>	<b>433,904</b>	<b>172</b>	<b>\$10,551</b>	<b>\$80,763</b>

Notes:

- Peak demand of 172 kW occurred in June 2018.
- Average demand over the past 12 months was 140 kW.
- The average electric cost over the past 12 months was \$0.186/kWh, which is the blended rate that includes energy supply, distribution, demand, and other charges. This report uses this blended rate to estimate energy cost savings.

## 3.2 Natural Gas

PSE&G delivers natural gas under rate class GSG.



Gas Billing Data			
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost
5/14/18	31	285	\$246
6/15/18	30	36	\$42
7/14/18	31	32	\$39
8/15/18	31	16	\$25
9/14/18	30	14	\$23
10/15/18	31	26	\$34
11/13/18	30	683	\$656
12/14/18	31	2,007	\$2,047
1/15/19	31	2,305	\$2,456
2/14/19	28	2,674	\$2,676
3/15/19	31	2,258	\$2,142
4/14/19	30	960	\$801
<b>Totals</b>	<b>365</b>	<b>11,295</b>	<b>\$11,187</b>
<b>Annual</b>	<b>365</b>	<b>11,295</b>	<b>\$11,187</b>

Notes:

- The average gas cost for the past 12 months is \$0.990/therm, which is the blended rate used throughout the analysis.

### 3.3 Benchmarking

Your building was benchmarked using the United States Environmental Protection Agency's (EPA) *Portfolio Manager*® software. Benchmarking compares your building's energy use to that of similar buildings across the country, while neutralizing variations due to location, occupancy and operating hours. Some building types can be scored with a 1-100 ranking of a building's energy performance relative to the national building market. A score of 50 represents the national average and a score of 100 is best.

This ENERGY STAR® benchmarking score provides a comprehensive snapshot of your building's energy performance. It assesses the building's physical assets, operations, and occupant behavior, which is compiled into a quick and easy-to-understand score.

#### Benchmarking Score

N/A

Due to its unique characteristics, this building type is not able to receive a benchmarking score. This report contains suggestions about how to improve building performance and reduce energy costs.




Figure 6 - Energy Use Intensity Comparison<sup>3</sup>

Energy use intensity (EUI) measures energy consumption per square foot and is the standard metric for comparing buildings' energy performance. A lower EUI means better performance and less energy consumed. A number of factors can cause a building to vary from the "typical" energy usage. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and occupant behavior all contribute to a building's energy use and the benchmarking score.

<sup>3</sup> Based on all evaluated ECMs

### **Tracking Your Energy Performance**

Keeping track of your energy use on a monthly basis is one of the best ways to keep energy costs in check. Update your utility information in Portfolio Manager® regularly, so that you can keep track of your building's performance.

**We have created a Portfolio Manager® account for your facility and we have already entered the monthly utility data shown above for you. Account login information for your account will be sent via email.**

Free online training is available to help you use ENERGY STAR® Portfolio Manager® to track your building's performance at: <https://www.energystar.gov/buildings/training>.

For more information on ENERGY STAR® and Portfolio Manager®, visit their website<sup>4</sup>.

---

<sup>4</sup> <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/earn-recognition/energy-star-certification/how-app-1>.

## 4 ENERGY CONSERVATION MEASURES

---

The goal of this audit report is to identify and evaluate potential energy efficiency improvements, provide information about the cost effectiveness of those improvements, and recognize potential financial incentives from NJBPU. Most energy conservation measures have received preliminary analysis of feasibility which identifies expected ranges of savings and costs. This level of analysis is typically sufficient to demonstrate project cost-effectiveness and help prioritize energy measures.

Calculations of energy use and savings are based on the current version of the *New Jersey's Clean Energy Program Protocols to Measure Resource Savings*, which is approved by the NJBPU. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances.

Operation and maintenance costs for the proposed new equipment will generally be lower than the current costs for the existing equipment—especially if the existing equipment is at or past its normal useful life. We have conservatively assumed there to be no impact on overall maintenance costs over the life of the equipment.

Financial incentives are based on the current NJCEP prescriptive SmartStart program. A higher level of investigation may be necessary to support any SmartStart Custom, Pay for Performance, or Direct Install incentive applications. Some measures and proposed upgrades may be eligible for higher incentives than those shown below through other NJCEP programs described in a following section of this report.

For a detailed list of the locations and recommended energy conservation measures for all inventoried equipment, see **Appendix A: Equipment Inventory & Recommendations**.

#	Energy Conservation Measure	Cost Effective?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$) *	Estimated Net Cost (\$)	Simple Payback Period (yrs) **	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>			<b>56,124</b>	<b>14.1</b>	<b>-11</b>	<b>\$10,335</b>	<b>\$38,624</b>	<b>\$17,066</b>	<b>\$21,558</b>	<b>2.1</b>	<b>55,203</b>
ECM 1	Install LED Fixtures	Yes	7,881	1.3	-1	\$1,458	\$13,615	\$6,000	\$7,615	5.2	7,826
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	Yes	5,872	1.7	-1	\$1,081	\$2,971	\$760	\$2,211	2.0	5,767
ECM 3	Retrofit Fixtures with LED Lamps	Yes	42,371	11.1	-9	\$7,797	\$22,038	\$10,306	\$11,732	1.5	41,611
<b>Lighting Control Measures</b>			<b>40,575</b>	<b>10.5</b>	<b>-9</b>	<b>\$7,467</b>	<b>\$39,427</b>	<b>\$9,755</b>	<b>\$29,672</b>	<b>4.0</b>	<b>39,847</b>
ECM 4	Install Occupancy Sensor Lighting Controls	Yes	37,648	9.8	-8	\$6,928	\$36,952	\$9,530	\$27,422	4.0	36,972
ECM 5	Install High/Low Lighting Controls	Yes	2,928	0.6	-1	\$539	\$2,475	\$225	\$2,250	4.2	2,875
<b>Variable Frequency Drive (VFD) Measures</b>			<b>13,114</b>	<b>3.3</b>	<b>0</b>	<b>\$2,441</b>	<b>\$11,822</b>	<b>\$2,600</b>	<b>\$9,222</b>	<b>3.8</b>	<b>13,206</b>
ECM 6	Install VFDs on Constant Volume (CV) Fans	Yes	13,114	3.3	0	\$2,441	\$11,822	\$2,600	\$9,222	3.8	13,206
<b>Electric Unitary HVAC Measures</b>			<b>38,969</b>	<b>34.6</b>	<b>0</b>	<b>\$7,253</b>	<b>\$264,132</b>	<b>\$21,480</b>	<b>\$242,652</b>	<b>33.5</b>	<b>39,242</b>
ECM 7	Install High Efficiency Air Conditioning Units	No	5,945	7.7	0	\$1,107	\$94,626	\$7,724	\$86,902	78.5	5,987
ECM 8	Install High Efficiency Heat Pumps	No	33,024	26.9	0	\$6,147	\$169,506	\$13,756	\$155,750	25.3	33,255
<b>Gas Heating (HVAC/Process) Replacement</b>			<b>0</b>	<b>0.0</b>	<b>53</b>	<b>\$526</b>	<b>\$21,277</b>	<b>\$7,200</b>	<b>\$14,077</b>	<b>26.8</b>	<b>6,218</b>
ECM 9	Install High Efficiency Furnaces	No	0	0.0	50	\$492	\$19,524	\$7,200	\$12,324	25.0	5,822
ECM 10	Install High Efficiency Unit Heaters	No	0	0.0	3	\$33	\$1,753	\$0	\$1,753	52.4	396
<b>Custom Measures</b>			<b>10,004</b>	<b>0.0</b>	<b>56</b>	<b>\$2,413</b>	<b>\$112,000</b>	<b>\$0</b>	<b>\$112,000</b>	<b>46.4</b>	<b>16,590</b>
ECM 11	Installation of an Energy Management System	No	10,004	0.0	56	\$2,413	\$112,000	\$0	\$112,000	46.4	16,590
<b>TOTALS</b>			<b>158,788</b>	<b>62.4</b>	<b>89</b>	<b>\$30,436</b>	<b>\$487,282</b>	<b>\$58,101</b>	<b>\$429,181</b>	<b>14.1</b>	<b>170,306</b>

\* - All incentives presented in this table are based on NJ SmartStart equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 7 – All Evaluated ECMs

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$) *	Estimated Net Cost (\$)	Simple Payback Period (yrs) **	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>		<b>56,124</b>	<b>14.1</b>	<b>-11</b>	<b>\$10,335</b>	<b>\$38,624</b>	<b>\$17,066</b>	<b>\$21,558</b>	<b>2.1</b>	<b>55,203</b>
ECM 1	Install LED Fixtures	7,881	1.3	-1	\$1,458	\$13,615	\$6,000	\$7,615	5.2	7,826
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	5,872	1.7	-1	\$1,081	\$2,971	\$760	\$2,211	2.0	5,767
ECM 3	Retrofit Fixtures with LED Lamps	42,371	11.1	-9	\$7,797	\$22,038	\$10,306	\$11,732	1.5	41,611
<b>Lighting Control Measures</b>		<b>40,575</b>	<b>10.5</b>	<b>-9</b>	<b>\$7,467</b>	<b>\$39,427</b>	<b>\$9,755</b>	<b>\$29,672</b>	<b>4.0</b>	<b>39,847</b>
ECM 4	Install Occupancy Sensor Lighting Controls	37,648	9.8	-8	\$6,928	\$36,952	\$9,530	\$27,422	4.0	36,972
ECM 5	Install High/Low Lighting Controls	2,928	0.6	-1	\$539	\$2,475	\$225	\$2,250	4.2	2,875
<b>Variable Frequency Drive (VFD) Measures</b>		<b>13,114</b>	<b>3.3</b>	<b>0</b>	<b>\$2,441</b>	<b>\$11,822</b>	<b>\$2,600</b>	<b>\$9,222</b>	<b>3.8</b>	<b>13,206</b>
ECM 6	Install VFDs on Constant Volume (CV) Fans	13,114	3.3	0	\$2,441	\$11,822	\$2,600	\$9,222	3.8	13,206
<b>TOTALS</b>		<b>109,814</b>	<b>27.8</b>	<b>-20</b>	<b>\$20,243</b>	<b>\$89,873</b>	<b>\$29,421</b>	<b>\$60,452</b>	<b>3.0</b>	<b>108,257</b>

\* - All incentives presented in this table are based on NJ SmartStart equipment incentives and assume proposed equipment meets minimum performance criteria for that program.

\*\* - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 8 – Cost Effective ECMs

## 4.1 Lighting

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Upgrades</b>		<b>56,124</b>	<b>14.1</b>	<b>-11</b>	<b>\$10,335</b>	<b>\$38,624</b>	<b>\$17,066</b>	<b>\$21,558</b>	<b>2.1</b>	<b>55,203</b>
ECM 1	Install LED Fixtures	7,881	1.3	-1	\$1,458	\$13,615	\$6,000	\$7,615	5.2	7,826
ECM 2	Retrofit Fluorescent Fixtures with LED Lamps and Drivers	5,872	1.7	-1	\$1,081	\$2,971	\$760	\$2,211	2.0	5,767
ECM 3	Retrofit Fixtures with LED Lamps	42,371	11.1	-9	\$7,797	\$22,038	\$10,306	\$11,732	1.5	41,611

When considering lighting upgrades, we suggest using a comprehensive design approach that simultaneously upgrades lighting fixtures and controls to maximize energy savings and improve occupant lighting. Comprehensive design will also consider appropriate lighting levels for different space types to make sure that the right amount of light is delivered where needed. If conversion to LED light sources are proposed, we suggest converting all of a specific lighting type (e.g., linear fluorescent) to LED lamps to minimize the number of lamp types in use at the facility, which should help reduce future maintenance costs.

### **ECM 1: Install LED Fixtures**

Replace existing fixtures containing metal halide lamps with new LED light fixtures. This measure saves energy by installing LEDs which use less power than other technologies with a comparable light output.

In some cases, HID fixtures can be retrofit with screw-based LED lamps. Replacing an existing HID fixture with a new LED fixture will generally provide better overall lighting optics; however, replacing the HID lamp with a LED screw-in lamp is typically a less expensive retrofit. We recommend you work with your lighting contractor to determine which retrofit solution is best suited to your needs and will be compatible with the existing fixture(s).

Maintenance savings may also be achieved since LED lamps last longer than other light sources and therefore do not need to be replaced as often.

**Affected building areas:** “glass box” area, east lobby, and exterior fixtures.

### **ECM 2: Retrofit Fluorescent Fixtures with LED Lamps and Drivers**

Retrofit fluorescent fixtures by removing the fluorescent tubes and ballasts and replacing them with LED tubes and LED drivers (if necessary), which are designed to be used in retrofitted fluorescent fixtures.

The measure uses the existing fixture housing but replaces the electric components with more efficient lighting technology which use less power than other lighting technologies but provides equivalent lighting output. Maintenance savings may also be achieved since LED tubes last longer than fluorescent tubes and therefore do not need to be replaced as often.

**Affected building areas:** all areas with fluorescent fixtures with T12 tubes (computer lab and children stacks).

### ECM 3: Retrofit Fixtures with LED Lamps

Replace fluorescent T8 lamps with LED lamps. Many LED tubes are direct replacements for existing fluorescent tubes and can be installed while leaving the fluorescent fixture ballast in place. LED lamps can be used in existing fixtures as a direct replacement for most other lighting technologies.

This measure saves energy by installing LEDs which use less power than other lighting technologies yet provide equivalent lighting output for the space. Maintenance savings may also be available, as longer-lasting LEDs lamps will not need to be replaced as often as the existing lamps.

**Affected building areas:** all areas with fluorescent fixtures with T8 tubes (non-fiction stacks, circulation areas, east lobby, room 101, children stacks, periodical & reference areas, and lower stacks).

## 4.2 Lighting Controls

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Lighting Control Measures</b>		<b>40,575</b>	<b>10.5</b>	<b>-9</b>	<b>\$7,467</b>	<b>\$39,427</b>	<b>\$9,755</b>	<b>\$29,672</b>	<b>4.0</b>	<b>39,847</b>
ECM 4	Install Occupancy Sensor Lighting Controls	37,648	9.8	-8	\$6,928	\$36,952	\$9,530	\$27,422	4.0	36,972
ECM 5	Install High/Low Lighting Controls	2,928	0.6	-1	\$539	\$2,475	\$225	\$2,250	4.2	2,875

Lighting controls reduce energy use by turning off or lowering lighting fixture power levels when not in use. A comprehensive approach to lighting design should upgrade the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

### ECM 4: Install Occupancy Sensor Lighting Controls

Install occupancy sensors to control lighting fixtures in areas that are frequently unoccupied, even for short periods. For most spaces, we recommend that lighting controls use dual technology sensors, which reduce the possibility of lights turning off unexpectedly.

Occupancy sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Most occupancy sensor lighting controls allow users to manually turn fixtures on/off, as needed. Some controls can also provide dimming options.

Occupancy sensors can be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are best suited to single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in large spaces, locations without local switching, and where wall switches are not in the line-of-sight of the main work area.

This measure provides energy savings by reducing the lighting operating hours.

**Affected building areas:** mezzanine, workshop, receiving, acquisition and catalogue rooms, offices, IT lab, and storage rooms.

## ECM 5: Install High/Low Lighting Controls

Install occupancy sensors to provide dual level lighting control for lighting fixtures in spaces that are infrequently occupied but may require some level of continuous lighting for safety or security reasons.

Lighting fixtures with these controls operate at default low levels when the area is unoccupied to provide minimal lighting to meet security or safety code requirements for egress. Sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Fixtures automatically switch back to low level after a predefined period of vacancy. In parking lots and parking garages with significant ambient lighting, this control can sometimes be combined with photocell controls to turn the lights off when there is sufficient daylight.

The controller lowers the light level by dimming the fixture output. Therefore, the controlled fixtures need to have a dimmable ballast or driver. This will need to be taken into account when selecting retrofit lamps and bulbs for the areas proposed for high/low control.

This measure provides energy savings by reducing the light fixture power draw when reduced light output is appropriate.

**Affected building areas:** lobbies and hallways.

For this type of measure the occupancy sensors will generally be ceiling or fixture mounted. Sufficient sensor coverage must be provided to ensure that lights turn on in each area as an occupant approaches.

## 4.3 Variable Frequency Drives (VFD)

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Variable Frequency Drive (VFD) Measures</b>		<b>13,114</b>	<b>3.3</b>	<b>0</b>	<b>\$2,441</b>	<b>\$11,822</b>	<b>\$2,600</b>	<b>\$9,222</b>	<b>3.8</b>	<b>13,206</b>
ECM 6	Install VFDs on Constant Volume (CV) Fans	13,114	3.3	0	\$2,441	\$11,822	\$2,600	\$9,222	3.8	13,206

Variable frequency drives control motors for fans, pumps, and process equipment based on the actual output required of the driven equipment. Energy savings result from more efficient control of motor energy usage when equipment operates at partial load. The magnitude of energy savings depends on the estimated amount of time that the motor would operate at partial load. For equipment with proposed VFDs, we have included replacing the controlled motor with a new inverter duty rated motor to conservatively account for the cost of an inverter duty rated motor.

## ECM 6: Install VFDs on Constant Volume (CV) Fans

Install VFDs to control constant volume fan motor speeds. This converts a constant-volume, single-zone air handling system into a variable-air-volume (VAV) system. A separate VFD is usually required to control the return fan motor or dedicated exhaust fan motor, if the air handler has one.

Zone thermostats signal the VFD to adjust fan speed to maintain the appropriate temperature in the zone, while maintaining a constant supply air temperature.

Energy savings result from reducing the fan speed (and power) when conditions allow for reduced air flow.

**Affected air handlers:** RTU 5, 6, and NRTU27.

## 4.4 Electric Unitary HVAC

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Electric Unitary HVAC Measures</b>		<b>38,969</b>	<b>34.6</b>	<b>0</b>	<b>\$7,253</b>	<b>\$264,132</b>	<b>\$21,480</b>	<b>\$242,652</b>	<b>33.5</b>	<b>39,242</b>
ECM 7	Install High Efficiency Air Conditioning Units	5,945	7.7	0	\$1,107	\$94,626	\$7,724	\$86,902	78.5	5,987
ECM 8	Install High Efficiency Heat Pumps	33,024	26.9	0	\$6,147	\$169,506	\$13,756	\$155,750	25.3	33,255

Replacing the unitary HVAC units has a long payback period and may not be justifiable based simply on energy considerations. However, most of the units at this facility are nearing or have reached the end of their normal useful life. Typically, the marginal cost of purchasing a high efficiency unit can be justified by the marginal savings from the improved efficiency. When the HVAC units are eventually replaced, consider purchasing equipment that exceeds the minimum efficiency required by building codes.

### **ECM 7: Install High Efficiency Air Conditioning Units**

We have evaluated replacing standard efficiency packaged air conditioning units with high efficiency packaged air conditioning units. The magnitude of energy savings for this measure depends on the relative efficiency of the older unit versus the new high efficiency unit, the average cooling load, and the estimated annual operating hours.

This measure is part of a measure to replace package units at this site and as such must be considered in combination with ECM 9.

**Affected units:** all packaged RTUs that are beyond their useful life (see Appendix A).

### **ECM 8: Install High Efficiency Heat Pumps**

We have evaluated replacing standard efficiency heat pumps with high efficiency heat pumps. A higher EER or SEER rating indicates a more efficient cooling system and a higher HSPF rating indicates more efficient heating mode. The magnitude of energy savings for this measure depends on the relative efficiency of the older unit versus the new high efficiency unit, the average heating and cooling loads, and the estimated annual operating hours.

**Affected units:** all packaged heat pumps that are beyond their useful life (see Appendix A).

## 4.5 Gas-Fired Heating

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Gas Heating (HVAC/Process) Replacement</b>		<b>0</b>	<b>0.0</b>	<b>53</b>	<b>\$526</b>	<b>\$21,277</b>	<b>\$7,200</b>	<b>\$14,077</b>	<b>26.8</b>	<b>6,218</b>
ECM 9	Install High Efficiency Furnaces	0	0.0	50	\$492	\$19,524	\$7,200	\$12,324	25.0	5,822
ECM 10	Install High Efficiency Unit Heaters	0	0.0	3	\$33	\$1,753	\$0	\$1,753	52.4	396

### **ECM 9: Install High Efficiency Furnaces**

We have evaluated replacing standard efficiency furnaces with high efficiency furnaces. Improved combustion technology and heat exchanger design optimize heat recovery from the combustion gases which can significantly improve furnace efficiency. Savings result from improved system efficiency.

This measure is part of a measure to replace package units at this site and as such must be considered in combination with ECM 7.

**Affected units:** all packaged RTUs that are beyond their useful life (see Appendix A).

### **ECM 10: Install High Efficiency Unit Heaters**

We have evaluated replacing the existing standard gas-fired unit heater with high efficiency gas-fired unit heater. Improved combustion technology and heat exchanger design optimize the heat recovery from the combustion gases which can significantly improve unit heater efficiency. Savings result from improved system efficiency.

Note: these units produce acidic condensate that requires proper drainage.

## 4.6 Custom Measures

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated Install Cost (\$)	Estimated Incentive (\$)*	Estimated Net Cost (\$)	Simple Payback Period (yrs)**	CO <sub>2</sub> e Emissions Reduction (lbs)
<b>Custom Measures</b>		<b>10,004</b>	<b>0.0</b>	<b>56</b>	<b>\$2,413</b>	<b>\$112,000</b>	<b>\$0</b>	<b>\$112,000</b>	<b>46.4</b>	<b>16,590</b>
ECM 11	Installation of an Energy Management System	10,004	0.0	56	\$2,413	\$112,000	\$0	\$112,000	46.4	16,590

### **ECM 11: Installation of an Energy Management System**

Most larger facilities have some type of energy management system (EMS) which provides for centralized, remote control and monitoring of HVAC equipment and sometimes lighting or other building systems. An EMS utilizes a system of temperature and pressure sensors that obtain feedback about field conditions and provide signals to control systems that adjust HVAC system operation for optimal functioning. Thirty years ago, most control systems were pneumatic systems driven by compressed air, with pneumatic thermostats and air driven actuators for valves and dampers. Pneumatic controls have largely been replaced by direct digital control (DDC) systems, but many pneumatic systems remain. Contemporary DDC systems afford tighter controls and enhanced monitoring and trending capabilities as compared to the older systems.

Often smaller facilities are not equipped with central controls. For many small sites, it has been less costly to install distributed local controls, such as programmable thermostats and timeclocks, rather than centralized DDC. Local controls do a reasonably good job of scheduling equipment and maintaining operating conditions by relying on controls integral to HVAC units, such as logic for compressor staging, to manage the equipment operating algorithms.

Even for smaller sites, inefficiencies arise when temperature sensors and thermostat schedules are not maintained, when there are separate systems for heating and cooling, and especially when equipment is added, or the facility is reconfigured or repurposed.

Based on our survey, it appears that the installation of an EMS at your site could increase the efficiency of your building HVAC system operation.

A controls upgrade would enable automated equipment “start” and “stop” times, temperature setpoints, lockouts and deadbands to be programmed remotely using a graphic interface. Controls can be configured to optimize ventilation and outside air intake by adjusting economizer position, damper function and fan speed. Existing chilled and hot water distribution system controls are typically “tied in”, including associated pumps and valves. Coordinated control of HVAC systems is dependent on a network of sensors and status points. A comprehensive building control system provides monitoring and control for all HVAC systems so operators can adjust system programming for optimal comfort and energy savings.

It is recommended that an HVAC engineer or contractor who specializes in energy management systems be contacted for a detailed evaluation and implementation costs. For the purposes of this report, the potential energy savings and measure costs were estimated based on industry standards and previous project experience. Further analysis should be conducted for the feasibility of this measure. This is not an investment grade analysis nor should be used as a basis for design and construction.

A high-level evaluation of potential savings and costs is provided for demonstration purposes only. It is a screening evaluation for the potential in installing an EMS. Based on industry standards and previous project experience, the potential energy savings may be up to 20% of existing HVAC energy use. The average cost for installing and EMS may be between \$2 and \$4 per square foot. Actual savings and costs will need to be outlined by the specific contractor engaged to implement the system. For the purposes of this report, we have conservatively estimated savings to be 5% of the HVAC energy consumption baseline.

## 5 ENERGY EFFICIENT BEST PRACTICES

A whole building maintenance plan will extend equipment life; improve occupant comfort, health, and safety; and reduce energy and maintenance costs. You may already be doing some of these things— see our list below for potential additions to your maintenance plan. Be sure to consult with qualified equipment specialists for details on proper maintenance and system operation.

### **Energy Tracking with ENERGY STAR® Portfolio Manager®**



You've heard it before - you can't manage what you don't measure. ENERGY STAR® Portfolio Manager® is an online tool that you can use to measure and track energy and water consumption, as well as greenhouse gas emissions<sup>5</sup>. Your account has already been established. Now you can continue to keep tabs on your energy performance every month.

### **Weatherization**

Caulk or weather strip leaky doors and windows to reduce drafts and loss of heated or cooled air. Sealing cracks and openings can reduce heating and cooling costs, improve building durability, and create a healthier indoor environment. Materials used may include caulk, polyurethane foam, and other weather-stripping materials. There is an energy savings opportunity by reducing the uncontrolled air exchange between the outside and inside of the building. Blower door assisted comprehensive building air sealing will reduce the amount of air exchange which will in turn reduce the load on the buildings heating and cooling equipment and thus providing energy savings and increased occupant comfort.

### **Doors and Windows**

Close exterior doors and windows in heated and cooled areas. Leaving doors and windows open leads to a loss of heat during the winter and chilled air during the summer. Reducing air changes per hour (ACH) can lead to increased occupant comfort as well as heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

### **Lighting Maintenance**



- Clean lamps, reflectors and lenses of dirt, dust, oil, and smoke buildup every six to twelve months. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust. Together, this can reduce total light output by up to 60% while still drawing full power.

In addition to routine cleaning, developing a maintenance schedule can ensure that maintenance is performed regularly, and it can reduce the overall cost of fixture re-lamping and re-ballasting. Group re-lamping and re-ballasting maintains lighting levels and minimizes the number of site visits by a lighting technician or contractor, decreasing the overall cost of maintenance.

---

<sup>5</sup> <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/use-portfolio-manager>.

## **Lighting Controls**

As part of a lighting maintenance schedule, test lighting controls to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight and photocell sensors, maintenance involves cleaning sensor lenses and confirming that setpoints and sensitivity are configured properly. Adjust exterior lighting time clock controls seasonally as needed to match your lighting requirements.

## **Motor Maintenance**

Motors have many moving parts. As these parts degrade over time, the efficiency of the motor is reduced. Routine maintenance prevents damage to motor components. Routine maintenance should include cleaning surfaces and ventilation openings on motors to prevent overheating, lubricating moving parts to reduce friction, inspecting belts and pulleys for wear and to ensure they are at proper alignment and tension, and cleaning and lubricating bearings. Consult a licensed technician to assess these and other motor maintenance strategies.

## **Thermostat Schedules and Temperature Resets**



Use thermostat setback temperatures and schedules to reduce heating and cooling energy use during periods of low or no occupancy. Thermostats should be programmed for a setback of 5°F-10°F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

## **Economizer Maintenance**

Economizers can significantly reduce cooling system load. A malfunctioning economizer can increase the amount of heating and mechanical cooling required by introducing excess amounts of cold or hot outside air. Common economizer malfunctions include broken outdoor thermostat or enthalpy control, or dampers that are stuck or improperly adjusted.

Periodic inspection and maintenance will keep economizers working in sync with the heating and cooling system. This maintenance should be part of annual system maintenance, and it should include proper setting of the outdoor thermostat/enthalpy control, inspection of control and damper operation, lubrication of damper connections, and adjustment of minimum damper position.

## **AC System Evaporator/Condenser Coil Cleaning**

Dirty evaporator and condenser coils restrict air flow and restrict heat transfer. This increases the loads on the evaporator and condenser fan and decreases overall cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

## **HVAC Filter Cleaning and Replacement**

Air filters should be checked regularly (often monthly) and cleaned or replaced when appropriate. Air filters reduce indoor air pollution, increase occupant comfort, and help keep equipment operating efficiently. If the building has a building management system, consider installing a differential pressure switch across filters to send an alarm about premature fouling or overdue filter replacement. Over time, filters become less and less effective as particulate buildup increases. Dirty filters also restrict air flow through the air conditioning or heat pump system, which increases the load on the distribution fans.

Duct leakage in commercial buildings can account for five to twenty-five percent of the supply airflow. In the case of rooftop air handlers, duct leakage can occur to the outside of the building wasting conditioned air. Check ductwork for leakage. Distribution system losses are dependent on air system temperature, the size of the distribution system, and the level of insulation of the ductwork. Significant energy savings can be achieved when insulation has not been well maintained. When the insulation is missing or worn, the system efficiency can be significantly reduced. This measure saves energy by reducing heat transfer in the distribution system. Eliminating duct leaks can improve ventilation system performance and reduce heating and cooling system operation.

### **Furnace Maintenance**

Preventative maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. Following the manufacturer's instructions, a yearly tune-up should: check for gas / carbon monoxide leaks; change the air and fuel filters; check components for cracks, corrosion, dirt, or debris build-up; ensure the ignition system is working properly; test and adjust operation and safety controls; inspect electrical connections; and lubricate motors and bearings.

### **Water Heater Maintenance**

The lower the supply water temperature that is used for hand washing sinks, the less energy is needed to heat the water. Reducing the temperature results in energy savings and the change is often unnoticeable to users. Be sure to review the domestic water temperature requirements for sterilizers and dishwashers as you investigate reducing the supply water temperature.

Also, preventative maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. At least once a year, follow manufacturer instructions to drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Annual checks should include checks for:

- Leaks or heavy corrosion on the pipes and valves.
- Corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot, or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional.
- For electric water heaters, look for signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank.
- For water heaters more than three years old, have a technician inspect the sacrificial anode annually.

## **Water Conservation**



Installing dual flush or low-flow toilets and low-flow/waterless urinals are ways to reduce water use. The EPA WaterSense® ratings for urinals is 0.5 gallons per flush (gpf) and for flush valve toilets is 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

For more information regarding water conservation go to the EPA's WaterSense® website<sup>6</sup> or download a copy of EPA's "WaterSense® at Work: Best Management Practices for Commercial and Institutional Facilities"<sup>7</sup> to get ideas for creating a water management plan and best practices for a wide range of water using systems.

Water conservation devices that do not reduce hot water consumption will not provide energy savings at the site level, but they may significantly affect your water and sewer usage costs. Any reduction in water use does however ultimately reduce grid-level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users.

If the facility has detached buildings with a master water meter for the entire campus, check for unnatural wet areas in the lawn or water seeping in the foundation at water pipe penetrations through the foundation. Periodically check overnight meter readings when the facility is unoccupied, and there is no other scheduled water usage.

Manage irrigation systems to use water more effectively outside the building. Adjust spray patterns so that water lands on intended lawns and plantings and not on pavement and walls. Consider installing an evapotranspiration irrigation controller that will prevent over-watering.

## **Procurement Strategies**

Purchasing efficient products reduces energy costs without compromising quality. Consider modifying your procurement policies and language to require ENERGY STAR® or WaterSense® products where available.

---

<sup>6</sup> <https://www.epa.gov/watersense>.

<sup>7</sup> <https://www.epa.gov/watersense/watersense-work-0>.

You don't have to look far in New Jersey to see one of the thousands of solar electric systems providing clean power to homes, businesses, schools, and government buildings. On-site generation includes both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) technologies that generate power to meet all or a portion of the facility's electric energy needs. Also referred to as distributed generation, these systems contribute to greenhouse gas (GHG) emission reductions, demand reductions and reduced customer electricity purchases, which results in improved electric grid reliability through better use of transmission and distribution systems.

Preliminary screenings were performed to determine if an on-site generation measure could be a cost-effective solution for your facility. Before deciding to install an on-site generation system, we recommend conducting a feasibility study to analyze existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.


## 6.1 Solar Photovoltaic

Photovoltaic (PV) panels convert sunlight into electricity. Individual panels are combined into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is then connected to the building's electrical distribution system.

A preliminary screening based on the facility's electric demand, size and location of free area, and shading elements shows that the facility has high potential for installing a PV array.

The amount of free area, ease of installation (location), and the lack of shading elements contribute to the high potential. A PV array located on the roof may be feasible. If you are interested in pursuing the installation of PV, we recommend conducting a full feasibility study.

The graphic below displays the results of the PV potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.



*Figure 9 - Photovoltaic Screening*

### Solar Renewable Energy Certificate (SREC) Registration Program (SRP)

Rebates are not available for solar projects, but owners of solar projects MUST register their projects in the SREC Registration Program before starting construction. Once your PV system is up and running, you periodically earn credits, which can then be sold on the open market for up to 15 years.

If you are considering installing solar photovoltaics on your building, visit [www.njcleanenergy.com/srec](http://www.njcleanenergy.com/srec) for more information about the SREC Registration Program.

Get more information about solar power in New Jersey or find a qualified solar installer who can help you decide if solar is right for your building:

- **Basic Info on Solar PV in NJ:** [www.njcleanenergy.com/whysolar](http://www.njcleanenergy.com/whysolar).
- **NJ Solar Market FAQs:** [www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs](http://www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs).
- **Approved Solar Installers in the NJ Market:** [www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved\\_vendorsearch/?id=60&start=1](http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1).

## 6.2 Combined Heat and Power

Combined heat and power (CHP) generates electricity at the facility and puts waste heat energy to good use. Common types of CHP systems are reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines.


CHP systems typically produce a portion of the electric power used on-site, with the balance of electric power needs supplied by the local utility company. The heat is used to supplement (or replace) existing boilers and provide space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for space cooling.

The key criteria used for screening is the amount of time that the CHP system would operate at full load and the facility's ability to use the recovered heat. Facilities with a continuous need for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has no potential for installing a cost-effective CHP system.

Based on a preliminary analysis, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation. Low or infrequent thermal load, and lack of space for siting the equipment are the most significant factors contributing to the lack of CHP potential.

The graphic below displays the results of the CHP potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.



*Figure 10 - Combined Heat and Power Screening*

Find a qualified firm that specializes in commercial CHP cost assessment and installation:  
[http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved\\_vendorsearch/](http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/).

## 7 PROJECT FUNDING AND INCENTIVES

Ready to improve your building's performance? New Jersey's Clean Energy Programs can help. Pick the program that works best for you. Incentive programs that may apply to this facility are identified in the Executive Summary. This section provides an overview of currently available New Jersey Clean Energy Programs.

	<b>SmartStart</b> <i>Flexibility to install at your own pace</i>	<b>Direct Install</b> <i>Turnkey installation</i>	<b>Pay for Performance</b> <i>Whole building upgrades</i>
<b>Who should use it?</b>	Buildings installing individual measures or small group of measures.	Small to mid-size facilities that can bundle multiple measures together.  Average peak demand should be below 200 kW.  Not suitable for significant building shell issues.	Mid to large size facilities looking to implement as many measures as possible at one time.  Peak demand should be over 200 kW.
<b>How does it work?</b>	Use in-house staff or your preferred contractor.	Pre-approved contractors pass savings along to you via reduced material and labor costs.	Whole-building approach to energy upgrades designed to reduce energy use by at least 15%. The more you save, the higher the incentives.
<b>What are the Incentives?</b>	Fixed incentives for specific energy efficiency measures.	Incentives pay up to 70% of eligible costs, up to \$125,000 per project.  You pay the remaining 30% directly to the contractor.	Up to 25% of installation cost, calculated based on level of energy savings per square foot.
<b>How do I participate?</b>	Submit an application for the specific equipment to be installed.	Contact a participating contractor in your region.	Contact a pre-qualified Partner to develop your Energy Reduction Plan and set your energy savings targets.
Take the next step by visiting <a href="http://www.njcleanenergy.com">www.njcleanenergy.com</a> for program details, applications, and to contact a qualified contractor.			



SmartStart offers incentives for installing prescriptive and custom energy efficiency measures at your facility. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades. This program serves most common equipment types and sizes.

SmartStart routinely adds, removes, or modifies incentives from year-to-year for various energy-efficient equipment based on market trends and new technologies.

#### **Equipment with Prescriptive Incentives Currently Available:**

*Electric Chillers  
Electric Unitary HVAC  
Gas Cooling  
Gas Heating  
Gas Water Heating  
Ground Source Heat Pumps  
Lighting*

*Lighting Controls  
Refrigeration Doors  
Refrigeration Controls  
Refrigerator/Freezer Motors  
Food Service Equipment  
Variable Frequency Drives*

#### **Incentives**

The SmartStart Prescriptive program provides fixed incentives for specific energy efficiency measures. Prescriptive incentives vary by equipment type.

SmartStart Custom provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentives. Custom incentives are calculated at \$0.16/kWh and \$1.60/therm based on estimated annual savings. Incentives are capped at 50% of the total installed incremental project cost, or a project cost buy down to a one-year payback (whichever is less). Program incentives are capped at \$500,000 per electric account and \$500,000 per natural gas account, per fiscal year.

#### **How to Participate**

Submit an application for the specific equipment to be installed. Many applications are designed as rebates, although others require application approval prior to installation. You can work with your preferred contractor or use internal staff to install measures.

Visit [www.njcleanenergy.com/SSB](http://www.njcleanenergy.com/SSB) for a detailed program description, instructions for applying, and applications.

## 7.2 Direct Install



Direct Install is a turnkey program available to existing small to medium-sized facilities with an average peak electric demand that does not exceed 200 kW over the recent 12-month period. You work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for

installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives, and controls.

### Incentives

The program pays up to 70% of the total installed cost of eligible measures, up to \$125,000 per project. Each entity is limited to incentives up to \$250,000 per fiscal year.

### How to Participate

To participate in Direct Install, you will need to contact the participating contractor assigned to the region of the state where your facility is located. A complete list of Direct Install program partners is provided on the Direct Install website linked below. The contractor will be paid the measure incentives directly by the program, which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the program, subject to program caps and eligibility, while the remaining 30% of the cost is paid to the contractor by the customer.

Detailed program descriptions and applications can be found at: [www.njcleanenergy.com/DI](http://www.njcleanenergy.com/DI).

### 7.3 Pay for Performance - Existing Buildings



Pay for Performance works for larger customers with a peak demand over 200 kW. The minimum installed scope of work must include at least two unique measures that results in at least 15% source energy savings, and lighting cannot make up the majority of the savings. P4P is a generally a good option for medium-to-large sized facilities looking to implement

as many measures as possible under a single project to achieve deep energy savings. This program has an added benefit of addressing measures that may not qualify for other programs. Many facilities pursuing an Energy Savings Improvement Program loan also use this program.

Based on the site building and utility data provided, the facility does not meet the requirements of the current P4P program.

#### Incentives

Incentives are based on estimated and achieved energy savings ranging from \$0.18-\$0.22/kWh and \$1.80-\$2.50/therm, capped at the lesser of 50% total project cost, or \$1 million per electric account and \$1 million per natural gas account, per fiscal year, not to exceed \$2 million per project. An incentive of \$0.15/square foot is also available to offset the cost of developing the Energy Reduction Plan (see below) contingent on the project moving forward with measure installation.

#### How to Participate

Contact one of the pre-approved consultants and contractors ("Partners"). Under direct contract to you, they will help further evaluate the measures identified in this report through development of the energy reduction plan), assist you in implementing selected measures, and verify actual savings one year after the installation. Your Partner will also help you apply for incentives.

Approval of the final scope of work is required by the program prior to installation. Installation can be done by the contractor of your choice (some P4P Partners are also contractors) or by internal staff, but the Partner remains involved throughout construction to ensure compliance with the program requirements.

Detailed program descriptions, instructions for applying, applications and list of Partners can be found at: [www.njcleanenergy.com/P4P](http://www.njcleanenergy.com/P4P).

## 7.4 Combined Heat and Power

The Combined Heat & Power (CHP) program provides incentives for eligible CHP or waste heat to power (WHP) projects. Eligible CHP or WHP projects must achieve an annual system efficiency of at least 65% (lower heating value, or LHV), based on total energy input and total utilized energy output. Mechanical energy may be included in the efficiency evaluation.

### Incentives

Eligible Technologies	Size (Installed Rated Capacity) <sup>1</sup>	Incentive (\$/kW)	% of Total Cost Cap per Project <sup>3</sup>	\$ Cap per Project <sup>3</sup>		
Powered by non-renewable or renewable fuel source <sup>4</sup>	≤500 kW	\$2,000	30-40% <sup>2</sup>	\$2 million		
Gas Internal Combustion Engine	>500 kW - 1 MW	\$1,000				
Gas Combustion Turbine	> 1 MW - 3 MW	\$550	30%	\$3 million		
Microturbine	>3 MW	\$350				
Fuel Cells with Heat Recovery						
Waste Heat to Power*	<1 MW	\$1,000	30%	\$2 million		
	> 1MW	\$500		\$3 million		

\*Waste Heat to Power: Powered by non-renewable fuel source, heat recovery or other mechanical recovery from existing equipment utilizing new electric generation equipment (e.g. steam turbine).

Check the NJCEP website for details on program availability, current incentive levels, and requirements.

### How to Participate

You work with a qualified developer or consulting firm to complete the CHP application. Once the application is approved the project can be installed. Information about the CHP program can be found at: [www.njcleanenergy.com/CHP](http://www.njcleanenergy.com/CHP).

## 7.5 SREC Registration Program

The SREC (Solar Renewable Energy Certificate) Registration Program (SRP) is used to register the intent to install solar projects in New Jersey. Rebates are not available for solar projects, but owners of solar projects *must* register their projects prior to the start of construction to establish the project's eligibility to earn SRECs. Registration of the intent to participate in New Jersey's solar marketplace provides market participants with information about the pipeline of anticipated new solar capacity and insight into future SREC pricing.

After the registration is accepted, construction is complete, and final paperwork has been submitted and is deemed complete, the project is issued a New Jersey certification number, which enables it to generate New Jersey SRECs. SRECs are generated once the solar project has been authorized to be energized by the Electric Distribution Company (EDC).

Each time a solar installation generates 1,000 kilowatt-hours (kWh) of electricity, an SREC is earned. Solar project owners report the energy production to the SREC Tracking System. This reporting allows SRECs to be placed in the customer's electronic account. SRECs can then be sold on the SREC Tracking System, providing revenue for the first 15 years of the project's life.

Electricity suppliers, the primary purchasers of SRECs, are required to pay a Solar Alternative Compliance Payment (SACP) if they do not meet the requirements of New Jersey's Solar Renewable Portfolio Standard. Purchasing SRECs can help them meet those requirements. As SRECs are traded in a competitive market, the price may vary significantly. The actual price of an SREC during a trading period fluctuates depending on supply and demand.

Information about the SRP can be found at: [www.njcleanenergy.com/srec](http://www.njcleanenergy.com/srec).

## 8 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

---

### 8.1 Retail Electric Supply Options

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. So, though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third-party supplier, consider shopping for a reduced rate from third-party electric suppliers. If your facility already buys electricity from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party electric suppliers is available at the NJBPU website<sup>8</sup>.

### 8.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey is also deregulated. Most customers that remain with the utility for natural gas service pay rates that are market-based and that fluctuate monthly. The utility provides basic gas supply service (BGSS) to customers who choose not to buy from a third-party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier typically depends on whether a customer prefers budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third-party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility does not already purchase natural gas from a third-party supplier, consider shopping for a reduced rate from third-party natural gas suppliers. If your facility already purchases natural gas from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party natural gas suppliers is available at the NJBPU website<sup>9</sup>.

---

<sup>8</sup> [www.state.nj.us/bpu/commercial/shopping.html](http://www.state.nj.us/bpu/commercial/shopping.html).

<sup>9</sup> [www.state.nj.us/bpu/commercial/shopping.html](http://www.state.nj.us/bpu/commercial/shopping.html).

## APPENDIX A: EQUIPMENT INVENTORY & RECOMMENDATIONS

### Lighting Inventory & Recommendations

	Existing Conditions						Proposed Conditions								Energy Impact & Financial Analysis							
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years	
Mezzanine	59	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	3,121	4	None	Yes	59	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,153	0.5	1,788	0	\$329	\$1,890	\$490	4.3	
Mezzanine	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0	
Stairwell	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	3,121		None	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	3,121	0.0	0	0	\$0	\$0	\$0	0.0	
Stairwell	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	S	17	3,121		None	No	1	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	17	3,121	0.0	0	0	\$0	\$0	\$0	0.0	
Work Shop	26	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	3,121	4	None	Yes	26	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,153	0.2	788	0	\$145	\$1,080	\$280	5.5	
Work Shop	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0	
Supply Storage	6	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,825	4	None	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	1,259	0.0	106	0	\$20	\$270	\$70	10.2	
Receiving Room	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	3,952	4	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,727	0.1	460	0	\$85	\$540	\$140	4.7	
Receiving Room	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0	
Garage	6	LED - Linear Tubes: (4) 2' Lamps	Wall Switch	S	34	2,190	4	None	Yes	6	LED - Linear Tubes: (4) 2' Lamps	Occupancy Sensor	34	1,511	0.1	150	0	\$28	\$116	\$40	2.8	
Adm Hallway	7	LED - Fixtures: LED Panel	Wall Switch	S	37	3,952	5	None	Yes	7	LED - Fixtures: LED Panel	High/Low Control	37	2,727	0.1	343	0	\$63	\$225	\$225	0.0	
Adm Hallway	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0	
Acquisition Room	16	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	3,121	4	None	Yes	16	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,153	0.1	485	0	\$89	\$540	\$140	4.5	
Catalogue Room	25	LED - Fixtures: LED Panel	Wall Switch	S	37	3,121	4	None	Yes	25	LED - Fixtures: LED Panel	Occupancy Sensor	37	2,153	0.3	966	0	\$178	\$1,080	\$280	4.5	
Restroom	1	LED - Fixtures: LED Panel	Wall Switch	S	37	1,825		None	No	1	LED - Fixtures: LED Panel	Wall Switch	37	1,825	0.0	0	0	\$0	\$0	\$0	0.0	
Men Restroom	1	LED - Fixtures: LED Panel	Wall Switch	S	37	2,920		None	No	1	LED - Fixtures: LED Panel	Wall Switch	37	2,920	0.0	0	0	\$0	\$0	\$0	0.0	
Women Restroom	1	LED - Fixtures: LED Panel	Wall Switch	S	37	2,920		None	No	1	LED - Fixtures: LED Panel	Wall Switch	37	2,920	0.0	0	0	\$0	\$0	\$0	0.0	
Janitorial	1	LED - Fixtures: LED Panel	Occupancy Sensor	S	37	2,727		None	No	1	LED - Fixtures: LED Panel	Occupancy Sensor	37	2,727	0.0	0	0	\$0	\$0	\$0	0.0	
Kitchen	3	LED - Fixtures: LED Panel	Wall Switch	S	37	3,121	4	None	Yes	3	LED - Fixtures: LED Panel	Occupancy Sensor	37	2,153	0.0	116	0	\$21	\$270	\$70	9.4	
Administration Area	48	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	3,952	4	None	Yes	48	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,727	0.4	1,842	0	\$339	\$1,620	\$420	3.5	
Administration Area	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0	
Office	6	LED - Fixtures: LED Panel	Wall Switch	S	37	3,121	4	None	Yes	6	LED - Fixtures: LED Panel	Occupancy Sensor	37	2,153	0.1	232	0	\$43	\$270	\$70	4.7	
Office	6	LED - Fixtures: LED Panel	Wall Switch	S	37	3,121	4	None	Yes	6	LED - Fixtures: LED Panel	Occupancy Sensor	37	2,153	0.1	232	0	\$43	\$270	\$70	4.7	
Office	6	LED - Fixtures: LED Panel	Wall Switch	S	37	3,121	4	None	Yes	6	LED - Fixtures: LED Panel	Occupancy Sensor	37	2,153	0.1	232	0	\$43	\$270	\$70	4.7	
Copy Room	3	LED - Fixtures: LED Panel	Occupancy Sensor	S	37	2,727		None	No	3	LED - Fixtures: LED Panel	Occupancy Sensor	37	2,727	0.0	0	0	\$0	\$0	\$0	0.0	

	Existing Conditions						Proposed Conditions								Energy Impact & Financial Analysis							
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years	
LAB Hallway	2	LED - Fixtures: Ambient 2x2 Fixture	Wall Switch	S	35	3,952		None	No	2	LED - Fixtures: Ambient 2x2 Fixture	Wall Switch	35	3,952	0.0	0	0	\$0	\$0	\$0	0.0	
LAB Hallway	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0	
Computer LAB	1	Linear Fluorescent - T12: 4' T12 (40W) - 2L	Wall Switch	S	88	2,190	2	Relamp & Reballast	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	2,190	0.1	140	0	\$26	\$69	\$20	1.9	
IT LAB	6	LED - Fixtures: Ambient 2x2 Fixture	Wall Switch	S	35	2,190	4	None	Yes	6	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	35	1,511	0.1	154	0	\$28	\$270	\$70	7.1	
Computer LAB	8	Linear Fluorescent - T12: 8' T12 (75W) - 2L	Wall Switch	S	158	2,190	2, 4	Relamp & Reballast	Yes	8	LED - Linear Tubes: (2) 8' Lamps	Occupancy Sensor	72	1,511	0.8	2,050	0	\$377	\$1,300	\$390	2.4	
Storage Room	3	Linear Fluorescent - T8: 2' T8 (17W) - 2L	Wall Switch	S	33	1,825	3, 4	Relamp	Yes	3	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	17	1,259	0.1	126	0	\$23	\$368	\$36	14.3	
Mechanical Room	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	1,825		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	29	1,825	0.0	0	0	\$0	\$0	\$0	0.0	
Restroom1	1	LED - Linear Tubes: (3) 2' Lamps	Occupancy Sensor	S	26	2,727		None	No	1	LED - Linear Tubes: (3) 2' Lamps	Occupancy Sensor	26	2,727	0.0	0	0	\$0	\$0	\$0	0.0	
Restroom1	1	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	S	15	2,727		None	No	1	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,727	0.0	0	0	\$0	\$0	\$0	0.0	
Restroom2	1	LED - Linear Tubes: (3) 2' Lamps	Occupancy Sensor	S	26	2,727		None	No	1	LED - Linear Tubes: (3) 2' Lamps	Occupancy Sensor	26	2,727	0.0	0	0	\$0	\$0	\$0	0.0	
Restroom2	1	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	S	15	2,727		None	No	1	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,727	0.0	0	0	\$0	\$0	\$0	0.0	
Room 04	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	S	29	2,727		None	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,727	0.0	0	0	\$0	\$0	\$0	0.0	
Room 05	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	S	29	2,727		None	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,727	0.0	0	0	\$0	\$0	\$0	0.0	
Room 06	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	S	29	2,727		None	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,727	0.0	0	0	\$0	\$0	\$0	0.0	
Room 07	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	S	29	2,727		None	No	6	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,727	0.0	0	0	\$0	\$0	\$0	0.0	
IT Office	9	LED - Fixtures: Ambient 2x2 Fixture	Wall Switch	S	35	3,121	4	None	Yes	9	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	35	2,153	0.1	329	0	\$61	\$270	\$70	3.3	
Server Room	6	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	S	35	2,727		None	No	6	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	35	2,727	0.0	0	0	\$0	\$0	\$0	0.0	
Ramp	15	LED Lamps: LED Screw in Lamp	Wall Switch	S	18	3,121	5	None	Yes	15	LED Lamps: LED Screw in Lamp	High/Low Control	18	2,153	0.1	282	0	\$52	\$450	\$0	8.7	
Non Fiction Stack	100	Linear Fluorescent - T8: 8' T8 (59W) - 1L	Wall Switch	S	58	3,121	3, 4	Relamp	Yes	100	LED - Linear Tubes: (1) 8' Lamp	Occupancy Sensor	36	2,153	2.9	11,176	-2	\$2,057	\$9,016	\$3,190	2.8	
Youth Room	4	LED - Fixtures: Ambient 2x2 Fixture	Wall Switch	S	35	3,121	4	None	Yes	4	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	35	2,153	0.0	146	0	\$27	\$270	\$70	7.4	
Cobby Area	26	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	3,121	4	None	Yes	26	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,153	0.2	788	0	\$145	\$1,080	\$280	5.5	
Cobby Area	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0	
CD Stack	6	LED - Fixtures: Ambient 2x2 Fixture	Wall Switch	S	35	3,121	4	None	Yes	6	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	35	2,153	0.1	219	0	\$40	\$270	\$70	5.0	
Main Lobby	19	LED - Fixtures: Ambient 2x2 Fixture	Wall Switch	S	35	3,952	5	None	Yes	19	LED - Fixtures: Ambient 2x2 Fixture	High/Low Control	35	2,727	0.2	880	0	\$162	\$675	\$0	4.2	
Main Lobby	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0	

	Existing Conditions						Proposed Conditions							Energy Impact & Financial Analysis							
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Main Entrance	2	LED - Fixtures: Ambient 2x2 Fixture	Wall Switch	S	35	3,952		None	No	2	LED - Fixtures: Ambient 2x2 Fixture	Wall Switch	35	3,952	0.0	0	0	\$0	\$0	\$0	0.0
Main Entrance	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Janitorial Closet	7	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	S	15	1,825	4	None	Yes	7	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	1,259	0.0	62	0	\$11	\$116	\$40	6.7
Men Restroom	2	LED - Linear Tubes: (2) 3' Lamps	Wall Switch	S	21	2,920		None	No	2	LED - Linear Tubes: (2) 3' Lamps	Wall Switch	21	2,920	0.0	0	0	\$0	\$0	\$0	0.0
Men Restroom	1	LED - Linear Tubes: (1) 2' Lamp	Wall Switch	S	9	2,920		None	No	1	LED - Linear Tubes: (1) 2' Lamp	Wall Switch	9	2,920	0.0	0	0	\$0	\$0	\$0	0.0
Women Restroom	2	LED - Linear Tubes: (2) 3' Lamps	Wall Switch	S	21	2,920		None	No	2	LED - Linear Tubes: (2) 3' Lamps	Wall Switch	21	2,920	0.0	0	0	\$0	\$0	\$0	0.0
Women Restroom	1	LED - Linear Tubes: (1) 2' Lamp	Wall Switch	S	9	2,920		None	No	1	LED - Linear Tubes: (1) 2' Lamp	Wall Switch	9	2,920	0.0	0	0	\$0	\$0	\$0	0.0
Circulation Area	12	Linear Fluorescent - T8: 8' T8 (59W) - 1L	Wall Switch	S	58	3,121	3, 4	Relamp	Yes	12	LED - Linear Tubes: (1) 8' Lamp	Occupancy Sensor	36	2,153	0.4	1,341	0	\$247	\$1,071	\$380	2.8
Book Drop	2	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	S	15	1,825		None	No	2	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	1,825	0.0	0	0	\$0	\$0	\$0	0.0
Office	6	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	S	35	2,727		None	No	6	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	35	2,727	0.0	0	0	\$0	\$0	\$0	0.0
Office	6	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	S	35	2,727		None	No	6	LED - Fixtures: Ambient 2x2 Fixture	Occupancy Sensor	35	2,727	0.0	0	0	\$0	\$0	\$0	0.0
Restroom	1	LED - Linear Tubes: (2) 3' Lamps	Wall Switch	S	21	2,190		None	No	1	LED - Linear Tubes: (2) 3' Lamps	Wall Switch	21	2,190	0.0	0	0	\$0	\$0	\$0	0.0
Storage Room	1	LED - Linear Tubes: (2) 3' Lamps	Wall Switch	S	21	1,825		None	No	1	LED - Linear Tubes: (2) 3' Lamps	Wall Switch	21	1,825	0.0	0	0	\$0	\$0	\$0	0.0
Electrical Room	4	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	S	15	1,825		None	No	4	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	15	1,825	0.0	0	0	\$0	\$0	\$0	0.0
Hallway	4	LED - Linear Tubes: (2) 3' Lamps	Wall Switch	S	21	3,952		None	No	4	LED - Linear Tubes: (2) 3' Lamps	Wall Switch	21	3,952	0.0	0	0	\$0	\$0	\$0	0.0
Lounge Room	3	Linear Fluorescent - T8: 8' T8 (59W) - 1L	Wall Switch	S	58	3,121	3, 4	Relamp	Yes	3	LED - Linear Tubes: (1) 8' Lamp	Occupancy Sensor	36	2,153	0.1	335	0	\$62	\$403	\$130	4.4
Lounge Room	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Lounge Room	4	LED - Fixtures: LED Fixture	Wall Switch	S	11	3,121	4	None	Yes	4	LED - Fixtures: LED Fixture	Occupancy Sensor	11	2,153	0.0	46	0	\$8	\$0	\$0	0.0
Lounge Room	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	S	15	3,121	4	None	Yes	1	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,153	0.0	15	0	\$3	\$0	\$0	0.0
Glass Box	7	Metal Halide: (1) 100W Lamp	Wall Switch	S	128	1,460	1	Fixture Replacement	No	7	LED - Fixtures: High-Bay	Wall Switch	38	1,460	0.6	989	0	\$182	\$3,874	\$2,100	9.8
East Lobby	8	LED - Fixtures: LED Fixture	Wall Switch	S	30	3,952	5	None	Yes	8	LED - Fixtures: LED Fixture	High/Low Control	30	2,727	0.1	318	0	\$58	\$225	\$0	3.9
East Lobby	9	Metal Halide: (1) 100W Lamp	Wall Switch	S	128	3,952	1, 5	Fixture Replacement	Yes	9	LED - Fixtures: High-Bay	High/Low Control	38	2,727	0.8	3,899	-1	\$718	\$5,431	\$2,700	3.8
East Lobby	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
East Lobby	12	Linear Fluorescent - T8: 8' T8 (59W) - 1L	Wall Switch	S	58	3,952	3, 5	Relamp	Yes	12	LED - Linear Tubes: (1) 8' Lamp	High/Low Control	36	2,727	0.4	1,698	0	\$313	\$756	\$240	1.7
East Lobby	4	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	S	32	3,952	3, 5	Relamp	Yes	4	LED - Linear Tubes: (1) 4' Lamp	High/Low Control	15	2,727	0.1	376	0	\$69	\$298	\$40	3.7

Existing Conditions							Proposed Conditions							Energy Impact & Financial Analysis							
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Men Restroom	2	LED - Linear Tubes: (2) 3' Lamps	Wall Switch	S	21	2,920		None	No	2	LED - Linear Tubes: (2) 3' Lamps	Wall Switch	21	2,920	0.0	0	0	\$0	\$0	\$0	0.0
Men Restroom	1	LED - Linear Tubes: (1) 2' Lamp	Wall Switch	S	9	2,920		None	No	1	LED - Linear Tubes: (1) 2' Lamp	Wall Switch	9	2,920	0.0	0	0	\$0	\$0	\$0	0.0
Women Restroom	2	LED - Linear Tubes: (2) 3' Lamps	Wall Switch	S	21	2,920		None	No	2	LED - Linear Tubes: (2) 3' Lamps	Wall Switch	21	2,920	0.0	0	0	\$0	\$0	\$0	0.0
Women Restroom	1	LED - Linear Tubes: (1) 2' Lamp	Wall Switch	S	9	2,920		None	No	1	LED - Linear Tubes: (1) 2' Lamp	Wall Switch	9	2,920	0.0	0	0	\$0	\$0	\$0	0.0
Room 03	26	LED - Fixtures: LED Fixture	Wall Switch	S	30	3,121	4	None	Yes	26	LED - Fixtures: LED Fixture	Occupancy Sensor	30	2,153	0.2	815	0	\$150	\$1,080	\$280	5.3
Room 03	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Room 01	20	Linear Fluorescent - T8: 8' T8 (59W) - 1L	Wall Switch	S	58	3,121	3, 4	Relamp	Yes	20	LED - Linear Tubes: (1) 8' Lamp	Occupancy Sensor	36	2,153	0.6	2,235	0	\$411	\$1,695	\$610	2.6
Room 01	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Children Stack	54	Linear Fluorescent - T8: 8' T8 (59W) - 1L	Wall Switch	S	58	3,121	3, 4	Relamp	Yes	54	LED - Linear Tubes: (1) 8' Lamp	Occupancy Sensor	36	2,153	1.6	6,035	-1	\$1,111	\$4,280	\$1,570	2.4
Children Stack	15	Linear Fluorescent - T12: 8' T12 (75W) - 1L	Wall Switch	S	92	3,121	2, 4	Relamp & Reballast	Yes	15	LED - Linear Tubes: (1) 8' Lamp	Occupancy Sensor	36	2,153	0.9	3,395	-1	\$625	\$1,807	\$440	2.2
Children Stack	12	Linear Fluorescent - T12: 4' T12 (40W) - 1L	Wall Switch	S	46	3,121	2, 4	Relamp & Reballast	Yes	12	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,153	0.4	1,456	0	\$268	\$1,146	\$260	3.3
Children Stack	3	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	S	15	3,121	4	None	Yes	3	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,153	0.0	45	0	\$8	\$0	\$0	0.0
Children Stack	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Children Activities Room	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	3,952	4	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,727	0.1	460	0	\$85	\$540	\$140	4.7
Children Activities Room	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Closet	1	LED - Fixtures: LED Panel	Wall Switch	S	37	1,825		None	No	1	LED - Fixtures: LED Panel	Wall Switch	37	1,825	0.0	0	0	\$0	\$0	\$0	0.0
Restroom	1	LED - Fixtures: LED Panel	Wall Switch	S	37	2,920		None	No	1	LED - Fixtures: LED Panel	Wall Switch	37	2,920	0.0	0	0	\$0	\$0	\$0	0.0
Periodical	24	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	S	44	3,121	4	None	Yes	24	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,153	0.3	1,091	0	\$201	\$810	\$210	3.0
Periodical	6	Linear Fluorescent - T8: 8' T8 (59W) - 1L	Wall Switch	S	58	3,121	3, 4	Relamp	Yes	6	LED - Linear Tubes: (1) 8' Lamp	Occupancy Sensor	36	2,153	0.2	671	0	\$123	\$536	\$190	2.8
Periodical	2	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	S	32	3,121	3, 4	Relamp	Yes	2	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,153	0.0	148	0	\$27	\$37	\$20	0.6
Reference Area	99	Linear Fluorescent - T8: 8' T8 (59W) - 1L	Wall Switch	S	58	3,121	3, 4	Relamp	Yes	99	LED - Linear Tubes: (1) 8' Lamp	Occupancy Sensor	36	2,153	2.9	11,065	-2	\$2,036	\$8,971	\$3,170	2.8
Reference Area	35	Linear Fluorescent - T8: 4' T8 (32W) - 1L	Wall Switch	S	32	3,121	3, 4	Relamp	Yes	35	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	15	2,153	0.7	2,595	-1	\$477	\$1,989	\$700	2.7
Reference Office 1	9	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	3,121	4	None	Yes	9	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,153	0.1	273	0	\$50	\$270	\$70	4.0
Reference Office 2	15	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	3,121	4	None	Yes	15	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,153	0.1	454	0	\$84	\$540	\$140	4.8
Fish Area	9	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	3,121	4	None	Yes	9	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,153	0.1	273	0	\$50	\$270	\$70	4.0

Existing Conditions							Proposed Conditions							Energy Impact & Financial Analysis							
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
NJ Room	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	3,121	4	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,153	0.1	364	0	\$67	\$540	\$140	6.0
Lawrence Room	9	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	3,121	4	None	Yes	9	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,153	0.1	273	0	\$50	\$270	\$70	4.0
ILL Room	9	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	29	3,121	4	None	Yes	9	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	29	2,153	0.1	273	0	\$50	\$270	\$70	4.0
Reading Area	48	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	3,121	3, 4	Relamp	Yes	48	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,153	2.7	10,190	-2	\$1,875	\$2,899	\$1,510	0.7
Skylight Area	90	LED - Linear Tubes: (1) 8' Lamp	Wall Switch	S	48	3,121	4	None	Yes	90	LED - Linear Tubes: (1) 8' Lamp	Occupancy Sensor	48	2,153	1.2	4,514	-1	\$831	\$270	\$70	0.2
Skylight Area	19	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	S	20	3,121	4	None	Yes	19	LED - Linear Tubes: (1) 4' Lamp	Occupancy Sensor	20	2,153	0.1	397	0	\$73	\$270	\$70	2.7
Lower Stack	106	Linear Fluorescent - T8: 8' T8 (59W) - 1L	Wall Switch	S	58	3,121	3, 4	Relamp	Yes	106	LED - Linear Tubes: (1) 8' Lamp	Occupancy Sensor	36	2,153	3.1	11,847	-3	\$2,180	\$9,551	\$3,380	2.8
Lower Stack	6	Linear Fluorescent - T8: 4' T8 (32W) - 3L	Wall Switch	S	93	3,121	3, 4	Relamp	Yes	6	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	44	2,153	0.3	1,274	0	\$234	\$599	\$250	1.5
Lower Stack	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Wall Pack	21	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Photocell		50	4,380		None	No	21	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Photocell	50	4,380	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Wall Pack	2	LED - Fixtures: Architectural Flood/Spot Luminaire	Photocell		41	4,380		None	No	2	LED - Fixtures: Architectural Flood/Spot Luminaire	Photocell	41	4,380	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Recessed	3	LED - Fixtures: Downlight Recessed	Photocell		30	4,380		None	No	3	LED - Fixtures: Downlight Recessed	Photocell	30	4,380	0.0	0	0	\$0	\$0	\$0	0.0
Parking Lot	12	LED - Fixtures: Outdoor Pole/Arm-Mounted Area/Roadway Fixture	Timedock		75	5,475		None	No	12	LED - Fixtures: Outdoor Pole/Arm-Mounted Area/Roadway Fixture	Timedock	75	5,475	0.0	0	0	\$0	\$0	\$0	0.0
Flag Light	2	LED - Fixtures: Architectural Flood/Spot Luminaire	Timedock		75	5,475		None	No	2	LED - Fixtures: Architectural Flood/Spot Luminaire	Timedock	75	5,475	0.0	0	0	\$0	\$0	\$0	0.0
Walkway Pole Light	2	Metal Halide: (1) 100W Lamp	Timedock		128	5,475	1	Fixture Replacement	No	2	LED - Fixtures: Outdoor Pole/Arm-Mounted Area/Roadway Fixture	Timedock	38	5,475	0.0	981	0	\$183	\$1,329	\$400	5.1
Step Light	4	Metal Halide: (1) 150W Lamp	Timedock		190	2,920	1	Fixture Replacement	No	4	LED - Fixtures: Bollard Fixture	Timedock	57	2,920	0.0	1,553	0	\$289	\$2,050	\$400	5.7
Exterior Wall Sconce	2	Metal Halide: (1) 100W Lamp	Timedock		128	5,110	1	Fixture Replacement	No	2	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Timedock	38	5,110	0.0	916	0	\$170	\$1,380	\$400	5.7

## Motor Inventory & Recommendations

		Existing Conditions							Proposed Conditions					Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Remaining Useful Life	Annual Operating Hours	ECM #	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Roof	Restrooms	8	Exhaust Fan	0.3	65.0%	No	W	4,380		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Garage	Garage	3	Other	0.5	70.0%	No	W	3,468		No	70.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Garage	Garage	1	Exhaust Fan	0.2	65.0%	No	W	3,468		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	Heat Pumps	18	Supply Fan	0.5	70.0%	No	B	3,468		No	70.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	RTU6	1	Supply Fan	5.0	89.5%	No	W	3,468	6	No	89.5%	Yes	1	1.4	5,419	0	\$1,009	\$4,197	\$1,800	2.4
Roof	Packaged Units	8	Supply Fan	0.5	70.0%	No	B	3,468		No	70.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	RTU5,27	2	Supply Fan	3.0	84.0%	No	W	3,468	6	No	89.5%	Yes	2	1.9	7,695	0	\$1,432	\$7,625	\$800	4.8
Roof	Heat Pumps	5	Supply Fan	0.3	65.0%	No	B	3,468		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0

## Electric HVAC Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis							
		System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (MBh)	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (MBh)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Roof	RTU3	1	Packaged AC	8.50		B	7	Yes	1	Packaged AC	8.50		11.50		0.8	618	0	\$115	\$15,148	\$1,241	120.9
Roof	NRTU4	1	Packaged AC	5.00		B	7	Yes	1	Packaged AC	5.00		14.00		1.0	804	0	\$150	\$11,345	\$920	69.7
Roof	NRTU5	1	Packaged AC	5.00		B	7	Yes	1	Packaged AC	5.00		14.00		1.0	804	0	\$150	\$11,345	\$920	69.7
Roof	HP2	1	Packaged Air-Source HP	3.50	41.00	B	8	Yes	1	Packaged Air-Source HP	3.50	41.00	14.00	3.80	1.3	1,640	0	\$305	\$7,941	\$644	23.9
Roof	RTU5	1	Packaged AC	8.50		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Roof	RTU4	1	Packaged AC	7.50		B	7	Yes	1	Packaged AC	7.50		11.50		0.9	723	0	\$135	\$13,366	\$1,095	91.1
Roof	HP2	1	Packaged Air-Source HP	4.00	50.50	B	8	Yes	1	Packaged Air-Source HP	4.00	50.50	14.00	3.80	1.5	1,824	0	\$339	\$9,076	\$736	24.6
Roof	HP10	1	Packaged Air-Source HP	3.50	41.00	B	8	Yes	1	Packaged Air-Source HP	3.50	41.00	14.00	3.80	1.3	1,640	0	\$305	\$7,941	\$644	23.9
Roof	RTU6	1	Packaged AC	12.50		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Roof	HP11	1	Packaged Air-Source HP	3.50	41.00	B	8	Yes	1	Packaged Air-Source HP	3.50	41.00	14.00	3.80	1.3	1,640	0	\$305	\$7,941	\$644	23.9
Roof	HP7	1	Packaged Air-Source HP	4.00	50.50	B	8	Yes	1	Packaged Air-Source HP	4.00	50.50	14.00	3.80	1.5	1,854	0	\$345	\$9,076	\$736	24.2
Roof	HP12	1	Packaged Air-Source HP	4.00	50.50	B	8	Yes	1	Packaged Air-Source HP	4.00	50.50	14.00	3.80	1.5	1,854	0	\$345	\$9,076	\$736	24.2
Roof	HP13	1	Packaged Air-Source HP	4.00	50.50	B	8	Yes	1	Packaged Air-Source HP	4.00	50.50	14.00	3.80	1.5	1,854	0	\$345	\$9,076	\$736	24.2
Roof	HP8	1	Packaged Air-Source HP	4.00	50.50	B	8	Yes	1	Packaged Air-Source HP	4.00	50.50	14.00	3.80	1.5	1,854	0	\$345	\$9,076	\$736	24.2
Roof	HP14	1	Packaged Air-Source HP	3.50	41.00	B	8	Yes	1	Packaged Air-Source HP	3.50	41.00	14.00	3.80	1.3	1,640	0	\$305	\$7,941	\$644	23.9
Roof	NRTU27	1	Packaged AC	10.00		W		No							0.0	0	0	\$0	\$0	\$0	0.0
Roof	HP27	1	Packaged Air-Source HP	2.00	22.40	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Roof	NRTU28	1	Packaged AC	5.00		B	7	Yes	1	Packaged AC	5.00		14.00		1.1	841	0	\$157	\$11,345	\$920	66.6
Roof	HP26	1	Packaged Air-Source HP	3.50	41.00	B	8	Yes	1	Packaged Air-Source HP	3.50	41.00	14.00	3.80	1.3	1,640	0	\$305	\$7,941	\$644	23.9
Roof	RTU8	1	Packaged AC	6.00		B	7	Yes	1	Packaged AC	6.00		11.50		0.8	579	0	\$108	\$10,693	\$876	91.1

		Existing Conditions						Proposed Conditions						Energy Impact & Financial Analysis							
Location	Area(s)/System(s) Served	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (kBtu/hr)	Cooling Mode Efficiency (SEER/EER)	Heating Mode Efficiency (COP)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Roof	HP25	1	Packaged Air-Source HP	5.00	30.71	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Roof	HP24	1	Packaged Air-Source HP	2.50	27.20	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Roof	HP19	1	Packaged Air-Source HP	2.00	21.80	B	8	Yes	1	Packaged Air-Source HP	2.00	21.80	14.00	3.80	0.3	413	0	\$77	\$4,538	\$368	54.2
Roof	HP18	1	Packaged Air-Source HP	3.50	41.00	B	8	Yes	1	Packaged Air-Source HP	3.50	41.00	14.00	3.80	1.3	1,640	0	\$305	\$7,941	\$644	23.9
Roof	HP23	1	Packaged Air-Source HP	4.00	34.12	B	8	Yes	1	Packaged Air-Source HP	4.00	34.12	14.00	3.80	1.2	1,406	0	\$262	\$9,076	\$736	31.9
Roof	HP17	1	Packaged Air-Source HP	3.50	41.00	B	8	Yes	1	Packaged Air-Source HP	3.50	41.00	14.00	3.80	1.3	1,640	0	\$305	\$7,941	\$644	23.9
Roof	HP16	1	Packaged Air-Source HP	4.00	50.50	B	8	Yes	1	Packaged Air-Source HP	4.00	50.50	14.00	3.80	1.5	1,854	0	\$345	\$9,076	\$736	24.2
Roof	HP22	1	Packaged Air-Source HP	4.00	50.50	B	8	Yes	1	Packaged Air-Source HP	4.00	50.50	14.00	3.80	1.5	1,854	0	\$345	\$9,076	\$736	24.2
Roof	HP15	1	Packaged Air-Source HP	3.50	41.00	B	8	Yes	1	Packaged Air-Source HP	3.50	41.00	14.00	3.80	1.3	1,523	0	\$284	\$7,941	\$644	25.7
Roof	HP21	1	Packaged Air-Source HP	6.00	50.50	B	8	Yes	1	Packaged Air-Source HP	6.00	50.50	11.50	3.60	1.2	1,603	0	\$298	\$10,679	\$876	32.9
Roof	HP9	1	Packaged Air-Source HP	4.00	50.50	B	8	Yes	1	Packaged Air-Source HP	4.00	50.50	14.00	3.80	1.5	1,824	0	\$339	\$9,076	\$736	24.6
Roof	HP20	1	Packaged Air-Source HP	4.00	50.50	B	8	Yes	1	Packaged Air-Source HP	4.00	50.50	14.00	3.80	1.5	1,824	0	\$339	\$9,076	\$736	24.6
Roof	RTU1	1	Packaged AC	6.00		B	7	Yes	1	Packaged AC	6.00		14.00		1.0	788	0	\$147	\$10,693	\$876	66.9
Roof	RTU2	1	Packaged AC	6.00		B	7	Yes	1	Packaged AC	6.00		14.00		1.0	788	0	\$147	\$10,693	\$876	66.9

## Fuel Heating Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions				Proposed Conditions							Energy Impact & Financial Analysis						
		System Quantity	System Type	Output Capacity per Unit (MBh)	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Roof	RTU3	1	Furnace	98	B	9	Yes	1	Furnace	98	82.00%	AFUE	0.0	0	3	\$28	\$2,229	\$800	51.9
Roof	NRTU4	1	Furnace	92	B	9	Yes	1	Furnace	92	82.00%	AFUE	0.0	0	4	\$43	\$2,084	\$800	29.7
Roof	NRTU5	1	Furnace	92	B	9	Yes	1	Furnace	92	82.00%	AFUE	0.0	0	4	\$43	\$2,084	\$800	29.7
Roof	RTU5	1	Furnace	160	W		No						0.0	0	0	\$0	\$0	\$0	0.0
Roof	RTU4	1	Furnace	41	B	9	Yes	1	Furnace	41	82.00%	AFUE	0.0	0	1	\$11	\$929	\$800	11.2
Roof	RTU6	1	Furnace	203	W		No						0.0	0	0	\$0	\$0	\$0	0.0
Roof	RTU7	1	Furnace	160	W		No						0.0	0	0	\$0	\$0	\$0	0.0
Roof	NRTU28	1	Furnace	92	B	9	Yes	1	Furnace	92	82.00%	AFUE	0.0	0	4	\$43	\$2,084	\$800	29.7
Roof	RTU8	1	Furnace	120	B	9	Yes	1	Furnace	120	82.00%	AFUE	0.0	0	6	\$56	\$2,719	\$800	34.0
Roof	RTU1	1	Furnace	93	B	9	Yes	1	Furnace	93	82.00%	AFUE	0.0	0	4	\$35	\$2,111	\$800	37.6
Roof	RTU2	1	Furnace	93	B	9	Yes	1	Furnace	93	82.00%	AFUE	0.0	0	4	\$35	\$2,111	\$800	37.6
Roof	HV1 - Mezzanine	1	Furnace	140	B	9	Yes	1	Furnace	140	95.00%	AFUE	0.0	0	20	\$198	\$3,172	\$800	12.0
Garage	Garage	1	Warm Air Unit Heater	60	B	10	Yes	1	Warm Air Unit Heater	60	83.00%	Et	0.0	0	3	\$33	\$1,753	\$0	52.4

## DHW Inventory & Recommendations

Location	Area(s)/System(s) Served	Existing Conditions				Proposed Conditions						Energy Impact & Financial Analysis						
		System Quantity	System Type	Remaining Useful Life	ECM #	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Janitorial Closets	Library	2	Storage Tank Water Heater (≤ 50 Gal)	W		No						0.0	0	0	\$0	\$0	\$0	0.0
Abobe Ceiling	Library	1	Storage Tank Water Heater (≤ 50 Gal)	W		No						0.0	0	0	\$0	\$0	\$0	0.0

### Plug Load Inventory

Existing Conditions				
Location	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?
Lawrence Library	124	Desktop Computer	120	Yes
Lawrence Library	21	Desktop Printer	85	Yes
Lawrence Library	4	Copy Machine	600	Yes
Lawrence Library	3	Microwave	1,000	No
Lawrence Library	3	Refrigerator	224	Yes
Lawrence Library	2	Water Cooler	92	No
Lawrence Library	3	Toaster/Coffe Machine	450	No

### Custom (High Level) Measure Analysis

Installation of an Energy Management System


Building Square Footage 56,000  
Percent of Conditioned Area Impacted 100%

Fuel Utility Rate \$9.904 MMBtu  
Blended Electric Utility Rate \$0.186 kWh


Existing Conditions						Proposed Conditions				Energy Impact & Financial Analysis							
Description	Area(s)/System(s) Served	Remaining Useful Life	Total HVAC Motor Usage kWh	Total HVAC Electric Usage kWh	Total HVAC Fuel Usage MMBtu	Description	% Savings HVAC Motor Usage kWh	% Savings HVAC Electric Usage kWh	% Savings HVAC Fuel Usage MMBtu	Estimated Cost per Sqft	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Total Installation Cost	Total Incentives	Simple Payback w/ Incentives in Years
Limited/No HVAC Controls	HVAC Equipment & Systems	B	77,895	122,194	1,113	Installation of an Energy Management System	5%	5%	5%	\$2.00	0.00	10,004	56	\$2,413	\$112,000	\$0	46.41

## APPENDIX B: ENERGY STAR® STATEMENT OF ENERGY PERFORMANCE

EUI is presented in terms of *site energy* and *source energy*. Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.



### ENERGY STAR® Statement of Energy Performance



**ENERGY STAR®  
Score<sup>1</sup>**

**Mercer County Library - Lawrence Branch**

Primary Property Type: Library  
Gross Floor Area (ft²): 56,000  
Built: 1983

For Year Ending: March 31, 2019  
Date Generated: March 04, 2020

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information			
<b>Property Address</b> Mercer County Library - Lawrence Branch 2751 Brunswick Pike Lawrenceville, New Jersey 08648	<b>Property Owner</b> Mercer County 640 South Broad Street PO Box 8068 Trenton, NJ 08650 (609) 989-6464	<b>Primary Contact</b> Leslie Floyd 640 South Broad Street PO Box 8068 Trenton, NJ 08650 (609) 989-6545 jbenner@mercercounty.org	
Property ID: 8387369			

Energy Consumption and Energy Use Intensity (EUI)			
<b>Site EUI</b> 47.3 kBtu/ft²	<b>Annual Energy by Fuel</b> Electric - Grid (kBtu) 1,500,364 (57%) Natural Gas (kBtu) 1,148,926 (43%)	<b>National Median Comparison</b> National Median Site EUI (kBtu/ft²) 70.4 National Median Source EUI (kBtu/ft²) 143.6 % Diff from National Median Source EUI -33%	
<b>Source EUI</b> 96.6 kBtu/ft²	<b>Annual Emissions</b> Greenhouse Gas Emissions (Metric Tons CO2e/year) 213		

### Signature & Stamp of Verifying Professional

I \_\_\_\_\_ (Name) verify that the above information is true and correct to the best of my knowledge.

LP Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Licensed Professional

\_\_\_\_\_  
( ) - \_\_\_\_\_  
\_\_\_\_\_



Professional Engineer or Registered  
Architect Stamp  
(if applicable)

## APPENDIX C: GLOSSARY

TERM	DEFINITION
<b>Blended Rate</b>	Used to calculate fiscal savings associated with measures. The blended rate is calculated by dividing the amount of your bill by the total energy use. For example, if your bill is \$22,217.22, and you used 266,400 kilowatt-hours, your blended rate is 8.3 cents per kilowatt-hour.
<b>Btu</b>	<i>British thermal unit</i> : a unit of energy equal to the amount of heat required to increase the temperature of one pound of water by one-degree Fahrenheit.
<b>CHP</b>	<i>Combined heat and power</i> . Also referred to as cogeneration.
<b>COP</b>	<i>Coefficient of performance</i> : a measure of efficiency in terms of useful energy delivered divided by total energy input.
<b>Demand Response</b>	Demand response reduces or shifts electricity usage at or among participating buildings/sites during peak energy use periods in response to time-based rates or other forms of financial incentives.
<b>DCV</b>	<i>Demand control ventilation</i> : a control strategy to limit the amount of outside air introduced to the conditioned space based on actual occupancy need.
<b>US DOE</b>	<i>United States Department of Energy</i>
<b>EC Motor</b>	<i>Electronically commutated motor</i>
<b>ECM</b>	<i>Energy conservation measure</i>
<b>EER</b>	<i>Energy efficiency ratio</i> : a measure of efficiency in terms of cooling energy provided divided by electric input.
<b>EUI</b>	<i>Energy Use Intensity</i> : measures energy consumption per square foot and is a standard metric for comparing buildings' energy performance.
<b>Energy Efficiency</b>	Reducing the amount of energy necessary to provide comfort and service to a building/area. Achieved through the installation of new equipment and/or optimizing the operation of energy use systems. Unlike conservation, which involves some reduction of service, energy efficiency provides energy reductions without sacrifice of service.
<b>ENERGY STAR®</b>	ENERGY STAR® is the government-backed symbol for energy efficiency. The ENERGY STAR® program is managed by the EPA.
<b>EPA</b>	<i>United States Environmental Protection Agency</i>
<b>Generation</b>	The process of generating electric power from sources of primary energy (e.g., natural gas, the sun, oil).
<b>GHG</b>	<i>Greenhouse gas</i> gases that are transparent to solar (short-wave) radiation but opaque to long-wave (infrared) radiation, thus preventing long-wave radiant energy from leaving Earth's atmosphere. The net effect is a trapping of absorbed radiation and a tendency to warm the planet's surface.

<b>gpf</b>	<i>Gallons per flush</i>
<b>gpm</b>	<i>Gallon per minute</i>
<b>HID</b>	<i>High intensity discharge:</i> high-output lighting lamps such as high-pressure sodium, metal halide, and mercury vapor.
<b>hp</b>	<i>Horsepower</i>
<b>HPS</b>	<i>High-pressure sodium:</i> a type of HID lamp
<b>HSPF</b>	<i>Heating seasonal performance factor:</i> a measure of efficiency typically applied to heat pumps. Heating energy provided divided by seasonal energy input.
<b>HVAC</b>	<i>Heating, ventilating, and air conditioning</i>
<b>IHP 2014</b>	US DOE Integral Horsepower rule. The current ruling regarding required electric motor efficiency.
<b>IPLV</b>	<i>Integrated part load value:</i> a measure of the part load efficiency usually applied to chillers.
<b>kBtu</b>	One thousand British thermal units
<b>kW</b>	<i>Kilowatt:</i> equal to 1,000 Watts.
<b>kWh</b>	<i>Kilowatt-hour:</i> 1,000 Watts of power expended over one hour.
<b>LED</b>	<i>Light emitting diode:</i> a high-efficiency source of light with a long lamp life.
<b>LGEA</b>	<i>Local Government Energy Audit</i>
<b>Load</b>	The total power a building or system is using at any given time.
<b>Measure</b>	A single activity, or installation of a single type of equipment, that is implemented in a building system to reduce total energy consumption.
<b>MH</b>	<i>Metal halide:</i> a type of HID lamp
<b>MBh</b>	<i>Thousand Btu per hour</i>
<b>MBtu</b>	<i>One thousand British thermal units</i>
<b>MMBtu</b>	<i>One million British thermal units</i>
<b>MV</b>	<i>Mercury Vapor:</i> a type of HID lamp
<b>NJBPU</b>	<i>New Jersey Board of Public Utilities</i>
<b>NJCEP</b>	<i>New Jersey's Clean Energy Program:</i> NJCEP is a statewide program that offers financial incentives, programs and services for New Jersey residents, business owners and local governments to help them save energy, money and the environment.
<b>psig</b>	<i>Pounds per square inch gauge</i>
<b>Plug Load</b>	Refers to the amount of power used in a space by products that are powered by means of an ordinary AC plug.

<b>PV</b>	<i>Photovoltaic</i> : refers to an electronic device capable of converting incident light directly into electricity (direct current).
<b>SEER</b>	<i>Seasonal energy efficiency ratio</i> : a measure of efficiency in terms of annual cooling energy provided divided by total electric input.
<b>SEP</b>	<i>Statement of energy performance</i> : a summary document from the ENERGY STAR® Portfolio Manager®.
<b>Simple Payback</b>	The amount of time needed to recoup the funds expended in an investment or to reach the break-even point between investment and savings.
<b>SREC</b>	<i>Solar renewable energy credit</i> : a credit you can earn from the state for energy produced from a photovoltaic array.
<b>T5, T8, T12</b>	A reference to a linear lamp diameter. The number represents increments of 1/8 <sup>th</sup> of an inch.
<b>Temperature Setpoint</b>	The temperature at which a temperature regulating device (thermostat, for example) has been set.
<b>therm</b>	100,000 Btu. Typically used as a measure of natural gas consumption.
<b>tons</b>	A unit of cooling capacity equal to 12,000 Btu/hr.
<b>Turnkey</b>	Provision of a complete product or service that is ready for immediate use
<b>VAV</b>	<i>Variable air volume</i>
<b>VFD</b>	<i>Variable frequency drive</i> : a controller used to vary the speed of an electric motor.
<b>WaterSense®</b>	The symbol for water efficiency. The WaterSense® program is managed by the EPA.
<b>Watt (W)</b>	Unit of power commonly used to measure electricity use.