





Local Government Energy Audit Report

Franklin Elementary School

August 1, 2023

Prepared for: Summit Board of Education 136 Blackburn Road Summit, New Jersey 07901 Prepared by: TRC 317 George Street New Brunswick, New Jersey 08901





Disclaimer

The goal of this audit report is to identify potential energy efficiency opportunities and help prioritize specific measures for implementation. Most energy conservation measures have received preliminary analysis of feasibility that identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to establish a basis for further discussion and to help prioritize energy measures.

TRC reviewed the energy conservation measures and estimates of energy savings for technical accuracy. Actual, achieved energy savings depend on behavioral factors and other uncontrollable variables and, therefore, estimates of final energy savings are not guaranteed. TRC and the New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

TRC bases estimated material and labor costs primarily on RS Means cost manuals as well as on our experience at similar facilities. This approach is based on standard cost estimating manuals and is vendor neutral. Cost estimates include material and labor pricing associated with one for one equipment replacements. Cost estimates do not include demolition or removal of hazardous waste. The actual implementation costs for energy savings projects are anticipated to be significantly higher based on the specific conditions at your site(s). We strongly recommend that you work with your design engineer or contractor to develop actual project costs for your specific scope of work for the installation of high efficiency equipment. We encourage you to obtain multiple estimates when considering measure installations. Actual installation costs can vary widely based on selected products and installers. TRC and NJBPU do not guarantee cost estimates and shall in no event be held liable should actual installed costs vary from these material and labor estimates.

Incentive values provided in this report are estimated based on previously run state efficiency programs. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. Please review all available utility program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

The customer and their respective contractor(s) are responsible to implement energy conservation measures in complete conformance with all applicable local, state, and federal requirements.

Copyright ©2023 TRC. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.





Table of Contents

1	Executi	ve Summary	1
	1.1	Planning Your Project	4
	Pick \	/our Installation Approach	4
	Optic	ons from Your Utility Company	4
	Presc	riptive and Custom Rebates	4
	Direc	t Install	4
	Optic	ons from New Jersey's Clean Energy Program	5
2	Existing	g Conditions	6
	2.1	Site Overview	6
	Recei	nt improvements and Facility Concerns	6
	2.2	Building Occupancy	6
	2.3	Building Envelope	7
	2.4	Lighting Systems	9
	2.5	Air Handling Systems	11
	Unit	Ventilators	.11
	Unita	ry Electric HVAC Equipment	. 12
	Unita Air H	ry Heating Equipment	.14
			15
	2.6	Building General Exhaust Air System	15
	2./	Realing Hot Water Systems	10
	2.0	Domestic Hot Water	18
	2.10	Food Service Equipment	19
	2.11	Refrigeration	19
	2.12	Plug Load and Vending Machines	20
	2.13	Water-Using Systems	21
3	Energy	Use and Costs	22
	3.1	Electricity	24
	3.2	Natural Gas	25
	3.3	Benchmarking	26
	Track	ing Your Energy Performance	.27
4	Energy	Conservation Measures	28
	4.1	Lighting	31
	ECM	1: Retrofit Fixtures with LED Lamps	.31
	4.2	Lighting Controls	31
	ECM	2: Install Occupancy Sensor Lighting Controls	.31
	ECM	3: Install High/Low Lighting Controls	.32
	4.3	Variable Frequency Drives (VFD)	32
_	ECM	4: Install VFDs on Constant Volume (CV) Fans	.33





	I	ECM 5: Install VFDs on Kitchen Hood Fan Motors	33
	4.4	Unitary HVAC	
	ſ	ECM 6: Install High Efficiency Heat Pumps	
	4.5	Gas-Fired Heating	
)	ECM 7: Install High Efficiency Furnaces	
	4.6	6 HVAC Improvements	
		ECM 8: Implement Demand Control Ventilation (DCV) ECM 9: Install Pipe Insulation	34 34
	4.7	7 Domestic Water Heating	
)	ECM 10: Install Low-Flow DHW Devices	
	4.8	3 Custom Measures	
)	ECM 11: Replace Gas Fired Water Heater with Heat Pump Water Heater	
	4.9	Measures for Future Consideration	
		Retro-Commissioning Study	
5	En	nergy Efficient Best Practices	
	,	Energy Tracking with ENERGY STAR Portfolio Manager	39
	,	Weatherization	
	ľ	Doors and Windows	
		Lighting Maintenance	40
	ļ	Lighting Controls	40
	I	Motor Maintenance	40
		Fans to Reduce Cooling Load	
	ſ	Inermostat Schedules and Temperature Resets	40
	I	AC System Evaporator/Condenser Coil Cleaning	40
	,	HVAC Filter Cleaning and Replacement	41
		Ductwork Maintenance	
	ļ	Boiler Maintenance	
	I	Furnace Maintenance	42
	I	Label HVAC Equipment	42
	(Optimize HVAC Equipment Schedules	42
	1	Water Heater Maintenance	
	1	Retrigeration Equipment Maintenance	
		Procurement Strategies	43
6	On	n-site Generation	45
	6.1	Solar Photovoltaic	
	6.3	Combined Heat and Power	
7	Ele	ectric Vehicles (EV)	49
	7.1	Electric Vehicle Charging	
8	Pro	oject Funding and Incentives	51
	8.1	Utility Energy Efficiency Programs	
	I	Prescriptive and Custom	52





	Dire	ct Install	
	Engi	neered Solutions	53
	8.2	New Jersey's Clean Energy Programs	54
	Larg	e Energy Users	54
	Com	bined Heat and Power	55
	Succ	essor Solar Incentive Program (SuSI)	56
	Ener	gy Savings Improvement Program	57
9	Projec	t Development	
10	Energy	/ Purchasing and Procurement Strategies	59
	10.1	Retail Electric Supply Options	
	10.2	Retail Natural Gas Supply Options	
Ap	pendix	A: Equipment Inventory & Recommendations	A-1
Ap	pendix	B: ENERGY STAR Statement of Energy Performance	B-1
Ap	pendix (C: Glossary	C-1





1 EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBPU) has sponsored this Local Government Energy Audit (LGEA) report for Franklin Elementary School. This report provides you with information about your facility's energy use, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help make changes in your facility. TRC conducted this study as part of a comprehensive effort to assist New Jersey school districts and local governments in controlling their energy costs and to help protect our environment by reducing statewide energy consumption.







POTENTIAL IMPROVEMENTS



This energy audit considered a range of potential energy improvements in your building. Costs and savings will vary between improvements. Presented below are two potential scopes of work for your consideration.



¹ Incentives are based on previously run state rebate programs. Contact your utility provider for current program incentives that may apply.

² A cost-effective measure is defined as one where the simple payback does not exceed two-thirds of the expected proposed equipment useful life. Simple payback is based on the net measure cost after potential incentives.

>TRC

#	Energy Conservation Measure	Cost Effective?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting	Upgrades		1,073	0.0	0	\$137	\$192	\$35	\$157	1.2	1,079
ECM 1	Retrofit Fixtures with LED Lamps	Yes	1,073	0.0	0	\$137	\$192	\$35	\$157	1.2	1,079
Lighting	Control Measures		17,576	5.0	-4	\$2,196	\$16,898	\$3,880	\$13,018	5.9	17,269
ECM 2	Install Occupancy Sensor Lighting Controls	Yes	15,558	4.5	-3	\$1,944	\$14,198	\$1,870	\$12,328	6.3	15,286
ECM 3	Install High/Low Lighting Controls	Yes	2,017	0.5	0	\$252	\$2,700	\$2,010	\$690	2.7	1,982
Variable	Frequency Drive (VFD) Measures		8,715	2.7	16	\$1,295	\$23,440	\$625	\$22,815	17.6	10,607
ECM 4	Install VFDs on Constant Volume (CV) Fans	No	7,332	2.7	0	\$934	\$19,933	\$550	\$19,383	20.7	7,384
ECM 5	Install VFDs on Kitchen Hood Fan Motors	Yes	1,383	0.0	16	\$361	\$3 <i>,</i> 508	\$75	\$3,433	9.5	3,224
Unitary	HVAC Measures		4,248	11.6	0	\$541	\$169,530	\$6,802	\$162,728	300.6	4,277
ECM 6	Install High Efficiency Heat Pumps	No	4,248	11.6	0	\$541	\$169,530	\$6,802	\$162,728	300.6	4,277
Gas Hea	ting (HVAC/Process) Replacement		0	0.0	15	\$174	\$3,007	\$500	\$2,507	14.4	1,724
ECM 7	Install High Efficiency Furnaces	Yes	0	0.0	15	\$174	\$3,007	\$500	\$2,507	14.4	1,724
HVAC Sy	rstem Improvements		0	0.0	95	\$1,120	\$6,601	\$164	\$6,437	5.7	11,092
ECM 8	Implement Demand Control Ventilation (DCV)	Yes	0	0.0	49	\$581	\$5 <i>,</i> 438	\$0	\$5,438	9.4	5,753
ECM 9	Install Pipe Insulation	Yes	0	0.0	46	\$539	\$1,163	\$164	\$999	1.9	5,340
Domest	c Water Heating Upgrade		0	0.0	14	\$162	\$186	\$88	\$98	0.6	1,605
ECM 10	Install Low-Flow DHW Devices	Yes	0	0.0	14	\$162	\$186	\$88	\$98	0.6	1,605
Custom	Measures		-13,130	0.0	140	-\$18	\$3,166	\$0	\$3,166	-175.9	3,170
ECM 11	Replace Gas Fired Water Heater with Heat Pump Water Heater	No	-13,130	0.0	140	-\$18	\$3,166	\$0	\$3,166	-175.9	3,170
	TOTALS (COST EFFECTIVE MEASURES)		20,032	5.0	135	\$4,150	\$30,392	\$4,742	\$25,650	6.2	35,992
TOTALS (ALL MEASURES)				19.3	275	\$5,607	\$223,022	\$12,094	\$210,927	37.6	50,823

* - All incentives presented in this table are included as placeholders for planning purposes and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

***Negative Payback Explained in Section 4.8

Figure 2 – Evaluated Energy Improvements

For more detail on each evaluated energy improvement and a break out of cost-effective improvements, see Section 4: Energy Conservation Measures.



TRC



1.1 Planning Your Project

Careful planning makes for a successful energy project. When considering this scope of work, you will have some decisions to make, such as:

- How will the project be funded and/or financed?
- Is it best to pursue individual ECMs, groups of ECMs, or use a comprehensive approach where all ECMs are installed together?
- Are there other facility improvements that should happen at the same time?

Pick Your Installation Approach

Utility-run energy efficiency programs and New Jersey's Clean Energy Programs, give you the flexibility to do a little or a lot. Rebates, incentives, and financing are available to help reduce both your installation costs and your energy bills. If you are planning to take advantage of these programs, make sure to review incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives <u>before</u> purchasing materials or starting installation.

Options from Your Utility Company

Prescriptive and Custom Rebates

For facilities wishing to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the Prescriptive and Custom Rebates program. To participate, you can use internal resources or an outside firm or contractor to perform the final design of the ECM(s) and install the equipment. Program pre-approval may be required for some incentives. Contact your utility company for more details prior to project installation.

Direct Install

The Direct Install program provides turnkey installation of multiple measures through an authorized contractor. This program can provide incentives up to 70% or 80% of the cost of selected measures. A Direct Install contractor will assess and verify individual measure eligibility and perform the installation work. The Direct Install program is available to sites with an average peak demand of less than 200 kW.

Engineered Solutions

The Engineered Solutions program provides tailored energy-efficiency assistance and turnkey engineering services to municipalities, universities, schools, hospitals, and healthcare facilities (MUSH), non-profit entities, and multifamily buildings. The program provides all professional services from audit, design, construction administration, to commissioning and measurement and verification for custom whole-building energy-efficiency projects. Engineered Solutions allows you to install as many measures as possible under a single project as well as address measures that may not qualify for other programs.

For more details on these programs please contact your utility provider.





Options from New Jersey's Clean Energy Program

Financing and Planning Support with the Energy Savings Improvement Program (ESIP)

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the ESIP. Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as attractive financing for implementing ECMs. You have already taken the first step as an LGEA customer, because this report is required to participate in ESIP.

Resiliency with Return on Investment through Combined Heat and Power (CHP)

The CHP program provides incentives for combined heat and power (i.e., cogeneration) and waste heat to power projects. Combined heat and power systems generate power on-site and recover heat from the generation system to meet on-site thermal loads. Waste heat to power systems use waste heat to generate power. You will work with a qualified developer who will design a system that meets your building's heating and cooling needs.

Successor Solar Incentive Program (SuSI)

New Jersey is committed to supporting solar energy. Solar projects help the state reach the renewable goals outlined in the state's Energy Master Plan. The SuSI program is used to register and certify solar projects in New Jersey. Rebates are not available, but certified solar projects are able to earn one SREC II (Solar Renewable Energy Certificates II) for each megawatt-hour of solar electricity produced from a qualifying solar facility.

Ongoing Electric Savings with Demand Response

The Demand Response Energy Aggregator program reduces electric loads at commercial facilities when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. By enabling commercial facilities to reduce electric demand during times of peak demand, the grid is made more reliable, and overall transmission costs are reduced for all ratepayers. Curtailment service providers provide regular payments to medium and large consumers of electric power for their participation in demand response (DR) programs. Program participation is voluntary, and facilities receive payments regardless of whether they are called upon to curtail their load during times of peak demand.

Large Energy User Program (LEUP)

LEUP is designed to promote self-investment in energy efficiency. It incentivizes owners/users of buildings to upgrade or install energy conserving measures in existing buildings to help offset the capital costs associated with the project. The efficiency upgrades are customized to meet the requirements of the customers' existing facilities, while advancing the State's energy efficiency, conservation, and greenhouse gas reduction goals.

For more details on these programs please visit New Jersey's Clean Energy Program website .



New Jersey's cleanenergy program"

TRC2 Existing Conditions

The New Jersey Board of Public Utilities (NJBPU) has sponsored this Local Government Energy Audit (LGEA) report for Franklin Elementary School. This report provides information on how your facility uses energy, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help you implement the ECMs.

TRC conducted this study as part of a comprehensive effort to assist New Jersey educational and local government facilities in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

2.1 Site Overview

On January 12, 2023, TRC performed an energy audit at Franklin Elementary School located in Summit, New Jersey. TRC met with Michael Martino to review the facility operations and help focus our investigation on specific energy-using systems.

Franklin Elementary School is a two-story, 48,280 square foot building built in 1970. Spaces include classrooms, offices, restrooms, storage rooms, corridors, multipurpose room, and electrical and mechanical spaces. The building is 100% heated by three condensing boilers and one roof top unit (RTU). The building is cooled by various Daikin variable refrigerant volume (VRV) heat pumps. The Daikin heat pumps provide only cooling as space heating is provided by the hot water boiler distribution system. Using the heat pumps for heating rather than hot water heating will contribute to reduce the building GHG emissions.

Recent improvements and Facility Concerns

In 2015, Franklin Elementary school phased out the use of fluorescent fixtures and replaced them with efficient LED lighting. In 2022, the facility installed one condensing hot water heater. In 2021, two split system heat pumps were installed. Other facility equipment has yet to be replaced, including Daikin heat pump units which are operating near the end of their useful life. The Greenheck energy recovery unit (ERU) located on the roof which serves the library appears in fair condition and has been evaluated for replacement.

2.2 Building Occupancy

The school operates Monday through Friday with standard classes running from 8:30 AM to 3:30 PM. Facility operating hours extend from 6:00 AM to 11:30 PM. The school year lasts for the standard 180 days with an average occupancy count of 45 staff and 303 students. Summer school classroom hours are 7:00 AM to 4:00 PM. It should be noted that the energy and economic analysis for this building is based on the use of the building during the utility billing period, and that results will vary depending on changes to building use patterns.

Building Name	Weekday/Weekend	Operating Schedule			
Franklin Elementary School	Weekday	6:00 AM - 11:30 PM			
General Operating Hours	Saturday	Varies			
Franklin Elementary School	Weekday	8:30 AM - 3:30 PM			
Class Hours	Weekend	Closed			

Figure	3.	Building	Occupancy	Schedule
--------	----	----------	-----------	----------



2.3 Building Envelope

The building walls are solid brick. The walls are in good condition. The roof has flat and pitched sections. The flat roof section is built up with a top sheet comprised of gravel and gray membrane. The pitched roof sections of the original building are finished with slate shingles that in fair aging condition. The flat roof was replaced in 2012 and is in good condition.

Facility windows are mainly operable and double paned. The seal between the glass and aluminum frame is in good condition. Non-operable windows also appear to be in good condition. Exterior doors consist of a mix of solid metal and aluminum framed with glass. Both door types are in good condition and are sealed well.



Exterior Walls – Original Buildings



Exterior Walls – Addition Buildings



Gravel Membrane Roof Sections



Gray Membrane Roof Sections









Pitched Roof with PVC Slate



Typical Windows







Exterior Doors

2.4 Lighting Systems

Franklin Elementary School has been exclusively operating with an LED lighting system after New Jersey's Clean Energy Direct Install Program retrofits in 2015. Franklin Elementary lighting fixtures mainly consist of 4-foot T8 equivalent linear LED tubes and 2-foot T8 equivalent U-Bend LED tubes. The gymnasium uses T5 high output LED linear tubes. Classroom lighting includes pendant, can, and retrofit drop ceiling fixtures with 2-lamp, 3-lamp, or 4-lamp fixtures. Additionally, emergency exit signs have been replaced with LED technology.

Most of the interior lighting is controlled by wall switches with a minimal number of ceiling mounted occupancy sensors present throughout the facility. Lighting in most are controlled by manually operated wall switches. The school's interior lighting fixtures are in good condition and all spaces are adequately lit.

Exterior lighting technology also uses LED sources. A mix of hardwired LED wall packs and plug in LED lamps comprise most of the exterior lighting. The exterior lighting is controlled by timer control system.







LED Tube Fixtures



LED Exit Sign







Wall Switch



Typical Wall Mounted LED Fixture



Electronic Timer



2.5 Air Handling Systems

Unit Ventilators

Unit ventilators are equipped with supply fan motors and digitally controlled outside air dampers and are connected to the hot water distribution system. They provide heating and ventilation to classrooms. A majority of the unit ventilators are floor mounted. Classroom 2 (Art room) and other classrooms are equipped with ceiling mounted units. Equipment is controlled by the building automation system (BAS).



Unit Ventilators



BAS View of Unit Ventilator





Unitary Electric HVAC Equipment

Some classrooms are cooled by window air conditioners (AC) with cooling capacities that range between 1.0 ton and 1.5 tons. The energy efficiency ratio (EER) of these units ranges from 11.80 to 12.00. These units are within their useful life and are in good condition.



Window AC

Wall AC

Various areas including classrooms and offices throughout Franklin Elementary School are conditioned by unitary electric HVAC equipment. These include one York split-system unit with direct expansion (DX) cooling and 12 Daikin air-source heat pumps located on the roof and labeled as CU-X. Indoor units are typically located on the wall or ceiling. The heat pumps provide only cooling as the heating capabilities are not used. Heating is provided by the hot water boiler distribution system.

Heat pump cooling capacities range between 6 tons and 12 tons. EER values are listed in the table following. These systems are controlled by the BAS.

Nine of the Daikin variable refrigerant volume (VRV) heat pumps were installed in 2011. These units are near the end of their useful life and have been evaluated for replacement.

The York 5-ton condensing unit located on the roof serves the STEAM lab. This unit is within its useful life and appears to be in good condition. It has an EER of 13.





Split System Air Source Heat Pump







BAS Screenshot - CU-4



York 5-ton Condensing Unit





Unit	Cooling Capacity (Tons)	Cooling Efficiency (EER)	Heating Capacity (MBh)	COP Heating Efficiency (%)	
CU-Classrooms	12.00	12.30	154.00	3.70	
CU-Music & Art	9.00	11.30	116.00	3.30	
CU-1-Master 10.00 Classrooms		11.30	11.30 129.00		
CU-1-Backup Classrooms	6.00	11.30	11.30 77.00		
CU-2 Classrooms	9.00	11.30	116.00	3.30	
CU-3 Classrooms 12.00		11.30	138.00	3.40	
CU-4-Master Classrooms	10.00	11.30	129.00	3.30	
CU-4-Backup Classrooms	6.00	11.30	77.00	2.65	
CU-Classrooms	12.00	11.30 138.00		3.40	
CU-Classrooms	12.00	11.30	138.00	3.40	
CU-Room 110-111	4.00	10.30	49.50	2.25	
CU-Room 112-113	4.00	10.30 49.50 2.		2.25	

Unitary Heating Equipment

Various spaces are heated by ceiling mounted electric resistance heaters including the corridor in the fifthgrade wing. These units are in good condition.

A Greenheck roof mounted, gas-fired unit equipped with economizer and energy recovery ventilation system serves the SGI rooms. It provides heated air through ductwork. The unit appears in fair condition and has been evaluated for replacement. It is controlled by the BAS.







Energy Recovery Unit (ERU)

Air Handling Units (AHUs)

There is one roof mounted air handling unit (AHU) labeled as RTU-1 that serves the library. It is equipped with a constant speed supply fan and hot water coils for heating. The AHU is operating beyond its useful life and appears in fair condition. It is controlled by the BAS.



RTU-1

2.6 Building General Exhaust Air System

General exhaust fans serve to ventilate restrooms, corridors, classrooms, and other spaces. Fractional horsepower motors drive the fans which appear to be in good condition. The BAS controls the exhaust fans, and they operate on the same schedule as the AHU.







Roof Exhaust Fans

2.7 Heating Hot Water Systems

Three, 1290 MBh AERCO condensing hot water boilers serve most of the building's heating load. The boilers have burners with nominal efficiency ratings of 86%. The boilers are configured to run together and modulate the load. Only one boiler was operating during the audit. Installed in 2009, the boilers are in good condition. The hydronic distribution system is two-pipe, heating only. Two, 10 hp variable speed pumps distribute heating hot water to AHUs, hydronic baseboards, and unit heaters.

The boilers operate based on outside air temperature. The boilers and the hot water loop are controlled by the BAS.



Heating Hot Water Boilers







Hot Water Loop

BALDOR - RELIANDER SUP BILOLOT DALDOR ELECTRIC CO
CAT. NO. EM3313T SPEC. 37F614T853 HP 10 VOLTS 230/460 AMPS 25/12.5
R.P.M. 1770 FRAME 215T HZ 60 PH 3 SER. F. 1.15 CODE H OES B CLASS F HEMA HOM, EV. 91.7 2 P.F. 82 2 PH 200 RATING 40C AMB-CONT
BEARINGS DE COULD DE CEOCO DE CEOCO DE COULT DE COULT DE COULT DE CEOCO DE

Heating Hot Water Pumps

2.8 Building Automation System (BAS)

An Automated Logic system controls the HVAC equipment, boilers, UVs, exhaust fans, RTUs, VRF systems, and AHUs. The system provides equipment scheduling control and monitors and controls space temperatures, supply air temperatures, humidity, and heating water loop temperatures.







BAS Screenshot

2.9 Domestic Hot Water

A 75-gallon Bradford White natural gas condensing water heater serves the domestic hot water demand for the Franklin Elementary School. A fractional horsepower domestic hot water pump circulates the water throughout the building. The system efficiency is estimated to be around 82%. The unit was installed in 2022. The domestic hot water pipes are mostly insulated, and the insulation is in good condition.





Domestic Hot Water Heater



2.10 Food Service Equipment

The kitchen has a mix of gas and electric equipment that is used to prepare meals for students. Most cooking is done using convection gas-fired ovens. Bulk prepared foods are held in an electric holding cabinet. Equipment is not high efficiency and is in good condition.

Visit <u>https://www.energystar.gov/products/commercial food service equipment</u> for the latest information on high efficiency food service equipment.



Gas-fired Stove

Electric Cooking Equipment

2.11 Refrigeration

The kitchen has two stand-up refrigerators and two stand-up freezers with a mix of solid and glass doors. There is a freezer chest as well as one refrigerator chest. All equipment is standard efficiency and in good condition.

Visit <u>https://www.energystar.gov/products/commercial_food_service_equipment</u> for the latest information on high efficiency food service equipment.







Solid Door Refrigerator

Glass Door Refrigerator

Freezer Chest

2.12 Plug Load and Vending Machines

There are 43 computer workstations throughout the facility. Plug loads throughout the building include general café and office equipment. There are classroom typical loads such as projectors. There are additional loads typically associated with elementary schools. Franklin also has a kiln and Robo 3D printers.

There are also typical office loads such as scanner/copiers, small printers, microwaves, and mini fridges; the site also has a server closet. There are two residential-style refrigerators throughout the facility that are in good condition.









Copier/Scanner

Residential -style Refrigerator

2.13 Water-Using Systems

There are several restrooms with toilets, urinals, and sinks. Faucet flow rates are at 2.2 gallons per minute (gpm) or higher. Toilets are rated at 2.5 gallons per flush (gpf) and urinals are rated at 2.5 gpf.



Typical Restroom Sink Flow



TRC3 Energy Use and Costs

Twelve months of utility billing data are used to develop annual energy consumption and cost data. This information creates a profile of the annual energy consumption and energy costs.



An energy balance identifies and quantifies energy use in your various building systems. This can highlight areas with the most potential for improvement. This energy balance was developed using calculated energy use for each of the end uses noted in the figure.

The energy auditor collects information regarding equipment operating hours, capacity, efficiency, and other operational parameters from facility staff, drawings, and on-site observations. This information is used as the inputs to calculate the existing conditions energy use for the site. The calculated energy use is then compared to the historical energy use and the initial inputs are revised, as necessary, to balance the calculated energy use to the historical energy use.







Figure 4 - Energy Balance



3.1 Electricity

TRC



JCP&L delivers electricity under General Service Secondary 3 Phase rate class.

	Electric Billing Data											
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost							
6/8/21	32	1,440	118	\$716	\$956							
7/7/21	29	21,360	127	\$776	\$2,802							
8/5/21	29	11,949	64	\$468	\$1,477							
9/7/21	33	26,640	127	\$776	\$3,292							
10/7/21	30	30,080	127	\$722	\$3,550							
11/5/21	29	22,000	81	\$455	\$2,570							
12/7/21	32	15,280	81	\$527	\$2,045							
1/7/22	31	28,080	84	\$548	\$3,232							
2/7/22	31	21,280	84	\$548	\$2,606							
3/8/22	29	29,280	100	\$667	\$3,460							
4/7/22	30	23,280	94	\$617	\$2,856							
5/7/22	30	1,520	91	\$502	\$743							
Totals	365	232,189	127	\$7,321	\$29,588							
Annual	365	232.189	127	\$7.321	\$29.588							

Notes:

- Peak demand of 127 kW occurred in June, September, and October '21.
- Average demand over the past 12 months was 98 kW.
- The average electric cost over the past 12 months was \$0.127/kWh, which is the blended rate that includes energy supply, distribution, demand, and other charges. This report uses this blended rate to estimate energy cost savings.



TRC3.2 Natural Gas

PSE&G delivers natural gas under rate class Large Volume Gas (LVG), with natural gas supply provided by Direct Energy, a third-party supplier.



Gas Billing Data										
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost							
6/7/21	32	492	\$401							
7/7/21	30	180	\$248							
8/5/21	29	163	\$237							
9/7/21	33	268	\$291							
10/5/21	28	127	\$221							
11/3/21	29	523	\$1,276							
12/7/21	34	2,479	\$2,442							
1/6/22	30	3,473	\$4,373							
2/4/22	29	6,291	\$6,916							
3/8/22	32	4,253	\$5,200							
4/4/22	27	2,617	\$3,155							
5/6/22	32	1,365	\$1,515							
Totals	365	22,229	\$26,274							
Annual	365	22,229	\$26,274							

Notes:

• The average gas cost for the past 12 months is \$1.182/therm, which is the blended rate used throughout the analysis.



TRC3.3 Benchmarking

Your building was benchmarked using the United States Environmental Protection Agency's (EPA) *Portfolio Manager®* software. Benchmarking compares your building's energy use to that of similar buildings across the country, while neutralizing variations due to location, occupancy, and operating hours. Some building types can be scored with a 1-100 ranking of a building's energy performance relative to the national building market. A score of 50 represents the national average and a score of 100 is best.

This ENERGY STAR benchmarking score provides a comprehensive snapshot of your building's energy performance. It assesses the building's physical assets, operations, and occupant behavior, which is compiled into a quick and easy-to-understand score.



Figure 5 - Energy Use Intensity Comparison³

Congratulations, your building performs better than the national average. This report has suggestions about how to keep your building running efficiently, further improve performance, and lower your energy bills even more.

Energy use intensity (EUI) measures energy consumption per square foot and is the standard metric for comparing buildings' energy performance. A lower EUI means better performance and less energy consumed. Several factors can cause a building to vary from typical energy usage. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and occupant behavior all contribute to a building's energy use and the benchmarking score.

³ Based on all evaluated ECMs





Tracking Your Energy Performance

Keeping track of your energy use on a monthly basis is one of the best ways to keep energy costs in check. Update your utility information in Portfolio Manager regularly, so that you can keep track of your building's performance.

We have created a Portfolio Manager account for your facility and have already entered the monthly utility data shown above for you. Account login information for your account will be sent via email.

Free online training is available to help you use ENERGY STAR Portfolio Manager to track your building's performance at: <u>https://www.energystar.gov/buildings/training.</u>

For more information on ENERGY STAR and Portfolio Manager, visit their <u>website</u>.



TRC 4 Energy Conservation Measures

The goal of this audit report is to identify and evaluate potential energy efficiency improvements and provide information about the cost effectiveness of those improvements. Most energy conservation measures have received preliminary analysis of feasibility, which identifies expected ranges of savings. This level of analysis is typically sufficient to demonstrate project cost-effectiveness and help prioritize energy measures.

Calculations of energy use and savings are based on the current version of the *New Jersey's Clean Energy Program Protocols to Measure Resource Savings*, which is approved by the NJBPU. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances.

Operation and maintenance costs for the proposed new equipment will generally be lower than the current costs for the existing equipment—especially if the existing equipment is at or past its normal useful life. We have conservatively assumed there to be no impact on overall maintenance costs over the life of the equipment.

Financial incentives in this report are based on the previously run state rebate program SmartStart, which has been retired. Now, all investor-owned gas and electric utility companies are offering complementary energy efficiency programs directly to their customers. Some measures and proposed upgrades may be eligible for higher incentives than those shown below. The incentives in the summary tables should be used for high-level planning purposes. To verify incentives, reach out to your utility provider or visit the <u>NJCEP website</u> for more information.

For a detailed list of the locations and recommended energy conservation measures for all inventoried equipment, see Appendix A: Equipment Inventory & Recommendations.

TRC

#	Energy Conservation Measure	Cost Effective?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting	Upgrades		1,073	0.0	0	\$137	\$192	\$35	\$157	1.2	1,079
ECM 1	Retrofit Fixtures with LED Lamps	Yes	1,073	0.0	0	\$137	\$192	\$35	\$157	1.2	1,079
Lighting	Control Measures		17,576	5.0	-4	\$2,196	\$16,898	\$3,880	\$13,018	5.9	17,269
ECM 2	Install Occupancy Sensor Lighting Controls	Yes	15,558	4.5	-3	\$1,944	\$14,198	\$1,870	\$12,328	6.3	15,286
ECM 3	Install High/Low Lighting Controls	Yes	2,017	0.5	0	\$252	\$2,700	\$2 <i>,</i> 010	\$690	2.7	1,982
Variable Frequency Drive (VFD) Measures			8,715	2.7	16	\$1,295	\$23,440	\$625	\$22,815	17.6	10,607
ECM 4	Install VFDs on Constant Volume (CV) Fans	No	7,332	2.7	0	\$934	\$19,933	\$550	\$19,383	20.7	7,384
ECM 5	Install VFDs on Kitchen Hood Fan Motors	Yes	1,383	0.0	16	\$361	\$3 <i>,</i> 508	\$75	\$3 <i>,</i> 433	9.5	3,224
Unitary HVAC Measures			4,248	11.6	0	\$541	\$169,530	\$6,802	\$162,728	300.6	4,277
ECM 6	Install High Efficiency Heat Pumps	No	4,248	11.6	0	\$541	\$169,530	\$6,802	\$162,728	300.6	4,277
Gas Hea	ting (HVAC/Process) Replacement		0	0.0	15	\$174	\$3,007	\$500	\$2,507	14.4	1,724
ECM 7	Install High Efficiency Furnaces	Yes	0	0.0	15	\$174	\$3,007	\$500	\$2,507	14.4	1,724
HVAC Sy	stem Improvements		0	0.0	95	\$1,120	\$6,601	\$164	\$6,437	5.7	11,092
ECM 8	Implement Demand Control Ventilation (DCV)	Yes	0	0.0	49	\$581	\$5 <i>,</i> 438	\$0	\$5 <i>,</i> 438	9.4	5,753
ECM 9	Install Pipe Insulation	Yes	0	0.0	46	\$539	\$1,163	\$164	\$999	1.9	5,340
Domesti	c Water Heating Upgrade		0	0.0	14	\$162	\$186	\$88	\$98	0.6	1,605
ECM 10	Install Low-Flow DHW Devices	Yes	0	0.0	14	\$162	\$186	\$88	\$98	0.6	1,605
Custom Measures			-13,130	0.0	140	-\$18	\$3,166	\$0	\$3,166	-175.9	3,170
ECM 11	Replace Gas Fired Water Heater with Heat Pump Water Heater	No	-13,130	0.0	140	-\$18	\$3,166	\$0	\$3,166	-175.9	3,170
	TOTALS				275	\$5,607	\$223,022	\$12,094	\$210,927	37.6	50,823

* - All incentives presented in this table are included as placeholders for planning purposes and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

***Negative Payback Explained in Section 4.8

Figure 6 – All Evaluated ECMs



TRC

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting	Upgrades	1,073	0.0	0	\$137	\$192	\$35	\$157	1.2	1,079
ECM 1	Retrofit Fixtures with LED Lamps	1,073	0.0	0	\$137	\$192	\$35	\$157	1.2	1,079
Lighting Control Measures		17,576	5.0	-4	\$2,196	\$16,898	\$3,880	\$13,018	5.9	17,269
ECM 2	Install Occupancy Sensor Lighting Controls	15,558	4.5	-3	\$1,944	\$14,198	\$1,870	\$12,328	6.3	15,286
ECM 3	Install High/Low Lighting Controls	2,017	0.5	0	\$252	\$2,700	\$2,010	\$690	2.7	1,982
Variable Frequency Drive (VFD) Measures		1,383	0.0	16	\$361	\$3,508	\$75	\$3,433	9.5	3,224
ECM 5	Install VFDs on Kitchen Hood Fan Motors	1,383	0.0	16	\$361	\$3,508	\$75	\$3 <i>,</i> 433	9.5	3,224
Gas Hea	ting (HVAC/Process) Replacement	0	0.0	15	\$174	\$3,007	\$500	\$2,507	14.4	1,724
ECM 7	Install High Efficiency Furnaces	0	0.0	15	\$174	\$3,007	\$500	\$2 <i>,</i> 507	14.4	1,724
HVAC Sy	ystem Improvements	0	0.0	95	\$1,120	\$6,601	\$164	\$6,437	5.7	11,092
ECM 8	Implement Demand Control Ventilation (DCV)	0	0.0	49	\$581	\$5,438	\$0	\$5 <i>,</i> 438	9.4	5,753
ECM 9	Install Pipe Insulation	0	0.0	46	\$539	\$1,163	\$164	\$999	1.9	5,340
Domestic Water Heating Upgrade		0	0.0	14	\$162	\$186	\$88	\$98	0.6	1,605
ECM 10	Install Low-Flow DHW Devices	0	0.0	14	\$162	\$186	\$88	\$98	0.6	1,605
	TOTALS	20,032	5.0	135	\$4,150	\$30,392	\$4,742	\$25,650	6.2	35,992

* - All incentives presented in this table are included as placeholders for planning purposes and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 7 – Cost Effective ECMs







4.1 Lighting

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (Ibs)
Lighting Upgrades		1,073	0.0	0	\$137	\$192	\$35	\$157	1.2	1,079
ECM 1	Retrofit Fixtures with LED Lamps	1,073	0.0	0	\$137	\$192	\$35	\$157	1.2	1,079

When considering lighting upgrades, we suggest using a comprehensive design approach that simultaneously upgrades lighting fixtures and controls to maximize energy savings and improve occupant lighting. Comprehensive design will also consider appropriate lighting levels for different space types to make sure that the right amount of light is delivered where needed. If conversion to LED light sources is proposed, we suggest converting all of a specific lighting type (e.g., linear fluorescent) to LED lamps to minimize the number of lamp types in use at the facility, which should help reduce future maintenance costs.

ECM 1: Retrofit Fixtures with LED Lamps

Replace fluorescent T8 and incandescent lamps with LED lamps. Many LED tubes are direct replacements for existing fluorescent tubes and can be installed while leaving the fluorescent fixture ballast in place. LED lamps can be used in existing fixtures as a direct replacement for most other lighting technologies. Be sure to specify replacement lamps that are compatible with existing dimming controls, where applicable. In some circumstances, you may need to upgrade your dimming system for optimum performance.

This measure saves energy by installing LEDs, which use less power than other lighting technologies yet provide equivalent lighting output for the space. Maintenance savings may also be available, as longerlasting LEDs lamps will not need to be replaced as often as the existing lamps.

Affected Building Areas: elevator room, exterior doors

4.2 Lighting Controls

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (Ibs)
Lighting Control Measures		17,576	5.0	-4	\$2,196	\$16,898	\$3,880	\$13,018	5.9	17,269
ECM 2	Install Occupancy Sensor Lighting Controls	15,558	4.5	-3	\$1,944	\$14,198	\$1,870	\$12,328	6.3	15,286
ECM 3	Install High/Low Lighting Controls	2,017	0.5	0	\$252	\$2,700	\$2,010	\$690	2.7	1,982

Lighting controls reduce energy use by turning off or lowering lighting fixture power levels when not in use. A comprehensive approach to lighting design should upgrade the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

ECM 2: Install Occupancy Sensor Lighting Controls

Install occupancy sensors to control lighting fixtures in areas that are frequently unoccupied, even for short periods. For most spaces, we recommend that lighting controls use dual technology sensors, which reduce the possibility of lights turning off unexpectedly.




Occupancy sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Most occupancy sensor lighting controls allow users to manually turn fixtures on/off, as needed. Some controls can also provide dimming options.

Occupancy sensors can be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are best suited to single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in large spaces, locations without local switching, and where wall switches are not in the line-of-sight of the main work area.

This measure provides energy savings by reducing the lighting operating hours.

Affected Building Areas: classrooms, offices, bathrooms, cafeteria, library, gymnasium

ECM 3: Install High/Low Lighting Controls

Install occupancy sensors to provide dual level lighting control for lighting fixtures in spaces that are infrequently occupied but may require some level of continuous lighting for safety or security reasons.

Lighting fixtures with these controls operate at default low levels when the area is unoccupied to provide minimal lighting to meet security or safety code requirements for egress. Sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Fixtures automatically switch back to low level after a predefined period of vacancy. In parking lots and parking garages with significant ambient lighting, this control can sometimes be combined with photocell controls to turn the lights off when there is sufficient daylight.

The controller lowers the light level by dimming the fixture output. Therefore, the controlled fixtures need to have a dimmable ballast or driver. This will need to be considered when selecting retrofit lamps and bulbs for the areas proposed for high/low control.

For this type of measure the occupancy sensors will generally be ceiling or fixture mounted. Sufficient sensor coverage must be provided to ensure that lights turn on in each area as occupants approach the area.

This measure provides energy savings by reducing the light fixture power draw when reduced light output is appropriate.

Affected Building Areas: corridors, stairwells

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Variable	e Frequency Drive (VFD) Measures	8,715	2.7	16	\$1,295	\$23,440	\$625	\$22,815	17.6	10,607
ECM 4	ECM 4 Install VFDs on Constant Volume (CV) Fans		2.7	0	\$934	\$19,933	\$550	\$19,383	20.7	7,384
ECM 5	Install VFDs on Kitchen Hood Fan Motors	1,383	0.0	16	\$361	\$3,508	\$75	\$3,433	9.5	3,224

4.3 Variable Frequency Drives (VFD)

Variable frequency drives control motors for fans, pumps, and process equipment based on the actual output required of the driven equipment. Energy savings result from more efficient control of motor energy usage when equipment operates at partial load. The magnitude of energy savings depends on the estimated amount of time that the motor would operate at partial load. For equipment with proposed VFDs, we have included replacing the controlled motor with a new inverter duty rated motor to conservatively account for the cost of an inverter duty rated motor.



ECM 4: Install VFDs on Constant Volume (CV) Fans

We evaluated installing VFDs to control constant volume fan motor speeds. This converts a constantvolume, single-zone air handling system into a variable-air-volume (VAV) system. A separate VFD is usually required to control the return fan motor or dedicated exhaust fan motor if the air handler has one.

Zone thermostats signal the VFD to adjust fan speed to maintain the appropriate temperature in the zone, while maintaining a constant supply air temperature.

Energy savings result from reducing the fan speed (and power) when conditions allow for reduced air flow.

Affected Air Handlers: HV-1, HV-2, RTU-1, exhaust fans

ECM 5: Install VFDs on Kitchen Hood Fan Motors

We evaluated installing a VFD and sensors to control the kitchen hood fan motor. The air flow of the hood is varied based on two key inputs: temperature and smoke/cooking fumes. The VFD controls the amount of exhaust (and kitchen make-up air) based on temperature—the lower the temperature the lower the flow. If the optic sensor is triggered by smoke or cooking fumes, the speed of the fan ramps up to 100%.

Energy savings result from reducing the hood fan speed (and power) when conditions allow for reduced air flow.

4.4 Unitary HVAC

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Annual Peak A Electric Demand Savings Savings S (kWh) (kW) (N		Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (Ibs)
Unitary HVAC Measures		4,248	11.6	0	\$541	\$169,530	\$6,802	\$162,728	300.6	4,277
ECM 6	Install High Efficiency Heat Pumps	4,248	11.6	0	\$541	\$169,530	\$6,802	\$162,728	300.6	4,277

Replacing the unitary HVAC units has a long payback period and may not be justifiable based simply on energy considerations. However, most of the units are nearing or have reached the end of their normal useful life. Typically, the marginal cost of purchasing a high efficiency unit can be justified by the marginal savings from the improved efficiency. When the Heat Pump is eventually replaced, consider purchasing equipment that exceeds the minimum efficiency required by building codes.

ECM 6: Install High Efficiency Heat Pumps

We evaluated replacing old heat pumps with high efficiency heat pumps. A higher EER or SEER rating indicates a more efficient cooling system, and a higher HSPF rating indicates more efficient heating mode. The magnitude of energy savings for this measure depends on the relative efficiency of the older unit versus the new high efficiency unit, the average heating and cooling loads, and the estimated annual operating hours.

Note that because the heating components of these units have never been used, no savings can be claimed from increased efficiency during heating operations. The project payback is therefore significantly longer than if these systems were providing both heating and cooling.

Affected Units: nine (older) Daikin heat pumps





#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (Ibs)
Gas He	ating (HVAC/Process) Replacement	0	0.0	15	\$174	\$3,007	\$500	\$2,507	14.4	1,724
ECM 7	CM 7 Install High Efficiency Furnaces		0.0	15	\$174	\$3,007	\$500	\$2,507	14.4	1,724

ECM 7: Install High Efficiency Furnaces

Replace the standard efficiency Greenheck ERU with a new ERU. Improved combustion technology and heat exchanger design optimize heat recovery from the combustion gases, which can significantly improve furnace efficiency. Savings result from improved system efficiency.

Note: these units produce acidic condensate that require proper drainage.

Affected Units: energy recovery unit (ERU)

4.6 HVAC Improvements

#	Energy Conservation Measure	Annual Peak Electric Demand Savings Savings S (kWh) (kW) (t		Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
HVAC S	ystem Improvements	0	0.0	95	\$1,120	\$6,601	\$164	\$6,437	5.7	11,092
ECM 8	CM 8 Implement Demand Control Ventilation (DCV)		0 0.0 4		\$581	\$5,438	\$0	\$5,438	9.4	5,753
ECM 9 Install Pipe Insulation		0	0.0	46	\$539	\$1,163	\$164	\$999	1.9	5,340

ECM 8: Implement Demand Control Ventilation (DCV)

Demand control ventilation (DCV) is a control strategy that monitors the indoor air's carbon dioxide (CO_2) content to measure room occupancy. This data is used to regulate the amount of outdoor air provided to the space for ventilation.

Standard ventilation systems often provide outside air based on a space's estimated maximum occupancy but not actual occupancy. During low occupancy periods, the space may then be over ventilated. This wastes energy through heating and cooling the excess outside air flow. DCV reduces unnecessary outdoor air intake by regulating ventilation based on actual occupancy levels. DCV is most suited for facilities where occupancy levels vary significantly from hour to hour and day to day.

Energy savings associated with DCV are based on hours of operation, space occupancy, outside air reduction, and other factors. Energy savings results from eliminating unnecessary ventilation and space conditioning. Implementation of this measure is dependent upon having a building automation system (BAS) or other smart building control system connected to the space conditioning equipment serving the noted areas.

Affected Building Areas: service area for ERU - SGI-4,5,6&7 and HV 1&2 (Auditorium)

ECM 9: Install Pipe Insulation

Install insulation on heating water and domestic hot water system piping. Distribution system losses are dependent on system fluid temperature, the size of the distribution system, and the level of insulation of the piping. Significant energy savings can be achieved when insulation has not been well maintained.





When the insulation is exposed to water, when the insulation has been removed from some areas of the pipe, or when valves have not been properly insulated system efficiency can be significantly reduced. This measure saves energy by reducing heat transfer in the distribution system.

Affected Systems: domestic hot water pipes in boiler room, kitchen, and custodial supply closet

4.7 Domestic Water Heating

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (Ibs)
Domes	tic Water Heating Upgrade	0	0.0	14	\$162	\$186	\$88	\$98	0.6	1,605
ECM 10	Install Low-Flow DHW Devices	0	0.0	14	\$162	\$186	\$88	\$98	0.6	1,605

ECM 10: Install Low-Flow DHW Devices

Install low-flow devices to reduce overall hot water demand. The following low-flow devices are recommended to reduce hot water usage:

Device	Flow Rate
Faucet aerators (lavatory)	0.5 gpm
Faucet aerator (kitchen)	1.5 gpm
Showerhead	2.0 gpm
Pre-rinse spray valve (kitchen)	1.28 gpm

Low-flow devices reduce the overall water flow from the fixture, while still providing adequate pressure for washing.

Additional cost savings may result from reduced water usage.

4.8 Custom Measures

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Annual Peak Electric Demand Savings Savings (kWh) (kW) (Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Custom Measures		-13,130	0.0	140	-\$18	\$3,166	\$0	\$3,166	-175.9	3,170
ECM 11	Replace Gas Fired Water Heater with Heat Pump Water Heater	-13,130	0.0	140	-\$18	\$3,166	\$0	\$3,166	-175.9	3,170

ECM 11: Replace Gas Fired Water Heater with Heat Pump Water Heater

A gas fired water heater uses a burner to heat water. Air source heat pump water heaters (HPWH) use a refrigeration cycle to transfer heat from the surrounding air to the domestic water. Water heater efficiency is rated by the uniform energy factor (UEF). For a relative comparison of water heater UEFs, the criteria for certifying a water heater in the ENERGY STAR program are provided below. These values indicate that HPWH heaters are significantly more efficient than gas fired water heaters.





There are two types of HPWH: those integrated with the heat pump and storage tank in the same unit, and those that are split into two sections (with the storage tank separate from the heat pump). The measure considers an integrated HPWH.

Water Heater Type	Minimum UEF	Other
Integrated HPWH	3.3	
Integrated HPWH	2.2	120 Volt, 15 Amp circuit
Split System HPWH	2.2	
Gas Fired Storage	0.64	≤ 55-gal, Medium Draw Pattern
Gas Fired Storage	0.68	≤ 55-gal, High Draw Pattern
Gas Fired Storage	0.78	> 55-gal, Medium Draw Pattern
Gas Fired Storage	0.80	> 55-gal, High Draw Pattern
Gas Fired Storage	0.80	Residential Duty
Gas Fired Instantaneous	0.87	

ENERGY STAR Uniform Energy Factor (UEF) Criteria for Certified Water Heaters *

* Note: Uniform Energy Factor (UEF): The newest measure of water heater overall efficiency. The higher the UEF value is, the more efficient the water heater. UEF is determined by the Department of Energy's test method outlined in 10 CFR Part 430, Subpart B, Appendix E.⁴

HPWH reject cold air. As such, they need to be installed in an unconditioned space of about 750 cubic feet with good ventilation⁵. Ideal locations are garages, large enclosed, unconditioned storage areas, or areas with excess heat such as a furnace or boiler room. The HPWH will also produce condensate so accommodations for draining the condensate need to be provided.

Most HPWH operate effectively down to an air temperature of 40 °F. Below that temperature, an electric resistance booster heater is typically required to achieve full heating capacity. It is critical that the HPWH controls are set up so that the electric resistance heat only engages when the air temperature is too cold for the HPWH to extract heat from it. HPWHs have a slow recovery. During periods of high demand, the electric resistance heating element, if enabled, may be energized to maintain set point, thus reducing the overall efficiency of the unit. It is recommended that a careful analysis of the hot water demand be conducted to determine if the application makes economic sense, and the HPWH heating capacity and storage are properly sized.

HPWH operate most effectively when the temperature difference between the incoming and outgoing water is high. Generally, this means that cold make-up water should be piped to the bottom of the tank and return water should be piped to the top of the tank in order to maintain stratification within the storage tank. Water should be drawn from the bottom of the tank to be heated. If there is a DHW recirculation pump, it should only be operated during high hot water demand periods.

⁴ <u>https://www.energy.gov/sites/prod/files/2014/06/f17/rwh_tp_final_rule.pdf</u>

⁵ <u>https://basc.pnnl.gov/code-compliance/heat-pump-water-heaters-code-compliance-</u> <u>brief#:~:text=HPWH%20must%20have%20unrestricted%20airflow,depending%20on%20size%20of%20system</u>





Switching from a gas fired water heater to a HPWH has the potential to reduce the sites overall greenhouse gas emissions. If the electricity for the HPWH is provided by an on-site photovoltaic (PV) system, then there are essentially no greenhouse gas (GHG) emissions. A 2016 study conducted at Cornell ⁶calculated the kg of methane (CH₄) and carbon dioxide (CO₂) produced per GJ of water heated. The study compared HPWH to gas and electric fired, storage and tankless water heaters. The study also considered electricity produced from natural gas and coal fired electric plants. In all cases the study found that HPWHs produced less methane than all of the other water heaters. The study also found that HPWH produced less carbon dioxide than electric resistance water heaters but more carbon dioxide than tankless gas water heaters and about the same amount of carbon dioxide as storage gas water heaters. The summary tables provide the reduction in CO2 equivalent emissions based on the typical New Jersey electric utility.

This measure has a negative simple payback due to the relative cost of electricity to natural gas. At this site the cost per Btu for natural gas is significantly lower than for electricity. Therefore, even though this measure will result in a net energy savings in terms of Btu at this site it will increase the overall cost for providing domestic hot water.

4.9 Measures for Future Consideration

There are additional opportunities for improvement that Summit Board of Education may wish to consider. These potential upgrades typically require further analysis, involve substantial capital investment, and/or include significant system reconfiguration. These measure(s) are therefore beyond the scope of this energy audit. These measure(s) are described here to support a whole building approach to energy efficiency and sustainability.

Summit Board of Education may wish to consider the Energy Savings Improvement Program (ESIP) or other whole building approach. With interest in implementing comprehensive, largescale and/or complex system wide projects, these measures may be pursued during development of a future energy savings plan. We recommend that you work with your energy service company (ESCO) and/or design team to:

- Evaluate these measures further.
- Develop firm costs.
- Determine measure savings.
- Prepare detailed implementation plans.

Other modernization or capital improvement funds may be leveraged for these types of refurbishments. As you plan for capital upgrades, be sure to consider the energy impact of the building systems and controls being specified.

Retro-Commissioning Study

Due to the complexity of today's HVAC systems and controls, a thorough analysis and rebalance of heating, ventilation, and cooling systems should periodically be conducted. There are indications at this site that systems may not be operating correctly or as efficiently as they could be. One important tool available to building operators to ensure proper system operation is retro-commissioning.

Retro-commissioning is a common practice recommended by the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE) to be implemented every few years. We recommend that you contact a reputable engineering firm that specializes in energy control systems and

⁶ <u>Greenhouse gas emissions from domestic hot water: Heat pumps compared to most commonly used systems. Bongghi Hong,</u> <u>Robert W. Howarth. Department of Ecology and Evolutionary Biology, Cornell University. Energy Science and Engineering 2016.</u>





retro-commissioning. Ask them to propose a scope of work and an outline of the procedures and processes to be implemented, including a schedule and the roles of all responsible parties.

Once goals and responsibilities are established, the objective of the investigation process is to understand how the building is currently operating, identify the issues, and determine the most cost-effective way to improve performance. The retro-commissioning agent will review building documentation, interview building occupants, and inspect and test the equipment. Information is then compiled into a report and shared with facility staff, who will select which recommendations to implement after reviewing the findings.

The implementation phase puts the selected processes into place. Typical measures may include sensor calibration, equipment schedule changes, damper linkage repair and similar relatively low-cost adjustments—although more expensive sophisticated programming and building control system upgrades may be warranted. Approved measures may be implemented by the agent, the building staff, or by subcontractors. Typically, a combination of these individuals makes up the retro-commissioning team.

After the approved measures are implemented, the team will verify that the changes are working as expected. Baseline and post-case measurements will allow building staff to monitor equipment and ensure that the benefits are maintained.



TRC 5 ENERGY EFFICIENT BEST PRACTICES

A whole building maintenance plan will extend equipment life; improve occupant comfort, health, and safety; and reduce energy and maintenance costs.

Operation and maintenance (O&M) plans enhance the operational efficiency of HVAC and other energy intensive systems and could save 5% –20% of the energy usage in your building without substantial capital investment. A successful plan includes your records of energy usage trends and costs, building equipment lists, current maintenance practices, and planned capital upgrades, and it incorporates your ideas for improved building operation. Your plan will address goals for energy-efficient operation, provide detail on how to reach the goals, and outline procedures for measuring and reporting whether goals have been achieved.

You may already be doing some of these things—see our list below for potential additions to your maintenance plan. Be sure to consult with qualified equipment specialists for details on proper maintenance and system operation.

Energy Tracking with ENERGY STAR Portfolio Manager



You've heard it before—you cannot manage what you do not measure. ENERGY STAR Portfolio Manager is an online tool that you can use to measure and track energy and water consumption, as well as greenhouse gas emissions⁷. Your account has already been established. Now you can continue to keep tabs on your energy performance every month.

Weatherization

Caulk or weather strip leaky doors and windows to reduce drafts and loss of heated or cooled air. Sealing cracks and openings can reduce heating and cooling costs, improve building durability, and create a healthier indoor environment. Materials used may include caulk, polyurethane foam, and other weatherstripping materials. There is an energy savings opportunity by reducing the uncontrolled air exchange between the outside and inside of the building. Blower door assisted comprehensive building air sealing will reduce the amount of air exchange, which will in turn reduce the load on the buildings heating and cooling equipment, providing energy savings and increased occupant comfort.

Doors and Windows

Close exterior doors and windows in heated and cooled areas. Leaving doors and windows open leads to a loss of heat during the winter and chilled air during the summer. Reducing air changes per hour can lead to increased occupant comfort as well as heating and cooling savings, especially when combined with proper HVAC controls and adequate ventilation.

⁷ <u>https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/use-portfolio-manager.</u>



TRC Lighting Maintenance



Clean lamps, reflectors and lenses of dirt, dust, oil, and smoke buildup every six to twelve months. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust. Together, this can reduce total light output by up to 60% while still drawing full power.

In addition to routine cleaning, developing a maintenance schedule can ensure that maintenance is performed regularly, and it can reduce the overall cost of fixture re-

lamping and re-ballasting. Group re-lamping and re-ballasting maintains lighting levels and minimizes the number of site visits by a lighting technician or contractor, decreasing the overall cost of maintenance.

Lighting Controls

As part of a lighting maintenance schedule, test lighting controls to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight and photocell sensors, maintenance involves cleaning sensor lenses and confirming that setpoints and sensitivity are configured properly. Adjust exterior lighting time clock controls seasonally as needed to match your lighting requirements.

Motor Maintenance

Motors have many moving parts. As these parts degrade over time, the efficiency of the motor is reduced. Routine maintenance prevents damage to motor components. Routine maintenance should include cleaning surfaces and ventilation openings on motors to prevent overheating, lubricating moving parts to reduce friction, inspecting belts and pulleys for wear and to ensure they are at proper alignment and tension, and cleaning and lubricating bearings. Consult a licensed technician to assess these and other motor maintenance strategies.

Fans to Reduce Cooling Load

Install ceiling fans to supplement your cooling system. Thermostat settings can typically be increased by 4°F with no change in overall occupant comfort due to the wind chill effect of moving air.

Thermostat Schedules and Temperature Resets



Use thermostat setback temperatures and schedules to reduce heating and cooling energy use during periods of low or no occupancy. Thermostats should be programmed for a setback of 5-10°F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

Economizer Maintenance

Economizers can significantly reduce cooling system load. A malfunctioning economizer can increase the amount of heating and mechanical cooling required by introducing excess amounts of cold or hot outside air. Common economizer malfunctions include broken outdoor thermostat or enthalpy control or dampers that are stuck or improperly adjusted.

Periodic inspection and maintenance will keep economizers working in sync with the heating and cooling system. This maintenance should be part of annual system maintenance, and it should include proper





setting of the outdoor thermostat/enthalpy control, inspection of control and damper operation, lubrication of damper connections, and adjustment of minimum damper position.

AC System Evaporator/Condenser Coil Cleaning

Dirty evaporator and condenser coils restrict air flow and restrict heat transfer. This increases the loads on the evaporator and condenser fan and decreases overall cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

HVAC Filter Cleaning and Replacement

Air filters should be checked regularly (often monthly) and cleaned or replaced when appropriate. Air filters reduce indoor air pollution, increase occupant comfort, and help keep equipment operating efficiently. If the building has a building management system, consider installing a differential pressure switch across filters to send an alarm about premature fouling or overdue filter replacement. Over time, filters become less and less effective as particulate buildup increases. Dirty filters also restrict air flow through the air conditioning or heat pump system, which increases the load on the distribution fans.

Ductwork Maintenance

Duct maintenance has two primary goals: keep the ducts clean to avoid air quality problems and seal leaks to save energy. Check for cleanliness, obstructions that block airflow, water damage, and leaks. Ducts should be inspected at least every two years.

The biggest symptoms of clogged air ducts are differing temperatures throughout the building and areas with limited airflow from supply registers. If a particular air duct is clogged, then air flow will only be cut off to some rooms in the building—not all of them. The reduced airflow will make it more difficult for those areas to reach the temperature setpoint, which will cause the HVAC system to run longer to cool or heat that area properly. If you suspect clogged air ducts, ensure that all areas in front of supply registers are clear of items that may block or restrict air flow, and you should check for fire dampers or balancing dampers that have failed closed.

Duct leakage in commercial buildings can account for 5%–25% of the supply airflow. In the case of rooftop air handlers, duct leakage can occur to the outside of the building wasting conditioned air. Check ductwork for leakage. Eliminating duct leaks can improve ventilation system performance and reduce heating and cooling system operation.

Distribution system losses are dependent on-air system temperature, the size of the distribution system, and the level of insulation of the ductwork. Significant energy savings can be achieved when insulation has not been well maintained. When the insulation is missing or worn, the system efficiency can be significantly reduced. This measure saves energy by reducing heat transfer in the distribution system.

Boiler Maintenance

Many boiler problems develop slowly over time, so regular inspection and maintenance is essential to keeping the heating system running efficiently and preventing expensive repairs. Annual tune-ups should include a combustion analysis to analyze the exhaust from the boilers and to ensure the boiler is operating safely and efficiently. Boilers should be cleaned according to the manufacturer's instructions to remove soot and scale from the boiler tubes to improve heat transfer.



TRC Furnace Maintenance

Preventative maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. Following the manufacturer's instructions, a yearly tune-up should check for gas / carbon monoxide leaks; change the air and fuel filters; check components for cracks, corrosion, dirt, or debris build-up; ensure the ignition system is working properly; test and adjust operation and safety controls; inspect electrical connections; and lubricate motors and bearings.

Label HVAC Equipment

For improved coordination in maintenance practices, we recommend labeling or re-labeling the site HVAC equipment. Maintain continuity in labeling by following labeling conventions as indicated in the facility drawings or BAS building equipment list. Use weatherproof or heatproof labeling or stickers for permanence, but do not cover over original equipment nameplates, which should be kept clean and readable whenever possible. Besides equipment, label piping for service and direction of flow when possible. Ideally, maintain a log of HVAC equipment, including nameplate information, asset tag designation, areas served, installation year, service dates, and other pertinent information.

This investment in your equipment will enhance collaboration and communication between your staff and your contracted service providers and may help you with regulatory compliance.

Optimize HVAC Equipment Schedules

Energy management systems (BAS) typically provide advanced controls for building HVAC systems, including chillers, boilers, air handling units, rooftop units and exhaust fans. The BAS monitors and reports operational status, schedules equipment start and stop times, locks out equipment operation based on outside air or space temperature, and often optimizes damper and valve operation based on complex algorithms. These BAS features, when in proper adjustment, can improve comfort for building occupants and save substantial energy.

Know your BAS scheduling capabilities. Regularly monitor HVAC equipment operating schedules and match them to building operating hours in order to eliminate unnecessary equipment operation and save energy. Monitoring should be performed often at sites with frequently changing usage patterns – daily in some cases. We recommend using the *optimal start* feature of the BAS (if available) to optimize the building warmup sequence. Most BAS scheduling programs provide for holiday schedules, which can be used during reduced use or shutdown periods. Finally, many systems are equipped with a one-time override function, which can be used to provide additional space conditioning due to a one-time, special event. When available this override feature should be used rather than changing the base operating schedule.

Water Heater Maintenance

The lower the supply water temperature that is used for hand washing sinks, the less energy is needed to heat the water. Reducing the temperature results in energy savings and the change is often unnoticeable to users. Be sure to review the domestic water temperature requirements for sterilizers and dishwashers as you investigate reducing the supply water temperature.

Also, preventative maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. At least once a year, follow manufacturer instructions to drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Annual checks should include checks for:

• Leaks or heavy corrosion on the pipes and valves.





- Corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot, or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional.
- For electric water heaters, look for signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank.
- For water heaters more than three years old, have a technician inspect the sacrificial anode annually.

Refrigeration Equipment Maintenance

Preventative maintenance keeps commercial refrigeration equipment running reliably and efficiently. Commercial refrigerators and freezers are mission-critical equipment that can cost a fortune when they go down. Even when they appear to be working properly, refrigeration units can be consuming too much energy. Have walk-in refrigeration and freezer and other commercial systems serviced at least annually. This practice will allow systems to perform to their highest capabilities and will help identify system issues if they exist.

Maintaining your commercial refrigeration equipment can save between 5% and 10% on energy costs. When condenser coils are dirty, your commercial refrigerators and freezers work harder to maintain the temperature inside. Worn gaskets, hinges, door handles or faulty seals cause cold air to leak from the unit, forcing the unit to run longer and use more electricity.

Regular cleaning and maintenance also help your commercial refrigeration equipment to last longer.

Water Conservation



Installing dual flush or low-flow toilets and low-flow/waterless urinals are ways to reduce water use. The EPA WaterSense[®] ratings for urinals is 0.5 gallons per flush (gpf) and for flush valve toilets is 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

For more information regarding water conservation go to the EPA's WaterSense website⁸ or download a copy of EPA's "WaterSense at Work: Best Management Practices

for Commercial and Institutional Facilities"⁹ to get ideas for creating a water management plan and best practices for a wide range of water using systems.

Water conservation devices that do not reduce hot water consumption will not provide energy savings at the site level, but they may significantly affect your water and sewer usage costs. Any reduction in water use does however ultimately reduce grid-level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users.

If the facility has detached buildings with a master water meter for the entire campus, check for unnatural wet areas in the lawn or water seeping in the foundation at water pipe penetrations through the foundation. Periodically check overnight meter readings when the facility is unoccupied, and there is no other scheduled water usage.

⁸ <u>https://www.epa.gov/watersense.</u>

⁹ <u>https://www.epa.gov/watersense/watersense-work-0.</u>





Manage irrigation systems to use water more effectively outside the building. Adjust spray patterns so that water lands on intended lawns and plantings and not on pavement and walls. Consider installing an evapotranspiration irrigation controller that will prevent over-watering.

Procurement Strategies

Purchasing efficient products reduces energy costs without compromising quality. Consider modifying your procurement policies and language to require ENERGY STAR or WaterSense products where available.

TRCON-SITE GENERATION



You don't have to look far in New Jersey to see one of the thousands of solar electric systems providing clean power to homes, businesses, schools, and government buildings. On-site generation includes both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) technologies that generate power to meet all or a portion of the facility's electric energy needs. Also referred to as distributed generation, these systems contribute to greenhouse gas (GHG) emission reductions, demand reductions, and reduced customer electricity purchases, which results in improved electric grid reliability through better use of transmission and distribution systems.

Preliminary screenings were performed to determine if an on-site generation measure could be a costeffective solution for your facility. Before deciding to install an on-site generation system, we recommend conducting a feasibility study to analyze existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.

TRC



6.1 Solar Photovoltaic

Photovoltaic (PV) panels convert sunlight into electricity. Individual panels are combined into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is then connected to the building's electrical distribution system.

A preliminary screening based on the facility's electric demand, size and location of free area, and shading elements shows that the facility has high potential for installing a PV array.

The amount of free area, ease of installation, and the lack of shading elements contribute to the high potential. A PV array located on the roof may be feasible. If you are interested in pursuing the installation of PV, we recommend conducting a full feasibility study.

The graphic below displays the results of the PV potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.



Figure 8 - Photovoltaic Screening

Successor Solar Incentive Program (SuSI)

The SuSI program replaces the SREC Registration Program (SRP) and the Transition Incentive (TI) program. The SuSI program is used to register and certify solar projects in New Jersey. Rebates are not available for solar projects. Solar projects may qualify to earn SREC- IIs (Solar Renewable Energy Certificates-II), however, the project owners *must* register their solar projects prior to the start of construction to establish the project's eligibility.





Get more information about solar power in New Jersey or find a qualified solar installer who can help you decide if solar is right for your building:

Successor Solar Incentive Program (SuSI): <u>https://www.njcleanenergy.com/renewable-energy/programs/susi-program</u>

- Basic Info on Solar PV in NJ: www.njcleanenergy.com/whysolar
- **NJ Solar Market FAQs**: <u>www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs.</u>
- Approved Solar Installers in the NJ Market: www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1



Combined Heat and Power

Combined heat and power (CHP) generates electricity at the facility and puts waste heat energy to good use. Common types of CHP systems are reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines.

CHP systems typically produce a portion of the electric power used on-site, with the balance of electric power needs supplied by the local utility company. The heat is used to supplement (or replace) existing boilers and provide space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for space cooling.

The key criteria used for screening is the amount of time that the CHP system would operate at full load and the facility's ability to use the recovered heat. Facilities with a continuous need for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has no potential for installing a cost-effective CHP system.

Based on a preliminary analysis, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation. The lack of gas service, low or infrequent thermal load, and lack of space for siting the equipment are the most significant factors contributing to the lack of CHP potential.

The graphic below displays the results of the CHP potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.



Figure 9 - Combined Heat and Power Screening

Find a qualified firm that specializes in commercial CHP cost assessment and installation: <u>http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/</u>



TRC 7 ELECTRIC VEHICLES (EV)

All electric vehicles (EVs) have an electric motor instead of an internal combustion engine. EVs function by plugging into a charge point, taking electricity from the grid, and then storing it in rechargeable batteries. Although electricity production may contribute to air pollution, the U.S. EPA categorizes allelectric vehicles as zero-emission vehicles because they produce no direct exhaust or tailpipe emissions.

EVs are typically more expensive than similar conventional and hybrid vehicles, although some cost can be recovered through fuel savings, federal tax credit, or state incentives.

7.1 Electric Vehicle Charging

EV charging stations provide a means for electric vehicle operators to recharge their batteries at a facility. While many EV drivers charge at home, others do not have access to regular home charging, and the ability to charge at work or in public locations is critical to making EVs practical for more drivers. Charging can also be used for electric fleet vehicles, which can reduce fuel and maintenance costs for fleets that replace gas or diesel vehicles with EVs.

EV charging comes in three main types. For this assessment, the screening considers addition of Level 2 charging, which is most common at workplaces and other public locations. Depending on the site type

and usage, other levels of charging power may be more appropriate.

The preliminary assessment of EV charging at the facility shows that there is high potential for adding EV chargers to the facility's parking, based on potential costs of installation and other site factors.

The primary costs associated with installing EV charging are the charger hardware and the cost to extend power from the facility to parking spaces. This may include upgrades to electric panels to serve increased loads.

The type and size of the parking area impact the costs and feasibility of adding EV charging. Parking structure installations can be less costly than surface lot installations as power may be

readily available, and equipment and wiring can be surface mounted. Parking lot installations often require trenching through concrete or asphalt surface. Large parking areas provide greater flexibility in charger siting than smaller lots.

The location and capacity of facility electric panels also impact charger installation costs. A Level 2 charger generally requires a dedicated 208-240V, 40 Amp circuit. The electric panel nearest the planned installation may not have available capacity and may need to be upgraded to serve new EV charging loads. Alternatively, chargers could be powered from a more distant panel. The distance from the panel to the location of charging stations ties directly to costs, as conduits, cables, and potential trenching costs all increase on a per-foot basis. The more charging stations planned, the more likely it is that additional electrical capacity will be needed.

Other factors to consider when planning for EV charging at a facility include who the intended users are, how long they park vehicles at the site, and whether they will need to pay for the electricity they use.







The graphic below displays the results of the EV charging assessment conducted as part of this audit. The position of each slider indicates the impact each factor has on the feasibility of installing EV charging at the site.



Figure 10 – EV Charger Screening

Electric Vehicle Programs Available

New Jersey is leading the way on electric vehicle (EV) adoption on the East Coast. There are several programs designed to encourage EV adoption in New Jersey, which is crucial to reaching a 100% clean energy future.

NJCEP offers a variety of EV programs for vehicles, charging stations, and fleets. Certain EV charging stations that receive electric utility service from Atlantic City Electric Company (ACE) or Public Service Electric & Gas Company (PSE&G), may be eligible for additional electric vehicle charging incentives directly from the utility. Projects may be eligible for both the incentives offered by this BPU program and incentives offered by ACE or PSE&G, up to 90% of the combined charger purchase and installation costs. Please check ACE or PSE&G program eligibility requirements before purchasing EV charging equipment, as additional conditions on types of eligible chargers may apply for utility incentives.

Both Jersey Central Power & Light (JCP&L) and Rockland Electric (RECO) have filed proposals for EV charging programs. BPU staff is currently reviewing those proposals.

For more information and to keep up to date on all EV programs please visit <u>https://www.njcleanenergy.com/commercial-industrial/programs/electric-vehicle-programs</u>



TRC8 PROJECT FUNDING AND INCENTIVES

Ready to improve your building's performance? New Jersey's Clean Energy Programs and Utility Energy Efficiency Programs can help. Pick the program that works best for you. This section provides an overview of currently available incentive programs in.

electric.	Sey Central Power& Light	O PSEG	Reckland Electric Company
SAS ELIZABETHTOWN	SOUTH GAS	JERSEY	Network Cash
rogram areas to	o be ser	ved by	the Utilities
rogram areas to Existing Buildings (res government)	o be ser sidential, co	ved by	/ the Utilities I, industrial,





TRC8.1 Utility Energy Efficiency Programs

The Clean Energy Act, signed into law by Governor Murphy in 2018, requires New Jersey's investor-owned gas and electric utilities to reduce their customers' use by set percentages over time. To help reach these targets the New Jersey Board of Public Utilities approved a comprehensive suite of energy efficiency programs to be run by the utility companies.

Prescriptive and Custom

The Prescriptive and Custom rebate program through your utility provider offers incentives for installing prescriptive and custom energy efficiency measures at your facility. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades. This program serves most common equipment types and sizes.

Equipment Examples

LightingVariable Frequency DrivesLighting ControlsElectronically Commutate MotorsHVAC EquipmentVariable Frequency DrivesRefrigerationPlug Loads ControlsGas HeatingWashers and DryersGas CoolingAgriculturalCommercial Kitchen EquipmentWater HeatingFood Service EquipmentVariable Frequency Drives

The Prescriptive program provides fixed incentives for specific energy efficiency measures. Prescriptive incentives vary by equipment type. The Custom program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentives.

Direct Install

Direct Install is a turnkey program available to existing small to medium-sized facilities with an average peak electric demand that does not exceed 200 kW or less over the recent 12-month period. You work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives, and controls

Incentives

The program pays up to 70% of the total installed cost of eligible measures.

How to Participate

To participate in Direct Install, you will work with a participating contractor. The contractor will be paid the measure incentives directly by the program, which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the Direct Install program, subject to program rules and eligibility, while the remaining percent of the cost is paid to the contractor by the customer.





Engineered Solutions

The Engineered Solutions Program provides tailored energy-efficiency assistance and services to municipalities, universities, schools, hospitals and healthcare facilities (MUSH), non-profit entities, and multifamily buildings. Customers receive expert guided services, including investment-grade energy auditing, engineering design, installation assistance, construction administration, commissioning, and measurement and verification (M&V) services to support the implementation of cost-effective and comprehensive efficiency projects. Engineered Solutions is generally a good option for medium to large sized facilities with a peak demand over 200 kW looking to implement as many measures as possible under a single project to achieve deep energy savings. Engineered Solutions has an added benefit of addressing measures that may not qualify for other programs. Many facilities pursuing an Energy Savings Improvement Program loan also use this program. Incentives for this program are based on project scope and energy savings achieved.

For more information on any of these programs, contact your local utility provider or visit https://www.njcleanenergy.com/transition.

TRC8.2 New Jersey's Clean Energy Programs



Save money while saving the planet! New Jersey's Clean Energy Program is a statewide program that offers incentives, programs, and services that benefit New Jersey residents, businesses, educational, non-profit, and government entities to help them save energy, money, and the environment.

Large Energy Users

The Large Energy Users Program (LEUP) is designed to foster self-directed investment in energy projects. This program is offered to New Jersey's largest energy customers that annually contribute at least \$200,000 to the NJCEP aggregate of all buildings/sites. This equates to roughly \$5 million in energy costs in the prior fiscal year.

Incentives

Incentives are based on the specifications below. The maximum incentive per entity is the lesser of:

- \$4 million
- 75% of the total project(s) cost
- 90% of total NJCEP fund contribution in previous year
- \$0.33 per projected kWh saved; \$3.75 per projected Therm saved annually

How to Participate

To participate in LEUP, you will first need submit an enrollment application. This program requires all qualified and approved applicants to submit an energy plan that outlines the proposed energy efficiency work for review and approval. Applicants may submit a Draft Energy Efficiency Plan (DEEP), or a Final Energy Efficiency Plan (FEEP). Once the FEEP is approved, the proposed work can begin.

Detailed program descriptions, instructions for applying, and applications can be found at <u>www.njcleanenergy.com/LEUP</u>.

TRC



Combined Heat and Power

The Combined Heat & Power (CHP) program provides incentives for eligible CHP or waste heat to power (WHP) projects. Eligible CHP or WHP projects must achieve an annual system efficiency of at least 65% (lower heating value, or LHV), based on total energy input and total utilized energy output. Mechanical energy may be included in the efficiency evaluation.

Incentives

Eligible Technologies	Size (Installed Rated Capacity) ¹	Incentive (\$/kW)	% of Total Cost Cap per Project ³	\$ Cap per Project ³
Powered by non- renewable or renewable fuel source ⁴	<u>≤</u> 500 kW	\$2,000	30-40% ²	\$2 million
Gas Internal Combustion Engine	>500 kW - 1 MW	\$1,000		
Gas Combustion Turbine	> 1 MW - 3 MW	\$550		
Microturbine Fuel Cells with Heat Recovery	>3 MW	\$350	30%	\$3 million
_				
Waste Heat to	<1 MW	\$1,000	30%	\$2 million
Power*	> 1MW	\$500	20.0	\$3 million

*Waste Heat to Power: Powered by non-renewable fuel source, heat recovery or other mechanical recovery from existing equipment utilizing new electric generation equipment (e.g. steam turbine).

Check the NJCEP website for details on program availability, current incentive levels, and requirements.

How to Participate

You will work with a qualified developer or consulting firm to complete the CHP application. Once the application is approved the project can be installed. Information about the CHP program can be found at www.njcleanenergy.com/CHP.



Successor Solar Incentive Program (SuSI)

The SuSI program replaces the SREC Registration Program (SRP) and the Transition Incentive (TI) program. The program is used to register and certify solar projects in New Jersey. Rebates are not available for solar projects, but owners of solar projects *must* register their projects prior to the start of construction to establish the project's eligibility to earn SREC-IIs (Solar Renewable Energy Certificates-II). SuSI consists of two sub-programs. The Administratively Determined Incentive (ADI) Program and the Competitive Solar Incentive (CSI) Program.

Administratively Determined Incentive (ADI) Program

The ADI Program provides administratively set incentives for net metered residential projects, net metered non-residential projects 5 MW or less, and all community solar projects.

After the registration is accepted, construction is complete, and a complete final as-built packet has been submitted, the project is issued a New Jersey certification number, which enables it to generate New Jersey SREC- IIs.

Market Segments	Size MW dc	Incentive Value (\$/SREC II)	Public Entities Incentive Value - \$20 Adder (\$/SRECII)
Net Metered Residential	All types and sizes	\$90	N/A
Small Net Metered Non-Residential located on Rooftop, Carport, Canopy and Floating Solar	Projects smaller than 1 MW	\$100	\$120
Large Net Metered Non-Residential located on Rooftop, Carport, Canopy and Floating Solar	Projects 1 MW to 5 MW	\$90	\$110
Small Net Metered Non-Residential Ground Mount	Projects smaller than 1 MW	\$85	\$105
Large Net Metered Non-Residential Ground Mount	Projects 1 MW to 5 MW	\$80	\$100
LMI Community Solar	Up to 5 MW	\$90	N/A
Non-LMI Community Solar	Up to 5 MW	\$70	N/A
Interim Subsection (t)	All types and sizes	\$100	N/A

Eligible projects may generate SREC-IIs for 15 years following the commencement of commercial operations which is defined as permission to operate (PTO) from the Electric Distribution Company. After 15 years, projects may be eligible for a NJ Class I REC.

SREC-IIs will be purchased monthly by the SREC-II Program Administrator who will allocate the SREC-IIs to the Load Serving Entities (BGS Providers and Third-Party Suppliers) annually based on their market share of retail electricity sold during the relevant Energy Year.

The ADI Program online portal is now open to new registrations.

Competitive Solar Incentive Program

The Competitive Solar Incentive (CSI) Program will provide competitively set incentives for grid supply projects and net metered non-residential projects greater than 5MW (dc). The program is currently under development. For updates, please continue to check the <u>Solar Proceedings</u> page on the New Jersey's Clean Energy Program website.

Solar projects help the State of New Jersey reach renewable energy goals outlined in the state's Energy Master Plan.

If you are considering installing solar photovoltaics on your building, visit the following link for more information: <u>https://njcleanenergy.com/renewable-energy/programs/susi-program</u>.

TRC



Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) serves New Jersey's government agencies by financing energy projects. An ESIP is a type of performance contract, whereby school districts, counties, municipalities, housing authorities, and other public and state entities enter into contracts to help finance building energy upgrades. Annual payments are lower than the savings projected from the energy conservation measures (ECMs), ensuring that ESIP projects are cash flow positive for the life of the contract.

ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs described above can also be used to help further reduce the total project cost of eligible measures.

How to Participate

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an energy services company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is used for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the energy savings plan can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Carefully consider all alternatives to develop an approach that best meets your needs. A detailed program descriptions and application can be found at <u>www.njcleanenergy.com/ESIP</u>.

ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you can use NJCEP incentive programs to help further reduce costs when developing the energy savings plan. Refer to the ESIP guidelines at the link above for further information and guidance on next steps.



PROJECT DEVELOPMENT

Energy conservation measures (ECMs) have been identified for your site, and their energy and economic analyses are provided within this LGEA report. Note that some of the identified projects may be mutually exclusive, such as replacing equipment versus upgrading motors or controls. The next steps with project development are to set goals and create a comprehensive project plan. The graphic below provides an overview of the process flow for a typical energy efficiency or renewable energy project. We recommend implementing as many ECMs as possible prior to undertaking a feasibility study for a renewable project. The cyclical nature of this process flow demonstrates the ongoing work required to continually improve building energy efficiency over time. If your building(s) scope of work is relatively simple to implement or small in scope, the measurement and verification (M&V) step may not be required. It should be noted through a typical project cycle, there will be changes in costs based on specific scopes of work, contractor selections, design considerations, construction, etc. The estimated costs provided throughout this LGEA report demonstrate the unburdened turn-key material and labor cost only. There will be contingencies and additional costs at the time of implementation. We recommend comprehensive project planning that includes the review of multiple bids for project work, incorporates potential operations and maintenance (O&M) cost savings, and maximizes your incentive potential.



Figure 11 – Project Development Cycle

TRC EVERGY PURCHASING AND PROCUREMENT STRATEGIES

10.1 Retail Electric Supply Options

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. Though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third-party supplier, consider shopping for a reduced rate from third-party electric suppliers. If your facility already buys electricity from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party electric suppliers is available at the NJBPU website¹⁰.

10.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey is also deregulated. Most customers that remain with the utility for natural gas service pay rates that are market based and fluctuate monthly. The utility provides basic gas supply service to customers who choose not to buy from a third-party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier typically depends on whether a customer prefers budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third-party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility does not already purchase natural gas from a third-party supplier, consider shopping for a reduced rate from third-party natural gas suppliers. If your facility already purchases natural gas from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party natural gas suppliers is available at the NJBPU website¹¹.

¹⁰ www.state.nj.us/bpu/commercial/shopping.html.

¹¹ www.state.nj.us/bpu/commercial/shopping.html.

APPENDIX A: EQUIPMENT INVENTORY & RECOMMENDATIONS

Lighting Inventory & Recommendations

	Existin	g Conditions					Proposed Conditions									Energy Impact & Financial Analysis						
Location	Fixture Quantit y	Fixture Description	Control System	Light Level	Watts per Fixtur e	Annual Operatin g Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantit y	Fixture Description	Control System	Watts per Fixtur e	Annual Operatin g Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years	
3rd and Fourth Girls Bath	1	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	S	38	2,600		None	No	1	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	38	2,600	0.0	0	0	\$0	\$0	\$0	0.0	
3rd and Fourth Girls Bath Hall	2	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	s	10	2,600		None	No	2	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	2,600	0.0	0	0	\$0	\$0	\$0	0.0	
Boiler Room 8	6	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	s	25	2,600		None	No	6	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	2,600	0.0	0	0	\$0	\$0	\$0	0.0	
Boys Restroom - Male 3rd Fourth	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	s	50	2,600	2	None	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,794	0.0	89	0	\$11	\$270	\$35	21.2	
Cafeteria	3	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	3	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0	
Cafeteria	22	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	s	50	2,600	2	None	Yes	22	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,794	0.2	975	0	\$122	\$540	\$70	3.9	
Cafeteria Hall Bath	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	2,600	2	None	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,794	0.0	89	0	\$11	\$270	\$35	21.2	
Cafeteria Hall Boys Bath (1)	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	s	50	2,600	2	None	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,794	0.0	89	0	\$11	\$270	\$35	21.2	
Classroom 1	6	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	s	50	2,100	2	None	Yes	6	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,449	0.1	215	0	\$27	\$270	\$35	8.8	
Classroom 110	9	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	2,100	2	None	Yes	9	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,449	0.1	322	0	\$40	\$270	\$35	5.8	
Classroom 111	9	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	2,100	2	None	Yes	9	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,449	0.1	322	0	\$40	\$270	\$35	5.8	
Classroom 112	9	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	2,100	2	None	Yes	9	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,449	0.1	322	0	\$40	\$270	\$35	5.8	
Classroom 113	9	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	s	50	2,100	2	None	Yes	9	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,449	0.1	322	0	\$40	\$270	\$35	5.8	
Classroom 128	12	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	s	38	1,449		None	No	12	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	38	1,449	0.0	0	0	\$0	\$0	\$0	0.0	
Classroom 129	14	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	s	38	1,449		None	No	14	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	38	1,449	0.0	0	0	\$0	\$0	\$0	0.0	
Classroom 130	14	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	S	38	1,449		None	No	14	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	38	1,449	0.0	0	0	\$0	\$0	\$0	0.0	
Classroom 131	18	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	S	38	1,449		None	No	18	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	38	1,449	0.0	0	0	\$0	\$0	\$0	0.0	
Classroom 132	18	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	S	38	1,449		None	No	18	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	38	1,449	0.0	0	0	\$0	\$0	\$0	0.0	
Classroom 133 SGI	4	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	s	38	2,100	2	None	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	38	1,449	0.0	109	0	\$14	\$270	\$35	17.3	
Classroom 136	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,100	2	None	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupanc y Sensor	25	1,449	0.0	18	0	\$2	\$0	\$0	0.0	
Classroom 136	12	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	s	50	2,100	2	None	Yes	12	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,449	0.1	430	0	\$54	\$270	\$35	4.4	
Classroom 137	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,100	2	None	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupanc y Sensor	25	1,449	0.0	18	0	\$2	\$0	\$0	0.0	
Classroom 137	12	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	s	50	2,100	2	None	Yes	12	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,449	0.1	430	0	\$54	\$270	\$35	4.4	
Classroom 139 D Library	4	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	2,100	2	None	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,449	0.0	143	0	\$18	\$270	\$35	13.1	
Classroom 2 Music	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0	



	Existin	g Conditions					Prop	osed Conditio	ns						Energy In	npact & F	inancial A	nalysis			
Location	Fixture Quantit Y	Fixture Description	Control System	Light Level	Watts per Fixtur e	Annual Operatin g Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantit y	Fixture Description	Control System	Watts per Fixtur e	Annual Operatin g Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Classroom 2 Music	22	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,100	2	None	Yes	22	LED - Linear Tubes: (2) 4' Lamps	Occupanc y Sensor	25	1,449	0.1	394	0	\$49	\$540	\$70	9.5
Classroom 200	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	s	25	2,100	2	None	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupanc y Sensor	25	1,449	0.0	18	0	\$2	\$0	\$0	0.0
Classroom 200	12	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	2,100	2	None	Yes	12	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,449	0.1	430	0	\$54	\$270	\$35	4.4
Classroom 201	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	s	25	2,100	2	None	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupanc y Sensor	25	1,449	0.0	18	0	\$2	\$0	\$0	0.0
Classroom 201	12	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	2,100	2	None	Yes	12	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,449	0.1	430	0	\$54	\$270	\$35	4.4
Classroom 204	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	s	50	2,100	2	None	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,449	0.0	72	0	\$9	\$116	\$20	10.7
Classroom 205	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,100	2	None	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupanc y Sensor	25	1,449	0.0	18	0	\$2	\$0	\$0	0.0
Classroom 205	14	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	s	50	2,100	2	None	Yes	14	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,449	0.2	501	0	\$63	\$270	\$35	3.8
Classroom 206	12	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,100	2	None	Yes	12	LED - Linear Tubes: (2) 4' Lamps	Occupanc y Sensor	25	1,449	0.1	215	0	\$27	\$270	\$35	8.8
Classroom 206	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	s	25	2,100	2	None	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupanc y Sensor	25	1,449	0.0	18	0	\$2	\$0	\$0	0.0
Classroom 207	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,100	2	None	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupanc y Sensor	25	1,449	0.0	18	0	\$2	\$0	\$0	0.0
Classroom 207	18	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	s	38	2,100	2	None	Yes	18	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	38	1,449	0.2	490	0	\$61	\$540	\$70	7.7
Classroom 208	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,100	2	None	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupanc y Sensor	25	1,449	0.0	18	0	\$2	\$0	\$0	0.0
Classroom 208	18	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	s	38	2,100	2	None	Yes	18	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	38	1,449	0.2	490	0	\$61	\$540	\$70	7.7
Classroom 209	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,100	2	None	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupanc y Sensor	25	683	0.0	39	0	\$5	\$0	\$0	0.0
Classroom 209	9	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	2,100	2	None	Yes	9	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,449	0.1	322	0	\$40	\$270	\$35	5.8
Classroom 210	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,100	2	None	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupanc y Sensor	25	1,449	0.0	18	0	\$2	\$0	\$0	0.0
Classroom 210	9	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	2,100	2	None	Yes	9	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,449	0.1	322	0	\$40	\$270	\$35	5.8
Classroom 211	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,100	2	None	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupanc y Sensor	25	1,449	0.0	18	0	\$2	\$0	\$0	0.0
Classroom 211	9	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	2,100	2	None	Yes	9	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,449	0.1	322	0	\$40	\$270	\$35	5.8
Classroom 214	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,100		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	2,100	0.0	0	0	\$0	\$0	\$0	0.0
Classroom 3 Art	22	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	s	25	2,100	2	None	Yes	22	LED - Linear Tubes: (2) 4' Lamps	Occupanc y Sensor	25	1,449	0.1	394	0	\$49	\$540	\$70	9.5
Classroom 3 Art room Rear room	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,100	2	None	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupanc y Sensor	25	1,449	0.0	72	0	\$9	\$270	\$35	26.3
Classroom OT/PT 120	6	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	s	50	2,100	2	None	Yes	6	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,449	0.1	215	0	\$27	\$270	\$35	8.8
Classroom SGI 138	6	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	2,100	2	None	Yes	6	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,449	0.1	215	0	\$27	\$270	\$35	8.8



	Existin	g Conditions					Prop	osed Conditio	ns						Energy In	npact & F	inancial A	nalysis			
Location	Fixture Quantit y	Fixture Description	Control System	Light Level	Watts per Fixtur e	Annual Operatin g Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantit y	Fixture Description	Control System	Watts per Fixtur e	Annual Operatin g Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Classroom SGI 4	8	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	S	38	2,100	2	None	Yes	8	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	38	1,449	0.1	218	0	\$27	\$270	\$35	8.6
Classroom SGI 5	3	LED - Fixtures: Ambient 2x4 Fixture	Wall Switch	s	38	2,100	2	None	Yes	3	LED - Fixtures: Ambient 2x4 Fixture	Occupanc v Sensor	38	1,449	0.0	82	0	\$10	\$116	\$20	9.4
Classroom SGI 5	6	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	s	38	2,100	2	None	Yes	6	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	38	1,449	0.1	163	0	\$20	\$116	\$20	4.7
Classroom SGI 6	3	LED - Fixtures: Ambient 2x4 Fixture	Wall Switch	S	38	2,100	2	None	Yes	3	LED - Fixtures : Ambient 2x4 Fixture	Occupanc y Sensor	38	1,449	0.0	82	0	\$10	\$116	\$20	9.4
Classroom SGI 6	6	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	S	38	2,100	2	None	Yes	6	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	38	1,449	0.1	163	0	\$20	\$116	\$20	4.7
Classroom SGI 7	8	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	s	38	2,100	2	None	Yes	8	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	38	1,449	0.1	218	0	\$27	\$270	\$35	8.6
Closet in 126 Boys Bath	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	1,100		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Corridor 1st 2nd Grade	9	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	9	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Corridor 1st 2nd Grade	11	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	2,600	3	None	Yes	11	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	50	1,794	0.1	488	0	\$61	\$450	\$385	1.1
Corridor 5th Grade	7	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	7	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Corridor 5th Grade	8	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,600	3	None	Yes	8	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	25	1,794	0.0	177	0	\$22	\$225	\$225	0.0
Corridor 5th Grade	9	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	S	38	2,600	3	None	Yes	9	LED - Linear Tubes: (3) 4' Lamps	High/Low Control	38	1,794	0.1	303	0	\$38	\$450	\$315	3.6
Corridor Music Area	6	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	6	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Corridor Music Area	9	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,600	3	None	Yes	9	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	25	1,794	0.1	199	0	\$25	\$450	\$315	5.4
Corridor Music Area	5	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	s	38	2,600	3	None	Yes	5	LED - Linear Tubes: (3) 4' Lamps	High/Low Control	38	1,794	0.0	168	0	\$21	\$0	\$0	0.0
Corridor Third and Fourth Grade	6	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	6	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Corridor Third and Fourth Grade	13	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	s	38	2,600	3	None	Yes	13	LED - Linear Tubes: (3) 4' Lamps	High/Low Control	38	1,794	0.1	438	0	\$55	\$675	\$455	4.0
Custodial closet 1	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	s	25	1,100		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Custodial office	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,600	2	None	Yes	1	LED - Linear Tubes: (2) 4' Lamps	Occupanc y Sensor	25	1,794	0.0	22	0	\$3	\$0	\$0	0.0
Custodial office	4	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	s	50	2,600	2	None	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,794	0.0	177	0	\$22	\$116	\$20	4.3
Custodial Supply	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	s	25	1,100		None	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	1,100	0.0	0	0	\$0	\$0	\$0	0.0
E3 Entrance	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
E3 Entrance	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	2,600		None	No	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	50	2,600	0.0	0	0	\$0	\$0	\$0	0.0
E4 Entrance	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
E4 Entrance	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,600		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	2,600	0.0	0	0	\$0	\$0	\$0	0.0



	Existin	g Conditions					Prop	osed Conditio	ns						Energy In	npact & F	inancial A	nalysis			
Location	Fixture Quantit y	Fixture Description	Control System	Light Level	Watts per Fixtur e	Annual Operatin g Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantit y	Fixture Description	Control System	Watts per Fixtur e	Annual Operatin g Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Elevator	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,600		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	2,600	0.0	0	0	\$0	\$0	\$0	0.0
Elevator	1	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	s	38	2,600		None	No	1	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	38	2,600	0.0	0	0	\$0	\$0	\$0	0.0
Elevator Area foyer 1st floor (1)	1	LED - Fixtures: Ambient 2x4 Fixture	Occupanc y Sensor	S	38	1,449		None	No	1	LED - Fixtures: Ambient 2x4 Fixture	Occupanc y Sensor	38	1,449	0.0	0	0	\$0	\$0	\$0	0.0
Elevator Area foyer 2nd floor	1	LED - Fixtures : Ambient 2x4 Fixture	Wall Switch	S	38	2,600		None	No	1	LED - Fixtures : Ambient 2x4 Fixture	Wall Switch	38	2,600	0.0	0	0	\$0	\$0	\$0	0.0
Elevator Hall 2nd floor New construction	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Elevator Hall 2nd floor New construction	5	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	S	38	1,449		None	No	5	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	38	1,449	0.0	0	0	\$0	\$0	\$0	0.0
Elevator Room	1	Linear Fluorescent - T8: 4' T8 (32W) - 4L	Wall Switch	s	114	1,100	1	Relamp	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	58	1,100	0.0	68	0	\$8	\$73	\$20	6.3
Entrance 8 Foyer	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	s	50	2,600		None	No	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	50	2,600	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Door Lights	3	Incandescent: (1) 65W BR30 Screw-In Lamp	Timeclock		65	4,360	1	Relamp	No	3	LED Lamps: (1) 10 W Led Lamp	Timeclock	10	4,360	0.0	719	0	\$92	\$72	\$9	0.7
Exterior Door Lights	2	Halogen Incandescent: BR30-65	Wall Switch		65	2,600	1	Relamp	No	2	LED Lamps: (1) 10 W Led Lamp	Wall Switch	10	2,600	0.0	286	0	\$36	\$48	\$6	1.1
Exterior Door Lights	2	LED - Fixtures: Low-Bay	Timeclock		50	4,360		None	No	2	LED - Fixtures: Low-Bay	Timeclock	50	4,360	0.0	0	0	\$0	\$0	\$0	0.0
Exterior E5 door	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Timeclock		10	4,360		None	No	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Timeclock	10	4,360	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Wallpacks	2	LED Lamps: (1) 50W Corn Bulb Screw-In Lamp	Timeclock		50	4,360		None	No	2	LED Lamps: (1) 50W Corn Bulb Screw-In Lamp	Timeclock	50	4,360	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Wallpacks	2	LED - Fixtures: Wall Pack	Timeclock		15	4,360		None	No	2	LED - Fixtures: Wall Pack	Timeclock	15	4,360	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Wallpacks	2	LED - Fixtures: Wall Pack	Timeclock		30	4,360		None	No	2	LED - Fixtures: Wall Pack	Timeclock	30	4,360	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Wallpacks	3	LED - Fixtures: Wall Pack	Timeclock		52	4,360		None	No	3	LED - Fixtures: Wall Pack	Timeclock	52	4,360	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Wallpacks	1	LED - Fixtures: Wall Pack	Timeclock		50	4,360		None	No	1	LED - Fixtures: Wall Pack	Timeclock	50	4,360	0.0	0	0	\$0	\$0	\$0	0.0
Gymnasium	3	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	3	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Gymnasium	9	LED - Linear Tubes: (6) 4' Lamps	Wall Switch	s	150	2,600	2	None	Yes	9	LED - Linear Tubes: (6) 4' Lamps	Occupanc y Sensor	150	1,794	0.3	1,197	0	\$150	\$540	\$70	3.1
Gymnasium Laura office	2	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	s	10	2,600		None	No	2	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	2,600	0.0	0	0	\$0	\$0	\$0	0.0
Gymnasium Stage	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Gymnasium Stage	6	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,600	2	None	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupanc y Sensor	25	1,794	0.0	133	0	\$17	\$270	\$35	14.1
Gymnasium Storage	2	D Lamps: (1) 10W A19 Screw-In Lamp Switch 5 1		10	1,100		None	No	2	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	1,100	0.0	0	0	\$0	\$0	\$0	0.0	
Kitchen	1	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	1	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen	3	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	2,600		None	No	3	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	2,600	0.0	0	0	\$0	\$0	\$0	0.0



	Existin	g Conditions					Prop	osed Conditio	ons						Energy In	npact & F	inancial A	nalysis			
Location	Fixture Quantit Y	Fixture Description	Control System	Light Level	Watts per Fixtur e	Annual Operatin g Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantit Y	Fixture Description	Control System	Watts per Fixtur e	Annual Operatin g Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen	6	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	s	25	2,600	2	None	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupanc y Sensor	25	1,794	0.0	133	0	\$17	\$0	\$0	0.0
Kitchen	4	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	2,600	2	None	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,794	0.0	177	0	\$22	\$270	\$35	10.6
40	3	LED - Fixtures: Ambient 2x4 Fixture	Occupanc y Sensor	s	34	1,449		None	No	3	LED - Fixtures: Ambient 2x4 Fixture	Occupanc y Sensor	34	1,449	0.0	0	0	\$0	\$0	\$0	0.0
Laboratory Foyer Art area	1	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	S	38	2,600		None	No	1	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	38	2,600	0.0	0	0	\$0	\$0	\$0	0.0
Laboratory Girls Art Area (1)	3	LED - Fixtures: Ambient 2x4 Fixture	Occupanc y Sensor	s	38	1,449		None	No	3	LED - Fixtures: Ambient 2x4 Fixture	Occupanc y Sensor	38	1,449	0.0	0	0	\$0	\$0	\$0	0.0
Library 139	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Library 139	8	LED - Fixtures: Downlight Surface Mount	Wall Switch	s	15	2,600	2	None	Yes	8	LED - Fixtures: Downlight Surface Mount	Occupanc y Sensor	15	1,794	0.0	106	0	\$13	\$270	\$35	17.7
Library 139	35	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	2,600	2	None	Yes	35	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,794	0.4	1,552	0	\$194	\$810	\$105	3.6
Library Office	4	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	2,600	2	None	Yes	4	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,794	0.0	177	0	\$22	\$116	\$20	4.3
Library Office Closet	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	S	13	1,100		None	No	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	13	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Main Office	5	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	S	38	2,600	2	None	Yes	5	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	38	1,794	0.0	168	0	\$21	\$116	\$20	4.6
Main Office entrance foyer	3	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	2,600	2	None	Yes	3	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,794	0.0	133	0	\$17	\$116	\$20	5.8
Main Office Hall	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,600		None	No	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	2,600	0.0	0	0	\$0	\$0	\$0	0.0
Nurse office	6	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,600	2	None	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupanc y Sensor	25	1,794	0.0	133	0	\$17	\$116	\$20	5.8
Nurses office Bath	1	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	s	38	1,449		None	No	1	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	38	1,449	0.0	0	0	\$0	\$0	\$0	0.0
Principal office	6	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,600	2	None	Yes	6	LED - Linear Tubes: (2) 4' Lamps	Occupanc y Sensor	25	1,794	0.0	133	0	\$17	\$116	\$20	5.8
PTO Storage	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,100		None	No	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	1,100	0.0	0	0	\$0	\$0	\$0	0.0
PTO Storage	2	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	S	13	1,100		None	No	2	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	13	1,100	0.0	0	0	\$0	\$0	\$0	0.0
PTO Storage	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	1,100		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Restroom -1st 2nd grade	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	2,600	2	None	Yes	1	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,794	0.0	44	0	\$6	\$116	\$20	17.3
Restroom -1st 2nd grade Boys	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	2,600	2	None	Yes	2	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,794	0.0	89	0	\$11	\$116	\$20	8.7
Restroom Library Adults	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,600		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	2,600	0.0	0	0	\$0	\$0	\$0	0.0
Restroom Library Children's	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,600		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	2,600	0.0	0	0	\$0	\$0	\$0	0.0
Staff Bath	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	2,600		None	No	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	2,600	0.0	0	0	\$0	\$0	\$0	0.0
Staff Bath	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,600		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	2,600	0.0	0	0	\$0	\$0	\$0	0.0



	Existin	g Conditions					Prop	osed Conditio	ns						Energy In	mpact & F	inancial A	nalysis			
Location	Fixture Quantit y	Fixture Description	Control System	Light Level	Watts per Fixtur e	Annual Operatin g Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantit y	Fixture Description	Control System	Watts per Fixtur e	Annual Operatin g Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Staff Foyer	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	S	13	2,600		None	No	1	LED - Linear Tubes: (1) 4' Lamp	Wall Switch	13	2,600	0.0	0	0	\$0	\$0	\$0	0.0
Staircase Library	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	s	25	2,600	3	None	Yes	4	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	25	1,794	0.0	89	0	\$11	\$225	\$140	7.7
Staircase New addition	5	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,630	3	None	Yes	5	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	25	2,505	0.0	155	0	\$19	\$225	\$175	2.6
Stem Lab 114	12	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	s	38	2,600	2	None	Yes	12	LED - Linear Tubes: (3) 4' Lamps	Occupanc y Sensor	38	1,794	0.1	404	0	\$51	\$540	\$70	9.3
Storage 10	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	s	25	1,100		None	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Storage 116	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	s	10	1,100		None	No	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Storage 12	5	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	s	10	1,100	2	None	Yes	5	LED Lamps: (1) 10W A19 Screw-In Lamp	Occupanc y Sensor	10	759	0.0	19	0	\$2	\$0	\$0	0.0
Storage 12	9	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	s	50	1,100	2	None	Yes	9	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	759	0.1	169	0	\$21	\$270	\$0	12.8
Storage 126	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	s	10	1,100		None	No	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Storage 13	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	s	10	1,100		None	No	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Storage 13 (1)	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,100		None	No	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Storage 13 (2)	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	s	10	1,100		None	No	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Storage 9	1	LED Lamps: (1) 35W Corn Bulb Screw-In Lamp	Wall Switch	S	34	1,100		None	No	1	LED Lamps: (1) 35W Corn Bulb Screw-In Lamp	Wall Switch	34	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Storage for Music 2	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	s	10	1,100		None	No	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Storage for Music 2 (1)	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	s	10	1,100		None	No	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Storage in Girls Bath 3rd 4th	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	s	10	1,100		None	No	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Teachers Lounge 124	16	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	s	50	2,600	2	None	Yes	16	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,794	0.2	709	0	\$89	\$540	\$70	5.3
Teachers Restroom First Grade Hall	1	LED - Linear Tubes: (4) 4' Lamps	Occupano y Sensor	s	50	1,449		None	No	1	LED - Linear Tubes: (4) 4' Lamps	Occupanc y Sensor	50	1,449	0.0	0	0	\$0	\$0	\$0	0.0

BPU	New Jersey's cleanenergy program*
-----	---

TRC

Motor Inventory & Recommendations

		Existin	g Conditions								Prop	osed Co	ondition	S		Energy In	npact & Fii	nancial Ar	alysis			
Location	Area(s)/System(s) Served	Motor Quantit y	Motor Application	HP Per Motor	Full Load Efficienc y	VFD Control?	Manufacturer	Model	Remaining Useful Life	Annual Operating Hours	ECM #	Install High Efficienc y Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Roof	Exhaust Fan- Various Spaces	14	Exhaust Fan	0.3	65.0%	No			W	2,200		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	Exhaust Fan-Room 6,7,21,22	1	Exhaust Fan	1.0	82.5%	No			W	2,200	4	No	85.5%	Yes	1	0.3	793	0	\$101	\$3,508	\$75	34.0
Roof	Exhaust Fan-Fifth Grade	1	Exhaust Fan	0.3	65.0%	No			W	2,200		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	Exhaust Fan-Room 8,9,18,19	1	Exhaust Fan	1.0	82.5%	No			W	2,200	4	No	85.5%	Yes	1	0.3	793	0	\$101	\$3,508	\$75	34.0
Roof	Exhaust Fan-Gym	1	Exhaust Fan	0.3	65.0%	No			W	2,200		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	Exhaust Fan-Room 15	1	Exhaust Fan	0.8	70.0%	No			W	2,200		No	70.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	Exhaust Fan- Kitchen Hood	1	Kitchen Hood Exhaust Fan	1.0	82.5%	No			В	2,100	5	No	85.5%	Yes	1	0.0	1,383	16	\$361	\$3,508	\$75	9.5
Boiler Room	Hot Water Pumps P1P2	2	Heating Hot Water Pump	10.0	91.7%	Yes			W	1,690		No	91.7%	No		0.0	0	0	\$0	\$0	\$0	0.0
Boiler Room	Sump Pump	1	Other	0.3	65.0%	No			W	500		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Various Spaces	Unit Ventalators Classrooms	29	Fan Coil Unit	0.3	65.0%	No			W	2,200		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Elevator Room	Elevator Hydraulic Pump	1	Other	25.0	82.0%	No			W	200		No	82.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	RTU-1 - Library	1	Supply Fan	0.5	75.0%	No			W	2,200		No	75.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	AHU-1 - Library	1	Supply Fan	3.0	87.5%	No			W	2,200		No	87.5%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	AHU-1 - Library	1	Return Fan	0.5	70.0%	No			W	2,200		No	70.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Various Spaces	Hydronic Unit Heater	4	Fan Coil Unit	0.3	65.0%	No			W	2,200		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
E-4 Entrance	E-4 Entrance Foyer	1	Fan Coil Unit	0.3	65.0%	No			W	2,200		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Various Spaces	Ceiling Mounted Electric Resistance Heaters	3	Supply Fan	0.1	65.0%	No			w	2,200		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	HV-1 Auditorium- Gym	1	Supply Fan	2.0	86.5%	No			W	2,745	4	No	86.5%	Yes	1	0.6	1,776	0	\$226	\$4,182	\$100	18.0
Roof	HV-2 Auditorium- Gym	1	Supply Fan	2.0	86.5%	No			W	2,745	4	No	86.5%	Yes	1	0.6	1,776	0	\$226	\$4,182	\$100	18.0
Roof	Split Systems	11	Supply Fan	1.0	85.0%	No			W	2,200		No	85.0%	No		0.0	0	0	\$0	\$0	\$0	0.0



TRC

		Existin	g Conditions								Prop	osed Co	ondition	5	Energy In	npact & Fi	nancial Ar	nalysis			
Location	Area(s)/System(s) Served	Motor Quantit Y	Motor Application	HP Per Motor	Full Load Efficienc Y	VFD Control?	Manufacturer	Model	Remaining Useful Life	Annual Operating Hours	ECM #	Install High Efficienc y Motors?	Full Load Efficiency	Install Number VFDs? of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Roof	Split Systems	2	Supply Fan	1.0	85.0%	No			w	0		No	85.0%	No	0.0	0	0	\$0	\$0	\$0	0.0

Packaged HVAC Inventory & Recommendations

		Existir	g Conditions								Prop	osed Co	onditio	ns					Energy In	ipact & Fir	nancial An	alysis			
Location	Area(s)/System(s) Served	System Quantit y	System Type	Cooling Capacit y per Unit (Tons)	Heating Capacity per Unit (MBh)	Cooling Mode Efficiency (SEER/IEER/ EER)	Heating Mode Efficiency	Manufacturer	Model	Remaining Useful Life	ECM #	Install High Efficienc y System?	System Quantit y	System Type	Cooling Capacit y per Unit (Tons)	Heating Capacity per Unit (MBh)	Cooling Mode Efficiency (SEER/IEER/ EER)	Heating Mode Efficiency	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Roof	RTU-1-Library	1	Forced Air Furnace		80.00		0.8 AFUE	Greenheck	PVF100	В	7	Yes	1	Forced Air Furnace		80.00		0.97 AFUE	0.0	0	15	\$174	\$3,007	\$500	14.4
Roof	CU-Room 112-113	1	Split-System Air- Source HP	4.00	49.50	10.30	2.25 COP	Daikin	RXTQ48TAVJUA	w		No							0.0	0	0	\$0	\$0	\$0	0.0
Roof	CU-Room 110-111	1	Split-System Air- Source HP	4.00	49.50	10.30	2.25 COP	Daikin	RXTQ48TAVJUA	w		No							0.0	0	0	\$0	\$0	\$0	0.0
Roof	CU-Classrooms	1	Split-System Air- Source HP	12.00	154.00	12.30	3.7 COP	Daikin	RXYQ144TTJU	w		No							0.0	0	0	\$0	\$0	\$0	0.0
Roof	CU-Stem Lab Room 114	1	Split-System	5.00		13.00		York	TCD60B31SA	w		No							0.0	0	0	\$0	\$0	\$0	0.0
Exterior E6 Area	CU- Music & Art Rooms	1	Split-System Air- Source HP	9.00	116.00	11.30	3.3 COP	Daikin	RXYQ108PATJ	В	6	Yes	1	Split-System Air- Source HP	9.00	116.00	12.80	3.5 COP	0.9	336	0	\$43	\$17,382	\$693	389.8
Roof	CU-1-Master Classrooms	1	Split-System Air- Source HP	10.00	129.00	11.30	3.3 COP	Daikin	RXYQ120PBTJ	В	6	Yes	1	Split-System Air- Source HP	10.00	129.00	12.80	3.5 COP	1.0	373	0	\$48	\$19 <i>,</i> 406	\$770	391.7
Roof	CU-1-Backup Classrooms	1	Split-System Air- Source HP	6.00	77.00	11.30	2.65 COP	Daikin	RXYQ72PBTJ	В	6	Yes	1	Split-System Air- Source HP	6.00	77.00	12.80	3.5 COP	1.4	0	0	\$0	\$12,591	\$462	0.0
Roof	CU-2 Classrooms	1	Split-System Air- Source HP	9.00	116.00	11.30	3.3 COP	Daikin	RXYQ108PATJ	В	6	Yes	1	Split-System Air- Source HP	9.00	116.00	12.80	3.5 COP	0.9	336	0	\$43	\$17,382	\$693	389.8
Roof	CU-3 Classrooms	1	Split-System Air- Source HP	12.00	138.00	11.30	3.4 COP	Daikin	RXYQ144PBTJ	В	6	Yes	1	Split-System Air- Source HP	12.00	138.00	15.00	3.3 COP	1.6	943	0	\$120	\$23 <i>,</i> 590	\$984	188.1
Roof	CU-4-Master Classrooms	1	Split-System Air- Source HP	10.00	129.00	11.30	3.3 COP	Daikin	RXYQ120PBTJ	В	6	Yes	1	Split-System Air- Source HP	10.00	129.00	12.80	3.5 COP	1.0	373	0	\$48	\$19,406	\$770	391.7
Roof	CU-4 Backup Classrooms	1	Split-System Air- Source HP	6.00	77.00	11.30	2.65 COP	Daikin	RXYQ72PBTJ	В	6	Yes	1	Split-System Air- Source HP	6.00	77.00	12.80	3.5 COP	1.4	0	0	\$0	\$12,591	\$462	0.0
Roof	CU-Classrooms	1	Split-System Air- Source HP	12.00	138.00	11.30	3.4 COP	Daikin	RXYQ144PBTJ	В	6	Yes	1	Split-System Air- Source HP	12.00	138.00	15.00	3.3 COP	1.6	943	0	\$120	\$23,590	\$984	188.1
Roof	CU-Classrooms	1	Split-System Air- Source HP	12.00	138.00	11.30	3.4 COP	Daikin	RXYQ144PBTJ	В	6	Yes	1	Split-System Air- Source HP	12.00	138.00	15.00	3.3 COP	1.6	943	0	\$120	\$23 <i>,</i> 590	\$984	188.1
Classroom 139 D Library	Window AC-139D Library	1	Window AC	1.00		12.00		Friedrich	CCW12B10A	w		No							0.0	0	0	\$0	\$0	\$0	0.0
Classroom OT/PT 120	Window AC- Classroom OT/PT 120	1	Window AC	1.29		11.80		Friedrich	CP15G10B	w		No							0.0	0	0	\$0	\$0	\$0	0.0
Classroom SGI 138	Window AC- Classroom SGI 138	1	Window AC	1.00		12.00		Friedrich	CCW12B10A	w		No							0.0	0	0	\$0	\$0	\$0	0.0
Library 139	Window AC Library139	1	Window AC	1.00		12.00		Friedrich	CCW12B10A	w		No							0.0	0	0	\$0	\$0	\$0	0.0
Library 139	Wall AC Library	1	Through-The-Wall AC	1.50		12.00		Friedrich	Unknown	w		No							0.0	0	0	\$0	\$0	\$0	0.0
Various Spaces	Ceiling Mounted Electric Resistance Heaters	3	Electric Resistance Heat		17.06		1 COP	Unknown	Unknown	w		No							0.0	0	0	\$0	\$0	\$0	0.0


Space Heating Boiler Inventory & Recommendations

	Existing Conditions					Prop	osed Co	ondition	าร				Energy Impact & Financial Analysis								
Location	Area(s)/System(s) Served	System Quantit y	System Type	Output Capacity per Unit (MBh)	Manufacturer	Model	Remaining Useful Life	ECM #	Install High Efficienc y System?	System Quantit Y	System Type	Output Capacity per Unit (MBh)	Heating Efficienc Y	Heating Efficienc y Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Boiler Room	Hydronic Heating System	3	Condensing Hot Water Boiler	1,290	Aerco	BMK1.5	w		No						0.0	0	0	\$0	\$0	\$0	0.0

Demand Control Ventilation Recommendations

		Recommendation Inputs					Energy Impact & Financial Analysis							
Location	Area(s)/System(s) Affected	ECM #	Number of Zones	Cooling Capacity of Controlled System (Tons)	Electric Heating Capacity of Controlled System (kBtu/hr)	Output Heating Capacity of Controlled System (MBh)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years	
Roof	RTU-1-Library	8	2.00	0.00	0.00	80.00	0.0	0	4	\$50	\$2,719	\$0	54.8	
Roof	HV1&2 Auditorium	8	2.00	0.00	0.00	920.00	0.0	0	45	\$531	\$2,719	\$0	5.1	

Pipe Insulation Recommendations

		Recommendation Inputs			Energy In	npact & Fii	nancial An	alysis			
Location	Area(s)/System(s) Affected	ECM #	Length of Uninsulate d Pipe (ft)	Pipe Diameter (in)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Boiler Room	Domestic Hot Water System	9	20	1.00	0.0	0	9	\$104	\$239	\$40	1.9
Boiler Room	Hot Water Heating System	9	30	2.00	0.0	0	25	\$290	\$492	\$60	1.5
Custodial Supply Closet	Hot Water Heating System	9	6	0.75	0.0	0	2	\$26	\$80	\$12	2.6
Kitchen	Hot Water Heating System	9	24	0.75	0.0	0	9	\$103	\$320	\$48	2.6
Kitchen	Hot Water Heating System	9	2	1.50	0.0	0	1	\$16	\$33	\$4	1.8

DHW Inventory & Recommendations

	Existing Conditions					Proposed Conditions						Energy Impact & Financial Analysis							
Location	Area(s)/System(s) Served	System Quantit Y	System Type	Manufacturer	Model	Remaining Useful Life	ECM #	Syster Replace? Quant y	n t System Type	Fuel Type	System Efficiency	Efficienc y Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Boiler Room	Franklin Elementary School	1	Storage Tank Water Heater (> 50 Gal)	Bradford White	RG2PV75H6N	w		No					0.0	0	0	\$0	\$0	\$0	0.0



Low-Flow Device Recommendations

	Reco	mmed	ation Inputs			Energy Impact & Financial Analysis									
Location	ECM #	Device Quantit y	Device Type	Existing Flow Rate (gpm)	Proposed Flow Rate (gpm)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years			
Franklin Elementary School	10	23	Faucet Aerator (Lavatory)	2.40	0.50	0.0	0	12	\$144	\$165	\$82	0.6			
Franklin Elementary School	10	3	Faucet Aerator (Kitchen)	2.40	1.50	0.0	0	2	\$18	\$22	\$6	0.9			

Commercial Refrigerator/Freezer Inventory & Recommendations

	Existin	ng Conditions			Proposed	Conditions	Energy In	npact & Fi	nancial Ar	alysis				
Location	Quantit y	Refrigerator/ Freezer Type	Manufacturer	Model	ENERGY STAR Qualified?	ECM #	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen	1	Freezer Chest	Avanti	CFC83Q0WG	No		No	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen	1	Refrigerator Chest	Powers	SM58HC-W	No		No	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen	1	Stand-Up Freezer, Solid Door (≤15 cu. ft.)	Imbera	VR06 CO2	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen	1	Stand-Up Freezer, Solid Door (16 - 30 cu. ft.)	Horizon	HFS1HC-1S	No		No	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen	1	Stand-Up Refrigerator, Solid Door (16 - 30 cu. ft.)	TRUE	T-23	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen	1	Stand-Up Refrigerator, Glass Door (16 - 30 cu. ft.)	TRUE	GDM-26	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0

Commercial Ice Maker Inventory & Recommendations

	Existin	g Conditions				Proposed	Conditions	Energy In	npact & Fi	nancial An	alysis			
Location	Quantit y	lce Maker Type	Manufacturer	Model	ENERGY STAR Qualified?	ECM #	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Nurses Office	1	Self-Contained Unit (<175 lbs/day), Batch	Whynter	Unknown	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0



Cooking Equipment Inventory & Recommendations

	Existing	Conditions				Proposed Conditions Energy Impact & Financial Analysis								
Location	Quantity	Equipment Type	Manufacturer	Model	High Efficiency Equipement?	ECM #	Install High Efficiency Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen	1	Insulated Food Holding Cabinet (Full Size)	Alto-Shaam	1000-UP	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen	1	Gas Convection Oven (Full Size)	Garland	Uknown	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen	1	Gas Rack Oven (Double)	Blodgett	Uknown	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0



Plug Load Inventory

	Existing Conditions										
Location	Quantit y	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified ?	Manufacturer	Model					
Franklin Middle School	4	Coffee Machine	900	No							
Franklin Middle School	1	Dehumidifier	480	No							
Franklin Middle School	43	Desktop	191	No							
Franklin Middle School	1	Electric Space Heater	1,500	No							
Franklin Middle School	11	Fan (Ceiling)	200	No							
Franklin Middle School	1	Fan (Large)	200	No							
Franklin Middle School	1	Kiln	11,000	No							
Franklin Middle School	3	Microwave	1,000	No							
Franklin Middle School	1	Television	120	No							
Franklin Middle School	3	Robo 3D Printer	180	No							
Franklin Middle School	1	Washing Machine	900	No							
Franklin Middle School	1	Server	2,000	No							
Franklin Middle School	1	Kitchen Hot Food Table	1,445	No							
Franklin Middle School	1	Paper Shredder	150	No							
Franklin Middle School	6	Printer (Medium/Small)	192	No							
Franklin Middle School	3	Printer/Copier (Large)	600	No							
Franklin Middle School	29	Projector	200	No							
Franklin Middle School	4	Refrigerator (Mini)	207	No							
Franklin Middle School	2	Refrigerator (Residential)	199	No							
Franklin Middle School	2	Toaster Oven	850	No							







APPENDIX B: ENERGY STAR STATEMENT OF ENERGY PERFORMANCE

Energy use intensity (EUI) is presented in terms of *site energy* and *source energy*. Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.

LEARN MORE AT energystar.gov	GY STAR [®] Sta mance	atement of Energy	
CO	Franklin Elemer	ntary School	
63	Primary Property Type Gross Floor Area (ft ²): Built: 1970	e: K-12 School 48,280	
ENERGY STAR® Score ¹	For Year Ending: April 30 Date Generated: Februar	0, 2022 ry 27, 2023	
1. The ENERGY STAR score is a 1-100 as climate and business activity.	ssessment of a building's energy	efficiency as compared with similar buildings nation	onwide, adjusting for
Property & Contact Information			
Property Address Franklin Elementary School 136 Blackburn Road Summit, New Jersey 07901 Property ID: 21960310	Property Owner Summit Public Schoo 14 Beekman Terrace Summit, NJ 07901-17 (908) 918-2100	Primary Contact Summit Schools 14 Beekman Terrace 702 Summit, NJ 07901-1702 (908) 918-2100 rrodri81@asu.edu	2
Energy Consumption and Ene	rgy Use Intensity (EUI)		
Site EUI Annual Energy 62.9 kBtu/ft² Natural Gas (kB Source EUI 95.6 kBtu/ft²	by Fuel stu) 2,218,492 (73%) sBtu) 816,608 (27%)	National Median Comparison National Median Site EUI (kBtu/ft²) National Median Source EUI (kBtu/ft²) % Diff from National Median Source EUI Annual Emissions Total (Location-Based) GHG Emissions (Metric Tons CO2e/year)	71.9 109.3 -12% 189
Signature & Stamp of Ver	ifying Professional		
I (Name) ve	rify that the above information	n is true and correct to the best of my knowled	ge.
LP Signature:	Date:	_ [
Licensed Professional			
		Professional Engineer or Register Architect Stamp (if applicable)	red

APPENDIX C: GLOSSARY

TERM	DEFINITION
Blended Rate	Used to calculate fiscal savings associated with measures. The blended rate is calculated by dividing the amount of your bill by the total energy use. For example, if your bill is \$22,217.22, and you used 266,400 kilowatt-hours, your blended rate is 8.3 cents per kilowatt-hour.
Btu	<i>British thermal unit</i> : a unit of energy equal to the amount of heat required to increase the temperature of one pound of water by one-degree Fahrenheit.
СНР	Combined heat and power. Also referred to as cogeneration.
СОР	<i>Coefficient of performance</i> : a measure of efficiency in terms of useful energy delivered divided by total energy input.
Demand Response	Demand response reduces or shifts electricity usage at or among participating buildings/sites during peak energy use periods in response to time-based rates or other forms of financial incentives.
DCV	Demand control ventilation: a control strategy to limit the amount of outside air introduced to the conditioned space based on actual occupancy need.
US DOE	United States Department of Energy
EC Motor	Electronically commutated motor
ECM	Energy conservation measure
EER	<i>Energy efficiency ratio</i> : a measure of efficiency in terms of cooling energy provided divided by electric input.
EUI	<i>Energy Use Intensity:</i> measures energy consumption per square foot and is a standard metric for comparing buildings' energy performance.
Energy Efficiency	Reducing the amount of energy necessary to provide comfort and service to a building/area. Achieved through the installation of new equipment and/or optimizing the operation of energy use systems. Unlike conservation, which involves some reduction of service, energy efficiency provides energy reductions without sacrifice of service.
ENERGY STAR	ENERGY STAR is the government-backed symbol for energy efficiency. The ENERGY STAR program is managed by the EPA.
EPA	United States Environmental Protection Agency
Generation	The process of generating electric power from sources of primary energy (e.g., natural gas, the sun, oil).
GHG	<i>Greenhouse gas</i> gases that are transparent to solar (short-wave) radiation but opaque to long-wave (infrared) radiation, thus preventing long-wave radiant energy from leaving Earth's atmosphere. The net effect is a trapping of absorbed radiation and a tendency to warm the planet's surface.
gpf	Gallons per flush

gpm	Gallon per minute
HID	High intensity discharge: high-output lighting lamps such as high-pressure sodium, metal halide, and mercury vapor.
hp	Horsepower
HPS	High-pressure sodium: a type of HID lamp.
HSPF	Heating seasonal performance factor: a measure of efficiency typically applied to heat pumps. Heating energy provided divided by seasonal energy input.
HVAC	Heating, ventilating, and air conditioning
IHP 2014	US DOE Integral Horsepower rule. The current ruling regarding required electric motor efficiency.
IPLV	Integrated part load value: a measure of the part load efficiency usually applied to chillers.
kBtu	One thousand British thermal units
kW	Kilowatt: equal to 1,000 Watts.
kWh	Kilowatt-hour: 1,000 Watts of power expended over one hour.
LED	Light emitting diode: a high-efficiency source of light with a long lamp life.
LGEA	Local Government Energy Audit
Load	The total power a building or system is using at any given time.
Measure	A single activity, or installation of a single type of equipment, that is implemented in a building system to reduce total energy consumption.
МН	Metal halide: a type of HID lamp.
MBh	Thousand Btu per hour
MBtu	One thousand British thermal units
MMBtu	One million British thermal units
MV	Mercury Vapor: a type of HID lamp.
NJBPU	New Jersey Board of Public Utilities
NJCEP	<i>New Jersey's Clean Energy Program:</i> NJCEP is a statewide program that offers financial incentives, programs and services for New Jersey residents, business owners and local governments to help them save energy, money, and the environment.
psig	Pounds per square inch gauge
Plug Load	Refers to the amount of power used in a space by products that are powered by means of an ordinary AC plug.
PV	<i>Photovoltaic:</i> refers to an electronic device capable of converting incident light directly into electricity (direct current).

SEER	Seasonal energy efficiency ratio: a measure of efficiency in terms of annual cooling energy provided divided by total electric input.
SEP	Statement of energy performance: a summary document from the ENERGY STAR Portfolio Manager.
Simple Payback	The amount of time needed to recoup the funds expended in an investment or to reach the break-even point between investment and savings.
SREC (II)	Solar renewable energy credit: a credit you can earn from the state for energy produced from a photovoltaic array.
T5, T8, T12	A reference to a linear lamp diameter. The number represents increments of $1/8^{th}$ of an inch.
Temperature Setpoint	The temperature at which a temperature regulating device (thermostat, for example) has been set.
therm	100,000 Btu. Typically used as a measure of natural gas consumption.
tons	A unit of cooling capacity equal to 12,000 Btu/hr.
Turnkey	Provision of a complete product or service that is ready for immediate use.
VAV	Variable air volume
VFD	Variable frequency drive: a controller used to vary the speed of an electric motor.
WaterSense®	The symbol for water efficiency. The WaterSense [®] program is managed by the EPA.
Watt (W)	Unit of power commonly used to measure electricity use.