



Local Government Energy Audit Report

Washington Elementary School

August 1, 2023

Prepared for:

Summit Board of Education
507 Morris Avenue
Summit, New Jersey 07901

Prepared by:

TRC
317 George Street
New Brunswick, New Jersey 08901

Disclaimer

The goal of this audit report is to identify potential energy efficiency opportunities and help prioritize specific measures for implementation. Most energy conservation measures have received preliminary analysis of feasibility that identifies expected ranges of savings and costs. This level of analysis is usually considered sufficient to establish a basis for further discussion and to help prioritize energy measures.

TRC reviewed the energy conservation measures and estimates of energy savings for technical accuracy. Actual, achieved energy savings depend on behavioral factors and other uncontrollable variables and, therefore, estimates of final energy savings are not guaranteed. TRC and the New Jersey Board of Public Utilities (NJBPU) shall in no event be liable should the actual energy savings vary.

TRC bases estimated material and labor costs primarily on RS Means cost manuals as well as on our experience at similar facilities. This approach is based on standard cost estimating manuals and is vendor neutral. Cost estimates include material and labor pricing associated with one for one equipment replacements. Cost estimates do not include demolition or removal of hazardous waste. The actual implementation costs for energy savings projects are anticipated to be significantly higher based on the specific conditions at your site(s). We strongly recommend that you work with your design engineer or contractor to develop actual project costs for your specific scope of work for the installation of high efficiency equipment. We encourage you to obtain multiple estimates when considering measure installations. Actual installation costs can vary widely based on selected products and installers. TRC and NJBPU do not guarantee cost estimates and shall in no event be held liable should actual installed costs vary from these material and labor estimates.

Incentive values provided in this report are estimated based on previously run state efficiency programs. Incentive levels are not guaranteed. The NJBPU reserves the right to extend, modify, or terminate programs without prior notice. Please review all available utility program incentives and eligibility requirements prior to selecting and installing any energy conservation measures.

The customer and their respective contractor(s) are responsible to implement energy conservation measures in complete conformance with all applicable local, state, and federal requirements.

Copyright ©2023 TRC. All rights reserved.

Reproduction or distribution of the whole, or any part of the contents of this document without written permission of TRC is prohibited. Neither TRC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any data, information, method, product or process disclosed in this document, or represents that its use will not infringe upon any privately-owned rights, including but not limited to, patents, trademarks or copyrights.

Table of Contents

1	Executive Summary.....	1
1.1	Planning Your Project	4
	Pick Your Installation Approach	4
	Options from Your Utility Company	4
	<i>Prescriptive and Custom Rebates</i>	4
	<i>Direct Install</i>	4
	<i>Engineered Solutions</i>	4
	Options from New Jersey's Clean Energy Program	5
2	Existing Conditions.....	6
2.1	Site Overview.....	6
	Recent improvements and Facility Concerns	6
2.2	Building Occupancy	7
2.3	Building Envelope	7
2.4	Lighting Systems.....	9
2.5	Air Handling Systems.....	11
	Unit Ventilators	11
	Unitary Electric HVAC Equipment	12
	Packaged Units	13
	Air Handling Units (AHUs)	14
2.6	Building Exhaust Air Systems.....	15
2.7	Heating Hot Water Systems	16
2.8	Building Automation System (BAS)	18
2.9	Domestic Hot Water	19
2.10	Food Service Equipment.....	19
2.11	Refrigeration.....	20
2.12	Plug Load and Vending Machines	20
2.13	Water-Using Systems	21
3	Energy Use and Costs	22
3.1	Electricity	24
3.2	Natural Gas.....	25
3.3	Benchmarking.....	26
	Tracking Your Energy Performance	27
4	Energy Conservation Measures	28
4.1	Lighting	31
	ECM 1: Install LED Fixtures	31
	ECM 2: Retrofit Fixtures with LED Lamps	31
4.2	Lighting Controls.....	32
	ECM 3: Install Occupancy Sensor Lighting Controls	32
	ECM 4: Install High/Low Lighting Controls	32
4.3	Variable Frequency Drives (VFD).....	33


ECM 5: Install VFDs on Constant Volume (CV) Fans.....	33
4.4 Unitary HVAC.....	33
ECM 6: Install High Efficiency Air Conditioning Units.....	34
ECM 7: Install High Efficiency Heat Pumps.....	34
4.5 Domestic Water Heating.....	34
ECM 8: Install Low-Flow DHW Devices.....	34
4.6 Custom Measures.....	35
ECM 9: Retro-Commissioning Study.....	35
ECM 10: Replace Gas Fired Water Heater with Heat Pump Water Heater.....	36
5 Energy Efficient Best Practices.....	38
Energy Tracking with ENERGY STAR Portfolio Manager.....	38
Weatherization.....	38
Lighting Maintenance.....	38
Lighting Controls.....	39
Motor Maintenance.....	39
Fans to Reduce Cooling Load.....	39
Thermostat Schedules and Temperature Resets.....	39
Economizer Maintenance.....	39
AC System Evaporator/Condenser Coil Cleaning.....	39
HVAC Filter Cleaning and Replacement.....	39
Ductwork Maintenance.....	40
Boiler Maintenance.....	40
Furnace Maintenance.....	40
Label HVAC Equipment.....	40
Optimize HVAC Equipment Schedules.....	41
Water Heater Maintenance.....	41
Refrigeration Equipment Maintenance.....	41
Water Conservation.....	42
Procurement Strategies.....	42
6 On-site Generation.....	43
6.2 Solar Photovoltaic.....	44
6.4 Combined Heat and Power.....	46
7 Electric Vehicles (EV).....	47
7.1 Electric Vehicle Charging.....	47
8 Project Funding and Incentives.....	49
8.1 Utility Energy Efficiency Programs.....	50
Prescriptive and Custom.....	50
Direct Install.....	50
Engineered Solutions.....	51
8.2 New Jersey's Clean Energy Programs.....	52
Large Energy Users.....	52
Combined Heat and Power.....	53
Successor Solar Incentive Program (SuSI).....	54
Energy Savings Improvement Program.....	55
9 Project Development.....	56

10	Energy Purchasing and Procurement Strategies	57
10.1	Retail Electric Supply Options.....	57
10.2	Retail Natural Gas Supply Options	57
Appendix A: Equipment Inventory & Recommendations		A-1
Appendix B: ENERGY STAR Statement of Energy Performance.....		B-1
Appendix C: Glossary		C-1

1 EXECUTIVE SUMMARY

The New Jersey Board of Public Utilities (NJBP) has sponsored this Local Government Energy Audit (LGEA) report for Washington Elementary School. This report provides you with information about your facility's energy use, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help make changes in your facility. TRC conducted this study as part of a comprehensive effort to assist New Jersey school districts and local governments in controlling their energy costs and to help protect our environment by reducing statewide energy consumption.

BUILDING PERFORMANCE REPORT



ENERGY STAR®
Benchmarking Score

63
(1-100 scale)

Congratulations, your building performs better than the national average. This report has suggestions about how to keep your building running efficiently, further improve performance, and lower your energy bills even more.




Figure 1 - Energy Use by System


POTENTIAL IMPROVEMENTS



This energy audit considered a range of potential energy improvements in your building. Costs and savings will vary between improvements. Presented below are two potential scopes of work for your consideration.


Scenario 1: Full Package (All Evaluated Measures)

Installation Cost	\$207,296
Potential Rebates & Incentives ¹	\$10,223
Annual Cost Savings	\$8,699
Annual Energy Savings	Electricity: 51,825 kWh Natural Gas: 2,029 Therms
Greenhouse Gas Emission Savings	38 Tons
Simple Payback	22.7 Years
Site Energy Savings (All Utilities)	11%



Scenario 2: Cost Effective Package²

Installation Cost	\$64,747
Potential Rebates & Incentives	\$4,910
Annual Cost Savings	\$8,075
Annual Energy Savings	Electricity: 59,330 kWh Natural Gas: 629 Therms
Greenhouse Gas Emission Savings	34 Tons
Simple Payback	7.4 Years
Site Energy Savings (all utilities)	8%



On-site Generation Potential

Photovoltaic	Medium
Combined Heat and Power	None

¹ Incentives are based on previously run state rebate programs. Contact your utility provider for current program incentives that may apply.

² A cost-effective measure is defined as one where the simple payback does not exceed two-thirds of the expected proposed equipment useful life. Simple payback is based on the net measure cost after potential incentives.

#	Energy Conservation Measure	Cost Effective?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades			1,253	0.0	0	\$155	\$761	\$104	\$657	4.2	1,259
ECM 1	Install LED Fixtures	Yes	1,117	0.0	0	\$139	\$692	\$100	\$592	4.3	1,124
ECM 2	Retrofit Fixtures with LED Lamps	Yes	137	0.0	0	\$17	\$69	\$4	\$65	3.9	134
Lighting Control Measures			26,110	5.1	-5	\$3,185	\$16,600	\$3,845	\$12,755	4.0	25,654
ECM 3	Install Occupancy Sensor Lighting Controls	Yes	22,363	4.4	-5	\$2,728	\$13,000	\$1,710	\$11,290	4.1	21,972
ECM 4	Install High/Low Lighting Controls	Yes	3,747	0.7	-1	\$457	\$3,600	\$2,135	\$1,465	3.2	3,681
Variable Frequency Drive (VFD) Measures			14,142	4.6	0	\$1,758	\$25,914	\$875	\$25,039	14.2	14,241
ECM 5	Install VFDs on Constant Volume (CV) Fans	Yes	14,142	4.6	0	\$1,758	\$25,914	\$875	\$25,039	14.2	14,241
Unitary HVAC Measures			5,625	13.2	0	\$699	\$138,600	\$5,315	\$133,285	190.6	5,664
ECM 6	Install High Efficiency Air Conditioning Units	No	1,723	1.6	0	\$214	\$16,475	\$464	\$16,012	74.8	1,735
ECM 7	Install High Efficiency Heat Pumps	No	3,901	11.7	0	\$485	\$122,125	\$4,851	\$117,274	241.8	3,929
Domestic Water Heating Upgrade			0	0.0	23	\$253	\$172	\$86	\$86	0.3	2,667
ECM 8	Install Low-Flow DHW Devices	Yes	0	0.0	23	\$253	\$172	\$86	\$86	0.3	2,667
Custom Measures			4,695	0.0	186	\$2,648	\$25,250	\$0	\$25,250	9.5	26,459
ECM 9	Retro-Commissioning Study	Yes	17,825	0.0	46	\$2,723	\$21,300	\$0	\$21,300	7.8	23,289
ECM 10	Replace Gas Fired Water Heater with Heat Pump Water Heater	No	-13,130	0.0	140	-\$75	\$3,950	\$0	\$3,950	-52.7	3,170
TOTALS (COST EFFECTIVE MEASURES)			59,330	9.7	63	\$8,075	\$64,747	\$4,910	\$59,837	7.4	67,108
TOTALS (ALL MEASURES)			51,825	22.9	203	\$8,699	\$207,296	\$10,225	\$197,071	22.7	75,943

* - All incentives presented in this table are included as placeholders for planning purposes and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

***Negative Payback Explained in Section 4.6

Figure 2 – Evaluated Energy Improvements

For more detail on each evaluated energy improvement and a break out of cost-effective improvements, see **Section 4: Energy Conservation Measures**.

1.1 Planning Your Project

Careful planning makes for a successful energy project. When considering this scope of work, you will have some decisions to make, such as:

- ◆ How will the project be funded and/or financed?
- ◆ Is it best to pursue individual ECMs, groups of ECMs, or use a comprehensive approach where all ECMs are installed together?
- ◆ Are there other facility improvements that should happen at the same time?

Pick Your Installation Approach

Utility-run energy efficiency programs and New Jersey's Clean Energy Programs, give you the flexibility to do a little or a lot. Rebates, incentives, and financing are available to help reduce both your installation costs and your energy bills. If you are planning to take advantage of these programs, make sure to review incentive program guidelines before proceeding. This is important because in most cases you will need to submit applications for the incentives before purchasing materials or starting installation.

Options from Your Utility Company

Prescriptive and Custom Rebates

For facilities wishing to pursue only selected individual measures (or planning to phase implementation of selected measures over multiple years), incentives are available through the Prescriptive and Custom Rebates program. To participate, you can use internal resources or an outside firm or contractor to perform the final design of the ECM(s) and install the equipment. Program pre-approval may be required for some incentives. Contact your utility company for more details prior to project installation.

Direct Install

The Direct Install program provides turnkey installation of multiple measures through an authorized contractor. This program can provide incentives up to 70% or 80% of the cost of selected measures. A Direct Install contractor will assess and verify individual measure eligibility and perform the installation work. The Direct Install program is available to sites with an average peak demand of less than 200 kW.

Engineered Solutions

The Engineered Solutions program provides tailored energy-efficiency assistance and turnkey engineering services to municipalities, universities, schools, hospitals, and healthcare facilities (MUSH), non-profit entities, and multifamily buildings. The program provides all professional services from audit, design, construction administration, to commissioning and measurement and verification for custom whole-building energy-efficiency projects. Engineered Solutions allows you to install as many measures as possible under a single project as well as address measures that may not qualify for other programs.

For more details on these programs please contact your utility provider.

Options from New Jersey's Clean Energy Program

Financing and Planning Support with the Energy Savings Improvement Program (ESIP)

For larger facilities with limited capital availability to implement ECMs, project financing may be available through the ESIP. Supported directly by the NJBPU, ESIP provides government agencies with project development, design, and implementation support services, as well as attractive financing for implementing ECMs. You have already taken the first step as an LGEA customer, because this report is required to participate in ESIP.

Resiliency with Return on Investment through Combined Heat and Power (CHP)

The CHP program provides incentives for combined heat and power (i.e., cogeneration) and waste heat to power projects. Combined heat and power systems generate power on-site and recover heat from the generation system to meet on-site thermal loads. Waste heat to power systems use waste heat to generate power. You will work with a qualified developer who will design a system that meets your building's heating and cooling needs.

Successor Solar Incentive Program (SuSI)

New Jersey is committed to supporting solar energy. Solar projects help the state reach the renewable goals outlined in the state's Energy Master Plan. The SuSI program is used to register and certify solar projects in New Jersey. Rebates are not available, but certified solar projects are able to earn one SREC II (Solar Renewable Energy Certificates II) for each megawatt-hour of solar electricity produced from a qualifying solar facility.

Ongoing Electric Savings with Demand Response

The Demand Response Energy Aggregator program reduces electric loads at commercial facilities when wholesale electricity prices are high or when the reliability of the electric grid is threatened due to peak power demand. By enabling commercial facilities to reduce electric demand during times of peak demand, the grid is made more reliable, and overall transmission costs are reduced for all ratepayers. Curtailment service providers provide regular payments to medium and large consumers of electric power for their participation in demand response (DR) programs. Program participation is voluntary, and facilities receive payments regardless of whether they are called upon to curtail their load during times of peak demand.

Large Energy User Program (LEUP)

LEUP is designed to promote self-investment in energy efficiency. It incentivizes owners/users of buildings to upgrade or install energy conserving measures in existing buildings to help offset the capital costs associated with the project. The efficiency upgrades are customized to meet the requirements of the customers' existing facilities, while advancing the State's energy efficiency, conservation, and greenhouse gas reduction goals.

For more details on these programs please visit [New Jersey's Clean Energy Program website](#) .



2 EXISTING CONDITIONS

The New Jersey Board of Public Utilities (NJBPUB) has sponsored this Local Government Energy Audit (LGEA) report for Washington Elementary School. This report provides information on how your facility uses energy, identifies energy conservation measures (ECMs) that can reduce your energy use, and provides information and assistance to help you implement the ECMs.

TRC conducted this study as part of a comprehensive effort to assist New Jersey educational and local government facilities in controlling energy costs and protecting our environment by offering a wide range of energy management options and advice.

2.1 Site Overview

On January 17, 2023, TRC performed an energy audit at Washington Elementary School located in Summit, New Jersey. TRC met with Michael Martino to review the facility operations and help focus our investigation on specific energy-using systems.

Washington Elementary School located at 507 Morris Avenue is a two-story, 53,340 square foot building originally built in 1913 and expanded in 1998 to accommodate additional spaces. Spaces include classrooms, gymnasium, administrative offices, cafeteria, corridors, stairwells, ballrooms, faculty dining room, commercial kitchen, and mechanical space.

Lighting systems consist mostly of LED sources. The building is 100% heated by three condensing boilers and is approximately 70% cooled by variable refrigerant volume (VRV) heat pumps and roof mounted package units (RTUs). The Daikin heat pumps provide cooling only as space heating is provided by the hot water boiler distribution system. Using the heat pumps for heating rather than the hot water heating system where possible will contribute to reduce the building GHG emissions and the building O & M costs.

Recent improvements and Facility Concerns

In 2019, Washington Elementary School phased out most of the fluorescent fixtures and replaced them with efficient LED sources. In 2009, three condensing boilers were installed. The site is interested in replacing the old RTUs and Daikin VRV heat pumps.



Aerial View - Washington Elementary School

2.2 Building Occupancy

The school operates Monday through Friday with standard classes running from 8:30 AM to 3:30 PM. Facility operating hours extend from 6:00 AM to 11:30 PM. The school year lasts for the standard 180 days with an average occupancy count of 59 staff and 307 students. School classroom hours are from 8:30 AM to 2:45 PM. It should be noted that the energy and economic analysis for this building is based on the use of the building during the utility billing period, and that results will vary depending on changes to building use patterns.

Building Name	Weekday/Weekend	Operating Schedule
Washington Elementary School General Operating Hours	Weekday	6:30 AM-11:30 PM
	Weekend	Varies
Washington Elementary School Class Hours	Weekday	8:30 AM-2:45 PM
	Weekend	Closed

Figure 3 - Building Occupancy Schedule

2.3 Building Envelope

The facility was constructed in different phases with the last addition in 1998. Building walls are constructed of concrete masonry units (CMU) over structural steel with a brick façade, with gypsum painted drywall and CMU interior finish. The level of exterior wall insulation is unknown. The building has both flat roof areas and pitched roof sections supported by steel trusses. The original building has a pitched roof covered with slate shingles that are in aging but fair condition. The additions have flat roof sections covered with a grey membrane, and small stone granular elements that are in fair and good condition. Additionally, the 1998 addition has a pitched roof section with a covering of asphalt shingles that are in good condition.

The original building windows are single paned glass with aluminum frames and are in fair condition. The glass-to-frame seals are in fair condition. The fixed window weather seals are in fair condition, showing some signs of wear. The addition windows are double paned glass with aluminum frames and are in good condition. The main entrance doors are glass with metal frames while the exit doors are constructed of metal frames and are in good condition with undamaged door seals. Degraded window and door seals increase drafts and outside air infiltration.



Original Building Walls




1998 Addition Building Walls



Clay Tiles Pitched Roof



Flat Roof Membranes





Asphalt Shingles



Single Paned Window



Exit Doors

2.4 Lighting Systems

Washington Elementary School has been operating an LED lighting system after New Jersey's Clean Energy Direct Install Program retrofits were performed in 2019.

Lighting fixtures consist of linear LED tubes, LED panels, and LED lamps. LED tubes include 2-lamp, 3-lamp, 4-lamp, and 6-lamp, 2-foot or 4-foot-long troffer, recessed, and surface mounted fixtures and 2-foot fixtures with U-bend LED tubes. The library is lit with a mix of LED panels and LED lamps. Classrooms and other spaces are mainly lit with linear tubes. There are four compact fluorescent lamps (CFLs) found in the garage and SGI offices. Exit signs are LED sources. Most fixtures are in good condition. Interior lighting levels were generally sufficient. Light fixtures are controlled by wall switches.

Exterior fixtures include LED lamps, LED fixtures, and two metal halide lamps. Fixtures are wall, recessed and pole mounted and controlled by timers and wall switches.



LED Tubes




LED Panel Fixtures



Bend LED Tube Fixture

U-



2-Foot-Long LED Tube Fixture



Wall Mounted LED Fixtures



Recessed LED Lamps



LED Pole Lights



Wall Mounted Metal Halide Lamp


2.5 Air Handling Systems

Unit Ventilators

Unit ventilators (UVs) are equipped with supply fan motors and digitally controlled outside air dampers and fan coil valves connected to the hot water distribution system. They provide heating and ventilation to classrooms. Some units appear to be in good operating condition while others are in fair condition. Equipment is controlled by the building automation system (BAS).




Classroom Unit Ventilator



BAS Screenshot - Unit Ventilator

Unitary Electric HVAC Equipment

Various classrooms and offices are cooled by two window air conditioners (ACs) and eight Daikin VRV heat pumps. Daikin VRV heat pumps are located on the roof and labeled as "CU." The heat pumps provide cooling only as the heating capabilities are not used; heating is provided by the hot water boiler distribution system. Seven heat pumps are rated at 8 tons while the other is rated at 6 tons. The units have reached the end of their useful life and have been evaluated for replacement. Additionally, the window ACs have also been evaluated for replacement. The heat pumps are controlled by the BAS.




FRIEDRICH			
MODEL/MODEL NO. CP24G30			
COOLING CAPACITY		23,500/23,000 Btu/h	
INPUT		2,500/2,450 W	
EER		9.4/9.4 Btu/h.W	
VOLT	230/208 V	Hz	60
AMPS	11.4/12.4 A	PHASE	1Ø
DESIGN PRESSURE		H.S.:450PSIG L.S.:250PSIG	
REFRIGERANT		R410A 40.20Z	
ROOM AIR CONDITIONER			

Window AC



CU-1			
DAIKIN INDUSTRIES, LTD. (K)			
AIR CONDITIONER			
MODEL	RXYQ108PATJ	SER. NO.	MADE IN JAPAN
NET WEIGHT	560 LBS.	MFG. DATE	
POWER SUPPLY	3 PHASE 208/230 V 60 Hz		
MAXIMUM OVERCURRENT PROTECTIVE DEVICE	60 A		
MIN. CIRCUIT AMPACITY	41.3 A		
FAN MOTOR	FLA 2.0 A	OUTPUT	750 W
COMP. MOTOR	RLA12.2+16.8 A	LRA	132 A
DESIGN PRESSURE	HIGH SIDE 478 PSIG LOW SIDE 320 PSIG		
AIR TIGHT TEST PRESSURE	HIGH SIDE 550 PSIG LOW SIDE 320 PSIG		
REFRIGERANT (FACTORY CHARGED)	R410A 20.1 LBS.		
ELECTRIC CHARACTERISTICS ARE ONLY FOR OUTDOOR UNIT.			
CONFORMS TO ANSI/UL STD 1995 CERTIFIED TO CAN/CSA STD C22.2 NO. 236			
3052365			
3P264296-11			

Typical Daikin VRV Heat Pump – CU-1



BAS - Daikin VRV Heat Pump – CU-2

Packaged Units

Larger spaces and offices are conditioned by five rooftop units (RTUs) that vary in cooling capacity between 1.5 tons to 7.5 tons. The units provide cooling through direct expansion (DX) and are equipped with supply fans, hot water coils, and economizers. The 7.5-ton Trane unit serving the library (RTU-W4) and the 5.0-ton York unit serving the main office are operating within their respective useful life and appear in good condition. The remaining three RTUs have reached the end of their useful lives, appear in fair condition, and have been evaluated for replacement. The RTUs are controlled by the BAS.



York RTU - Office



RTU-W1 – SGI




BAS Screenshot - RTU-W1

Air Handling Units (AHUs)

The gymnasium is heated by two heating and ventilation units labeled as HV-1 and HV-2. The units are equipped with 3 hp supply fans and hot water coils. The units appear in fair condition. They are controlled by the BAS.

The kitchen is served by a rooftop mounted make-up air unit (MUA) that is equipped with a supply fan and a hot water coil. It appears in fair condition and is controlled by the BAS.



BAS Screenshot - HV-1



MUA

2.6 Building Exhaust Air Systems


The restrooms, hallways, classrooms, and other areas are exhausted by motor driven exhaust fans. There is also a kitchen hood exhaust fan. The equipment is in good condition and is controlled by the BAS or manual switches, depending on the system.



Regular Exhaust Fan



Kitchen Hood



BAS Screenshot - Roof Mounted Exhaust Fans

2.7 Heating Hot Water Systems

Three Aerco 1720 MBh condensing hot water boilers serve the building's heating load. The boilers have burners with nominal efficiency ratings of up to 93%. The boilers are configured in an automated sequence, and they all run together to modulate the load and to stage based on the outside air temperature. Installed in 2009, the boilers are near the end of their useful life and been evaluated for replacement. The hydronic distribution system is a two-pipe, heating-only system. The boiler room

contain two, 15 hp variable flow pumps that distribute heating hot water to unit ventilators, fan coil units, HV units, package units, hydronic baseboards, and unit heaters.

The boilers operate based on outside air temperature. The boilers and the hot water loops are controlled by the BAS. The building occupied heating setpoint is 68°F, and the unoccupied heating setpoint is 55°F.


The BAS hot water loop screenshot indicates supply water temperature is set for 135°F which means the return water temperature is sufficiently low for the boilers to operate efficiently in condensing mode.



Condensing Boilers




15 hp Variable Flow Pumps



BAS Screenshot - Hot Water Loop

2.8 Building Automation System (BAS)


An Automated Logic system controls the HVAC equipment, boilers, UVs, exhaust fans, RTUs, and MUA. The system provides equipment scheduling control and monitors and controls space temperatures, supply air temperatures, humidity, and heating water loop temperatures.



Main Page - BAS Screenshot

2.9 Domestic Hot Water

Hot water for the original building is produced by a 100-gallon, 85 MBh gas-fired storage water heater with an efficiency rating of 80% located in the boiler room. The water heater is in good condition. Domestic hot water pipes are insulated, and the insulation is in good condition.



100 Gallon Gas-Fired Storage Tank Water Heater

2.10 Food Service Equipment

The kitchen has a mix of gas and electric equipment that is used to prepare breakfast and lunch for students. Most cooking is done using a gas-fired combination oven/steam cooker and a gas-fired convection oven. Some bulk prepared foods are held in one full size electric holding cabinet. Equipment is high efficiency and is in good condition.

Visit https://www.energystar.gov/products/commercial_food_service_equipment for the latest information on high efficiency food service equipment.




Gas-Fired Cooking Equipment

2.11 Refrigeration

The kitchen has a stand-up refrigerator with solid doors and a refrigerator chest. The cafeteria has a freezer and a refrigerator chest. All equipment is standard efficiency and in good condition.

Visit https://www.energystar.gov/products/commercial_food_service_equipment for the latest information on high efficiency food service equipment.



Stand-Up Solid Doors Refrigerator

2.12 Plug Load and Vending Machines

There are 42 computer workstations throughout the facility. Plug loads throughout the building include general café and office equipment. There are classroom typical loads such as projectors. There are additional loads typically associated with elementary schools.

There are also typical office loads such as scanner/copiers, small printers, microwaves, and mini fridges. There are approximately two residential-style refrigerators throughout the facility that are in good condition.



Copier/Scanner



Residential Style Refrigerator

2.13 Water-Using Systems

There are several restrooms with toilets, urinals, and sinks. Faucet flow rates are at 2.2 gallons per minute (gpm) or higher. Toilets are rated at 2.5 gallons per flush (gpf) and urinals are rated at 2.5 gpf.




Typical Sink

3 ENERGY USE AND COSTS

Twelve months of utility billing data are used to develop annual energy consumption and cost data. This information creates a profile of the annual energy consumption and energy costs.

Utility Summary		
Fuel	Usage	Cost
Electricity	295,830 kWh	\$36,774
Natural Gas	24,988 Therms	\$27,801
Total		\$64,576



An energy balance identifies and quantifies energy use in your various building systems. This can highlight areas with the most potential for improvement. This energy balance was developed using calculated energy use for each of the end uses noted in the figure.

The energy auditor collects information regarding equipment operating hours, capacity, efficiency, and other operational parameters from facility staff, drawings, and on-site observations. This information is used as the inputs to calculate the existing conditions energy use for the site. The calculated energy use is then compared to the historical energy use and the initial inputs are revised, as necessary, to balance the calculated energy use to the historical energy use.





Figure 4 - Energy Balance

JCP&L delivers electricity under General Service Secondary 3 Phase rate class.




Electric Billing Data					
Period Ending	Days in Period	Electric Usage (kWh)	Demand (kW)	Demand Cost	Total Electric Cost
6/4/21	31	21,120	80	\$722	\$2,746
7/2/21	28	22,240	119	\$722	\$2,821
8/3/21	32	25,280	119	\$722	\$3,111
9/3/21	31	24,800	120	\$729	\$3,074
10/5/21	32	26,560	120	\$729	\$3,346
11/3/21	29	17,760	120	\$729	\$2,551
12/3/21	30	19,520	120	\$812	\$2,713
1/5/22	33	28,480	90	\$592	\$3,312
2/3/22	29	26,080	89	\$586	\$3,078
3/4/22	29	21,440	120	\$812	\$2,884
4/5/22	32	26,400	90	\$589	\$2,934
5/5/22	30	36,960	120	\$812	\$4,303
Totals	366	296,640	120	\$8,556	\$36,875
Annual	365	295,830	120	\$8,533	\$36,774

Notes:

- Peak demand of 120 kW occurred in multiple months.
- Average demand over the past 12 months was 109 kW.
- The average electric cost over the past 12 months was \$0.124/kWh, which is the blended rate that includes energy supply, distribution, demand, and other charges. This report uses this blended rate to estimate energy cost savings.

3.2 Natural Gas

PSE&G delivers natural gas under rate class Large Volume Gas (LVG), with natural gas supply provided by Direct Energy, a third-party supplier.



Gas Billing Data			
Period Ending	Days in Period	Natural Gas Usage (Therms)	Natural Gas Cost
6/7/21	32	533	\$422
7/7/21	30	262	\$289
8/5/21	29	173	\$277
9/7/21	33	368	\$341
10/5/21	28	159	\$238
11/3/21	29	564	\$1,162
12/7/21	34	2,700	\$2,434
1/6/22	30	3,557	\$4,314
2/4/22	29	6,915	\$7,582
3/8/22	32	5,373	\$6,127
4/6/22	29	3,075	\$3,024
5/6/22	30	1,308	\$1,592
Totals	365	24,988	\$27,801
Annual	365	24,988	\$27,801

Notes:

- The average gas cost for the past 12 months is \$1.113/therm, which is the blended rate used throughout the analysis.

3.3 Benchmarking

Your building was benchmarked using the United States Environmental Protection Agency's (EPA) *Portfolio Manager*® software. Benchmarking compares your building's energy use to that of similar buildings across the country, while neutralizing variations due to location, occupancy, and operating hours. Some building types can be scored with a 1-100 ranking of a building's energy performance relative to the national building market. A score of 50 represents the national average and a score of 100 is best.

This ENERGY STAR benchmarking score provides a comprehensive snapshot of your building's energy performance. It assesses the building's physical assets, operations, and occupant behavior, which is compiled into a quick and easy-to-understand score.




Figure 5 - Energy Use Intensity Comparison³

Congratulations, your building performs better than the national average. This report has suggestions about how to keep your building running efficiently, further improve performance, and lower your energy bills even more.

Energy use intensity (EUI) measures energy consumption per square foot and is the standard metric for comparing buildings' energy performance. A lower EUI means better performance and less energy consumed. Several factors can cause a building to vary from typical energy usage. Local weather conditions, building age and insulation levels, equipment efficiency, daily occupancy hours, changes in occupancy throughout the year, equipment operating hours, and occupant behavior all contribute to a building's energy use and the benchmarking score.

³ Based on all evaluated ECMs



Tracking Your Energy Performance

Keeping track of your energy use on a monthly basis is one of the best ways to keep energy costs in check. Update your utility information in Portfolio Manager regularly, so that you can keep track of your building's performance.

We have created a Portfolio Manager account for your facility and have already entered the monthly utility data shown above for you. Account login information for your account will be sent via email.

Free online training is available to help you use ENERGY STAR Portfolio Manager to track your building's performance at: <https://www.energystar.gov/buildings/training>.

For more information on ENERGY STAR and Portfolio Manager, visit their [website](#).

4 ENERGY CONSERVATION MEASURES

The goal of this audit report is to identify and evaluate potential energy efficiency improvements and provide information about the cost effectiveness of those improvements. Most energy conservation measures have received preliminary analysis of feasibility, which identifies expected ranges of savings. This level of analysis is typically sufficient to demonstrate project cost-effectiveness and help prioritize energy measures.

Calculations of energy use and savings are based on the current version of the *New Jersey's Clean Energy Program Protocols to Measure Resource Savings*, which is approved by the NJBPU. Further analysis or investigation may be required to calculate more precise savings based on specific circumstances.

Operation and maintenance costs for the proposed new equipment will generally be lower than the current costs for the existing equipment—especially if the existing equipment is at or past its normal useful life. We have conservatively assumed there to be no impact on overall maintenance costs over the life of the equipment.

Financial incentives in this report are based on the previously run state rebate program SmartStart, which has been retired. Now, all investor-owned gas and electric utility companies are offering complementary energy efficiency programs directly to their customers. Some measures and proposed upgrades may be eligible for higher incentives than those shown below. The incentives in the summary tables should be used for high-level planning purposes. To verify incentives, reach out to your utility provider or visit the [NJCEP website](#) for more information.

For a detailed list of the locations and recommended energy conservation measures for all inventoried equipment, see Appendix A: Equipment Inventory & Recommendations.

#	Energy Conservation Measure	Cost Effective?	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades			1,253	0.0	0	\$155	\$761	\$104	\$657	4.2	1,259
ECM 1	Install LED Fixtures	Yes	1,117	0.0	0	\$139	\$692	\$100	\$592	4.3	1,124
ECM 2	Retrofit Fixtures with LED Lamps	Yes	137	0.0	0	\$17	\$69	\$4	\$65	3.9	134
Lighting Control Measures			26,110	5.1	-5	\$3,185	\$16,600	\$3,845	\$12,755	4.0	25,654
ECM 3	Install Occupancy Sensor Lighting Controls	Yes	22,363	4.4	-5	\$2,728	\$13,000	\$1,710	\$11,290	4.1	21,972
ECM 4	Install High/Low Lighting Controls	Yes	3,747	0.7	-1	\$457	\$3,600	\$2,135	\$1,465	3.2	3,681
Variable Frequency Drive (VFD) Measures			14,142	4.6	0	\$1,758	\$25,914	\$875	\$25,039	14.2	14,241
ECM 5	Install VFDs on Constant Volume (CV) Fans	Yes	14,142	4.6	0	\$1,758	\$25,914	\$875	\$25,039	14.2	14,241
Unitary HVAC Measures			5,625	13.2	0	\$699	\$138,600	\$5,315	\$133,285	190.6	5,664
ECM 6	Install High Efficiency Air Conditioning Units	No	1,723	1.6	0	\$214	\$16,475	\$464	\$16,012	74.8	1,735
ECM 7	Install High Efficiency Heat Pumps	No	3,901	11.7	0	\$485	\$122,125	\$4,851	\$117,274	241.8	3,929
Domestic Water Heating Upgrade			0	0.0	23	\$253	\$172	\$86	\$86	0.3	2,667
ECM 8	Install Low-Flow DHW Devices	Yes	0	0.0	23	\$253	\$172	\$86	\$86	0.3	2,667
Custom Measures			4,695	0.0	186	\$2,648	\$25,250	\$0	\$25,250	9.5	26,459
ECM 9	Retro-Commissioning Study	Yes	17,825	0.0	46	\$2,723	\$21,300	\$0	\$21,300	7.8	23,289
ECM 10	Replace Gas Fired Water Heater with Heat Pump Water Heater	No	-13,130	0.0	140	-\$75	\$3,950	\$0	\$3,950	-52.7	3,170
TOTALS			51,825	22.9	203	\$8,699	\$207,296	\$10,225	\$197,071	22.7	75,943

* - All incentives presented in this table are included as placeholders for planning purposes and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

***Negative Payback Explained in Section 4.6

Figure 6 – All Evaluated ECMs

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		1,253	0.0	0	\$155	\$761	\$104	\$657	4.2	1,259
ECM 1	Install LED Fixtures	1,117	0.0	0	\$139	\$692	\$100	\$592	4.3	1,124
ECM 2	Retrofit Fixtures with LED Lamps	137	0.0	0	\$17	\$69	\$4	\$65	3.9	134
Lighting Control Measures		26,110	5.1	-5	\$3,185	\$16,600	\$3,845	\$12,755	4.0	25,654
ECM 3	Install Occupancy Sensor Lighting Controls	22,363	4.4	-5	\$2,728	\$13,000	\$1,710	\$11,290	4.1	21,972
ECM 4	Install High/Low Lighting Controls	3,747	0.7	-1	\$457	\$3,600	\$2,135	\$1,465	3.2	3,681
Variable Frequency Drive (VFD) Measures		14,142	4.6	0	\$1,758	\$25,914	\$875	\$25,039	14.2	14,241
ECM 5	Install VFDs on Constant Volume (CV) Fans	14,142	4.6	0	\$1,758	\$25,914	\$875	\$25,039	14.2	14,241
Domestic Water Heating Upgrade		0	0.0	23	\$253	\$172	\$86	\$86	0.3	2,667
ECM 8	Install Low-Flow DHW Devices	0	0.0	23	\$253	\$172	\$86	\$86	0.3	2,667
Custom Measures		17,825	0.0	46	\$2,723	\$21,300	\$0	\$21,300	7.8	23,289
ECM 9	Retro-Commissioning Study	17,825	0.0	46	\$2,723	\$21,300	\$0	\$21,300	7.8	23,289
TOTALS		59,330	9.7	63	\$8,075	\$64,747	\$4,910	\$59,837	7.4	67,108

* - All incentives presented in this table are included as placeholders for planning purposes and are based on previously run state rebate programs. Contact your utility provider for details on current programs.

** - Simple Payback Period is based on net measure costs (i.e. after incentives).

Figure 7 – Cost Effective ECMs

4.1 Lighting

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Upgrades		1,253	0.0	0	\$155	\$761	\$104	\$657	4.2	1,259
ECM 1	Install LED Fixtures	1,117	0.0	0	\$139	\$692	\$100	\$592	4.3	1,124
ECM 2	Retrofit Fixtures with LED Lamps	137	0.0	0	\$17	\$69	\$4	\$65	3.9	134

When considering lighting upgrades, we suggest using a comprehensive design approach that simultaneously upgrades lighting fixtures and controls to maximize energy savings and improve occupant lighting. Comprehensive design will also consider appropriate lighting levels for different space types to make sure that the right amount of light is delivered where needed. If conversion to LED light sources is proposed, we suggest converting all of a specific lighting type (e.g., linear fluorescent) to LED lamps to minimize the number of lamp types in use at the facility, which should help reduce future maintenance costs.

ECM 1: Install LED Fixtures

Replace existing fixtures containing metal halide lamps with new LED light fixtures. This measure saves energy by installing LEDs, which use less power than other technologies with a comparable light output.

In some cases, HID fixtures can be retrofit with screw-based LED lamps. Replacing an existing HID fixture with a new LED fixture will generally provide better overall lighting optics; however, replacing the HID lamp with a LED screw-in lamp is typically a less expensive retrofit. We recommend you work with your lighting contractor to determine which retrofit solution is best suited to your needs and will be compatible with the existing fixtures.

Maintenance savings may also be achieved since LED lamps last longer than other light sources and therefore do not need to be replaced as often.

Affected Building Areas: exterior wall mounted fixtures

ECM 2: Retrofit Fixtures with LED Lamps

Replace CFL lamps with LED lamps. Many LED tubes are direct replacements for existing fluorescent tubes and can be installed while leaving the fluorescent fixture ballast in place. LED lamps can be used in existing fixtures as a direct replacement for most other lighting technologies. Be sure to specify replacement lamps that are compatible with existing dimming controls, where applicable. In some circumstances, you may need to upgrade your dimming system for optimum performance.

This measure saves energy by installing LEDs, which use less power than other lighting technologies yet provide equivalent lighting output for the space. Maintenance savings may also be available, as longer-lasting LEDs lamps will not need to be replaced as often as the existing lamps.

Affected Building Areas: garage and SGI offices

4.2 Lighting Controls

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Lighting Control Measures		26,110	5.1	-5	\$3,185	\$16,600	\$3,845	\$12,755	4.0	25,654
ECM 3	Install Occupancy Sensor Lighting Controls	22,363	4.4	-5	\$2,728	\$13,000	\$1,710	\$11,290	4.1	21,972
ECM 4	Install High/Low Lighting Controls	3,747	0.7	-1	\$457	\$3,600	\$2,135	\$1,465	3.2	3,681

Lighting controls reduce energy use by turning off or lowering lighting fixture power levels when not in use. A comprehensive approach to lighting design should upgrade the lighting fixtures and the controls together for maximum energy savings and improved lighting for occupants.

ECM 3: Install Occupancy Sensor Lighting Controls

Install occupancy sensors to control lighting fixtures in areas that are frequently unoccupied, even for short periods. For most spaces, we recommend that lighting controls use dual technology sensors, which reduce the possibility of lights turning off unexpectedly.

Occupancy sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Most occupancy sensor lighting controls allow users to manually turn fixtures on/off, as needed. Some controls can also provide dimming options.

Occupancy sensors can be mounted on the wall at existing switch locations, mounted on the ceiling, or in remote locations. In general, wall switch replacement sensors are best suited to single occupant offices and other small rooms. Ceiling-mounted or remote mounted sensors are used in large spaces, locations without local switching, and where wall switches are not in the line-of-sight of the main work area.

This measure provides energy savings by reducing the lighting operating hours.

Affected Building Areas: offices, classrooms, gymnasium, library, restrooms, and storage rooms

ECM 4: Install High/Low Lighting Controls

Install occupancy sensors to provide dual level lighting control for lighting fixtures in spaces that are infrequently occupied but may require some level of continuous lighting for safety or security reasons.

Lighting fixtures with these controls operate at default low levels when the area is unoccupied to provide minimal lighting to meet security or safety code requirements for egress. Sensors detect occupancy using ultrasonic and/or infrared sensors. When an occupant enters the space, the lighting fixtures switch to full lighting levels. Fixtures automatically switch back to low level after a predefined period of vacancy. In parking lots and parking garages with significant ambient lighting, this control can sometimes be combined with photocell controls to turn the lights off when there is sufficient daylight.

The controller lowers the light level by dimming the fixture output. Therefore, the controlled fixtures need to have a dimmable ballast or driver. This will need to be considered when selecting retrofit lamps and bulbs for the areas proposed for high/low control.

For this type of measure the occupancy sensors will generally be ceiling or fixture mounted. Sufficient sensor coverage must be provided to ensure that lights turn on in each area as occupants approach the area.

This measure provides energy savings by reducing the light fixture power draw when reduced light output is appropriate.

Affected Building Areas: corridors, stairwells, and 3rd floor landing areas

4.3 Variable Frequency Drives (VFD)

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Variable Frequency Drive (VFD) Measures		14,142	4.6	0	\$1,758	\$25,914	\$875	\$25,039	14.2	14,241
ECM 5	Install VFDs on Constant Volume (CV) Fans	14,142	4.6	0	\$1,758	\$25,914	\$875	\$25,039	14.2	14,241

Variable frequency drives control motors for fans, pumps, and process equipment based on the actual output required of the driven equipment. Energy savings result from more efficient control of motor energy usage when equipment operates at partial load. The magnitude of energy savings depends on the estimated amount of time that the motor would operate at partial load. For equipment with proposed VFDs, we have included replacing the controlled motor with a new inverter duty rated motor to conservatively account for the cost of an inverter duty rated motor.

ECM 5: Install VFDs on Constant Volume (CV) Fans

Install VFDs to control constant volume fan motor speeds. This converts a constant-volume, single-zone air handling system into a variable-air-volume (VAV) system. A separate VFD is usually required to control the return fan motor or dedicated exhaust fan motor if the air handler has one.

Zone thermostats signal the VFD to adjust fan speed to maintain the appropriate temperature in the zone, while maintaining a constant supply air temperature.

For air handlers with direct expansion (DX) cooling systems, the minimum air flow across the cooling coil required to prevent the coil from freezing must be determined during the final project design. The control system programming should maintain the minimum air flow whenever the compressor is operating. Prior to implementation, verify minimum fan speed in cooling mode with the manufacturer. Note that savings will vary depending on the operating characteristics of each AHU.

Energy savings result from reducing the fan speed (and power) when conditions allow for reduced air flow.

Affected Air Handlers: gym exhaust fans, RTU-W3, RTU-W4s and HV units

4.4 Unitary HVAC

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Unitary HVAC Measures		5,625	13.2	0	\$699	\$138,600	\$5,315	\$133,285	190.6	5,664
ECM 6	Install High Efficiency Air Conditioning Units	1,723	1.6	0	\$214	\$16,475	\$464	\$16,012	74.8	1,735
ECM 7	Install High Efficiency Heat Pumps	3,901	11.7	0	\$485	\$122,125	\$4,851	\$117,274	241.8	3,929

Replacing the unitary HVAC units has a long payback period and may not be justifiable based simply on energy considerations. However, most of the units are nearing or have reached the end of their normal useful life. Typically, the marginal cost of purchasing a high efficiency unit can be justified by the marginal savings from the improved efficiency. When the unitary HVAC units are eventually replaced, consider purchasing equipment that exceeds the minimum efficiency required by building codes.

ECM 6: Install High Efficiency Air Conditioning Units

We evaluated replacing standard efficiency window and packaged air conditioning units with high efficiency window packaged air conditioning units. The magnitude of energy savings for this measure depends on the relative efficiency of the older unit versus the new high efficiency unit, the average cooling and heating load, and the estimated annual operating hours.

Affected Units: Three 1.5-ton RTUs & two window ACs. Note: ECM 5 includes installing a VFD to control the fan speed for RTU-W3, one of the 1.5-ton units. If replacing the unit, the current energy code will typically require package units to be factory equipped with VFD control.

ECM 7: Install High Efficiency Heat Pumps

Replace standard efficiency heat pumps with high efficiency heat pumps. A higher EER or SEER rating indicates a more efficient cooling system, and a higher HSPF rating indicates more efficient heating mode. The magnitude of energy savings for this measure depends on the relative efficiency of the older unit versus the new high efficiency unit, the average heating and cooling loads, and the estimated annual operating hours.

Affected Units: eight Daikin VRV heat pumps

4.5 Domestic Water Heating

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Domestic Water Heating Upgrade		0	0.0	23	\$253	\$172	\$86	\$86	0.3	2,667
ECM 11	Install Low-Flow DHW Devices	0	0.0	23	\$253	\$172	\$86	\$86	0.3	2,667

ECM 8: Install Low-Flow DHW Devices

Install low-flow devices to reduce overall hot water demand. The following low-flow devices are recommended to reduce hot water usage:

Device	Flow Rate
Faucet aerators (lavatory)	0.5 gpm
Faucet aerator (kitchen)	1.5 gpm
Showerhead	2.0 gpm
Pre-rinse spray valve (kitchen)	1.28 gpm

Low-flow devices reduce the overall water flow from the fixture, while still providing adequate pressure for washing. Additional cost savings may result from reduced water usage.

4.6 Custom Measures

#	Energy Conservation Measure	Annual Electric Savings (kWh)	Peak Demand Savings (kW)	Annual Fuel Savings (MMBtu)	Annual Energy Cost Savings (\$)	Estimated M&L Cost (\$)	Estimated Incentive (\$)*	Estimated Net M&L Cost (\$)	Simple Payback Period (yrs)**	CO ₂ e Emissions Reduction (lbs)
Custom Measures		4,695	0.0	186	\$2,648	\$25,250	\$0	\$25,250	9.5	26,459
ECM 9	Retro-Commissioning Study	17,825	0.0	46	\$2,723	\$21,300	\$0	\$21,300	7.8	23,289
ECM 10	Replace Gas Fired Water Heater with Heat Pump Water Heater	-13,130	0.0	140	-\$75	\$3,950	\$0	\$3,950	-52.7	3,170

ECM 9: Retro-Commissioning Study

Due to the complexity of today's HVAC systems and controls a thorough analysis and rebalance of heating, ventilation, and cooling systems should periodically be conducted. There are indications at this site that systems may not be operating correctly or as efficiently as they could be. One important tool available to building operators to ensure proper system operation is retro-commissioning.

Retro-commissioning is a common practice recommended by the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE) to be implemented every few years. We recommend that you contact a reputable engineering firm that specializes in energy control systems and retro-commissioning. Ask them to propose a scope of work and an outline of the procedures and processes to be implemented, including a schedule and the roles of all responsible parties.

Once goals and responsibilities are established, the objective of the investigation process is to understand how the building is currently operating, identify the issues, and determine the most cost-effective way to improve performance. The retro-commissioning agent will review building documentation, interview building occupants, and inspect and test the equipment. Information is then compiled into a report and shared with facility staff, who will select which recommendations to implement after reviewing the findings.

The implementation phase puts the selected processes into place. Typical measures may include sensor calibration, equipment schedule changes, damper linkage repair and similar relatively low-cost adjustments—although more expensive sophisticated programming and building control system upgrades may be warranted. Approved measures may be implemented by the agent, the building staff, or by subcontractors. Typically, a combination of these individuals makes up the retro-commissioning team.

After the approved measures are implemented, the team will verify that the changes are working as expected. Baseline and post-case measurements will allow building staff to monitor equipment and ensure that the benefits are maintained.

A high-level evaluation of potential savings and costs is provided for demonstration purposes only. It is a screening evaluation for the potential in HVAC control improvements. Based on industry standards and previous project experience, the potential energy savings may be up to 15% of existing HVAC energy use. We estimate the cost of retro-commissioning studies and control improvements at \$0.40 per square foot. Actual savings and costs will need to be outlined by the specific contractor engaged to perform the study. For the purposes of this report, we have conservatively estimated savings to be 4% of the HVAC energy consumption baseline.

ECM 10: Replace Gas Fired Water Heater with Heat Pump Water Heater

A gas fired water heater uses a burner to heat water. Air source heat pump water heaters (HPWH) use a refrigeration cycle to transfer heat from the surrounding air to the domestic water. Water heater efficiency is rated by the uniform energy factor (UEF). For a relative comparison of water heater UEFs, the criteria for certifying a water heater in the ENERGY STAR program are provided below. These values indicate that HPWH heaters are significantly more efficient than gas fired water heaters.

There are two types of HPWH: those integrated with the heat pump and storage tank in the same unit, and those that are split into two sections (with the storage tank separate from the heat pump). The measure considers an integrated HPWH.

ENERGY STAR Uniform Energy Factor (UEF) Criteria for Certified Water Heaters *

Water Heater Type	Minimum UEF	Other
Integrated HPWH	3.3	
Integrated HPWH	2.2	120 Volt, 15 Amp circuit
Split System HPWH	2.2	
Gas Fired Storage	0.64	≤ 55 gal, Medium Draw Pattern
Gas Fired Storage	0.68	≤ 55 gal, High Draw Pattern
Gas Fired Storage	0.78	> 55 gal, Medium Draw Pattern
Gas Fired Storage	0.80	> 55 gal, High Draw Pattern
Gas Fired Storage	0.80	Residential Duty
Gas Fired Instantaneous	0.87	

* Note: Uniform Energy Factor (UEF): The newest measure of water heater overall efficiency. The higher the UEF value is, the more efficient the water heater. UEF is determined by the Department of Energy's test method outlined in 10 CFR Part 430, Subpart B, Appendix E.⁴

HPWH reject cold air. As such, they need to be installed in an unconditioned space of about 750 cubic feet with good ventilation⁵. Ideal locations are garages, large enclosed, unconditioned storage areas, or areas with excess heat such as a furnace or boiler room. The HPWH will also produce condensate so accommodations for draining the condensate need to be provided.

Most HPWH operate effectively down to an air temperature of 40 °F. Below that temperature, an electric resistance booster heater is typically required to achieve full heating capacity. It is critical that the HPWH controls are set up so that the electric resistance heat only engages when the air temperature is too cold for the HPWH to extract heat from it. HPWHs have a slow recovery. During periods of high demand, the electric resistance heating element, if enabled, may be energized to maintain set point, thus reducing the

⁴ https://www.energy.gov/sites/prod/files/2014/06/f17/rwh_tp_final_rule.pdf

⁵ <https://basel.pnnl.gov/code-compliance/heat-pump-water-heaters-code-compliance-brief#:~:text=HPWH%20must%20have%20unrestricted%20airflow,depending%20on%20size%20of%20system>

overall efficiency of the unit. It is recommended that a careful analysis of the hot water demand be conducted to determine if the application makes economic sense, and the HPWH heating capacity and storage are properly sized.

HPWH operate most effectively when the temperature difference between the incoming and outgoing water is high. Generally, this means that cold make-up water should be piped to the bottom of the tank and return water should be piped to the top of the tank in order to maintain stratification within the storage tank. Water should be drawn from the bottom of the tank to be heated. If there is a DHW recirculation pump, it should only be operated during high hot water demand periods.

Switching from a gas fired water heater to a HPWH has the potential to reduce the sites overall greenhouse gas emissions. If the electricity for the HPWH is provided by an on-site photovoltaic (PV) system then there are essentially no greenhouse gas (GHG) emissions. A 2016 study conducted at Cornell⁶ calculated the kg of methane (CH₄) and carbon dioxide (CO₂) produced per GJ of water heated. The study compared HPWH to gas and electric fired, storage and tankless water heaters. The study also considered electricity produced from natural gas and coal fired electric plants. In all cases the study found that HPWHs produced less methane than all of the other water heaters. The study also found that HPWH produced less carbon dioxide than electric resistance water heaters but more carbon dioxide than tankless gas water heaters and about the same amount of carbon dioxide as storage gas water heaters. The summary tables provide the reduction in CO₂ equivalent emissions based on the typical New Jersey electric utility.

This measure has a negative simple payback due to the relative cost of electricity to natural gas. At this site the cost per Btu for natural gas is significantly lower than for electricity. Therefore, even though this measure will result in a net energy savings in terms of Btu at this site it will increase the overall cost for providing domestic hot water.

⁶ [Greenhouse gas emissions from domestic hot water: Heat pumps compared to most commonly used systems. Bongghi Hong, Robert W. Howarth. Department of Ecology and Evolutionary Biology, Cornell University. Energy Science and Engineering 2016.](#)

5 ENERGY EFFICIENT BEST PRACTICES

A whole building maintenance plan will extend equipment life; improve occupant comfort, health, and safety; and reduce energy and maintenance costs.

Operation and maintenance (O&M) plans enhance the operational efficiency of HVAC and other energy intensive systems and could save 5%–20% of the energy usage in your building without substantial capital investment. A successful plan includes your records of energy usage trends and costs, building equipment lists, current maintenance practices, and planned capital upgrades, and it incorporates your ideas for improved building operation. Your plan will address goals for energy-efficient operation, provide detail on how to reach the goals, and outline procedures for measuring and reporting whether goals have been achieved.

You may already be doing some of these things—see our list below for potential additions to your maintenance plan. Be sure to consult with qualified equipment specialists for details on proper maintenance and system operation.

Energy Tracking with ENERGY STAR Portfolio Manager



You've heard it before—you cannot manage what you do not measure. ENERGY STAR Portfolio Manager is an online tool that you can use to measure and track energy and water consumption, as well as greenhouse gas emissions⁷. Your account has already been established. Now you can continue to keep tabs on your energy performance every month.

Weatherization

Caulk or weather strip leaky doors and windows to reduce drafts and loss of heated or cooled air. Sealing cracks and openings can reduce heating and cooling costs, improve building durability, and create a healthier indoor environment. Materials used may include caulk, polyurethane foam, and other weather-stripping materials. There is an energy savings opportunity by reducing the uncontrolled air exchange between the outside and inside of the building. Blower door assisted comprehensive building air sealing will reduce the amount of air exchange, which will in turn reduce the load on the buildings heating and cooling equipment, providing energy savings and increased occupant comfort.

Lighting Maintenance



- Clean lamps, reflectors and lenses of dirt, dust, oil, and smoke buildup every six to twelve months. Light levels decrease over time due to lamp aging, lamp and ballast failure, and buildup of dirt and dust. Together, this can reduce total light output by up to 60% while still drawing full power.
- In addition to routine cleaning, developing a maintenance schedule can ensure that maintenance is performed regularly, and it can reduce the overall cost of fixture re-lamping and re-ballasting. Group re-lamping and re-ballasting maintains lighting levels and minimizes the number of site visits by a lighting technician or contractor, decreasing the overall cost of maintenance.

⁷ <https://www.energystar.gov/buildings/facility-owners-and-managers/existing-buildings/use-portfolio-manager>.

Lighting Controls

As part of a lighting maintenance schedule, test lighting controls to ensure proper functioning. For occupancy sensors, this requires triggering the sensor and verifying that the sensor's timer settings are correct. For daylight and photocell sensors, maintenance involves cleaning sensor lenses and confirming that setpoints and sensitivity are configured properly. Adjust exterior lighting time clock controls seasonally as needed to match your lighting requirements.


Motor Maintenance

Motors have many moving parts. As these parts degrade over time, the efficiency of the motor is reduced. Routine maintenance prevents damage to motor components. Routine maintenance should include cleaning surfaces and ventilation openings on motors to prevent overheating, lubricating moving parts to reduce friction, inspecting belts and pulleys for wear and to ensure they are at proper alignment and tension, and cleaning and lubricating bearings. Consult a licensed technician to assess these and other motor maintenance strategies.

Fans to Reduce Cooling Load

Install ceiling fans to supplement your cooling system. Thermostat settings can typically be increased by 4°F with no change in overall occupant comfort due to the wind chill effect of moving air.

Thermostat Schedules and Temperature Resets



Use thermostat setback temperatures and schedules to reduce heating and cooling energy use during periods of low or no occupancy. Thermostats should be programmed for a setback of 5-10°F during low occupancy hours (reduce heating setpoints and increase cooling setpoints). Cooling load can be reduced by increasing the facility's occupied setpoint temperature. In general, during the cooling season, thermostats should be set as high as possible without sacrificing occupant comfort.

Economizer Maintenance

Economizers can significantly reduce cooling system load. A malfunctioning economizer can increase the amount of heating and mechanical cooling required by introducing excess amounts of cold or hot outside air. Common economizer malfunctions include broken outdoor thermostat or enthalpy control or dampers that are stuck or improperly adjusted.

Periodic inspection and maintenance will keep economizers working in sync with the heating and cooling system. This maintenance should be part of annual system maintenance, and it should include proper setting of the outdoor thermostat/enthalpy control, inspection of control and damper operation, lubrication of damper connections, and adjustment of minimum damper position.

AC System Evaporator/Condenser Coil Cleaning

Dirty evaporator and condenser coils restrict air flow and restrict heat transfer. This increases the loads on the evaporator and condenser fan and decreases overall cooling system performance. Keeping the coils clean allows the fans and cooling system to operate more efficiently.

HVAC Filter Cleaning and Replacement

Air filters should be checked regularly (often monthly) and cleaned or replaced when appropriate. Air filters reduce indoor air pollution, increase occupant comfort, and help keep equipment operating

efficiently. If the building has a building management system, consider installing a differential pressure switch across filters to send an alarm about premature fouling or overdue filter replacement. Over time, filters become less and less effective as particulate buildup increases. Dirty filters also restrict air flow through the air conditioning or heat pump system, which increases the load on the distribution fans.

Ductwork Maintenance

Duct maintenance has two primary goals: keep the ducts clean to avoid air quality problems and seal leaks to save energy. Check for cleanliness, obstructions that block airflow, water damage, and leaks. Ducts should be inspected at least every two years.

The biggest symptoms of clogged air ducts are differing temperatures throughout the building and areas with limited airflow from supply registers. If a particular air duct is clogged, then air flow will only be cut off to some rooms in the building—not all of them. The reduced airflow will make it more difficult for those areas to reach the temperature setpoint, which will cause the HVAC system to run longer to cool or heat that area properly. If you suspect clogged air ducts, ensure that all areas in front of supply registers are clear of items that may block or restrict air flow, and you should check for fire dampers or balancing dampers that have failed closed.

Duct leakage in commercial buildings can account for 5%–25% of the supply airflow. In the case of rooftop air handlers, duct leakage can occur to the outside of the building wasting conditioned air. Check ductwork for leakage. Eliminating duct leaks can improve ventilation system performance and reduce heating and cooling system operation.

Distribution system losses are dependent on-air system temperature, the size of the distribution system, and the level of insulation of the ductwork. Significant energy savings can be achieved when insulation has not been well maintained. When the insulation is missing or worn, the system efficiency can be significantly reduced. This measure saves energy by reducing heat transfer in the distribution system.

Boiler Maintenance

Many boiler problems develop slowly over time, so regular inspection and maintenance is essential to keeping the heating system running efficiently and preventing expensive repairs. Annual tune-ups should include a combustion analysis to analyze the exhaust from the boilers and to ensure the boiler is operating safely and efficiently. Boilers should be cleaned according to the manufacturer's instructions to remove soot and scale from the boiler tubes to improve heat transfer.

Furnace Maintenance

Preventative maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. Following the manufacturer's instructions, a yearly tune-up should check for gas / carbon monoxide leaks; change the air and fuel filters; check components for cracks, corrosion, dirt, or debris build-up; ensure the ignition system is working properly; test and adjust operation and safety controls; inspect electrical connections; and lubricate motors and bearings.

Label HVAC Equipment

For improved coordination in maintenance practices, we recommend labeling or re-labeling the site HVAC equipment. Maintain continuity in labeling by following labeling conventions as indicated in the facility drawings or BAS building equipment list. Use weatherproof or heatproof labeling or stickers for permanence, but do not cover over original equipment nameplates, which should be kept clean and readable whenever possible. Besides equipment, label piping for service and direction of flow when

possible. Ideally, maintain a log of HVAC equipment, including nameplate information, asset tag designation, areas served, installation year, service dates, and other pertinent information.

This investment in your equipment will enhance collaboration and communication between your staff and your contracted service providers and may help you with regulatory compliance.

Optimize HVAC Equipment Schedules

Energy management systems (BAS) typically provide advanced controls for building HVAC systems, including chillers, boilers, air handling units, rooftop units and exhaust fans. The BAS monitors and reports operational status, schedules equipment start and stop times, locks out equipment operation based on outside air or space temperature, and often optimizes damper and valve operation based on complex algorithms. These BAS features, when in proper adjustment, can improve comfort for building occupants and save substantial energy.

Know your BAS scheduling capabilities. Regularly monitor HVAC equipment operating schedules and match them to building operating hours in order to eliminate unnecessary equipment operation and save energy. Monitoring should be performed often at sites with frequently changing usage patterns – daily in some cases. We recommend using the *optimal start* feature of the BAS (if available) to optimize the building warmup sequence. Most BAS scheduling programs provide for holiday schedules, which can be used during reduced use or shutdown periods. Finally, many systems are equipped with a one-time override function, which can be used to provide additional space conditioning due to a one-time, special event. When available this override feature should be used rather than changing the base operating schedule.

Water Heater Maintenance

The lower the supply water temperature that is used for hand washing sinks, the less energy is needed to heat the water. Reducing the temperature results in energy savings and the change is often unnoticeable to users. Be sure to review the domestic water temperature requirements for sterilizers and dishwashers as you investigate reducing the supply water temperature.

Also, preventative maintenance can extend the life of the system, maintain energy efficiency, and ensure safe operation. At least once a year, follow manufacturer instructions to drain a few gallons out of the water heater using the drain valve. If there is a lot of sediment or debris, then a full flush is recommended. Turn the temperature down and then completely drain the tank. Annual checks should include checks for:

- Leaks or heavy corrosion on the pipes and valves.
- Corrosion or wear on the gas line and on the piping. If you noticed any black residue, soot, or charred metal, this is a sign you may be having combustion issues and you should have the unit serviced by a professional.
- For electric water heaters, look for signs of leaking such as rust streaks or residue around the upper and lower panels covering the electrical components on the tank.
- For water heaters more than three years old, have a technician inspect the sacrificial anode annually.

Refrigeration Equipment Maintenance

Preventative maintenance keeps commercial refrigeration equipment running reliably and efficiently. Commercial refrigerators and freezers are mission-critical equipment that can cost a fortune when they go down. Even when they appear to be working properly, refrigeration units can be consuming too much

energy. Have walk-in refrigeration and freezer and other commercial systems serviced at least annually. This practice will allow systems to perform to their highest capabilities and will help identify system issues if they exist.

Maintaining your commercial refrigeration equipment can save between 5% and 10% on energy costs. When condenser coils are dirty, your commercial refrigerators and freezers work harder to maintain the temperature inside. Worn gaskets, hinges, door handles or faulty seals cause cold air to leak from the unit, forcing the unit to run longer and use more electricity.

Regular cleaning and maintenance also help your commercial refrigeration equipment to last longer.

Water Conservation



Installing dual flush or low-flow toilets and low-flow/waterless urinals are ways to reduce water use. The EPA WaterSense® ratings for urinals is 0.5 gallons per flush (gpf) and for flush valve toilets is 1.28 gpf (this is lower than the current 1.6 gpf federal standard).

For more information regarding water conservation go to the EPA's WaterSense website⁸ or download a copy of EPA's "WaterSense at Work: Best Management Practices for Commercial and Institutional Facilities"⁹ to get ideas for creating a water management plan and best practices for a wide range of water using systems.

Water conservation devices that do not reduce hot water consumption will not provide energy savings at the site level, but they may significantly affect your water and sewer usage costs. Any reduction in water use does however ultimately reduce grid-level electricity use since a significant amount of electricity is used to deliver water from reservoirs to end users.

If the facility has detached buildings with a master water meter for the entire campus, check for unnatural wet areas in the lawn or water seeping in the foundation at water pipe penetrations through the foundation. Periodically check overnight meter readings when the facility is unoccupied, and there is no other scheduled water usage.

Manage irrigation systems to use water more effectively outside the building. Adjust spray patterns so that water lands on intended lawns and plantings and not on pavement and walls. Consider installing an evapotranspiration irrigation controller that will prevent over-watering.

Procurement Strategies

Purchasing efficient products reduces energy costs without compromising quality. Consider modifying your procurement policies and language to require ENERGY STAR or WaterSense products where available.

⁸ <https://www.epa.gov/watersense>.

⁹ <https://www.epa.gov/watersense/watersense-work-0>.

6 ON-SITE GENERATION

You don't have to look far in New Jersey to see one of the thousands of solar electric systems providing clean power to homes, businesses, schools, and government buildings. On-site generation includes both renewable (e.g., solar, wind) and non-renewable (e.g., fuel cells) technologies that generate power to meet all or a portion of the facility's electric energy needs. Also referred to as distributed generation, these systems contribute to greenhouse gas (GHG) emission reductions, demand reductions, and reduced customer electricity purchases, which results in improved electric grid reliability through better use of transmission and distribution systems.

Preliminary screenings were performed to determine if an on-site generation measure could be a cost-effective solution for your facility. Before deciding to install an on-site generation system, we recommend conducting a feasibility study to analyze existing energy profiles, siting, interconnection, and the costs associated with the generation project including interconnection costs, departing load charges, and any additional special facilities charges.

6.2 Solar Photovoltaic

Photovoltaic (PV) panels convert sunlight into electricity. Individual panels are combined into an array that produces direct current (DC) electricity. The DC current is converted to alternating current (AC) through an inverter. The inverter is then connected to the building's electrical distribution system.

A preliminary screening based on the facility's electric demand, size and location of free area, and shading elements shows that the facility has medium potential for installing a PV array.

The amount of free area, ease of installation (location), and the lack of shading elements contribute to the medium potential. A PV array located on the roof may be feasible. If you are interested in pursuing the installation of PV, we recommend conducting a full feasibility study.

The graphic below displays the results of the PV potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.




Figure 8 - Photovoltaic Screening

Successor Solar Incentive Program (SuSI)

The SuSI program replaces the SREC Registration Program (SRP) and the Transition Incentive (TI) program. The SuSI program is used to register and certify solar projects in New Jersey. Rebates are not available for solar projects. Solar projects may qualify to earn SREC- IIs (Solar Renewable Energy Certificates-II), however, the project owners *must* register their solar projects prior to the start of construction to establish the project's eligibility.

Get more information about solar power in New Jersey or find a qualified solar installer who can help you decide if solar is right for your building:

Successor Solar Incentive Program (SuSI): <https://www.njcleanenergy.com/renewable-energy/programs/susi-program>

- **Basic Info on Solar PV in NJ:** www.njcleanenergy.com/whysolar
- **NJ Solar Market FAQs:** www.njcleanenergy.com/renewable-energy/program-updates-and-background-information/solar-transition/solar-market-faqs.
- **Approved Solar Installers in the NJ Market:** www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/?id=60&start=1

6.4 Combined Heat and Power

Combined heat and power (CHP) generates electricity at the facility and puts waste heat energy to good use. Common types of CHP systems are reciprocating engines, microturbines, fuel cells, backpressure steam turbines, and (at large facilities) gas turbines.

CHP systems typically produce a portion of the electric power used on-site, with the balance of electric power needs supplied by the local utility company. The heat is used to supplement (or replace) existing boilers and provide space heating and/or domestic hot water heating. Waste heat can also be routed through absorption chillers for space cooling.

The key criteria used for screening is the amount of time that the CHP system would operate at full load and the facility's ability to use the recovered heat. Facilities with a continuous need for large quantities of waste heat are the best candidates for CHP.

A preliminary screening based on heating and electrical demand, siting, and interconnection shows that the facility has no potential for installing a cost-effective CHP system.

Based on a preliminary analysis, the facility does not appear to meet the minimum requirements for a cost-effective CHP installation. The low or infrequent thermal load, and lack of space for siting the equipment are the most significant factors contributing to the lack of CHP potential.

The graphic below displays the results of the CHP potential screening conducted as a part of this audit. The position of each slider indicates the potential (potential increases to the right) that each factor contributes to the overall site potential.




Figure 9 - Combined Heat and Power Screening

Find a qualified firm that specializes in commercial CHP cost assessment and installation:
http://www.njcleanenergy.com/commercial-industrial/programs/nj-smartstart-buildings/tools-and-resources/tradeally/approved_vendorsearch/

7 ELECTRIC VEHICLES (EV)

All electric vehicles (EVs) have an electric motor instead of an internal combustion engine. EVs function by plugging into a charge point, taking electricity from the grid, and then storing it in rechargeable batteries. Although electricity production may contribute to air pollution, the U.S. EPA categorizes all-electric vehicles as zero-emission vehicles because they produce no direct exhaust or tailpipe emissions.

EVs are typically more expensive than similar conventional and hybrid vehicles, although some cost can be recovered through fuel savings, federal tax credit, or state incentives.

7.1 Electric Vehicle Charging

EV charging stations provide a means for electric vehicle operators to recharge their batteries at a facility. While many EV drivers charge at home, others do not have access to regular home charging, and the ability to charge at work or in public locations is critical to making EVs practical for more drivers. Charging can also be used for electric fleet vehicles, which can reduce fuel and maintenance costs for fleets that replace gas or diesel vehicles with EVs.

EV charging comes in three main types. For this assessment, the screening considers addition of Level 2 charging, which is most common at workplaces and other public locations. Depending on the site type and usage, other levels of charging power may be more appropriate.

The preliminary assessment of EV charging at the facility shows that there is medium potential for adding EV chargers to the facility's parking, based on potential costs of installation and other site factors.

The primary costs associated with installing EV charging are the charger hardware and the cost to extend power from the facility to parking spaces. This may include upgrades to electric panels to serve increased loads.

The type and size of the parking area impact the costs and feasibility of adding EV charging. Parking structure installations can be less costly than surface lot installations as power may be readily available, and equipment and wiring can be surface mounted. Parking lot installations often require trenching through concrete or asphalt surface. Large parking areas provide greater flexibility in charger siting than smaller lots.

The location and capacity of facility electric panels also impact charger installation costs. A Level 2 charger generally requires a dedicated 208-240V, 40 Amp circuit. The electric panel nearest the planned installation may not have available capacity and may need to be upgraded to serve new EV charging loads. Alternatively, chargers could be powered from a more distant panel. The distance from the panel to the location of charging stations ties directly to costs, as conduits, cables, and potential trenching costs all increase on a per-foot basis. The more charging stations planned, the more likely it is that additional electrical capacity will be needed.

Other factors to consider when planning for EV charging at a facility include who the intended users are, how long they park vehicles at the site, and whether they will need to pay for the electricity they use.



The graphic below displays the results of the EV charging assessment conducted as part of this audit. The position of each slider indicates the impact each factor has on the feasibility of installing EV charging at the site.




Figure 10 – EV Charger Screening

Electric Vehicle Programs Available

New Jersey is leading the way on electric vehicle (EV) adoption on the East Coast. There are several programs designed to encourage EV adoption in New Jersey, which is crucial to reaching a 100% clean energy future.

NJCEP offers a variety of EV programs for vehicles, charging stations, and fleets. Certain EV charging stations that receive electric utility service from Atlantic City Electric Company (ACE) or Public Service Electric & Gas Company (PSE&G), may be eligible for additional electric vehicle charging incentives directly from the utility. Projects may be eligible for both the incentives offered by this BPU program and incentives offered by ACE or PSE&G, up to 90% of the combined charger purchase and installation costs. Please check ACE or PSE&G program eligibility requirements before purchasing EV charging equipment, as additional conditions on types of eligible chargers may apply for utility incentives.

Both Jersey Central Power & Light (JCP&L) and Rockland Electric (RECO) have filed proposals for EV charging programs. BPU staff is currently reviewing those proposals.

For more information and to keep up to date on all EV programs please visit <https://www.njcleanenergy.com/commercial-industrial/programs/electric-vehicle-programs>

8 PROJECT FUNDING AND INCENTIVES

Ready to improve your building's performance? New Jersey's Clean Energy Programs and Utility Energy Efficiency Programs can help. Pick the program that works best for you. This section provides an overview of currently available incentive programs in.



Program areas to be served by the Utilities:

- Existing Buildings (residential, commercial, industrial, government)
- Efficient Products
 - HVAC
 - Appliance Rebates
 - Appliance Recycling

Proposed New Programs & Features:

- Dedicated multi-family program
- More financing options
- Quick home energy check-ups



Program areas staying with NJCEP:

- New Construction (residential, commercial, industrial, government)
- Large Energy Users
- Combined Heat & Power & Fuel Cells
- State Facilities
- Local Government Energy Audits
- Energy Savings Improvement Program
- Solar & Community Solar

8.1 Utility Energy Efficiency Programs

The Clean Energy Act, signed into law by Governor Murphy in 2018, requires New Jersey's investor-owned gas and electric utilities to reduce their customers' use by set percentages over time. To help reach these targets the New Jersey Board of Public Utilities approved a comprehensive suite of energy efficiency programs to be run by the utility companies.

Prescriptive and Custom

The Prescriptive and Custom rebate program through your utility provider offers incentives for installing prescriptive and custom energy efficiency measures at your facility. This program provides an effective mechanism for securing incentives for energy efficiency measures installed individually or as part of a package of energy upgrades. This program serves most common equipment types and sizes.

Equipment Examples

Lighting

Lighting Controls

HVAC Equipment

Refrigeration

Gas Heating

Gas Cooling

Commercial Kitchen Equipment

Food Service Equipment

Variable Frequency Drives

Electronically Commutate Motors

Variable Frequency Drives

Plug Loads Controls

Washers and Dryers

Agricultural

Water Heating

The Prescriptive program provides fixed incentives for specific energy efficiency measures. Prescriptive incentives vary by equipment type. The Custom program provides incentives for more unique or specialized technologies or systems that are not addressed through prescriptive incentives.

Direct Install

Direct Install is a turnkey program available to existing small to medium-sized facilities with an average peak electric demand that does not exceed 200 kW or less over the recent 12-month period. You work directly with a pre-approved contractor who will perform a free energy assessment at your facility, identify specific eligible measures, and provide a clear scope of work for installation of selected measures. Energy efficiency measures may include lighting and lighting controls, refrigeration, HVAC, motors, variable speed drives, and controls

Incentives

The program pays up to 70% of the total installed cost of eligible measures.

How to Participate

To participate in Direct Install, you will work with a participating contractor. The contractor will be paid the measure incentives directly by the program, which will pass on to you in the form of reduced material and implementation costs. This means up to 70% of eligible costs are covered by the Direct Install program, subject to program rules and eligibility, while the remaining percent of the cost is paid to the contractor by the customer.

Engineered Solutions

The Engineered Solutions Program provides tailored energy-efficiency assistance and services to municipalities, universities, schools, hospitals and healthcare facilities (MUSH), non-profit entities, and multifamily buildings. Customers receive expert guided services, including investment-grade energy auditing, engineering design, installation assistance, construction administration, commissioning, and measurement and verification (M&V) services to support the implementation of cost-effective and comprehensive efficiency projects. Engineered Solutions is generally a good option for medium to large sized facilities with a peak demand over 200 kW looking to implement as many measures as possible under a single project to achieve deep energy savings. Engineered Solutions has an added benefit of addressing measures that may not qualify for other programs. Many facilities pursuing an Energy Savings Improvement Program loan also use this program. Incentives for this program are based on project scope and energy savings achieved.

For more information on any of these programs, contact your local utility provider or visit <https://www.njcleanenergy.com/transition>.

8.2 New Jersey's Clean Energy Programs

Save money while saving the planet! New Jersey's Clean Energy Program is a statewide program that offers incentives, programs, and services that benefit New Jersey residents, businesses, educational, non-profit, and government entities to help them save energy, money, and the environment.

Large Energy Users

The Large Energy Users Program (LEUP) is designed to foster self-directed investment in energy projects. This program is offered to New Jersey's largest energy customers that annually contribute at least \$200,000 to the NJCEP aggregate of all buildings/sites. This equates to roughly \$5 million in energy costs in the prior fiscal year.

Incentives

Incentives are based on the specifications below. The maximum incentive per entity is the lesser of:

- \$4 million
- 75% of the total project(s) cost
- 90% of total NJCEP fund contribution in previous year
- \$0.33 per projected kWh saved; \$3.75 per projected Therm saved annually

How to Participate

To participate in LEUP, you will first need submit an enrollment application. This program requires all qualified and approved applicants to submit an energy plan that outlines the proposed energy efficiency work for review and approval. Applicants may submit a Draft Energy Efficiency Plan (DEEP), or a Final Energy Efficiency Plan (FEEP). Once the FEEP is approved, the proposed work can begin.

Detailed program descriptions, instructions for applying, and applications can be found at www.njcleanenergy.com/LEUP.

Combined Heat and Power

The Combined Heat & Power (CHP) program provides incentives for eligible CHP or waste heat to power (WHP) projects. Eligible CHP or WHP projects must achieve an annual system efficiency of at least 65% (lower heating value, or LHV), based on total energy input and total utilized energy output. Mechanical energy may be included in the efficiency evaluation.

Incentives

Eligible Technologies	Size (Installed Rated Capacity) ¹	Incentive (\$/kW)	% of Total Cost Cap per Project ³	\$ Cap per Project ³		
Powered by non-renewable or renewable fuel source ⁴	≤500 kW	\$2,000	30-40% ²	\$2 million		
Gas Internal Combustion Engine	>500 kW - 1 MW	\$1,000				
Gas Combustion Turbine	> 1 MW - 3 MW	\$550	30%	\$3 million		
Microturbine	>3 MW	\$350				
Fuel Cells with Heat Recovery						
Waste Heat to Power*	<1 MW	\$1,000	30%	\$2 million		
	> 1MW	\$500		\$3 million		

*Waste Heat to Power: Powered by non-renewable fuel source, heat recovery or other mechanical recovery from existing equipment utilizing new electric generation equipment (e.g. steam turbine).

Check the NJCEP website for details on program availability, current incentive levels, and requirements.

How to Participate

You will work with a qualified developer or consulting firm to complete the CHP application. Once the application is approved the project can be installed. Information about the CHP program can be found at www.njcleanenergy.com/CHP.

Successor Solar Incentive Program (SuSI)

The SuSI program replaces the SREC Registration Program (SRP) and the Transition Incentive (TI) program. The program is used to register and certify solar projects in New Jersey. Rebates are not available for solar projects, but owners of solar projects *must* register their projects prior to the start of construction to establish the project's eligibility to earn SREC-IIs (Solar Renewable Energy Certificates-II). SuSI consists of two sub-programs. The Administratively Determined Incentive (ADI) Program and the Competitive Solar Incentive (CSI) Program.

Administratively Determined Incentive (ADI) Program

The ADI Program provides administratively set incentives for net metered residential projects, net metered non-residential projects 5 MW or less, and all community solar projects.

After the registration is accepted, construction is complete, and a complete final as-built packet has been submitted, the project is issued a New Jersey certification number, which enables it to generate New Jersey SREC- IIs.

Market Segments	Size MW dc	Incentive Value (\$/SREC II)	Public Entities Incentive Value - \$20 Adder (\$/SRECII)
Net Metered Residential	All types and sizes	\$90	N/A
Small Net Metered Non-Residential located on Rooftop, Carport, Canopy and Floating Solar	Projects smaller than 1 MW	\$100	\$120
Large Net Metered Non-Residential located on Rooftop, Carport, Canopy and Floating Solar	Projects 1 MW to 5 MW	\$90	\$110
Small Net Metered Non-Residential Ground Mount	Projects smaller than 1 MW	\$85	\$105
Large Net Metered Non-Residential Ground Mount	Projects 1 MW to 5 MW	\$80	\$100
LMI Community Solar	Up to 5 MW	\$90	N/A
Non-LMI Community Solar	Up to 5 MW	\$70	N/A
Interim Subsection (t)	All types and sizes	\$100	N/A

Eligible projects may generate SREC-IIs for 15 years following the commencement of commercial operations which is defined as permission to operate (PTO) from the Electric Distribution Company. After 15 years, projects may be eligible for a NJ Class I REC.

SREC-IIs will be purchased monthly by the SREC-II Program Administrator who will allocate the SREC-IIs to the Load Serving Entities (BGS Providers and Third-Party Suppliers) annually based on their market share of retail electricity sold during the relevant Energy Year.

The ADI Program online portal is now open to new registrations.

Competitive Solar Incentive Program

The Competitive Solar Incentive (CSI) Program will provide competitively set incentives for grid supply projects and net metered non-residential projects greater than 5MW (dc). The program is currently under development. For updates, please continue to check the [Solar Proceedings](#) page on the New Jersey's Clean Energy Program website.

Solar projects help the State of New Jersey reach renewable energy goals outlined in the state's Energy Master Plan.

If you are considering installing solar photovoltaics on your building, visit the following link for more information: <https://njcleanenergy.com/renewable-energy/programs/susi-program>.

Energy Savings Improvement Program

The Energy Savings Improvement Program (ESIP) serves New Jersey's government agencies by financing energy projects. An ESIP is a type of performance contract, whereby school districts, counties, municipalities, housing authorities, and other public and state entities enter into contracts to help finance building energy upgrades. Annual payments are lower than the savings projected from the energy conservation measures (ECMs), ensuring that ESIP projects are cash flow positive for the life of the contract.

ESIP provides government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. NJCEP incentive programs described above can also be used to help further reduce the total project cost of eligible measures.

How to Participate

This LGEA report is the first step to participating in ESIP. Next, you will need to select an approach for implementing the desired ECMs:

- (1) Use an energy services company or "ESCO."
- (2) Use independent engineers and other specialists, or your own qualified staff, to provide and manage the requirements of the program through bonds or lease obligations.
- (3) Use a hybrid approach of the two options described above where the ESCO is used for some services and independent engineers, or other specialists or qualified staff, are used to deliver other requirements of the program.

After adopting a resolution with a chosen implementation approach, the development of the energy savings plan can begin. The ESP demonstrates that the total project costs of the ECMs are offset by the energy savings over the financing term, not to exceed 15 years. The verified savings will then be used to pay for the financing.

The ESIP approach may not be appropriate for all energy conservation and energy efficiency improvements. Carefully consider all alternatives to develop an approach that best meets your needs. A detailed program descriptions and application can be found at www.njcleanenergy.com/ESIP.

ESIP is a program delivered directly by the NJBPU and is not an NJCEP incentive program. As mentioned above, you can use NJCEP incentive programs to help further reduce costs when developing the energy savings plan. Refer to the ESIP guidelines at the link above for further information and guidance on next steps.

9 PROJECT DEVELOPMENT

Energy conservation measures (ECMs) have been identified for your site, and their energy and economic analyses are provided within this LGEA report. Note that some of the identified projects may be mutually exclusive, such as replacing equipment versus upgrading motors or controls. The next steps with project development are to set goals and create a comprehensive project plan. The graphic below provides an overview of the process flow for a typical energy efficiency or renewable energy project. We recommend implementing as many ECMs as possible prior to undertaking a feasibility study for a renewable project. The cyclical nature of this process flow demonstrates the ongoing work required to continually improve building energy efficiency over time. If your building(s) scope of work is relatively simple to implement or small in scope, the measurement and verification (M&V) step may not be required. It should be noted through a typical project cycle, there will be changes in costs based on specific scopes of work, contractor selections, design considerations, construction, etc. The estimated costs provided throughout this LGEA report demonstrate the unburdened turn-key material and labor cost only. There will be contingencies and additional costs at the time of implementation. We recommend comprehensive project planning that includes the review of multiple bids for project work, incorporates potential operations and maintenance (O&M) cost savings, and maximizes your incentive potential.




Figure 11 – Project Development Cycle

10 ENERGY PURCHASING AND PROCUREMENT STRATEGIES

10.1 Retail Electric Supply Options

Energy deregulation in New Jersey has increased energy buyers' options by separating the function of electricity distribution from that of electricity supply. Though you may choose a different company from which to buy your electric power, responsibility for your facility's interconnection to the grid and repair to local power distribution will still reside with the traditional utility company serving your region.

If your facility is not purchasing electricity from a third-party supplier, consider shopping for a reduced rate from third-party electric suppliers. If your facility already buys electricity from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party electric suppliers is available at the NJBPU website¹⁰.

10.2 Retail Natural Gas Supply Options

The natural gas market in New Jersey is also deregulated. Most customers that remain with the utility for natural gas service pay rates that are market based and fluctuate monthly. The utility provides basic gas supply service to customers who choose not to buy from a third-party supplier for natural gas commodity.

A customer's decision about whether to buy natural gas from a retail supplier typically depends on whether a customer prefers budget certainty and/or longer-term rate stability. Customers can secure longer-term fixed prices by signing up for service through a third-party retail natural gas supplier. Many larger natural gas customers may seek the assistance of a professional consultant to assist in their procurement process.

If your facility does not already purchase natural gas from a third-party supplier, consider shopping for a reduced rate from third-party natural gas suppliers. If your facility already purchases natural gas from a third-party supplier, review and compare prices at the end of each contract year.

A list of licensed third-party natural gas suppliers is available at the NJBPU website¹¹.

¹⁰ www.state.nj.us/bpu/commercial/shopping.html.

¹¹ www.state.nj.us/bpu/commercial/shopping.html.



APPENDIX A: EQUIPMENT INVENTORY & RECOMMENDATIONS

Lighting Inventory & Recommendations

Existing Conditions							Proposed Conditions							Energy Impact & Financial Analysis							
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
2nd Floor Girls Bath	3	LED - Fixtures: Ambient 2x4 Fixture	Wall Switch	S	34	3,270	3	None	Yes	3	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	34	2,256	0.0	114	0	\$14	\$270	\$35	16.9
2nd floor Mens Bath	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270		None	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	50	3,270	0.0	0	0	\$0	\$0	\$0	0.0
3rd Floor Landing	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	3,270	4	None	Yes	1	LED Lamps: (1) 10W A19 Screw-In Lamp	High/Low Control	10	2,256	0.0	11	0	\$1	\$0	\$0	0.0
3rd Floor Landing	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	58	3,270	4	None	Yes	1	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	58	2,256	0.0	65	0	\$8	\$225	\$35	24.1
Back staircase to parking lot	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,270	4	None	Yes	2	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	25	2,256	0.0	56	0	\$7	\$0	\$0	0.0
Back staircase to parking lot	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	4	None	Yes	2	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	50	2,256	0.0	112	0	\$14	\$225	\$70	11.4
Bathroom in Class 5	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	3,270		None	No	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	3,270	0.0	0	0	\$0	\$0	\$0	0.0
Bathroom in Class 6	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	3,270		None	No	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	3,270	0.0	0	0	\$0	\$0	\$0	0.0
Bathroom in Class 7	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	3,270		None	No	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	3,270	0.0	0	0	\$0	\$0	\$0	0.0
Boiler Room	1	LED Lamps: (1) 45W High Ouput A Screw-In Lamp	Wall Switch	S	10	1,000		None	No	1	LED Lamps: (1) 45W High Ouput A Screw-In Lamp	Wall Switch	10	1,000	0.0	0	0	\$0	\$0	\$0	0.0
Boiler Room	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	1,000		None	No	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	1,000	0.0	0	0	\$0	\$0	\$0	0.0
Cafeteria	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Cafeteria	2	LED - Fixtures: Ambient 2x4 Fixture	Wall Switch	S	34	3,270		None	No	2	LED - Fixtures: Ambient 2x4 Fixture	Wall Switch	34	3,270	0.0	0	0	\$0	\$0	\$0	0.0
Cafeteria	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,270		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	3,270	0.0	0	0	\$0	\$0	\$0	0.0
Cafeteria	12	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	669	0	\$82	\$270	\$35	2.9
Cafeteria Pantry	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,100		None	No	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Cafeteria Pantry	1	LED Lamps: (1) 30W Corn Bulb Screw-In Lamp	Wall Switch	S	30	1,100		None	No	1	LED Lamps: (1) 30W Corn Bulb Screw-In Lamp	Wall Switch	30	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Cafeteria Supply Storage 2	3	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	S	9	1,100		None	No	3	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	9	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Classroom 10	9	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	9	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	502	0	\$61	\$270	\$35	3.8
Classroom 11	9	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	9	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	502	0	\$61	\$270	\$35	3.8
Classroom 12	9	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	9	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	502	0	\$61	\$270	\$35	3.8
Classroom 14 music	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Classroom 14 music	20	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	S	38	3,270	3	None	Yes	20	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	38	2,256	0.2	847	0	\$103	\$540	\$70	4.5
Classroom 15	6	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	S	38	3,270	3	None	Yes	6	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	38	2,256	0.1	254	0	\$31	\$270	\$35	7.6
Classroom 16	12	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	669	0	\$82	\$270	\$35	2.9

Existing Conditions							Proposed Conditions							Energy Impact & Financial Analysis							
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Classroom 18	12	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	669	0	\$82	\$270	\$35	2.9
Classroom 2	6	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	6	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	335	0	\$41	\$270	\$35	5.8
Classroom 20	9	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	9	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	502	0	\$61	\$270	\$35	3.8
Classroom 201	9	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	9	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	502	0	\$61	\$270	\$35	3.8
Classroom 202	12	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	669	0	\$82	\$270	\$35	2.9
Classroom 203	9	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	9	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	502	0	\$61	\$270	\$35	3.8
Classroom 204	9	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	9	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	502	0	\$61	\$270	\$35	3.8
Classroom 205	3	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	3	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.0	167	0	\$20	\$270	\$35	11.5
Classroom 22	18	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,270	3	None	Yes	18	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	25	2,256	0.1	502	0	\$61	\$540	\$70	7.7
Classroom 3	8	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	8	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	446	0	\$54	\$270	\$35	4.3
Classroom 301	7	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	7	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	390	0	\$48	\$270	\$35	4.9
Classroom 302	7	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	7	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	390	0	\$48	\$270	\$35	4.9
Classroom 303	7	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	7	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	390	0	\$48	\$270	\$35	4.9
Classroom 304	10	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	10	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	558	0	\$68	\$270	\$35	3.5
Classroom 4	21	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	21	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.2	1,171	0	\$143	\$540	\$70	3.3
Classroom 5	5	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,270	3	None	Yes	5	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	25	2,256	0.0	139	0	\$17	\$0	\$0	0.0
Classroom 5	12	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	669	0	\$82	\$270	\$35	2.9
Classroom 6	5	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,270	3	None	Yes	5	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	25	2,256	0.0	139	0	\$17	\$0	\$0	0.0
Classroom 6	12	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	669	0	\$82	\$270	\$35	2.9
Classroom 7	5	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,270	3	None	Yes	5	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	25	2,256	0.0	139	0	\$17	\$0	\$0	0.0
Classroom 7	12	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	669	0	\$82	\$270	\$35	2.9
Classroom 8	17	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	17	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.2	948	0	\$116	\$540	\$70	4.1
Classroom 9	12	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	12	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	669	0	\$82	\$270	\$35	2.9
Corridor 1st & 2nd SGI	4	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	4	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Corridor 1st & 2nd SGI	21	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	4	None	Yes	21	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	50	2,256	0.2	1,171	0	\$143	\$900	\$735	1.2

Existing Conditions							Proposed Conditions							Energy Impact & Financial Analysis							
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Corridor 3rd Floor	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Corridor 3rd Floor	1	LED - Fixtures: Ambient 2x4 Fixture	Wall Switch	S	34	3,850	4	None	Yes	1	LED - Fixtures: Ambient 2x4 Fixture	High/Low Control	34	2,657	0.0	45	0	\$5	\$0	\$0	0.0
Corridor 3rd Floor	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,850	4	None	Yes	2	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	50	2,657	0.0	131	0	\$16	\$225	\$70	9.7
Corridor First Floor	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Corridor First Floor	3	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,850	4	None	Yes	3	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	50	2,657	0.0	197	0	\$24	\$225	\$105	5.0
Corridor First Floor	1	LED - Linear Tubes: (3) 2' Lamps	Wall Switch	S	17	3,850	4	None	Yes	1	LED - Linear Tubes: (3) 2' Lamps	High/Low Control	17	2,657	0.0	22	0	\$3	\$0	\$0	0.0
Corridor Gym Area	3	LED - Fixtures: Ambient 2x4 Fixture	Wall Switch	S	34	3,850	4	None	Yes	3	LED - Fixtures: Ambient 2x4 Fixture	High/Low Control	34	2,657	0.0	134	0	\$16	\$225	\$105	7.3
Corridor Gym Area	9	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,850	4	None	Yes	9	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	50	2,657	0.1	591	0	\$72	\$450	\$315	1.9
Corridor Main office	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Corridor Main office	4	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	3,850	4	None	Yes	4	LED Lamps: (1) 10W A19 Screw-In Lamp	High/Low Control	10	2,657	0.0	53	0	\$6	\$225	\$140	13.3
Corridor Main office	6	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,850	4	None	Yes	6	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	25	2,657	0.0	197	0	\$24	\$225	\$210	0.6
Corridor Main office	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,850	4	None	Yes	2	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	50	2,657	0.0	131	0	\$16	\$0	\$0	0.0
Corridor second floor	3	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	3	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Corridor second floor	1	LED - Fixtures: Ambient 2x4 Fixture	Wall Switch	S	34	3,850	4	None	Yes	1	LED - Fixtures: Ambient 2x4 Fixture	High/Low Control	34	2,657	0.0	45	0	\$5	\$0	\$0	0.0
Corridor second floor	6	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,850	4	None	Yes	6	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	50	2,657	0.1	394	0	\$48	\$225	\$210	0.3
Custodial storage 1	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	1,100		None	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Electrical Room 1	2	LED Lamps: (1) 30W Corn Bulb Screw-In Lamp	Wall Switch	S	30	1,000		None	No	2	LED Lamps: (1) 30W Corn Bulb Screw-In Lamp	Wall Switch	30	1,000	0.0	0	0	\$0	\$0	\$0	0.0
Electrical Room 1	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	1,000		None	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	1,000	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Doors	3	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch		10	3,850		None	No	3	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	3,850	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Doors	1	LED Lamps: (1) 30W Corn Bulb Screw-In Lamp	Wall Switch		30	3,850		None	No	1	LED Lamps: (1) 30W Corn Bulb Screw-In Lamp	Wall Switch	30	3,850	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Flood Lamps	4	LED Lamps: (1) 18W PAR38 Screw-In Lamp	Wall Switch		18	990		None	No	4	LED Lamps: (1) 18W PAR38 Screw-In Lamp	Wall Switch	18	990	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Front Entrance	3	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch		10	3,850		None	No	3	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	3,850	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Front Entrance	1	LED - Fixtures: Flood Fixture	Timedclock		20	990		None	No	1	LED - Fixtures: Flood Fixture	Timedclock	20	990	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Parking Lot	4	LED - Fixtures: Outdoor Pole/Arm-Mounted Area/Roadway Fixture	Timedclock		175	900		None	No	4	LED - Fixtures: Outdoor Pole/Arm-Mounted Area/Roadway Fixture	Timedclock	175	900	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Soffit	3	LED Lamps: (1) 18W PAR38 Screw-In Lamp	Wall Switch		18	1,000		None	No	3	LED Lamps: (1) 18W PAR38 Screw-In Lamp	Wall Switch	18	1,000	0.0	0	0	\$0	\$0	\$0	0.0

Existing Conditions							Proposed Conditions							Energy Impact & Financial Analysis							
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Exterior Wallpacks	7	LED - Fixtures: Flood Fixture	Photocell		52	4,380		None	No	7	LED - Fixtures: Flood Fixture	Photocell	52	4,380	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Wallpacks	2	LED - Fixtures: Wall Pack	Timedclock		150	990		None	No	2	LED - Fixtures: Wall Pack	Timedclock	150	990	0.0	0	0	\$0	\$0	\$0	0.0
Exterior Wallpacks	2	Metal Halide: (1) 150W Lamp	Timedclock		190	3,850	1	Fixture Replacement	No	2	LED - Fixtures: Outdoor Wall-Mounted Area Fixture	Timedclock	45	3,850	0.0	1,117	0	\$139	\$692	\$100	4.3
Front staircase	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,850	4	None	Yes	2	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	25	2,657	0.0	66	0	\$8	\$0	\$0	0.0
Front staircase	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,850	4	None	Yes	2	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	50	2,657	0.0	131	0	\$16	\$225	\$70	9.7
Garage 1	2	Compact Fluorescent: (1) 32W A19 Screw-In Lamp	Wall Switch	S	32	3,270	2	Relamp	No	2	LED Lamps: LED Lamp	Wall Switch	21	3,270	0.0	79	0	\$10	\$34	\$2	3.4
Guidance classroom	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	3,270		None	No	1	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	3,270	0.0	0	0	\$0	\$0	\$0	0.0
Guidance classroom	1	LED - Fixtures: Downlight Surface Mount	Wall Switch	S	10	3,270		None	No	1	LED - Fixtures: Downlight Surface Mount	Wall Switch	10	3,270	0.0	0	0	\$0	\$0	\$0	0.0
Gymnasium 1	4	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	4	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Gymnasium 1	12	LED - Linear Tubes: (6) 4' Lamps	Wall Switch	S	150	3,850	3	None	Yes	12	LED - Linear Tubes: (6) 4' Lamps	Occupancy Sensor	150	2,657	0.4	2,363	0	\$288	\$540	\$70	1.6
Gymnasium Office	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,270	3	None	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	25	2,256	0.0	56	0	\$7	\$116	\$20	14.1
Gymnasium Stage	3	LED Lamps: (1) 18W PAR38 Screw-In Lamp	Wall Switch	S	18	3,270		None	No	3	LED Lamps: (1) 18W PAR38 Screw-In Lamp	Wall Switch	18	3,270	0.0	0	0	\$0	\$0	\$0	0.0
Head Custodial Office	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	2,695	3	None	Yes	2	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	25	1,860	0.0	46	0	\$6	\$116	\$20	17.1
Head Custodial Office	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	2,695	3	None	Yes	1	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	1,860	0.0	46	0	\$6	\$0	\$0	0.0
Instrumental lesson Room	2	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	S	38	3,270	3	None	Yes	2	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	38	2,256	0.0	85	0	\$10	\$116	\$20	9.3
Instrumental lesson Room	2	LED - Linear Tubes: (2) 2' Lamps	Wall Switch	S	9	3,270	3	None	Yes	2	LED - Linear Tubes: (2) 2' Lamps	Occupancy Sensor	9	2,256	0.0	19	0	\$2	\$0	\$0	0.0
Kitchen 1	2	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	3,850		None	No	2	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	3,850	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen 1	5	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,850		None	No	5	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	50	3,850	0.0	0	0	\$0	\$0	\$0	0.0
Laminated Room	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	1,000		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	1,000	0.0	0	0	\$0	\$0	\$0	0.0
Library 1	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Library 1	38	LED - Fixtures: Ambient 2x4 Fixture	Wall Switch	S	34	3,270	3	None	Yes	38	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	34	2,256	0.3	1,441	0	\$176	\$810	\$105	4.0
Library 1	22	LED Lamps: (2) 15.5W Plug-In Lamps	Wall Switch	S	31	3,270	3	None	Yes	22	LED Lamps: (2) 15.5W Plug-In Lamps	Occupancy Sensor	31	2,256	0.2	760	0	\$93	\$540	\$70	5.1
Lower Boys Bathroom	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,270	3	None	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	25	2,256	0.0	84	0	\$10	\$270	\$35	23.0
Lower Faculty Bath (2)	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,270		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	3,270	0.0	0	0	\$0	\$0	\$0	0.0
Lower Girls Bathroom (1)	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,270	3	None	Yes	3	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	25	2,256	0.0	84	0	\$10	\$270	\$35	23.0

Existing Conditions							Proposed Conditions							Energy Impact & Financial Analysis							
Location	Fixture Quantity	Fixture Description	Control System	Light Level	Watts per Fixture	Annual Operating Hours	ECM #	Fixture Recommendation	Add Controls?	Fixture Quantity	Fixture Description	Control System	Watts per Fixture	Annual Operating Hours	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Lower Mens Bath	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,270		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	3,270	0.0	0	0	\$0	\$0	\$0	0.0
Lower Womens Bath (1)	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,270		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	3,270	0.0	0	0	\$0	\$0	\$0	0.0
Main Entrance Foyer	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,850		None	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	50	3,850	0.0	0	0	\$0	\$0	\$0	0.0
Main office	10	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,270	3	None	Yes	10	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	25	2,256	0.1	279	0	\$34	\$270	\$35	6.9
Nurses Office	4	LED - Linear Tubes: (3) 4' Lamps	Wall Switch	S	38	3,270	3	None	Yes	4	LED - Linear Tubes: (3) 4' Lamps	Occupancy Sensor	38	2,256	0.0	169	0	\$21	\$270	\$35	11.4
Nurses Office	1	LED - Linear Tubes: (4) 2' Lamps	Wall Switch	S	34	3,270	3	None	Yes	1	LED - Linear Tubes: (4) 2' Lamps	Occupancy Sensor	34	2,256	0.0	38	0	\$5	\$0	\$0	0.0
Office in Library	4	LED - Fixtures: Ambient 2x4 Fixture	Wall Switch	S	34	3,270	3	None	Yes	4	LED - Fixtures: Ambient 2x4 Fixture	Occupancy Sensor	34	2,256	0.0	152	0	\$18	\$116	\$20	5.2
Principals Office	4	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,270	3	None	Yes	4	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	25	2,256	0.0	112	0	\$14	\$116	\$20	7.1
PTO Closet	2	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	S	10	1,100		None	No	2	LED Lamps: (1) 10W A19 Screw-In Lamp	Wall Switch	10	1,100	0.0	0	0	\$0	\$0	\$0	0.0
PTO Closet	2	LED - Fixtures: Ambient - 4' - Direct Fixture	Wall Switch	S	34	1,100		None	No	2	LED - Fixtures: Ambient - 4' - Direct Fixture	Wall Switch	34	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Rear staircase	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,850	4	None	Yes	2	LED - Linear Tubes: (2) 4' Lamps	High/Low Control	25	2,657	0.0	66	0	\$8	\$0	\$0	0.0
Rear staircase	2	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,850	4	None	Yes	2	LED - Linear Tubes: (4) 4' Lamps	High/Low Control	50	2,657	0.0	131	0	\$16	\$225	\$70	9.7
Restroom Nurses office	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,270		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	3,270	0.0	0	0	\$0	\$0	\$0	0.0
SGL	1	Compact Fluorescent: (1) 26W A19 Screw-In Lamp	Wall Switch	S	26	3,270	2	Relamp	No	1	LED Lamps: LED Lamp	Wall Switch	18	3,270	0.0	29	0	\$4	\$17	\$1	4.6
SGL	8	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,270	3	None	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	25	2,256	0.0	223	0	\$27	\$270	\$35	8.6
SGL 2	1	Compact Fluorescent: (1) 26W A19 Screw-In Lamp	Wall Switch	S	26	3,270	2	Relamp	No	1	LED Lamps: LED Lamp	Wall Switch	18	3,270	0.0	29	0	\$4	\$17	\$1	4.6
SGL 2	8	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	3,270	3	None	Yes	8	LED - Linear Tubes: (2) 4' Lamps	Occupancy Sensor	25	2,256	0.0	223	0	\$27	\$270	\$35	8.6
Sprinkler room	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	1,000		None	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	1,000	0.0	0	0	\$0	\$0	\$0	0.0
Storage 5 Gym	1	LED Lamps: (1) 18W PAR38 Screw-In Lamp	Wall Switch	S	18	1,100		None	No	1	LED Lamps: (1) 18W PAR38 Screw-In Lamp	Wall Switch	18	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Storage across from Gym	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	1,100		None	No	2	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Storage closet 12	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	1,100		None	No	3	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Storage In Cafeteria	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	S	25	1,100		None	No	1	LED - Linear Tubes: (2) 4' Lamps	Wall Switch	25	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Storage in Classroom 9	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	1,100		None	No	1	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	50	1,100	0.0	0	0	\$0	\$0	\$0	0.0
Teachers Lounge	2	Exit Signs: LED - 2 W Lamp	None		6	8,760		None	No	2	Exit Signs: LED - 2 W Lamp	None	6	8,760	0.0	0	0	\$0	\$0	\$0	0.0
Teachers Lounge	7	LED - Linear Tubes: (4) 4' Lamps	Wall Switch	S	50	3,270	3	None	Yes	7	LED - Linear Tubes: (4) 4' Lamps	Occupancy Sensor	50	2,256	0.1	390	0	\$48	\$270	\$35	4.9

Motor Inventory & Recommendations

		Existing Conditions									Proposed Conditions					Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Manufacturer	Model	Remaining Useful Life	Annual Operating Hours	ECM #	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Roof	Exhaust Fan-Various Spaces	8	Exhaust Fan	0.3	65.0%	No			W	2,600		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	Exhaust Fan-Gym	2	Exhaust Fan	2.0	80.0%	No			W	2,745	5	No	86.5%	Yes	2	1.3	4,359	0	\$542	\$8,363	\$200	15.1
Roof	Exhaust Fan-Hallways	1	Exhaust Fan	0.5	70.0%	No			W	2,745		No	70.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	Exhaust Fan-Kitchen Hood	1	Kitchen Hood Exhaust Fan	0.5	70.0%	No			W	2,600		No	70.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Boiler Room	Heating Hot Water Pump P1-P2	2	Heating Hot Water Pump	15.0	91.7%	Yes			W	2,020		No	91.7%	No		0.0	0	0	\$0	\$0	\$0	0.0
Custodial storage 1	Injector Pump	1	Other	0.8	70.0%	No			W	1,000		No	70.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Electrical Room 1	Sump Pump	1	Other	0.3	65.0%	No			W	1,000		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
PTO Closet	Sump Pump	1	Other	0.3	65.0%	No			W	1,000		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Various spaces	Hydronic Unit Heaters	2	Fan Coil Unit	0.1	65.0%	No			W	3,431		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	RTU-W1 - SGI	1	Supply Fan	0.3	70.0%	No			W	2,600		No	70.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	Supply Fan RTU	2	Supply Fan	0.3	65.0%	No			B	2,600		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	RTU-W3 - Faculty Room	1	Supply Fan	0.3	70.0%	No			W	2,600		No	70.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	RTU-W4 - Library	1	Supply Fan	3.0	84.0%	No			W	2,600	5	No	89.5%	Yes	1	0.9	2,885	0	\$359	\$4,555	\$200	12.1
Roof	Supply Fan-York RTU	1	Supply Fan	1.5	80.0%	No			W	2,600	5	No	86.5%	Yes	1	0.5	1,548	0	\$192	\$3,887	\$75	19.8
Roof	HV-1-Gym	1	Supply Fan	3.0	86.5%	No			W	2,600	5	No	89.5%	Yes	1	0.9	2,675	0	\$333	\$4,555	\$200	13.1
Roof	HV-2--Gym	1	Supply Fan	3.0	86.5%	No			W	2,600	5	No	89.5%	Yes	1	0.9	2,675	0	\$333	\$4,555	\$200	13.1
Roof	Supply Fan-MUA	1	Supply Fan	1.0	80.0%	No			W	2,600		No	80.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Washington Elementary School Various Spaces	Unit Ventilators Classrooms	26	Fan Coil Unit	0.2	65.0%	No			W	2,600		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Corridor Main Office	Ceiling Mounted Electric Resistance Heaters	2	Supply Fan	0.1	65.0%	No			W	2,745		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
Roof	Supply Fan RTU	1	Supply Fan	0.3	65.0%	No			B	0		No	65.0%	No		0.0	0	0	\$0	\$0	\$0	0.0
		Existing Conditions									Proposed Conditions					Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	Motor Quantity	Motor Application	HP Per Motor	Full Load Efficiency	VFD Control?	Manufacturer	Model	Remaining Useful Life	Annual Operating Hours	ECM #	Install High Efficiency Motors?	Full Load Efficiency	Install VFDs?	Number of VFDs	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Roof	Supply Fan RTU	7	Supply Fan	2.0	84.0%	No			B	2,600	5	Yes	86.5%	No		0.2	701	0	\$87	\$4,690	\$0	53.8
Roof	Supply Fan RTU	1	Supply Fan	2.0	84.0%	No			B	0		No	84.0%	No		0.0	0	0	\$0	\$0	\$0	0.0



Packaged HVAC Inventory & Recommendations

		Existing Conditions									Proposed Conditions								Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (MBh)	Cooling Mode Efficiency (SEER/IEER/EER)	Heating Mode Efficiency	Manufacturer	Model	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Cooling Capacity per Unit (Tons)	Heating Capacity per Unit (MBh)	Cooling Mode Efficiency (SEER/IEER/EER)	Heating Mode Efficiency	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Roof	RTU-W1 - SGI	1	Package Unit	1.50		9.50		Trane	TCC018F100BG	B	6	Yes	1	Package Unit	1.50		16.00		0.4	423	0	\$53	\$4,613	\$155	84.7
Roof	RTU-W3 - Faculty Room	1	Package Unit	1.50		9.50		Trane	TCC018F100BG	B	6	Yes	1	Package Unit	1.50		16.00		0.4	423	0	\$53	\$4,613	\$155	84.7
Roof	RTU-W4 - Library	1	Package Unit	7.50		10.50		Trane	THC092F3R0A0EC	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Roof	RTU - School	1	Package Unit	1.50		9.50		Trane	TCC018F100BG	B	6	Yes	1	Package Unit	1.50		16.00		0.4	423	0	\$53	\$4,613	\$155	84.7
Roof	RTU - Main Office	1	Package Unit	5.00		10.00		York	ZE060C00B2A1AB A1A2	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Roof	CU-1 - Classrooms 100	1	Split-System Air-Source HP	9.00	116.00	11.30	3.3 COP	Daikin	RXQ108PATJ	B	7	Yes	1	Split-System Air-Source HP	9.00	116.00	12.80	3.5 COP	0.9	616	0	\$77	\$17,382	\$693	217.9
Roof	CU-2 - Nurse Office	1	Split-System Air-Source HP	8.00	103.00	11.30	2.85 COP	Daikin	RXYQ96PBTJ	B	7	Yes	1	Split-System Air-Source HP	8.00	103.00	12.80	3.5 COP	1.5	548	0	\$68	\$15,358	\$616	216.6
Tall Roof	CU-3 - Classrooms 100	1	Split-System Air-Source HP	8.00	103.00	11.30	2.85 COP	Daikin	RXYQ96PBTJ	B	7	Yes	1	Split-System Air-Source HP	8.00	103.00	12.80	3.5 COP	1.5	548	0	\$68	\$15,358	\$616	216.6
Tall Roof	CU-4 - Classrooms 101	1	Split-System Air-Source HP	8.00	103.00	11.30	2.85 COP	Daikin	RXYQ96PBTJ	B	7	Yes	1	Split-System Air-Source HP	8.00	103.00	12.80	3.5 COP	1.5	548	0	\$68	\$15,358	\$616	216.6
Roof	CU-5-Master-Main Hallway Science Lab	1	Split-System Air-Source HP	8.00	103.00	11.30	2.85 COP	Daikin	RXYQ96PBTJ	B	7	Yes	1	Split-System Air-Source HP	8.00	103.00	12.80	3.5 COP	1.5	548	0	\$68	\$15,358	\$616	216.6
Roof	CU-5-Back up-Science	1	Split-System Air-Source HP	6.00	77.00	11.30	2.65 COP	Daikin	RXYQ72PBTJ	B	7	Yes	1	Split-System Air-Source HP	6.00	77.00	12.80	3.5 COP	1.4	0	0	\$0	\$12,591	\$462	0.0
Roof	CU-6-Classroom 200	1	Split-System Air-Source HP	8.00	103.00	11.30	2.85 COP	Daikin	RXYQ96PBTJ	B	7	Yes	1	Split-System Air-Source HP	8.00	103.00	12.80	3.5 COP	1.5	548	0	\$68	\$15,358	\$616	216.6
Roof	CU-7 - Classrooms 300	1	Split-System Air-Source HP	8.00	103.00	11.30	2.85 COP	Daikin	RXYQ96PBTJ	B	7	Yes	1	Split-System Air-Source HP	8.00	103.00	12.80	3.5 COP	1.5	548	0	\$68	\$15,358	\$616	216.6
Classroom 22	Window AC-Classroom 22	1	Window AC	1.96		9.40		Friedrich	CP24G30	B	6	Yes	1	Window AC	1.96		12.00		0.3	298	0	\$37	\$1,541	\$0	41.6
Guidance Office	Window AC-Guidance	1	Window AC	1.50		10.10		Unknown	Unknown	B	6	Yes	1	Window AC	1.50		12.00		0.1	155	0	\$19	\$1,094	\$0	56.7
Corridor Main Office	Ceiling Mounted Electric Resistance Heaters	1	Electric Resistance Heat		17.06		1 COP	Unknown	Unknown	W		No							0.0	0	0	\$0	\$0	\$0	0.0
Corridor 1st & 2nd Grade	1st & 2nd Grade Corridor	1	Electric Resistance Heat		17.06		1 COP	Dayton	3UG74	W		No							0.0	0	0	\$0	\$0	\$0	0.0

Space Heating Boiler Inventory & Recommendations

		Existing Conditions						Proposed Conditions							Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	System Quantity	System Type	Output Capacity per Unit (MBh)	Manufacturer	Model	Remaining Useful Life	ECM #	Install High Efficiency System?	System Quantity	System Type	Output Capacity per Unit (MBh)	Heating Efficiency	Heating Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Boiler Room	Hydronic Heating System	3	Condensing Hot Water Boiler	1,720	Aerco	BMK2.0	B		No						0.0	0	0	\$0	\$0	\$0	0.0

DHW Inventory & Recommendations

		Existing Conditions					Proposed Conditions							Energy Impact & Financial Analysis						
Location	Area(s)/System(s) Served	System Quantity	System Type	Manufacturer	Model	Remaining Useful Life	ECM #	Replace?	System Quantity	System Type	Fuel Type	System Efficiency	Efficiency Units	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Boiler Room	Domestic Hot Water	1	Storage Tank Water Heater (> 50 Gal)	Bradford White Corporation	100T88B3N	W		No						0.0	0	0	\$0	\$0	\$0	0.0

Low-Flow Device Recommendations

Recommendation Inputs						Energy Impact & Financial Analysis						
Location	ECM #	Device Quantity	Device Type	Existing Flow Rate (gpm)	Proposed Flow Rate (gpm)	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Various Spaces	11	24	Faucet Aerator (Lavatory)	2.20	0.50	0.0	0	23	\$253	\$172	\$86	0.3

Commercial Refrigerator/Freezer Inventory & Recommendations

Existing Conditions						Proposed Conditions		Energy Impact & Financial Analysis						
Location	Quantity	Refrigerator/ Freezer Type	Manufacturer	Model	ENERGY STAR Qualified?	ECM #	Install ENERGY STAR Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Cafeteria	1	Freezer Chest	Unknown	Unknown	No		No	0.0	0	0	\$0	\$0	\$0	0.0
Cafeteria	1	Refrigerator Chest	Powers	SM58HC	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen	1	Refrigerator Chest	Powers	681	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen	1	Stand-Up Refrigerator, Solid Door (31 - 50 cu. ft.)	Traulsen	GHT 2-3NUT	No		No	0.0	0	0	\$0	\$0	\$0	0.0

Cooking Equipment Inventory & Recommendations

Existing Conditions						Proposed Conditions		Energy Impact & Financial Analysis						
Location	Quantity	Equipment Type	Manufacturer	Model	High Efficiency Equipment?	ECM #	Install High Efficiency Equipment?	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Total Incentives	Simple Payback w/ Incentives in Years
Kitchen	1	Gas Combination Oven/Steam Cooker (<15 Pans)	Garland	MCO-GS-10-S Master 200	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen	1	Gas Convection Oven (Full Size)	Garland	Unknown	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0
Kitchen	1	Insulated Food Holding Cabinet (Full Size)	Alto-Shaam	1000-UP	Yes		No	0.0	0	0	\$0	\$0	\$0	0.0

Plug Load Inventory

Existing Conditions						
Location	Quantity	Equipment Description	Energy Rate (W)	ENERGY STAR Qualified?	Manufacturer	Model
Washington Elementary	3	Cofee Machine	900	No		
Washington Elementary	1	Dehumidifier	480	No		
Washington Elementary	42	Desktop	191	No		
Washington Elementary	1	Dishwasher	900	No		
Washington Elementary	1	Electric Space Heater	1,500	No		
Washington Elementary	5	Ceiling Fan	200	No		
Washington Elementary	5	Portable Fan	100	No		
Washington Elementary	5	Microwave	1,000	No		
Washington Elementary	3	Robo 3D Printer	180	No		
Washington Elementary	1	Washing Machine	720	No		
Washington Elementary	2	6ft Electric Base Board heater	1,500	No		
Washington Elementary	1	Server	2,000	No		
Washington Elementary	2	Paper Shredder	150	No		
Washington Elementary	13	Printer (Medium/Small)	192	No		
Washington Elementary	3	Printer/Copier (Large)	600	No		
Washington Elementary	28	Projector	200	No		
Washington Elementary	2	Refrigerator (Mini)	207	No		
Washington Elementary	2	Refrigerator (Residential)	199	No		
Washington Elementary	1	Television	120	No		
Washington Elementary	1	Toaster Oven	850	No		
Washington Elementary	1	Kitchen Hot Food Table	1,445	No		


Custom (High Level) Measure Analysis

Retro-Commissioning Study

Retro-Commissioning Study						Building Square Footage		53,340		Fuel Utility Rate		\$11.126		MMBtu							
						Percent of Conditioned Area Impacted		100%		Blended Electric Utility Rate		\$0.124		kWh							
Existing Conditions						Proposed Conditions					Energy Impact & Financial Analysis										
Description	Area(s)/System(s) Served	Remaining Useful Life	Total HVAC Motor Usage kWh	Total HVAC Electric Usage kWh	Total HVAC Fuel Usage MMBtu	Description	% Savings HVAC Motor Usage kWh	% Savings HVAC Electric Usage kWh	% Savings HVAC Fuel Usage MMBtu	Estimated Cost per Sqft	Total Peak kW Savings	Total Annual kWh Savings	Total Annual MMBtu Savings	Total Annual Energy Cost Savings	Estimated M&L Cost (\$)	Base Incentives	Enhanced Incentives	Total Incentives	Total Net Cost	Payback w/o Incentives in Years	Simple Payback w/ Incentives in Years
HVAC Controls Not Currently Optimized	HVAC Equipment & Systems	3	116,698	43,114	2,280	Retro-Commissioning Study	15%	4%	2%	\$0.40	0.00	19,229	46	\$2,898	\$21,300	\$0	\$0	\$0	\$21,300	7.35	7.35

APPENDIX B: ENERGY STAR STATEMENT OF ENERGY PERFORMANCE

Energy use intensity (EUI) is presented in terms of *site energy* and *source energy*. Site energy is the amount of fuel and electricity consumed by a building as reflected in utility bills. Source energy includes fuel consumed to generate electricity consumed at the site, factoring in electric production and distribution losses for the region.



ENERGY STAR® Statement of Energy Performance

63

ENERGY STAR®
Score¹

Washington Elementary School

Primary Property Type: K-12 School
Gross Floor Area (ft²): 53,340
Built: 1913

For Year Ending: April 30, 2022
Date Generated: February 27, 2023

1. The ENERGY STAR score is a 1-100 assessment of a building's energy efficiency as compared with similar buildings nationwide, adjusting for climate and business activity.

Property & Contact Information		
Property Address Washington Elementary School 507 Morris Avenue Summit, New Jersey 07901	Property Owner Summit Public Schools 14 Beekman Terrace Summit, NJ 07901-1702 (908) 918-2100	Primary Contact Summit Schools 14 Beekman Terrace Summit, NJ 07901-1702 (908) 918-2100 rrodri81@asu.edu
Property ID: 21959908		

Energy Consumption and Energy Use Intensity (EUI)			
Site EUI	Annual Energy by Fuel	National Median Comparison	
65.5 kBtu/ft²	Natural Gas (kBtu)	National Median Site EUI (kBtu/ft²)	74.9
	Electric - Grid (kBtu)	National Median Source EUI (kBtu/ft²)	116.2
		% Diff from National Median Source EUI	-13%
Source EUI			
101.6 kBtu/ft²	Annual Emissions		
	Total (Location-Based) GHG Emissions (Metric Tons CO2e/year)		220

Signature & Stamp of Verifying Professional

I _____ (Name) verify that the above information is true and correct to the best of my knowledge.

LP Signature: _____ Date: _____

Licensed Professional

 () _____



Professional Engineer or Registered Architect Stamp (if applicable)

APPENDIX C: GLOSSARY

TERM	DEFINITION
Blended Rate	Used to calculate fiscal savings associated with measures. The blended rate is calculated by dividing the amount of your bill by the total energy use. For example, if your bill is \$22,217.22, and you used 266,400 kilowatt-hours, your blended rate is 8.3 cents per kilowatt-hour.
Btu	<i>British thermal unit</i> : a unit of energy equal to the amount of heat required to increase the temperature of one pound of water by one-degree Fahrenheit.
CHP	<i>Combined heat and power</i> . Also referred to as cogeneration.
COP	<i>Coefficient of performance</i> : a measure of efficiency in terms of useful energy delivered divided by total energy input.
Demand Response	Demand response reduces or shifts electricity usage at or among participating buildings/sites during peak energy use periods in response to time-based rates or other forms of financial incentives.
DCV	<i>Demand control ventilation</i> : a control strategy to limit the amount of outside air introduced to the conditioned space based on actual occupancy need.
US DOE	<i>United States Department of Energy</i>
EC Motor	<i>Electronically commutated motor</i>
ECM	<i>Energy conservation measure</i>
EER	<i>Energy efficiency ratio</i> : a measure of efficiency in terms of cooling energy provided divided by electric input.
EUI	<i>Energy Use Intensity</i> : measures energy consumption per square foot and is a standard metric for comparing buildings' energy performance.
Energy Efficiency	Reducing the amount of energy necessary to provide comfort and service to a building/area. Achieved through the installation of new equipment and/or optimizing the operation of energy use systems. Unlike conservation, which involves some reduction of service, energy efficiency provides energy reductions without sacrifice of service.
ENERGY STAR	ENERGY STAR is the government-backed symbol for energy efficiency. The ENERGY STAR program is managed by the EPA.
EPA	<i>United States Environmental Protection Agency</i>
Generation	The process of generating electric power from sources of primary energy (e.g., natural gas, the sun, oil).
GHG	<i>Greenhouse gas</i> gases that are transparent to solar (short-wave) radiation but opaque to long-wave (infrared) radiation, thus preventing long-wave radiant energy from leaving Earth's atmosphere. The net effect is a trapping of absorbed radiation and a tendency to warm the planet's surface.
gpf	<i>Gallons per flush</i>

gpm	<i>Gallon per minute</i>
HID	<i>High intensity discharge</i> : high-output lighting lamps such as high-pressure sodium, metal halide, and mercury vapor.
hp	<i>Horsepower</i>
HPS	<i>High-pressure sodium</i> : a type of HID lamp.
HSPF	<i>Heating seasonal performance factor</i> : a measure of efficiency typically applied to heat pumps. Heating energy provided divided by seasonal energy input.
HVAC	<i>Heating, ventilating, and air conditioning</i>
IHP 2014	US DOE Integral Horsepower rule. The current ruling regarding required electric motor efficiency.
IPLV	<i>Integrated part load value</i> : a measure of the part load efficiency usually applied to chillers.
kBtu	One thousand British thermal units
kW	<i>Kilowatt</i> : equal to 1,000 Watts.
kWh	<i>Kilowatt-hour</i> : 1,000 Watts of power expended over one hour.
LED	<i>Light emitting diode</i> : a high-efficiency source of light with a long lamp life.
LGEA	<i>Local Government Energy Audit</i>
Load	The total power a building or system is using at any given time.
Measure	A single activity, or installation of a single type of equipment, that is implemented in a building system to reduce total energy consumption.
MH	<i>Metal halide</i> : a type of HID lamp.
MBh	<i>Thousand Btu per hour</i>
MBtu	<i>One thousand British thermal units</i>
MMBtu	<i>One million British thermal units</i>
MV	<i>Mercury Vapor</i> : a type of HID lamp.
NJBPU	<i>New Jersey Board of Public Utilities</i>
NJCEP	<i>New Jersey's Clean Energy Program</i> : NJCEP is a statewide program that offers financial incentives, programs and services for New Jersey residents, business owners and local governments to help them save energy, money, and the environment.
psig	Pounds per square inch gauge
Plug Load	Refers to the amount of power used in a space by products that are powered by means of an ordinary AC plug.
PV	<i>Photovoltaic</i> : refers to an electronic device capable of converting incident light directly into electricity (direct current).

SEER	<i>Seasonal energy efficiency ratio</i> : a measure of efficiency in terms of annual cooling energy provided divided by total electric input.
SEP	<i>Statement of energy performance</i> : a summary document from the ENERGY STAR Portfolio Manager.
Simple Payback	The amount of time needed to recoup the funds expended in an investment or to reach the break-even point between investment and savings.
SREC (II)	<i>Solar renewable energy credit</i> : a credit you can earn from the state for energy produced from a photovoltaic array.
T5, T8, T12	A reference to a linear lamp diameter. The number represents increments of 1/8 th of an inch.
Temperature Setpoint	The temperature at which a temperature regulating device (thermostat, for example) has been set.
therm	100,000 Btu. Typically used as a measure of natural gas consumption.
tons	A unit of cooling capacity equal to 12,000 Btu/hr.
Turnkey	Provision of a complete product or service that is ready for immediate use.
VAV	<i>Variable air volume</i>
VFD	<i>Variable frequency drive</i> : a controller used to vary the speed of an electric motor.
WaterSense®	The symbol for water efficiency. The WaterSense® program is managed by the EPA.
Watt (W)	Unit of power commonly used to measure electricity use.